

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

December 23, 1980

MEMORANDUM FOR: Chairman Ahearne  
Commissioner Gilinsky  
Commissioner Hendrie  
Commissioner Bradford

FROM: William J. Dircks, Executive Director for Operations

SUBJECT: DAILY STAFF NOTES, DECEMBER 22, 1980

NRRMEETING WITH DUKE POWER COMPANY - MCGUIRE HYDROGEN CONTROL MEASURES

The staff will meet with the Duke Power Company to discuss all aspects of hydrogen control measures relating to McGuire. The meeting will be Tuesday, December 23, 1980 at 9:30 a.m. in Room P-422.

SP

1. Based on a recent review of the Idaho radiation control program, the staff has informed Idaho of its opinion that the State's program for regulation of agreement materials is adequate to protect the public health and safety and is compatible with the Commission's program.
2. Based on a recent <sup>Follow-up</sup> review of Florida radiation control program, the staff has informed Florida of its opinion that the State's program for regulation of agreement materials is adequate to protect the public health and safety and is compatible with the Commission's program.

8101150862

REGION I PLANT STATUS- 12/22/80

PLANT NAME	PLANT STATUS	REASON OR COMMENT
% POWER	DOWN	
*BEAVER VALLEY 1	X	POTENTIAL LEAK THROUGH PRESSURIZER SAFETY VALVE
CALVERT CLIFFS 1	X	PREPARING TO GO TO POWER
CALVERT CLIFFS 2	65	COASTING DOWN
FITZPATRICK	100	
GINNA	100	
HADDAM NECK	100	
INDIAN POINT 2	X	REPAIR FAN COOLERS
INDIAN POINT 3	58	SLOW RETURN TO FULL POWER
MAINE YANKEE	80	RETURNING TO FULL POWER FROM MAIN OUTAGE
MILLSTONE 1	X	DEFUELED
MILLSTONE 2	100	
*NINE MILE POINT 1	90	RETURNING TO POWER FROM SHUTDOWN
OYSTER CREEK	92	CONDENSATE DEMINERALIZER DP
PEACH BOTTOM 2	100	
PEACH BOTTOM 3	X	TRIP DUE TO FW SYSTEM MALFUNCTION - PREPARING TO RESTART
PILOTIM 1	100	
SALEM 1	X	REFUELING
SALEM 2	X	AWAITING LICENSE
THREE MILE ISLAND 1	X	NRC ORDER
THREE MILE ISLAND 2	X	NRC ORDER
VERMONT YANKEE	X	REFUELING
YANKEE ROWE	100	

REGION II PLANT STATUS- 12/22/80

PLANT NAME	PLANT STATUS	REASON OR COMMENT
% POWER	DOWN	
BROWNS FERRY 1	99	
BROWNS FERRY 2	99	
BROWNS FERRY 3	X	REFUELING
BRUNSWICK 1	85	CONDENSER VACUUM PROBLEMS
BRUNSWICK 2	40	INCREASING POWER
CRYSTAL RIVER 3	100	
FARLEY 1	X	REFUELING
HATCH 1	80	ADMINISTRATIVE LIMIT
HATCH 2	X	REFUELING
NORTH ANNA 1	61	COAST DOWN
NORTH ANNA 2	100	
OCOONEE 1	100	
OCOONEE 2	98	
OCOONEE 3	X	REFUELING
ROBINSON 2	100	
SEQUOYAH 1	44	HAVING WATER QUALITY PROBLEMS
ST. LUCIE 1	100	
SURRY 1	X	S. G. REPLACEMENT
SURRY 2	100	
TURKEY POINT 3	100	
TURKEY POINT 4	X	REFUELING

PLANT NAME	PLANT STATUS	REASON OR COMMENT	RF
% POWER	DOWN		
BIG ROCK POINT	X	REFUELING	
COOK 1	100		
COOK 2	100		
DAVIS-BESSE 1	55	WORK COMPLETE ON FW PUMPS	
DRESDEN 1	X	CHEMICAL CLEANING	
DRESDEN 2	47	COASTDOWN	
*DRESDEN 3	X	TECH SPEC VIOLATION	
		CONTAINMENT INTEGRITY BROKEN	
		WHILE NOT IN COLD SHUTDOWN	
DUANE ARNOLD	87	INCREASING POWER AND	
		PRECONDITIONING	
KEWAUNEE	100		
LACROSSE	X	REFUELING	
LASALLE	X	AWAITING LICENSE	
MONTICELLO	100		
PALISADES	99		
POINT BEACH 1	X	REFUELING	
POINT BEACH 2	100		
PRAIRIE ISLAND 1	100		
PRAIRIE ISLAND 2	100		
*QUAD CITIES 1	24	RETURNING TO POWER FOLLOWING	
		REFUELING	
QUAD CITIES 2	95		
ZION 1	94		
ZION 2	93	LIMITED BY LOW PRESSURE	
		TURBINE	

REGION IV PLANT STATUS- 12/22/80

PLANT NAME	PLANT STATUS	REASON OR COMMENT	R
% POWER	DOWN		
ARKANSAS 1	72	3 PUMPS LIMIT; LEAKING PUMP	
*ARKANSAS 2	17	CONDENSER TUBE LEAKS	
COOPER	98		
FORT CALHOUN	75	ADMINISTRATIVE CONTROL (FUEL	
		CONSERVATION)	
FORT ST. VRAIN	68	70% POWER LIMIT	

REGION V PLANT STATUS- 12/22/80

PLANT NAME	PLANT STATUS	REASON OR COMMENT	R
% POWER	DOWN		
DIABLO CANYON	X	AWAITING LICENSE	
RANCHO SECO	100		
SAN ONOFRE	X	SG RESLEEVEING	
TROJAN	100		

\* - REASON OR COMMENT HAS CHANGED IN PAST 24 HOURS

# - REACTOR SCRAM WITHIN PAST 24 HOURS

NOTE - REACTOR STATUS DATA COLLECTED BETWEEN  
6 A. M. AND 8 A. M. EACH DAY EXCEPT  
HOLIDAYS AND WEEKENDS