

**Northeast  
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

June 26, 1997

Docket No. 50-423  
B16513

Re:10CFR 50.73(a)(2)(i)(B)

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555


Millstone Nuclear Power Station Unit 3  
Licensee Event Report 97-033-00  
Submitted Pursuant to 10CFR 50.73(a)(2)(i)(B)

This letter forwards Licensee Event Report 97-033-00, documenting a condition that was determined at Millstone Unit No. 3 on May 27, 1997. This LER is submitted pursuant to 10CFR 50.73(a)(2)(i)(B). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. David A. Smith at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY  
COMPANY

  
\_\_\_\_\_  
G. D. Hicks  
Unit Director, Millstone Unit No. 3

*IE20*

9707080422 970626  
PDR ADOCK 05000423  
S PDR



Attachment: 1) NNECO's commitments in response to LER 97-033-00  
2) LER 97-033-00

cc: H. J. Miller, Region I Administrator  
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3  
J. W. Andersen, NRC Project Manager, Millstone Unit No. 3  
W. D. Travers, Dr., Director, Special Projects

Docket No. 50-423  
B16513

Attachment 1

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Commitments  
In Response To  
**(LER 97-033-00)**

June 26, 1997

Enclosure  
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B16513-01	The Intermediate Range Neutron Flux, P-6 interlock bistable calibration will be brought into compliance with the Technical Specifications.	Prior to entry into Mode 4

Docket No. 50-423  
B16513

Attachment 2

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Submittal of  
(LER 97-033-00)

June 26, 1997