

From: Schiller, Alina
Sent: Monday, June 8, 2020 4:55 PM
To: Vogtle PEmails
Subject: Conference call for VEGP Units 3 and 4 LAR 20-003, TS 3.3.13 for MCR VES Instrumentation Applicability Change and Include Undervoltage Actuation

From: Schiller, Alina
Sent: Monday, June 08, 2020 4:03 PM
To: Williamson, Daniel W. <X2DWWILL@SOUTHERNCO.COM>
Subject: Conference call for VEGP Units 3 and 4 LAR 20-003, TS 3.3.13 for MCR VES Instrumentation Applicability Change and Include Undervoltage Actuation

Good afternoon Dan,

NRC Staff have a question for SNC about the revised TS 3.3.13. SNC added "Condition" A and modified B, including adding "REQUIRED ACTION" B.1, which says that when one function in a channel is inoperable to verify that the other channel is operable. However, B.2 still states, "Verify alternate radiation monitors are OPERABLE." It is unclear if B.1 and B.2 are repetitive for the radiation monitors (both indicating SNC has to ensure that the radiation monitors in the operable channel remain functional) or if B.2 is indicating that some additional radiation monitors need to be relied on (such as the non-safety related MCR area monitor or portable monitors) or something else.

NRC Staff would like to have a call with SNC to make sure that they understand the revised TS. Will SNC be available to support a short discussion during Thursday conference call on 6/11/20 at 10:00am? Please let me know.

Thank you,

Alina Schiller

Project Manager
Office of Nuclear Reactor Regulation
Vogtle Project Office
O-13 C10
301-415-8177
202-459-3560 (cell)

Hearing Identifier: Vogtle_COL_Docs_Public
Email Number: 571

Mail Envelope Properties (BL0PR0901MB4324E01EA18944A65F4508BA96850)

Subject: Conference call for VEGP Units 3 and 4 LAR 20-003, TS 3.3.13 for MCR VES Instrumentation Applicability Change and Include Undervoltage Actuation
Sent Date: 6/8/2020 4:54:42 PM
Received Date: 6/8/2020 4:54:45 PM
From: Schiller, Alina

Created By: Alina.Schiller@nrc.gov

Recipients:
"Vogtle PEmails" <Vogtle.PEmails@nrc.gov>
Tracking Status: None

Post Office: BL0PR0901MB4324.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	1412	6/8/2020 4:54:45 PM

Options
Priority: Normal
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date: