



**Tom Simril**  
Vice President  
Catawba Nuclear Station

**Duke Energy**  
CN01VP | 4800 Concord Road  
York, SC 29745

o: 803.701.3340  
f: 803.701.3221  
tom.simril@duke-energy.com

RA-20-0186

June 10, 2020

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Subject: Duke Energy Carolinas, LLC (Duke Energy)  
Catawba Nuclear Station, Unit 1  
Facility Operating License Number NPF-35  
Docket Number 50-413  
Core Operating Limits Report (COLR) for Unit 1 Cycle 26 Reload Core

Pursuant to Catawba Technical Specification 5.6.5.d, enclosed is the subject COLR. This COLR revision is being submitted to update the limits of the Catawba Unit 1 Cycle 26 reload core.

This letter, the enclosed COLR, and the attached COLR Appendix A, do not contain any regulatory commitments.

Please direct any questions or concerns to Sherry Andrews, Regulatory Affairs, at (803) 701-3424.

Sincerely,

Tom Simril  
Vice President, Catawba Nuclear Station

Enclosure: Catawba Unit 1, Cycle 26, Revision 0, Core Operating Limits Report

Attachment: Catawba Unit 1, Cycle 26, Revision 0, Core Operating Limits Report,  
Appendix A, Power Distribution Monitoring Factors

U.S. Nuclear Regulatory Commission  
RA-20-0186  
June 10, 2020  
Page | 2

xc (with enclosure; with attachment):

L. Dudes, Region II Administrator  
U.S. Nuclear Regulatory Commission  
Marquis One Tower  
245 Peachtree Center Avenue NE, Suite 1200  
Atlanta, GA 30303-1257

J. D. Austin, Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Catawba Nuclear Station

K. Cotton, Project Manager  
U.S. Nuclear Regulatory Commission  
11555 Rockville Pike  
Mailstop O-8B1A  
Rockville, MD 20852

**Enclosure**

Catawba Unit 1, Cycle 26, Revision 0, Core Operating Limits Report



<b>Facility Code :</b>	CN	
<b>Applicable Facilities :</b>	CN	
<b>Document Number :</b>	CNEI-0400-352	
<b>Document Revision Number :</b>	000	
<b>Document EC Number :</b>		
<b>Change Reason :</b>	NTM #2254236	
<b>Document Title :</b>	Catawba 1 Cycle 26 Core Operating Limits Report	
Swihart, Dallas	Originator	4/22/2020
Hill, Amy E	Verifier	4/22/2020
Hawes, Mark W	Site Impact Review	4/22/2020
Hight, Randy A	Safety Analysis Verifier	4/22/2020
Robinson, Duncan	Approver	4/22/2020
<b>Notes :</b>		

**Catawba 1 Cycle 26**  
**Core Operating Limits Report**  
**Revision 0**

**May 2020**

Reference: CNC-1553.05-00-0685, Rev. 0  
Reload 50.59 #: 02323338



**QA CONDITION 1**

The information presented in this report has been prepared and issued in accordance with Catawba Technical Specification 5.6.5.

## **Catawba 1 Cycle 26 Core Operating Limits Report**

### **Implementation Instructions for Revision 0**

#### **Revision Description and CR Tracking**

Revision 0 of the Catawba Unit 1 Cycle 26 COLR contains limits specific to the reload core.

#### **Implementation Schedule**

The Catawba Unit 1 Cycle 26 COLR requires the reload 50.59 (AR #02323338) be approved prior to implementation and fuel loading.

Revision 0 may become effective any time during No MODE between cycles 25 and 26 but must become effective prior to entering MODE 6 which starts cycle 26. The Catawba Unit 1 Cycle 26 COLR will cease to be effective during No MODE between cycle 26 and 27.

#### **Data Files to be Implemented**

No data files are transmitted as part of this document.

#### **Additional Information**

CDR was performed by Safety Analysis for COLR Sections 1.1, 2.1, and 2.9 – 2.18.

CNS Reactor Engineering performed site inspection in accordance with AD-NF-ALL-0807 and AD-NF-NGO-0214.

**Catawba 1 Cycle 26 Core Operating Limits Report****REVISION LOG**

<b><u>Revision</u></b>	<b><u>Effective Date</u></b>	<b><u>Pages Affected</u></b>	<b><u>COLR</u></b>
0	May 2020	1-31, Appendix A*	C1C26 COLR, Rev. 0

\* Appendix A contains power distribution monitoring factors used in Technical Specification Surveillance and is not uploaded as part of the EI body. However, Appendix A is uploaded into the document management system, for ease of transmittal to the NRC.

## Catawba 1 Cycle 26 Core Operating Limits Report

### 1.0 Core Operating Limits Report

This Core Operating Limits Report (COLR) has been prepared in accordance with requirements of Technical Specification 5.6.5. Technical Specifications that reference this report are listed below along with the NRC approved analytical methods used to develop and/or determine COLR parameters identified in Technical Specifications.

TS Section	Technical Specifications	COLR Parameter	COLR Section	NRC Approved Methodology (Section 1.1 Number)
2.1.1	Reactor Core Safety Limits	RCS Temperature and Pressure Safety Limits	2.1	6, 7, 8, 9, 10, 12, 15, 16, 19, 20
3.1.1	Shutdown Margin	Shutdown Margin	2.2	6, 7, 8, 12, 14, 15, 16, 19, 20
3.1.3	Moderator Temperature Coefficient	MTC	2.3	6, 7, 8, 14, 16, 18
3.1.4	Rod Group Alignment Limits	Shutdown Margin	2.2	6, 7, 8, 12, 14, 15, 16, 19, 20
3.1.5	Shutdown Bank Insertion Limit	Shutdown Margin Rod Insertion Limits	2.2 2.4	2, 4, 6, 7, 8, 9, 10 12, 14, 15, 16, 19, 20
3.1.6	Control Bank Insertion Limit	Shutdown Margin Rod Insertion Limits	2.2 2.5	2, 4, 6, 7, 8, 9, 10 12, 14, 15, 16, 19, 20
3.1.8	Physics Tests Exceptions	Shutdown Margin	2.2	6, 7, 8, 12, 14, 15, 16, 19, 20
3.2.1	Heat Flux Hot Channel Factor	F <sub>Q</sub> AFD OTΔT Penalty Factors	2.6 2.8 2.9 2.6	2, 4, 6, 7, 8, 9, 10 12, 15, 16, 19, 20
3.2.2	Nuclear Enthalpy Rise Hot Channel Factor	FΔH Penalty Factors	2.7 2.7	2, 4, 6, 7, 8, 9, 10 12, 15, 16, 19, 20
3.2.3	Axial Flux Difference	AFD	2.8	2, 4, 6, 7, 8, 15, 16
3.3.1	Reactor Trip System Instrumentation	OTΔT OPΔT	2.9 2.9	6, 7, 8, 9, 10, 12 15, 16, 19, 20
3.3.9	Boron Dilution Mitigation System	Reactor Makeup Water Flow Rate	2.10	6, 7, 8, 14, 16
3.4.1	RCS Pressure, Temperature and Flow limits for DNB	RCS Pressure, Temperature and Flow	2.11	6, 7, 8, 9, 10, 12, 19, 20
3.5.1	Accumulators	Max and Min Boron Conc.	2.12	6, 7, 8, 14, 16
3.5.4	Refueling Water Storage Tank	Max and Min Boron Conc.	2.13	6, 7, 8, 14, 16
3.7.15	Spent Fuel Pool Boron Concentration	Min Boron Concentration	2.14	6, 7, 8, 14, 16
3.9.1	Refueling Operations - Boron Concentration	Min Boron Concentration	2.15	6, 7, 8, 14, 16
5.6.5	Core Operating Limits Report (COLR)	Analytical Methods	1.1	None

The Selected Licensee Commitments that reference this report are listed below

SLC Section	Selected Licensee Commitment	COLR Parameter	COLR Section	NRC Approved Methodology (Section 1.1 Number)
16.7-9	Standby Shutdown System	Standby Makeup Pump Water Supply	2.16	6, 7, 8, 14, 16
16.9-11	Boration Systems – Borated Water Source – Shutdown	Borated Water Volume and Conc. for BAT/RWST	2.17	6, 7, 8, 14, 16
16.9-12	Boration Systems – Borated Water Source – Operating	Borated Water Volume and Conc. for BAT/RWST	2.18	6, 7, 8, 14, 16



## Catawba 1 Cycle 26 Core Operating Limits Report

### 1.1 Analytical Methods

Analytical methods used to determine core operating limits for parameters identified in Technical Specifications and previously reviewed and approved by the NRC as specified in Technical Specification 5.6.5 are as follows.

1. WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," (W Proprietary).

Revision 0

Report Date: July 1985

**Not Used**

2. WCAP-10054-P-A, "Westinghouse Small Break ECCS Evaluation Model using the NOTRUMP Code," (W Proprietary).

Revision 0

Report Date: August 1985

Addendum 2, "Addendum to the Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code: Safety Injection into the Broken Loop and COSI Condensation Model," (W Proprietary). (Referenced in Duke Letter DPC-06-101)

Revision 1

July 1997

3. WCAP-10266-P-A, "The 1981 Version of Westinghouse Evaluation Model Using BASH Code", (W Proprietary).

Revision 2

Report Date: March 1987

**Not Used**

4. WCAP-12945-P-A, Volume 1 and Volumes 2-5, "Code Qualification Document for Best-Estimate Loss of Coolant Analysis," (W Proprietary).

Revision: Volume 1 (Revision 2) and Volumes 2-5 (Revision 1)

Report Date: March 1998

5. BAW-10168P-A, "B&W Loss-of-Coolant Accident Evaluation Model for Recirculating Steam Generator Plants," (B&W Proprietary).

Revision 1

SER Date: January 22, 1991

Revision 2

SER Dates: August 22, 1996 and November 26, 1996

Revision 3

SER Date: June 15, 1994

**Not Used**

## Catawba 1 Cycle 26 Core Operating Limits Report

### 1.1 Analytical Methods (continued)

6. DPC-NE-3000-PA, "Thermal-Hydraulic Transient Analysis Methodology," (Duke Energy Proprietary).

Revision 5a

Report Date: October 2012

7. DPC-NE-3001-PA, "Multidimensional Reactor Transients and Safety Analysis Physics Parameter Methodology," (Duke Energy Proprietary).

Revision 1

Report Date: March 2015

8. DPC-NE-3002-A, "UFSAR Chapter 15 System Transient Analysis Methodology".

Revision 4c

Report Date: February 2019

9. DPC-NE-2004P-A, "Duke Power Company McGuire and Catawba Nuclear Stations Core Thermal-Hydraulic Methodology using VIPRE-01," (Duke Energy Proprietary).

Revision 2a

Report Date: December 2008

10. DPC-NE-2005P-A, "Thermal Hydraulic Statistical Core Design Methodology," (Duke Energy Proprietary).

Revision 5

Report Date: March 2016

11. DPC-NE-2008P-A, "Fuel Mechanical Reload Analysis Methodology Using TACO3," (Duke Energy Proprietary).

Revision 0

Report Date: April 1995

**Not Used**

12. DPC-NE-2009-P-A, "Westinghouse Fuel Transition Report," (Duke Energy Proprietary).

Revision 3c

Report Date: March 2017

13. DPC-NE-1004-A, "Nuclear Design Methodology Using CASMO-3/SIMULATE-3P."

Revision 1a

Report Date: January 2009

**Not Used**

## Catawba 1 Cycle 26 Core Operating Limits Report

### 1.1 Analytical Methods (continued)

14. DPC-NF-2010-A, "Nuclear Physics Methodology for Reload Design."

Revision 2a

Report Date: December 2009

15. DPC-NE-2011-PA, "Nuclear Design Methodology Report for Core Operating Limits of Westinghouse Reactors," (Duke Energy Proprietary).

Revision 1a

Report Date: June 2009

16. DPC-NE-1005-PA, "Nuclear Design Methodology Using CASMO-4 / SIMULATE-3 MOX," (Duke Energy Proprietary).

Revision 1

Report Date: November 2008

17. BAW-10231P-A, "COPERNIC Fuel Rod Design Computer Code" (Framatome ANP Proprietary)

Revision 1

SER Date: January 14, 2004

**Not Used**

18. DPC-NE-1007-P-A, "McGuire & Catawba Nuclear Stations Conditional Exemption of the EOC MTC Measurement Methodology", (Duke Energy and W Proprietary)

Revision 0

Report Date: April 2015

19. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," (W Proprietary).

Revision 0

Report Date: April 1995

20. WCAP-12610-P-A & CENPD-404-P-A, Addendum 1-A, "Optimized ZIRLO™," (W Proprietary).

Revision 0

Report Date: July 2006

## Catawba 1 Cycle 26 Core Operating Limits Report

### 2.0 Operating Limits

Cycle-specific parameter limits for specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using NRC approved methodologies specified in Section 1.1.

#### 2.1 Reactor Core Safety Limits (TS 2.1.1)

Reactor Core Safety Limits are shown in Figure 1.

#### 2.2 Shutdown Margin - SDM (TS 3.1.1, TS 3.1.4, TS 3.1.5, TS 3.1.6, TS 3.1.8)

**2.2.1** For TS 3.1.1, SDM shall be  $\geq 1.3\% \Delta K/K$  in MODE 2 with  $K_{\text{eff}} < 1.0$  and in MODES 3 and 4.


**2.2.2** For TS 3.1.1, SDM shall be  $\geq 1.0\% \Delta K/K$  in MODE 5.

**2.2.3** For TS 3.1.4, SDM shall be  $\geq 1.3\% \Delta K/K$  in MODE 1 and MODE 2.

**2.2.4** For TS 3.1.5, SDM shall be  $\geq 1.3\% \Delta K/K$  in MODE 1 and MODE 2 with any control bank not fully inserted.

**2.2.5** For TS 3.1.6, SDM shall be  $\geq 1.3\% \Delta K/K$  in MODE 1 and MODE 2 with  $K_{\text{eff}} \geq 1.0$ .

**2.2.6** For TS 3.1.8, SDM shall be  $\geq 1.3\% \Delta K/K$  in MODE 2 during PHYSICS TESTS.

**Catawba 1 Cycle 26 Core Operating Limits Report****Figure 1****Reactor Core Safety Limits  
(Four Loops in Operation)**

## Catawba 1 Cycle 26 Core Operating Limits Report

### 2.3 Moderator Temperature Coefficient - MTC (TS 3.1.3)

#### 2.3.1 Moderator Temperature Coefficient (MTC) Limits are:

MTC shall be less positive than the upper limits shown in Figure 2.

BOC, ARO, HZP MTC shall be less positive than  $0.7\text{E-}04 \Delta\text{K/K/}^\circ\text{F}$ .

EOC, ARO, RTP MTC shall be less negative than the  $-4.3\text{E-}04 \Delta\text{K/K/}^\circ\text{F}$  lower MTC limit.

#### 2.3.2 300 ppm MTC Surveillance Limit is:

Measured 300 ppm ARO, equilibrium RTP MTC shall be less negative than or equal to  $-3.65\text{E-}04 \Delta\text{K/K/}^\circ\text{F}$ .

#### 2.3.3 The Revised Predicted near-EOC 300 ppm ARO RTP MTC shall be calculated using the procedure contained in DPC-NE-1007-PA.

If the Revised Predicted MTC is less negative than or equal to the 300 ppm SR 3.1.3.2 Surveillance Limit, and all benchmark data contained in the surveillance procedure is satisfied, then an MTC measurement in accordance with SR 3.1.3.2 is not required to be performed.

#### 2.3.4 60 ppm MTC Surveillance Limit is:

Measured 60 ppm ARO, equilibrium RTP MTC shall be less negative than or equal to  $-4.125\text{E-}04 \Delta\text{K/K/}^\circ\text{F}$ .

Where:


BOC =	Beginning of Cycle (burnup corresponding to most positive MTC)
EOC =	End of Cycle
ARO =	All Rods Out
HZP =	Hot Zero Power
RTP =	Rated Thermal Power
ppm =	Parts per million (Boron)

### 2.4 Shutdown Bank Insertion Limit (TS 3.1.5)

#### 2.4.1 Each shutdown bank shall be withdrawn to at least 222 steps. Shutdown banks are withdrawn in sequence and with no overlap.

### 2.5 Control Bank Insertion Limits (TS 3.1.6)


#### 2.5.1 Control banks shall be within the insertion, sequence, and overlap limits shown in Figure 3. Specific control bank withdrawal and overlap limits as a function of the fully withdrawn position are shown in Table 1.

**Catawba 1 Cycle 26 Core Operating Limits Report****Figure 2****Moderator Temperature Coefficient Upper Limit Versus Power Level**

**NOTE:** Compliance with Technical Specification 3.1.3 may require rod withdrawal limits. Refer to the Unit 1 ROD manual for details.

## Catawba 1 Cycle 26 Core Operating Limits Report

**Figure 3**  
**Control Bank Insertion Limits Versus Percent Rated Thermal Power**



The Rod Insertion Limits (RIL) for Control Bank D (CD), Control Bank C (CC), and Control Bank B (CB) can be calculated by:

$$\text{Bank CD RIL} = 2.3(P) - 69 \quad \{30 \leq P \leq 100\}$$

$$\text{Bank CC RIL} = 2.3(P) + 47 \quad \{0 \leq P \leq 76.1\} \text{ for CC RIL} = 222 \{76.1 < P \leq 100\}$$

$$\text{Bank CB RIL} = 2.3(P) + 163 \quad \{0 \leq P \leq 25.7\} \text{ for CB RIL} = 222 \{25.7 < P \leq 100\}$$

where  $P = \% \text{ of Rated Thermal Power}$

**NOTE:** Compliance with Technical Specification 3.1.3 may require rod withdrawal limits. Refer to the Unit 1 ROD manual for details.



**Catawba 1 Cycle 26 Core Operating Limits Report****Table 1**

<b>Control Bank Withdrawal Sequence Equation</b>			
<b>Control Bank A</b>	<b>Control Bank B</b>	<b>Control Bank C</b>	<b>Control Bank D</b>
0 Start	0	0	0
116	0 Start	0	0
CBA Stop	CBA - 116	0	0
CBA	116	0 Start	0
CBA	CBB Stop	CBB - 116	0
CBA	CBB	116	0 Start
CBA	CBB	CBC Stop	CBC - 116

Where:

*CBA* = Fully withdrawn position of Control Bank A

*CBB* = Fully withdrawn position of Control Bank B

*CBC* = Fully withdrawn position of Control Bank C

Allowed Control Bank Fully Withdrawn Positions Range from 223 Steps to 231 Steps for frequent RCCA Reposition Required per CNEI-0400-091, Rev. 6, "RCCA Axial Repositioning Schedule for Catawba Nuclear Station"

## Catawba 1 Cycle 26 Core Operating Limits Report

### 2.6 Heat Flux Hot Channel Factor - $F_Q(X,Y,Z)$ (TS 3.2.1)

**2.6.1**  $F_Q(X,Y,Z)$  steady-state limits are defined by the following relationships:

$$\begin{aligned} F_Q^{RTP} * K(Z)/P & \quad \text{for } P > 0.5 \\ F_Q^{RTP} * K(Z)/0.5 & \quad \text{for } P \leq 0.5 \end{aligned}$$

where,

$$P = \frac{\text{Thermal Power}}{\text{Rated Thermal Power}}$$

Note: Measured  $F_Q(X,Y,Z)$  shall be increased by 3% to account for manufacturing tolerances and 5% to account for measurement uncertainty when comparing against the LCO limits. The manufacturing tolerance and measurement uncertainty are implicitly included in the  $F_Q$  surveillance limits as defined in COLR Sections 2.6.5 and 2.6.6.

**2.6.2**  $F_Q^{RTP} = 2.70 \times K(BU)$

**2.6.3**  $K(Z)$  is the normalized  $F_Q(X,Y,Z)$  as a function of core height.  $K(Z)$  for Westinghouse RFA fuel is provided in Figure 4.

**2.6.4**  $K(BU)$  is the normalized  $F_Q(X,Y,Z)$  as a function of burnup.  $F_Q^{RTP}$  with the  $K(BU)$  penalty for Westinghouse RFA fuel is analytically confirmed in cycle-specific reload calculations.  $K(BU)$  is set to 1.0 at all burnups.

The following parameters are required for core monitoring per the Surveillance Requirements of Technical Specification 3.2.1:

**2.6.5**  $[F_Q^L(X,Y,Z)]^{OP} = \frac{F_Q^D(X,Y,Z) * M_Q(X,Y,Z)}{UMT * MT * TILT}$

where:

$[F_Q^L(X,Y,Z)]^{OP}$  = Cycle dependent maximum allowable design peaking factor that ensures  $F_Q(X,Y,Z)$  LOCA limit is not exceeded for operation within AFD, RIL, and QPTR limits.  
 $F_Q^L(X,Y,Z)^{OP}$  includes allowances for calculation and measurement uncertainties.

$F_Q^D(X,Y,Z)$  = Design power distribution for  $F_Q$ .  $F_Q^D(X,Y,Z)$  is provided in Appendix Table A-1 for normal operating conditions and in Appendix Table A-4 for power escalation testing during initial startup operation.

### Catawba 1 Cycle 26 Core Operating Limits Report

$M_Q(X,Y,Z)$  = Margin remaining in core location X,Y,Z to the LOCA limit in the transient power distribution.  $M_Q(X,Y,Z)$  is provided in Appendix Table A-1 for normal operating conditions and in Appendix Table A-4 for power escalation testing during initial startup operation.

UMT = Total Peak Measurement Uncertainty. (UMT = 1.05)

MT = Engineering Hot Channel Factor. (MT = 1.03)

TILT = Peaking penalty to account for allowable quadrant power tilt ratio of 1.02. (TILT = 1.035)

$$2.6.6 \quad [F_Q^L(X,Y,Z)]^{RPS} = \frac{F_Q^D(X,Y,Z) * M_C(X,Y,Z)}{UMT * MT * TILT}$$

where:

$[F_Q^L(X,Y,Z)]^{RPS}$  = Cycle dependent maximum allowable design peaking factor that ensures  $F_Q(X,Y,Z)$  Centerline Fuel Melt (CFM) limit is not exceeded for operation within AFD, RIL, and QPTR limits.  $[F_Q^L(X,Y,Z)]^{RPS}$  includes allowances for calculation and measurement uncertainties.

$F_Q^D(X,Y,Z)$  = Defined in Section 2.6.5.

$M_C(X,Y,Z)$  = Margin remaining to the CFM limit in core location X,Y,Z from the transient power distribution.  $M_C(X,Y,Z)$  is provided in Appendix Table A-2 for normal operating conditions and in Appendix Table A-5 for power escalation testing during initial startup operations.

UMT = Defined in Section 2.6.5.

MT = Defined in Section 2.6.5.


TILT = Defined in Section 2.6.5.

**Catawba 1 Cycle 26 Core Operating Limits Report****2.6.7**  $KSLOPE = 0.0725$ 

where:

$KSLOPE$  = Adjustment to  $K_1$  value from  $OT\Delta T$  trip setpoint required to compensate for each 1%  $F_Q^M(X,Y,Z)$  exceeds  $F_Q^L(X,Y,Z)^{RPS}$ .

**2.6.8**  $F_Q(X,Y,Z)$  Penalty Factors for Technical Specification Surveillances 3.2.1.2 and 3.2.1.3 are provided in Table 2.

**Catawba 1 Cycle 26 Core Operating Limits Report****Figure 4** **$K(Z)$ , Normalized  $F_Q(X,Y,Z)$  as a Function of Core Height  
for RFA Fuel**

## Catawba 1 Cycle 26 Core Operating Limits Report

### Table 2

**$F_Q(X,Y,Z)$  and  $F_{\Delta H}(X,Y)$  Penalty Factors  
For Tech Spec Surveillances 3.2.1.2, 3.2.1.3 and 3.2.2.2**

<b>Burnup (EFPD)</b>	<b><math>F_Q(X,Y,Z)</math> Penalty Factor(%)</b>	<b><math>F_{\Delta H}(X,Y)</math> Penalty Factor (%)</b>
4	2.00	2.00
12	2.00	2.00
25	2.00	2.00
50	2.00	2.00
75	2.00	2.00
100	2.00	2.00
125	2.00	2.00
150	2.00	2.00
175	2.00	2.00
200	2.00	2.00
225	2.00	2.00
250	2.00	2.00
275	2.00	2.00
300	2.00	2.00
325	2.00	2.00
350	2.00	2.00
375	2.00	2.00
400	2.00	2.00
425	2.00	2.00
445	2.00	2.00
466	2.00	2.00
476	2.00	2.00
485	2.00	2.00
495	2.00	2.00
505	2.00	2.00

**Note:** Linear interpolation is adequate for intermediate cycle burnups. All cycle burnups outside the range of the table shall use a 2% penalty factor for both  $F_Q(X,Y,Z)$  and  $F_{\Delta H}(X,Y)$  for compliance with Tech Spec Surveillances 3.2.1.2, 3.2.1.3 and 3.2.2.2.

## Catawba 1 Cycle 26 Core Operating Limits Report

### 2.7 Nuclear Enthalpy Rise Hot Channel Factor - $F_{\Delta H}(X,Y)$ (TS 3.2.2)

$F_{\Delta H}$  steady-state limits referred to in Technical Specification 3.2.2 are defined by the following relationship.

$$2.7.1 \quad [F_{\Delta H}^L(X,Y)]^{LCO} = \text{MARP}(X,Y) * \left[ 1.0 + \frac{1}{\text{RRH}} * (1.0 - P) \right]$$

where:

$[F_{\Delta H}^L(X,Y)]^{LCO}$  is the steady-state, maximum allowed radial peak and includes allowances for calculation/measurement uncertainty.

$\text{MARP}(X,Y) =$  Cycle-specific operating limit Maximum Allowable Radial Peaks.  $\text{MARP}(X,Y)$  radial peaking limits are provided in Table 3.

$$P = \frac{\text{Thermal Power}}{\text{Rated Thermal Power}}$$

$\text{RRH} =$  Thermal Power reduction required to compensate for each 1% measured radial peak,  $F_{\Delta H}^M(X,Y)$ , exceeds the limit.

$$(\text{RRH} = 3.34, 0.0 < P \leq 1.0)$$

The following parameters are required for core monitoring per surveillance requirements of Technical Specification 3.2.2.

$$2.7.2 \quad [F_{\Delta H}^L(X,Y)]^{SURV} = \frac{F_{\Delta H}^D(X,Y) * M_{\Delta H}(X,Y)}{\text{UMR} * \text{TILT}}$$

where:

$[F_{\Delta H}^L(X,Y)]^{SURV} =$  Cycle dependent maximum allowable design peaking factor that ensures  $F_{\Delta H}(X,Y)$  limit is not exceeded for operation within AFD, RIL, and QPTR limits.  $F_{\Delta H}^L(X,Y)^{SURV}$  includes allowances for calculation and measurement uncertainty.

$F_{\Delta H}^D(X,Y) =$  Design power distribution for  $F_{\Delta H}$ .  $F_{\Delta H}^D(X,Y)$  is provided in Appendix Table A-3 for normal operation and in Appendix Table A-6 for power escalation testing during initial startup operation.

## Catawba 1 Cycle 26 Core Operating Limits Report

$M_{\Delta H}(X,Y)$  = Margin remaining in core location X,Y relative to the Operational DNB limits in the transient power distribution.  $M_{\Delta H}(X,Y)$  is provided in Appendix Table A-3 for normal operation and in Appendix Table A-6 for power escalation testing during initial startup operation.

UMR = Uncertainty value for measured radial peaks (UMR = 1.0). UMR is 1.0 since a factor of 1.04 is implicitly included in the variable  $M_{\Delta H}(X,Y)$ .

TILT = Defined in Section 2.6.5.

**2.7.3** RRH is defined in Section 2.7.1.

**2.7.4** TRH = 0.04

where:

TRH = Reduction in OTΔT  $K_1$  setpoint required to compensate for each 1% that the measured radial peak,  $F_{\Delta H}^M(X,Y)$  exceeds its limit.

**2.7.5**  $F_{\Delta H}(X,Y)$  Penalty Factors for Technical Specification Surveillance 3.2.2.2 are provided in Table 2.

## **2.8 Axial Flux Difference – AFD (TS 3.2.3)**


**2.8.1** Axial Flux Difference (AFD) Limits are provided in Figure 5.



**Catawba 1 Cycle 26 Core Operating Limits Report**

**Table 3**  
**Maximum Allowable Radial Peaks (MARPs)**  
**RFA Steady State Limiting Value Between**  
**Loss of Flow Accident (LOFA) MARPs and  $F\Delta H_{LOCA}$**

Core Height (ft)	Axial Peak												
	1.05	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.1	3	3.25
0.12	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.3151	1.2461
1.20	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.3007	1.2235
2.40	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.4633	1.4616
3.60	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.4675	1.3874
4.80	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.2987	1.2579
6.00	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.3293	1.2602
7.20	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.5982	1.2871	1.2195
8.40	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6010	1.5127	1.2182	1.1578
9.60	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.5808	1.5301	1.4444	1.1431	1.0914
10.80	1.6058	1.6058	1.6058	1.6058	1.6058	1.6058	1.5743	1.5573	1.5088	1.4624	1.3832	1.1009	1.0470
11.40	1.6058	1.6058	1.6058	1.6058	1.6057	1.5826	1.5289	1.5098	1.4637	1.4218	1.3458	1.0670	1.0142

**Catawba 1 Cycle 26 Core Operating Limits Report****Figure 5****Percent of Rated Thermal Power Versus Percent Axial Flux Difference Limits**

**NOTE:** Compliance with Technical Specification 3.2.1 may require more restrictive AFD limits. Refer to the Unit 1 ROD manual for operational AFD limits.

## Catawba 1 Cycle 26 Core Operating Limits Report

### 2.9 Reactor Trip System Instrumentation Setpoints (TS 3.3.1) Table 3.3.1-1

#### 2.9.1 Overtemperature $\Delta T$ Setpoint Parameter Values

<u>Parameter</u>	<u>Nominal Value</u>
Nominal $T_{avg}$ at RTP	$T' \leq 585.1^{\circ}\text{F}$
Nominal RCS Operating Pressure	$P' = 2235 \text{ psig}$
Overtemperature $\Delta T$ reactor trip setpoint	$K_1 = 1.1978$
Overtemperature $\Delta T$ reactor trip heatup setpoint penalty coefficient	$K_2 = 0.03340/^{\circ}\text{F}$
Overtemperature $\Delta T$ reactor trip depressurization setpoint penalty coefficient	$K_3 = 0.001601/\text{psi}$
Time constants utilized in the lead-lag compensator for $\Delta T$	$\tau_1 = 8 \text{ sec.}$ $\tau_2 = 3 \text{ sec.}$
Time constant utilized in the lag compensator for $\Delta T$	$\tau_3 = 0 \text{ sec.}$
Time constants utilized in the lead-lag compensator for $T_{avg}$	$\tau_4 = 22 \text{ sec.}$ $\tau_5 = 4 \text{ sec.}$
Time constant utilized in the measured $T_{avg}$ lag compensator	$\tau_6 = 0 \text{ sec.}$
$f_1(\Delta I)$ "positive" breakpoint	$= 19.0 \% \Delta I$
$f_1(\Delta I)$ "negative" breakpoint	$= \text{N/A}^*$
$f_1(\Delta I)$ "positive" slope	$= 1.769 \% \Delta T_0 / \% \Delta I$
$f_1(\Delta I)$ "negative" slope	$= \text{N/A}^*$

- \*  $f_1(\Delta I)$  negative breakpoints and slopes for OTAT are less restrictive than OPAT  $f_2(\Delta I)$  negative breakpoint and slope. Therefore, during a transient which challenges negative imbalance limits, OPAT  $f_2(\Delta I)$  limits will result in a reactor trip before OTAT  $f_1(\Delta I)$  limits are reached. This makes implementation of an OTAT  $f_1(\Delta I)$  negative breakpoint and slope unnecessary.

## Catawba 1 Cycle 26 Core Operating Limits Report

### 2.9.2 Overpower $\Delta T$ Setpoint Parameter Values

<u>Parameter</u>	<u>Nominal Value</u>
Nominal $T_{avg}$ at RTP	$T'' \leq 585.1^{\circ}\text{F}$
Overpower $\Delta T$ reactor trip setpoint	$K_4 = 1.0864$
Overpower $\Delta T$ reactor trip penalty	$K_5 = 0.02 / ^{\circ}\text{F}$ for increasing $T_{avg}$ $K_5 = 0.00 / ^{\circ}\text{F}$ for decreasing $T_{avg}$
Overpower $\Delta T$ reactor trip heatup setpoint penalty coefficient	$K_6 = 0.001179/^{\circ}\text{F}$ for $T > T''$ $K_6 = 0.0 / ^{\circ}\text{F}$ for $T \leq T''$
Time constants utilized in the lead-lag compensator for $\Delta T$	$\tau_1 = 8 \text{ sec.}$ $\tau_2 = 3 \text{ sec.}$
Time constant utilized in the lag compensator for $\Delta T$	$\tau_3 = 0 \text{ sec.}$
Time constant utilized in the measured $T_{avg}$ lag compensator	$\tau_6 = 0 \text{ sec.}$
Time constant utilized in the rate-lag controller for $T_{avg}$	$\tau_7 = 10 \text{ sec.}$
$f_2(\Delta I)$ "positive" breakpoint	$= 35.0 \% \Delta I$
$f_2(\Delta I)$ "negative" breakpoint	$= -35.0 \% \Delta I$
$f_2(\Delta I)$ "positive" slope	$= 7.0 \% \Delta T_0 / \% \Delta I$
$f_2(\Delta I)$ "negative" slope	$= 7.0 \% \Delta T_0 / \% \Delta I$

## Catawba 1 Cycle 26 Core Operating Limits Report

### 2.10 Boron Dilution Mitigation System (TS 3.3.9)

#### 2.10.1 Reactor Makeup Water Pump flow rate limits:

<u>Applicable Mode</u>	<u>Limit</u>
MODE 3	$\leq$ 80 gpm
MODE 4 or 5	$\leq$ 70 gpm

### 2.11 RCS Pressure, Temperature, and Flow Limits for DNB (TS 3.4.1)

RCS pressure, temperature and flow limits for DNB are shown in Table 4.

### 2.12 Accumulators (TS 3.5.1)

#### 2.12.1 Boron concentration limits during MODES 1 and 2, and MODE 3 with RCS pressure >1000 psi:

<u>Parameter</u>	<u>Applicable Burnup</u>	<u>Limit</u>
Accumulator <b>minimum</b> boron concentration.	0 - 200 EFPD	2,500 ppm
Accumulator <b>minimum</b> boron concentration.	200.1 - 300 EFPD	2,449 ppm
Accumulator <b>minimum</b> boron concentration.	300.1 - 400 EFPD	2,243 ppm
Accumulator <b>minimum</b> boron concentration.	400.1 - 505 EFPD	2,087 ppm
Accumulator <b>maximum</b> boron concentration.	0 - 505 EFPD	3,075 ppm

**Catawba 1 Cycle 26 Core Operating Limits Report****Table 4**

## Reactor Coolant System DNB Parameters

<b>PARAMETER</b>	<b>INDICATION</b>	<b>No. Operable CHANNELS</b>	<b>LIMITS</b>
1. Indicated RCS Average Temperature	meter	4	$\leq 587.2$ °F
	meter	3	$\leq 586.9$ °F
	computer	4	$\leq 587.7$ °F
	computer	3	$\leq 587.5$ °F
	meter	4	$\geq 2209.8$ psig
	meter	3	$\geq 2212.1$ psig
2. Indicated Pressurizer Pressure	computer	4	$\geq 2205.8$ psig
	computer	3	$\geq 2207.5$ psig
3. RCS Total Flow Rate			$\geq 384,000$ gpm

**Catawba 1 Cycle 26 Core Operating Limits Report****2.13 Refueling Water Storage Tank - RWST (TS 3.5.4)****2.13.1** Boron concentration limits during MODES 1, 2, 3, and 4:

<u>Parameter</u>	<u>Limit</u>
RWST minimum boron concentration.	2,700 ppm
RWST maximum boron concentration.	3,075 ppm

**2.14 Spent Fuel Pool Boron Concentration (TS 3.7.15)****2.14.1** Minimum boron concentration limit for the spent fuel pool. Applicable when fuel assemblies are stored in the spent fuel pool.

<u>Parameter</u>	<u>Limit</u>
Spent fuel pool minimum boron concentration.	2,700 ppm

**2.15 Refueling Operations - Boron Concentration (TS 3.9.1)****2.15.1** Minimum boron concentration limit for filled portions of the Reactor Coolant System, refueling canal, and refueling cavity for MODE 6 conditions. The minimum boron concentration limit and plant refueling procedures ensure that core  $K_{\text{eff}}$  remains within MODE 6 reactivity requirement of  $K_{\text{eff}} \leq 0.95$ .

<u>Parameter</u>	<u>Limit</u>
Minimum boron concentration of the Reactor Coolant System, the refueling canal, and the refueling cavity.	2,700 ppm

## Catawba 1 Cycle 26 Core Operating Limits Report

### 2.16 Standby Shutdown System - (SLC-16.7-9)

**2.16.1** Minimum boron concentration limit for the spent fuel pool required for Standby Makeup Pump Water Supply. Applicable for MODES 1, 2, and 3.

<u>Parameter</u>	<u>Limit</u>
Spent fuel pool minimum boron concentration for TR 16.7-9-3.	2,700 ppm

### 2.17 Boration Systems Borated Water Source – Shutdown (SLC 16.9-11)

**2.17.1** Volume and boron concentrations for the Boric Acid Tank (BAT) and the Refueling Water Storage Tank (RWST) during MODE 4 with any RCS cold leg temperature  $\leq 210$  °F, and MODES 5 and 6.

<u>Parameter</u>	<u>Limit</u>
------------------	--------------

**NOTE: When cycle burnup is  $\geq 445$  EFPD, Figure 6 may be used to determine the required BAT Minimum Level.**

BAT minimum boron concentration	7,000 ppm
Volume of 7,000 ppm boric acid solution required to maintain SDM at 68°F	2,000 gallons
BAT Minimum Shutdown Volume (Includes the additional volumes listed in SLC 16.9-11)	13,086 gallons (14.9%)
RWST minimum boron concentration	2,700 ppm
Volume of 2,700 ppm boric acid solution required to maintain SDM at 68 °F	7,000 gallons
RWST Minimum Shutdown Volume (Includes the additional volumes listed in SLC 16.9-11)	48,500 gallons (8.7%)



## Catawba 1 Cycle 26 Core Operating Limits Report

### 2.18 Boration Systems Borated Water Source - Operating (SLC 16.9-12)

**2.18.1** Volume and boron concentrations for the Boric Acid Tank (BAT) and the Refueling Water Storage Tank (RWST) during MODES 1, 2, and 3 and MODE 4 with all RCS cold leg temperatures > 210 °F\*.


**\* NOTE: The SLC 16.9-12 applicability is down to MODE 4 temperatures of > 210°F. The minimum volumes calculated support cooldown to 200°F to satisfy UFSAR Chapter 9 requirements.**

Parameter

Limit

**NOTE: When cycle burnup is  $\geq 445$  EFPD, Figure 6 may be used to determine the required BAT Minimum Level.**

BAT minimum boron concentration	7,000 ppm
Volume of 7,000 ppm boric acid solution required to maintain SDM at 210 °F	13,500 gallons
BAT Minimum Shutdown Volume (Includes the additional volumes listed in SLC 16.9-12)	25,200 gallons (45.8%)
RWST minimum boron concentration	2,700 ppm
Volume of 2,700 ppm boric acid solution required to maintain SDM at 210 °F	57,107 gallons
RWST Minimum Shutdown Volume (Includes the additional volumes listed in SLC 16.9-12)	98,607 gallons (22.0%)

**Catawba 1 Cycle 26 Core Operating Limits Report****Figure 6****Boric Acid Storage Tank Indicated Level Versus  
Primary Coolant Boron Concentration****(Valid When Cycle Burnup is  $\geq 445$  EFPD)****This figure includes additional volumes listed in SLC 16.9-11 and 16.9-12**

## **Catawba 1 Cycle 26 Core Operating Limits Report**

### **Appendix A**

#### **Power Distribution Monitoring Factors**

Appendix A contains power distribution monitoring factors used in Technical Specification Surveillance. This data was generated in the Catawba 1 Cycle 26 Maneuvering Analysis calculation file, CNC-1553.05-00-0682. Due to the size of the monitoring factor data, Appendix A is controlled electronically within the Duke document management system and is not included in the Duke internal copies of the COLR. The Plant Reactor Engineering and Support Systems section will control this information via computer file(s) and should be contacted if there is a need to access this information.

Appendix A is available to be transmitted to the NRC.

## **Attachment**

Catawba Unit 1, Cycle 26, Revision 0, Core Operating Limits Report,  
Appendix A, Power Distribution Monitoring Factors

**Appendix A**  
**Power Distribution Monitoring Factors**

<b>Table</b>	<b>Description</b>	<b>Page</b>
TABLE A-1	F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN), NORMAL OPERATION	2
TABLE A-2	M-SUB-C VALUES (F-SUB-Q RPS MARGIN), NORMAL OPERATION	218
TABLE A-3	F-DEL-H & M-DEL-H VALUES, NORMAL OPERATION	242
TABLE A-4	F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN), POWER ESCALATION	251
TABLE A-5	M-SUB-C VALUES (F-SUB-Q RPS MARGIN), POWER ESCALATION	299
TABLE A-6	F-DEL-H & M-DEL-H VALUES, POWER ESCALATION	305

# C1C26 Core Operating Limits Report

TABLE A-1

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4821	* 0.5514	* 0.6475	* 0.5621	* 0.6303	* 0.5354	* 0.5346	* 0.2994
	* 3.6704	* 3.6191	* 2.9946	* 3.3899	* 2.9666	* 3.4730	* 3.4446	* 5.5420
9	* 0.5514	* 0.6304	* 0.5775	* 0.6372	* 0.5504	* 0.5233	* 0.5288	* 0.2960
	* 3.6191	* 3.1608	* 3.3245	* 2.9867	* 3.4215	* 3.5649	* 3.4990	* 5.6460
10	* 0.6475	* 0.5772	* 0.5278	* 0.5424	* 0.6170	* 0.5246	* 0.4899	* 0.2674
	* 2.9946	* 3.3262	* 3.6756	* 3.5495	* 3.1468	* 3.7072	* 3.8741	* 6.2830
11	* 0.5621	* 0.6370	* 0.5422	* 0.6101	* 0.5418	* 0.5500	* 0.3807	* 0.1883
	* 3.3899	* 2.9879	* 3.5509	* 3.1961	* 3.6051	* 3.4973	* 4.7682	* 9.2890
12	* 0.6303	* 0.5504	* 0.6169	* 0.5416	* 0.4841	* 0.4896	* 0.3102	*
	* 2.9666	* 3.4220	* 3.1474	* 3.6064	* 3.6641	* 3.6448	* 5.5120	*
13	* 0.5354	* 0.5233	* 0.5248	* 0.5500	* 0.4896	* 0.4288	* 0.2354	*
	* 3.4730	* 3.5648	* 3.7061	* 3.4973	* 3.6445	* 4.1006	* 7.0409	*
14	* 0.5346	* 0.5288	* 0.4899	* 0.3808	* 0.3101	* 0.2354	*	*
	* 3.4446	* 3.4984	* 3.8734	* 4.7677	* 5.5088	* 7.0416	*	*
15	* 0.2994	* 0.2962	* 0.2675	* 0.1857	* F-SUB-Q			
	* 5.5420	* 5.6412	* 6.2827	* 9.2699	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1384	* 1.1894	* 1.3940	* 1.1921	* 1.3655	* 1.2145	* 1.3125	* 0.6791
	* 1.6986	* 1.7047	* 1.4146	* 1.6322	* 1.4023	* 1.5651	* 1.4348	* 2.5019
9	* 1.1894	* 1.3878	* 1.2918	* 1.3868	* 1.2114	* 1.1998	* 1.3022	* 0.6755
	* 1.7047	* 1.4599	* 1.5191	* 1.4052	* 1.5928	* 1.5855	* 1.4526	* 2.5333
10	* 1.3940	* 1.2909	* 1.1399	* 1.1732	* 1.3622	* 1.2092	* 1.2234	* 0.6107
	* 1.4146	* 1.5202	* 1.7393	* 1.6750	* 1.4507	* 1.6449	* 1.5831	* 2.8140
11	* 1.1921	* 1.3862	* 1.1728	* 1.3735	* 1.2060	* 1.2849	* 0.8629	* 0.4334
	* 1.6322	* 1.4057	* 1.6756	* 1.4401	* 1.6487	* 1.5237	* 2.1316	* 4.1218
12	* 1.3655	* 1.2110	* 1.3620	* 1.2055	* 1.1482	* 1.2493	* 0.7046	*
	* 1.4023	* 1.5930	* 1.4509	* 1.6494	* 1.6081	* 1.4975	* 2.4745	*
13	* 1.2145	* 1.1999	* 1.2098	* 1.2849	* 1.2494	* 1.0987	* 0.5523	*
	* 1.5651	* 1.5853	* 1.6443	* 1.5236	* 1.4974	* 1.6796	* 3.0675	*
14	* 1.3125	* 1.3025	* 1.2236	* 0.8632	* 0.7042	* 0.5523	*	*
	* 1.4348	* 1.4524	* 1.5828	* 2.1312	* 2.4737	* 3.0678	*	*
15	* 0.6791	* 0.6759	* 0.6108	* 0.4277	* F-SUB-Q			
	* 2.5019	* 2.5325	* 2.8136	* 4.1092	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3717	* 1.3401	* 1.3291	* 1.3332	* 1.3200	* 1.4298	* 1.4216	* 0.7720
	* 1.4757	* 1.5240	* 1.5091	* 1.4818	* 1.4635	* 1.3486	* 1.3457	* 2.2347
9	* 1.3401	* 1.4008	* 1.4557	* 1.3700	* 1.4074	* 1.4277	* 1.4243	* 0.7772
	* 1.5240	* 1.4638	* 1.3892	* 1.4432	* 1.4045	* 1.3521	* 1.3486	* 2.2340
10	* 1.3291	* 1.4542	* 1.3470	* 1.3441	* 1.3863	* 1.4179	* 1.4081	* 0.7203
	* 1.5091	* 1.3915	* 1.4957	* 1.4929	* 1.4396	* 1.4116	* 1.3937	* 2.4219
11	* 1.3332	* 1.3690	* 1.3436	* 1.3971	* 1.3952	* 1.4187	* 1.0225	* 0.5202
	* 1.4818	* 1.4439	* 1.4935	* 1.4328	* 1.4343	* 1.3988	* 1.8233	* 3.4844
12	* 1.3200	* 1.4073	* 1.3860	* 1.3947	* 1.4103	* 1.3980	* 0.8112	*
	* 1.4635	* 1.4045	* 1.4398	* 1.4349	* 1.3828	* 1.3920	* 2.1906	*
13	* 1.4298	* 1.4278	* 1.4187	* 1.4187	* 1.3983	* 1.3434	* 0.6740	*
	* 1.3486	* 1.3519	* 1.4109	* 1.3988	* 1.3917	* 1.4199	* 2.5660	*
14	* 1.4216	* 1.4245	* 1.4085	* 1.0229	* 0.8107	* 0.6740	*	*
	* 1.3457	* 1.3485	* 1.3933	* 1.8229	* 2.1903	* 2.5663	*	*
15	* 0.7720	* 0.7777	* 0.7204	* 0.5158	* F-SUB-Q			
	* 2.2347	* 2.2333	* 2.4213	* 3.4581	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4833	* 1.4328	* 1.4255	* 1.3990	* 1.4337	* 1.5582	* 1.5763	* 0.8059
	* 1.3932	* 1.4493	* 1.4146	* 1.4343	* 1.3689	* 1.2524	* 1.2309	* 2.1718
9	* 1.4328	* 1.5178	* 1.5605	* 1.4688	* 1.5226	* 1.5689	* 1.5810	* 0.8176
	* 1.4493	* 1.3705	* 1.3163	* 1.3695	* 1.3171	* 1.2459	* 1.2319	* 2.1549
10	* 1.4255	* 1.5586	* 1.4490	* 1.4446	* 1.5266	* 1.5509	* 1.5755	* 0.7589
	* 1.4146	* 1.3189	* 1.4120	* 1.4239	* 1.3271	* 1.3073	* 1.2625	* 2.3318
11	* 1.3990	* 1.4676	* 1.4441	* 1.5259	* 1.5192	* 1.5791	* 1.0904	* 0.5500
	* 1.4343	* 1.3701	* 1.4246	* 1.3334	* 1.3386	* 1.2797	* 1.7372	* 3.3412
12	* 1.4337	* 1.5225	* 1.5263	* 1.5184	* 1.5498	* 1.5570	* 0.8559	*
	* 1.3689	* 1.3172	* 1.3271	* 1.3393	* 1.2820	* 1.2773	* 2.1180	*
13	* 1.5582	* 1.5692	* 1.5520	* 1.5791	* 1.5574	* 1.5258	* 0.7214	*
	* 1.2524	* 1.2456	* 1.3064	* 1.2797	* 1.2770	* 1.2776	* 2.4490	*
14	* 1.5763	* 1.5813	* 1.5760	* 1.0909	* 0.8552	* 0.7213	*	*
	* 1.2309	* 1.2317	* 1.2621	* 1.7367	* 2.1180	* 2.4493	*	*
15	* 0.8059	* 0.8182	* 0.7591	* 0.5440	* F-SUB-Q			
	* 2.1718	* 2.1541	* 2.3312	* 3.3236	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5150	* 1.4606	* 1.4643	* 1.4228	* 1.4898	* 1.6162	* 1.6543	* 0.8292
	* 1.3911	* 1.4490	* 1.4274	* 1.4350	* 1.3392	* 1.2225	* 1.1918	* 2.1490
9	* 1.4606	* 1.5639	* 1.5932	* 1.5163	* 1.5708	* 1.6334	* 1.6599	* 0.8423
	* 1.4490	* 1.3534	* 1.3093	* 1.3476	* 1.2976	* 1.2156	* 1.1920	* 2.1270
10	* 1.4643	* 1.5909	* 1.4786	* 1.4895	* 1.5967	* 1.6072	* 1.6591	* 0.7843
	* 1.4274	* 1.3122	* 1.4073	* 1.4088	* 1.2934	* 1.2811	* 1.2169	* 2.2930
11	* 1.4228	* 1.5154	* 1.4888	* 1.5943	* 1.5771	* 1.6611	* 1.1329	* 0.5659
	* 1.4350	* 1.3482	* 1.4096	* 1.3009	* 1.3136	* 1.2403	* 1.7020	* 3.2957
12	* 1.4898	* 1.5707	* 1.5963	* 1.5762	* 1.6126	* 1.6399	* 0.8860	*
	* 1.3392	* 1.2976	* 1.2933	* 1.3143	* 1.2537	* 1.2383	* 2.0899	*
13	* 1.6162	* 1.6337	* 1.6084	* 1.6611	* 1.6402	* 1.6210	* 0.7512	*
	* 1.2225	* 1.2153	* 1.2801	* 1.2404	* 1.2381	* 1.2290	* 2.4055	*
14	* 1.6543	* 1.6602	* 1.6597	* 1.1333	* 0.8852	* 0.7511	*	*
	* 1.1918	* 1.1917	* 1.2165	* 1.7016	* 2.0901	* 2.4058	*	*
15	* 0.8292	* 0.8429	* 0.7845	* 0.5587	* F-SUB-Q			
	* 2.1490	* 2.1261	* 2.2924	* 3.2843	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5228	* 1.4664	* 1.4764	* 1.4311	* 1.5160	* 1.6499	* 1.6958	* 0.8453
	* 1.4040	* 1.4638	* 1.4408	* 1.4536	* 1.3410	* 1.2196	* 1.1840	* 2.1492
9	* 1.4664	* 1.5792	* 1.6028	* 1.5378	* 1.5945	* 1.6686	* 1.7019	* 0.8579
	* 1.4638	* 1.3577	* 1.3233	* 1.3533	* 1.3010	* 1.2115	* 1.1836	* 2.1279
10	* 1.4764	* 1.6003	* 1.4871	* 1.5115	* 1.6331	* 1.6356	* 1.7036	* 0.8021
	* 1.4408	* 1.3265	* 1.4240	* 1.4084	* 1.2903	* 1.2770	* 1.2046	* 2.2823
11	* 1.4311	* 1.5367	* 1.5107	* 1.6284	* 1.6135	* 1.7050	* 1.1618	* 0.5763
	* 1.4536	* 1.3540	* 1.4091	* 1.2955	* 1.3083	* 1.2292	* 1.6804	* 3.2860
12	* 1.5160	* 1.5944	* 1.6329	* 1.6130	* 1.6498	* 1.6851	* 0.9070	*
	* 1.3410	* 1.3010	* 1.2902	* 1.3088	* 1.2475	* 1.2304	* 2.0823	*
13	* 1.6499	* 1.6691	* 1.6370	* 1.7049	* 1.6853	* 1.6752	* 0.7720	*
	* 1.2196	* 1.2111	* 1.2760	* 1.2293	* 1.2302	* 1.2187	* 2.3988	*
14	* 1.6958	* 1.7022	* 1.7042	* 1.1621	* 0.9061	* 0.7719	*	*
	* 1.1840	* 1.1834	* 1.2042	* 1.6801	* 2.0828	* 2.3992	*	*
15	* 0.8453	* 0.8586	* 0.8022	* 0.5689	* F-SUB-Q			
	* 2.1492	* 2.1269	* 2.2820	* 3.2750	* M-SUB-Q			



# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5356	* 1.4765	* 1.4957	* 1.4441	* 1.5484	* 1.6871	* 1.7423	* 0.8511
	* 1.4087	* 1.4692	* 1.4485	* 1.4701	* 1.3413	* 1.2184	* 1.1771	* 2.1817
9	* 1.4765	* 1.6007	* 1.6185	* 1.5630	* 1.6200	* 1.7075	* 1.7486	* 0.8656
	* 1.4692	* 1.3541	* 1.3339	* 1.3582	* 1.3053	* 1.2086	* 1.1762	* 2.1545
10	* 1.4957	* 1.6157	* 1.5008	* 1.5340	* 1.6742	* 1.6672	* 1.7509	* 0.8079
	* 1.4485	* 1.3373	* 1.4371	* 1.4014	* 1.2752	* 1.2716	* 1.1934	* 2.3114
11	* 1.4441	* 1.5618	* 1.5332	* 1.6641	* 1.6407	* 1.7508	* 1.1743	* 0.5785
	* 1.4701	* 1.3590	* 1.4021	* 1.2857	* 1.3005	* 1.2141	* 1.6776	* 3.3211
12	* 1.5484	* 1.6199	* 1.6740	* 1.6401	* 1.6901	* 1.7321	* 0.9140	*
	* 1.3413	* 1.3054	* 1.2754	* 1.3012	* 1.2374	* 1.2203	* 2.1032	*
13	* 1.6871	* 1.7081	* 1.6687	* 1.7507	* 1.7323	* 1.7302	* 0.7794	*
	* 1.2184	* 1.2082	* 1.2705	* 1.2142	* 1.2201	* 1.2025	* 2.4231	*
14	* 1.7423	* 1.7490	* 1.7515	* 1.1746	* 0.9130	* 0.7793	*	*
	* 1.1771	* 1.1760	* 1.1930	* 1.6774	* 2.1039	* 2.4235	*	*
15	* 0.8511	* 0.8663	* 0.8080	* 0.5691	* F-SUB-Q			
	* 2.1817	* 2.1535	* 2.3112	* 3.3218	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5375	* 1.4765	* 1.5006	* 1.4471	* 1.5648	* 1.7092	* 1.7698	* 0.8552
	* 1.4299	* 1.4940	* 1.4722	* 1.4997	* 1.3597	* 1.2322	* 1.1873	* 2.2250
9	* 1.4765	* 1.6074	* 1.6224	* 1.5746	* 1.6330	* 1.7313	* 1.7762	* 0.8703
	* 1.4940	* 1.3717	* 1.3537	* 1.3788	* 1.3224	* 1.2205	* 1.1857	* 2.1949
10	* 1.5006	* 1.6195	* 1.5041	* 1.5451	* 1.6972	* 1.6845	* 1.7793	* 0.8126
	* 1.4722	* 1.3562	* 1.4580	* 1.4174	* 1.2797	* 1.2800	* 1.1982	* 2.3491
11	* 1.4471	* 1.5737	* 1.5442	* 1.6828	* 1.6585	* 1.7779	* 1.1848	* 0.5802
	* 1.4997	* 1.3797	* 1.4182	* 1.2915	* 1.3068	* 1.2144	* 1.6927	* 3.3565
12	* 1.5648	* 1.6329	* 1.6970	* 1.6577	* 1.7190	* 1.7598	* 0.9198	*
	* 1.3597	* 1.3224	* 1.2799	* 1.3076	* 1.2372	* 1.2184	* 2.1187	*
13	* 1.7092	* 1.7319	* 1.6861	* 1.7777	* 1.7600	* 1.7651	* 0.7856	*
	* 1.2322	* 1.2200	* 1.2788	* 1.2145	* 1.2183	* 1.2000	* 2.4431	*
14	* 1.7698	* 1.7766	* 1.7799	* 1.1850	* 0.9187	* 0.7854	*	*
	* 1.1873	* 1.1854	* 1.1978	* 1.6926	* 2.1195	* 2.4436	*	*
15	* 0.8552	* 0.8710	* 0.8126	* 0.5699	* F-SUB-Q			
	* 2.2250	* 2.1939	* 2.3492	* 3.3621	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5403	* 1.4771	* 1.5077	* 1.4502	* 1.5826	* 1.7305	* 1.7973	* 0.8559 *
	* 1.4679	* 1.5333	* 1.4934	* 1.5338	* 1.3816	* 1.2513	* 1.2019	* 2.2854 *
9	* 1.4771	* 1.6162	* 1.6274	* 1.5896	* 1.6452	* 1.7540	* 1.8039	* 0.8721 *
	* 1.5333	* 1.3891	* 1.3769	* 1.4000	* 1.3443	* 1.2376	* 1.1996	* 2.2504 *
10	* 1.5077	* 1.6244	* 1.5080	* 1.5550	* 1.7206	* 1.7012	* 1.8073	* 0.8136 *
	* 1.4934	* 1.3795	* 1.4852	* 1.4380	* 1.2940	* 1.2926	* 1.2072	* 2.4055 *
11	* 1.4502	* 1.5886	* 1.5540	* 1.7018	* 1.6756	* 1.8045	* 1.1901	* 0.5797 *
	* 1.5338	* 1.4008	* 1.4388	* 1.3103	* 1.3269	* 1.2273	* 1.7189	* 3.4240 *
12	* 1.5826	* 1.6451	* 1.7204	* 1.6744	* 1.7462	* 1.7870	* 0.9217	*
	* 1.3816	* 1.3444	* 1.2937	* 1.3279	* 1.2521	* 1.2315	* 2.1670	*
13	* 1.7305	* 1.7546	* 1.7027	* 1.8043	* 1.7871	* 1.7981	* 0.7877	*
	* 1.2513	* 1.2371	* 1.2914	* 1.2275	* 1.2314	* 1.2077	* 2.4953	*
14	* 1.7973	* 1.8043	* 1.8079	* 1.1903	* 0.9205	* 0.7875	*	
	* 1.2019	* 1.1993	* 1.2068	* 1.7189	* 2.1681	* 2.4959	*	
15	* 0.8559	* 0.8728	* 0.8136	* 0.5687	* F-SUB-Q			
	* 2.2854	* 2.2494	* 2.4057	* 3.4346	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5178	* 1.4544	* 1.4798	* 1.4299	* 1.5632	* 1.7198	* 1.7830	* 0.8608
	* 1.5255	* 1.5913	* 1.5585	* 1.6001	* 1.4427	* 1.2993	* 1.2501	* 2.3442
9	* 1.4544	* 1.5899	* 1.6043	* 1.5666	* 1.6316	* 1.7444	* 1.7899	* 0.8740
	* 1.5913	* 1.4488	* 1.4340	* 1.4605	* 1.3938	* 1.2831	* 1.2467	* 2.3151
10	* 1.4798	* 1.6011	* 1.4877	* 1.5426	* 1.7034	* 1.6921	* 1.7945	* 0.8207
	* 1.5585	* 1.4368	* 1.5465	* 1.4876	* 1.3384	* 1.3364	* 1.2492	* 2.4540
11	* 1.4299	* 1.5656	* 1.5418	* 1.6843	* 1.6751	* 1.7903	* 1.2028	* 0.5839
	* 1.6001	* 1.4615	* 1.4885	* 1.3604	* 1.3621	* 1.2706	* 1.7419	* 3.4862
12	* 1.5632	* 1.6314	* 1.7031	* 1.6743	* 1.7405	* 1.7738	* 0.9300	
	* 1.4427	* 1.3939	* 1.3386	* 1.3627	* 1.2991	* 1.2818	* 2.2105	
13	* 1.7198	* 1.7450	* 1.6951	* 1.7901	* 1.7739	* 1.7888	* 0.7971	
	* 1.2993	* 1.2826	* 1.3351	* 1.2708	* 1.2817	* 1.2544	* 2.5456	
14	* 1.7830	* 1.7903	* 1.7950	* 1.2028	* 0.9288	* 0.7969	*	
	* 1.2501	* 1.2465	* 1.2489	* 1.7420	* 2.2117	* 2.5463	*	
15	* 0.8608	* 0.8747	* 0.8205	* 0.5740	* F-SUB-Q			
	* 2.3442	* 2.3140	* 2.4544	* 3.4894	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5243	* 1.4585	* 1.4945	* 1.4357	* 1.5879	* 1.7453	* 1.8184	* 0.8530
	* 1.5636	* 1.6346	* 1.5914	* 1.6459	* 1.4700	* 1.3259	* 1.2692	* 2.4477
9	* 1.4585	* 1.6057	* 1.6137	* 1.5890	* 1.6453	* 1.7711	* 1.8253	* 0.8696
	* 1.6346	* 1.4798	* 1.4719	* 1.4868	* 1.4277	* 1.3080	* 1.2654	* 2.4067
10	* 1.4945	* 1.6104	* 1.4946	* 1.5522	* 1.7338	* 1.7117	* 1.8295	* 0.8127
	* 1.5914	* 1.4749	* 1.5894	* 1.5250	* 1.3562	* 1.3600	* 1.2648	* 2.5592
11	* 1.4357	* 1.5879	* 1.5511	* 1.7085	* 1.6836	* 1.8231	* 1.1958	* 0.5768
	* 1.6459	* 1.4879	* 1.5260	* 1.3816	* 1.3969	* 1.2851	* 1.8069	* 3.6354
12	* 1.5879	* 1.6451	* 1.7335	* 1.6822	* 1.7712	* 1.8071	* 0.9207	*
	* 1.4700	* 1.4278	* 1.3565	* 1.3980	* 1.3164	* 1.2943	* 2.2930	*
13	* 1.7453	* 1.7718	* 1.7134	* 1.8228	* 1.8071	* 1.8290	* 0.7886	*
	* 1.3259	* 1.3075	* 1.3586	* 1.2853	* 1.2942	* 1.2656	* 2.6465	*
14	* 1.8184	* 1.8257	* 1.8300	* 1.1959	* 0.9194	* 0.7884	*	*
	* 1.2692	* 1.2651	* 1.2644	* 1.8070	* 2.2945	* 2.6472	*	*
15	* 0.8530	* 0.8703	* 0.8125	* 0.5645	* F-SUB-Q			
	* 2.4477	* 2.4055	* 2.5598	* 3.6551	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5128	* 1.4461	* 1.4851	* 1.4253	* 1.5867	* 1.7478	* 1.8243	* 0.8494
	* 1.5872	* 1.6544	* 1.6051	* 1.6672	* 1.5023	* 1.3675	* 1.3093	* 2.5468
9	* 1.4461	* 1.5974	* 1.6030	* 1.5851	* 1.6410	* 1.7749	* 1.8311	* 0.8660
	* 1.6544	* 1.4944	* 1.4896	* 1.5073	* 1.4586	* 1.3484	* 1.3055	* 2.5060
10	* 1.4851	* 1.5995	* 1.4843	* 1.5469	* 1.7362	* 1.7136	* 1.8360	* 0.8100
	* 1.6051	* 1.4927	* 1.6080	* 1.5524	* 1.3909	* 1.4017	* 1.3058	* 2.6596
11	* 1.4253	* 1.5839	* 1.5457	* 1.7077	* 1.6831	* 1.8281	* 1.1956	* 0.5740
	* 1.6672	* 1.5084	* 1.5535	* 1.4161	* 1.4384	* 1.3266	* 1.8652	* 3.7733
12	* 1.5867	* 1.6409	* 1.7358	* 1.6817	* 1.7788	* 1.8124	* 0.9177	*
	* 1.5023	* 1.4588	* 1.3912	* 1.4392	* 1.3552	* 1.3350	* 2.3779	*
13	* 1.7478	* 1.7756	* 1.7154	* 1.8278	* 1.8124	* 1.8400	* 0.7869	*
	* 1.3675	* 1.3479	* 1.4003	* 1.3268	* 1.3350	* 1.2996	* 2.7371	*
14	* 1.8243	* 1.8316	* 1.8365	* 1.1956	* 0.9164	* 0.7866	*	*
	* 1.3093	* 1.3053	* 1.3054	* 1.8654	* 2.3795	* 2.7379	*	*
15	* 0.8494	* 0.8667	* 0.8098	* 0.5610	* F-SUB-Q			
	* 2.5468	* 2.5048	* 2.6604	* 3.7985	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4851	* 1.4186	* 1.4533	* 1.3995	* 1.5617	* 1.7296	* 1.8030	* 0.8481
	* 1.5744	* 1.6419	* 1.5967	* 1.6529	* 1.4866	* 1.3458	* 1.2901	* 2.4851
9	* 1.4186	* 1.5656	* 1.5739	* 1.5566	* 1.6200	* 1.7577	* 1.8102	* 0.8622
	* 1.6419	* 1.4845	* 1.4770	* 1.4946	* 1.4390	* 1.3262	* 1.2862	* 2.4520
10	* 1.4533	* 1.5705	* 1.4584	* 1.5270	* 1.7121	* 1.6957	* 1.8159	* 0.8108
	* 1.5967	* 1.4802	* 1.5932	* 1.5331	* 1.3751	* 1.3802	* 1.2874	* 2.5923
11	* 1.3995	* 1.5554	* 1.5260	* 1.6832	* 1.6727	* 1.8063	* 1.1988	* 0.5736
	* 1.6529	* 1.4957	* 1.5342	* 1.4010	* 1.4081	* 1.3096	* 1.8126	* 3.7002
12	* 1.5617	* 1.6198	* 1.7117	* 1.6717	* 1.7650	* 1.7917	* 0.9189	*
	* 1.4866	* 1.4392	* 1.3754	* 1.4089	* 1.3597	* 1.3293	* 2.3334	*
13	* 1.7296	* 1.7584	* 1.6976	* 1.8059	* 1.7917	* 1.8232	* 0.7901	*
	* 1.3458	* 1.3257	* 1.3787	* 1.3098	* 1.3293	* 1.3138	* 2.7188	*
14	* 1.8030	* 1.8106	* 1.8164	* 1.1987	* 0.9175	* 0.7898	*	*
	* 1.2901	* 1.2859	* 1.2870	* 1.8130	* 2.3352	* 2.7197	*	*
15	* 0.8481	* 0.8629	* 0.8105	* 0.5618	* F-SUB-Q			
	* 2.4851	* 2.4508	* 2.5932	* 3.7165	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4816	* 1.4131	* 1.4573	* 1.3952	* 1.5745	* 1.7430	* 1.8258	* 0.8347
	* 1.5384	* 1.6042	* 1.5487	* 1.6130	* 1.4392	* 1.3056	* 1.2453	* 2.4581
9	* 1.4131	* 1.5713	* 1.5720	* 1.5669	* 1.6216	* 1.7721	* 1.8328	* 0.8520
	* 1.6042	* 1.4408	* 1.4407	* 1.4477	* 1.4033	* 1.2860	* 1.2417	* 2.4156
10	* 1.4573	* 1.5684	* 1.4549	* 1.5254	* 1.7292	* 1.7074	* 1.8379	* 0.7977
	* 1.5487	* 1.4439	* 1.5551	* 1.4961	* 1.3288	* 1.3391	* 1.2425	* 2.5645
11	* 1.3952	* 1.5656	* 1.5242	* 1.6940	* 1.6704	* 1.8253	* 1.1838	* 0.5630
	* 1.6130	* 1.4489	* 1.4973	* 1.3589	* 1.3799	* 1.2640	* 1.7904	* 3.6614
12	* 1.5745	* 1.6214	* 1.7288	* 1.6688	* 1.7833	* 1.8116	* 0.9034	*
	* 1.4392	* 1.4035	* 1.3291	* 1.3812	* 1.3120	* 1.2813	* 2.3116	*
13	* 1.7430	* 1.7729	* 1.7093	* 1.8249	* 1.8116	* 1.8511	* 0.7766	*
	* 1.3056	* 1.2854	* 1.3376	* 1.2642	* 1.2814	* 1.2611	* 2.6920	*
14	* 1.8258	* 1.8332	* 1.8385	* 1.1837	* 0.9020	* 0.7764	*	*
	* 1.2453	* 1.2414	* 1.2422	* 1.7908	* 2.3134	* 2.6929	*	*
15	* 0.8347	* 0.8527	* 0.7974	* 0.5488	* F-SUB-Q			
	* 2.4581	* 2.4144	* 2.5655	* 3.6954	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4651	* 1.3961	* 1.4435	* 1.3793	* 1.5675	* 1.7388	* 1.8257	* 0.8245 *
	* 1.4909	* 1.5560	* 1.4984	* 1.5640	* 1.3872	* 1.2569	* 1.1959	* 2.3867 *
9	* 1.3960	* 1.5581	* 1.5555	* 1.5574	* 1.6100	* 1.7689	* 1.8327	* 0.8425 *
	* 1.5560	* 1.3921	* 1.3951	* 1.3962	* 1.3558	* 1.2374	* 1.1923	* 2.3427 *
10	* 1.4435	* 1.5518	* 1.4392	* 1.5131	* 1.7250	* 1.7023	* 1.8379	* 0.7884 *
	* 1.4984	* 1.3984	* 1.5064	* 1.4456	* 1.2790	* 1.2899	* 1.1930	* 2.4872 *
11	* 1.3793	* 1.5561	* 1.5118	* 1.6857	* 1.6622	* 1.8227	* 1.1731	* 0.5551 *
	* 1.5640	* 1.3974	* 1.4467	* 1.3103	* 1.3322	* 1.2166	* 1.7314	* 3.5574 *
12	* 1.5675	* 1.6098	* 1.7246	* 1.6606	* 1.7835	* 1.8100	* 0.8931	*
	* 1.3872	* 1.3560	* 1.2793	* 1.3334	* 1.2667	* 1.2343	* 2.2383	*
13	* 1.7388	* 1.7696	* 1.7043	* 1.8223	* 1.8099	* 1.8562	* 0.7684	*
	* 1.2569	* 1.2369	* 1.2883	* 1.2169	* 1.2343	* 1.2116	* 2.6034	*
14	* 1.8257	* 1.8332	* 1.8384	* 1.1730	* 0.8916	* 0.7682	*	
	* 1.1959	* 1.1921	* 1.1927	* 1.7319	* 2.2402	* 2.6043	*	
15	* 0.8245	* 0.8432	* 0.7881	* 0.5404	* F-SUB-Q			
	* 2.3866	* 2.3415	* 2.4883	* 3.5952	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4424	* 1.3732	* 1.4212	* 1.3575	* 1.5501	* 1.7237	* 1.8118	* 0.8160 *
	* 1.4563	* 1.5214	* 1.4642	* 1.5292	* 1.3498	* 1.2195	* 1.1590	* 2.3212 *
9	* 1.3732	* 1.5356	* 1.5321	* 1.5375	* 1.5908	* 1.7546	* 1.8188	* 0.8334 *
	* 1.5214	* 1.3585	* 1.3624	* 1.3602	* 1.3194	* 1.1997	* 1.1554	* 2.2793 *
10	* 1.4212	* 1.5281	* 1.4172	* 1.4938	* 1.7082	* 1.6870	* 1.8244	* 0.7813 *
	* 1.4642	* 1.3657	* 1.4715	* 1.4072	* 1.2403	* 1.2510	* 1.1549	* 2.4147 *
11	* 1.3575	* 1.5361	* 1.4925	* 1.6676	* 1.6451	* 1.8073	* 1.1650	* 0.5494 *
	* 1.5292	* 1.3614	* 1.4084	* 1.2721	* 1.2919	* 1.1775	* 1.6751	* 3.4569 *
12	* 1.5501	* 1.5906	* 1.7078	* 1.6435	* 1.7719	* 1.7954	* 0.8846	*
	* 1.3498	* 1.3196	* 1.2406	* 1.2930	* 1.2225	* 1.1936	* 2.1693	*
13	* 1.7237	* 1.7554	* 1.6892	* 1.8069	* 1.7953	* 1.8457	* 0.7621	*
	* 1.2195	* 1.1991	* 1.2494	* 1.1778	* 1.1937	* 1.1674	* 2.5174	*
14	* 1.8118	* 1.8193	* 1.8249	* 1.1649	* 0.8831	* 0.7618	*	
	* 1.1590	* 1.1551	* 1.1546	* 1.6755	* 2.1713	* 2.5183	*	
15	* 0.8160	* 0.8341	* 0.7809	* 0.5345	* F-SUB-Q			
	* 2.3212	* 2.2781	* 2.4159	* 3.4961	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4112	* 1.3430	* 1.3867	* 1.3282	* 1.5181	* 1.6955	* 1.7801	* 0.8102
	* 1.5499	* 1.6203	* 1.5640	* 1.6301	* 1.4372	* 1.2921	* 1.2294	* 2.4386
9	* 1.3430	* 1.5002	* 1.4997	* 1.5034	* 1.5621	* 1.7269	* 1.7873	* 0.8249
	* 1.6203	* 1.4492	* 1.4508	* 1.4498	* 1.4001	* 1.2700	* 1.2251	* 2.4016
10	* 1.3867	* 1.4950	* 1.3869	* 1.4670	* 1.6753	* 1.6592	* 1.7936	* 0.7771
	* 1.5640	* 1.4550	* 1.5672	* 1.4928	* 1.3157	* 1.3245	* 1.2231	* 2.5314
11	* 1.3282	* 1.5020	* 1.4659	* 1.6350	* 1.6236	* 1.7755	* 1.1602	* 0.5456
	* 1.6301	* 1.4511	* 1.4941	* 1.3494	* 1.3574	* 1.2459	* 1.7509	* 3.6279
12	* 1.5181	* 1.5619	* 1.6749	* 1.6225	* 1.7462	* 1.7640	* 0.8803	*
	* 1.4372	* 1.4003	* 1.3160	* 1.3583	* 1.2868	* 1.2616	* 2.2667	*
13	* 1.6955	* 1.7277	* 1.6613	* 1.7751	* 1.7639	* 1.8169	* 0.7601	*
	* 1.2921	* 1.2695	* 1.3229	* 1.2462	* 1.2617	* 1.2296	* 2.6215	*
14	* 1.7801	* 1.7878	* 1.7941	* 1.1600	* 0.8788	* 0.7598	*	*
	* 1.2294	* 1.2248	* 1.2228	* 1.7514	* 2.2689	* 2.6225	*	*
15	* 0.8102	* 0.8256	* 0.7767	* 0.5324	* F-SUB-Q			
	* 2.4386	* 2.4004	* 2.5327	* 3.6580	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4048	* 1.3353	* 1.3889	* 1.3205	* 1.5242	* 1.6988	* 1.7928	* 0.7912
	* 1.4952	* 1.5682	* 1.5049	* 1.5826	* 1.3833	* 1.2465	* 1.1798	* 2.4190
9	* 1.3353	* 1.5033	* 1.4945	* 1.5082	* 1.5558	* 1.7310	* 1.7997	* 0.8092
	* 1.5682	* 1.3938	* 1.4040	* 1.3940	* 1.3569	* 1.2244	* 1.1757	* 2.3711
10	* 1.3889	* 1.4896	* 1.3798	* 1.4587	* 1.6836	* 1.6602	* 1.8049	* 0.7581
	* 1.5049	* 1.4078	* 1.5192	* 1.4459	* 1.2603	* 1.2776	* 1.1731	* 2.5114
11	* 1.3205	* 1.5067	* 1.4573	* 1.6383	* 1.6140	* 1.7840	* 1.1361	* 0.5312
	* 1.5826	* 1.3953	* 1.4472	* 1.2952	* 1.3173	* 1.1922	* 1.7238	* 3.6073
12	* 1.5242	* 1.5556	* 1.6832	* 1.6123	* 1.7522	* 1.7727	* 0.8584	*
	* 1.3833	* 1.3571	* 1.2606	* 1.3186	* 1.2272	* 1.2045	* 2.2378	*
13	* 1.6988	* 1.7318	* 1.6625	* 1.7836	* 1.7726	* 1.8318	* 0.7400	*
	* 1.2465	* 1.2238	* 1.2759	* 1.1925	* 1.2046	* 1.1687	* 2.5886	*
14	* 1.7929	* 1.8002	* 1.8054	* 1.1359	* 0.8569	* 0.7397	*	*
	* 1.1798	* 1.1754	* 1.1727	* 1.7243	* 2.2400	* 2.5896	*	*
15	* 0.7912	* 0.8099	* 0.7577	* 0.5157	* F-SUB-Q			
	* 2.4190	* 2.3699	* 2.5128	* 3.6556	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3843	* 1.3151	* 1.3690	* 1.2999	* 1.5042	* 1.6788	* 1.7723	* 0.7770
	* 1.4536	* 1.5281	* 1.4667	* 1.5455	* 1.3474	* 1.2120	* 1.1466	* 2.3700
9	* 1.3151	* 1.4832	* 1.4737	* 1.4869	* 1.5332	* 1.7110	* 1.7790	* 0.7949
	* 1.5281	* 1.3567	* 1.3679	* 1.3584	* 1.3226	* 1.1898	* 1.1425	* 2.3220
10	* 1.3690	* 1.4688	* 1.3595	* 1.4362	* 1.6616	* 1.6393	* 1.7834	* 0.7446
	* 1.4667	* 1.3715	* 1.4815	* 1.4096	* 1.2245	* 1.2422	* 1.1396	* 2.4592
11	* 1.2999	* 1.4854	* 1.4349	* 1.6162	* 1.5914	* 1.7610	* 1.1191	* 0.5213
	* 1.5455	* 1.3597	* 1.4109	* 1.2593	* 1.2804	* 1.1570	* 1.6799	* 3.5354
12	* 1.5042	* 1.5330	* 1.6612	* 1.5897	* 1.7320	* 1.7497	* 0.8432	*
	* 1.3474	* 1.3228	* 1.2248	* 1.2817	* 1.1845	* 1.1673	* 2.1850	*
13	* 1.6788	* 1.7119	* 1.6417	* 1.7606	* 1.7496	* 1.8099	* 0.7265	*
	* 1.2120	* 1.1893	* 1.2405	* 1.1573	* 1.1674	* 1.1301	* 2.5262	*
14	* 1.7723	* 1.7795	* 1.7839	* 1.1189	* 0.8417	* 0.7262	*	
	* 1.1466	* 1.1422	* 1.1393	* 1.6804	* 2.1872	* 2.5271	*	
15	* 0.7770	* 0.7956	* 0.7442	* 0.5058	F-SUB-Q			
	* 2.3700	* 2.3208	* 2.4606	* 3.5850	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3475	* 1.2801	* 1.3229	* 1.2655	* 1.4523	* 1.6300	* 1.7100	* 0.7673
	* 1.4418	* 1.5163	* 1.4669	* 1.5350	* 1.3491	* 1.2060	* 1.1481	* 2.3224
9	* 1.2801	* 1.4353	* 1.4351	* 1.4340	* 1.4912	* 1.6612	* 1.7166	* 0.7814
	* 1.5163	* 1.3547	* 1.3574	* 1.3611	* 1.3138	* 1.1838	* 1.1438	* 2.2859
10	* 1.3229	* 1.4303	* 1.3241	* 1.3961	* 1.6017	* 1.5915	* 1.7199	* 0.7358
	* 1.4669	* 1.3610	* 1.4701	* 1.4003	* 1.2255	* 1.2355	* 1.1409	* 2.4078
11	* 1.2655	* 1.4325	* 1.3949	* 1.5586	* 1.5513	* 1.6984	* 1.1076	* 0.5155
	* 1.5350	* 1.3624	* 1.4016	* 1.2579	* 1.2649	* 1.1566	* 1.6392	* 3.4593
12	* 1.4523	* 1.4910	* 1.6013	* 1.5502	* 1.6793	* 1.6869	* 0.8342	
	* 1.3491	* 1.3140	* 1.2259	* 1.2657	* 1.1755	* 1.1664	* 2.1318	
13	* 1.6300	* 1.6621	* 1.5936	* 1.6979	* 1.6867	* 1.7407	* 0.7187	
	* 1.2060	* 1.1832	* 1.2339	* 1.1569	* 1.1665	* 1.1304	* 2.4628	
14	* 1.7100	* 1.7171	* 1.7204	* 1.1074	* 0.8328	* 0.7184	*	
	* 1.1481	* 1.1435	* 1.1405	* 1.6397	* 2.1338	* 2.4638	*	
15	* 0.7673	* 0.7821	* 0.7353	* 0.5024	* F-SUB-Q			
	* 2.3224	* 2.2846	* 2.4093	* 3.4920	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3325	* 1.2660	* 1.3109	* 1.2575	* 1.4315	* 1.6049	* 1.6789	* 0.7416 *
	* 1.4175	* 1.4908	* 1.4398	* 1.5026	* 1.3310	* 1.1904	* 1.1365	* 2.3398 *
9	* 1.2660	* 1.4205	* 1.4230	* 1.4153	* 1.4677	* 1.6342	* 1.6845	* 0.7579 *
	* 1.4908	* 1.3308	* 1.3304	* 1.3408	* 1.2975	* 1.1693	* 1.1327	* 2.2944 *
10	* 1.3109	* 1.4188	* 1.3104	* 1.3733	* 1.5732	* 1.5631	* 1.6820	* 0.7080 *
	* 1.4398	* 1.3340	* 1.4447	* 1.3835	* 1.2117	* 1.2221	* 1.1334	* 2.4360 *
11	* 1.2575	* 1.4139	* 1.3720	* 1.5337	* 1.5187	* 1.6635	* 1.0691	* 0.4955 *
	* 1.5026	* 1.3421	* 1.3848	* 1.2440	* 1.2565	* 1.1461	* 1.6508	* 3.5044 *
12	* 1.4315	* 1.4675	* 1.5727	* 1.5170	* 1.6497	* 1.6522	* 0.8028 *	
	* 1.3310	* 1.2977	* 1.2121	* 1.2578	* 1.1600	* 1.1554	* 2.1532 *	
13	* 1.6049	* 1.6350	* 1.5652	* 1.6631	* 1.6521	* 1.6980	* 0.6870 *	
	* 1.1904	* 1.1688	* 1.2205	* 1.1464	* 1.1555	* 1.1232	* 2.5028 *	
14	* 1.6789	* 1.6849	* 1.6824	* 1.0689	* 0.8013	* 0.6868 *		
	* 1.1365	* 1.1325	* 1.1331	* 1.6513	* 2.1554	* 2.5038 *		
15	* 0.7416	* 0.7586	* 0.7075	* 0.4809	* F-SUB-Q			
	* 2.3398	* 2.2930	* 2.4376	* 3.5528	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2645	* 1.2154	* 1.2673	* 1.2330	* 1.3552	* 1.5161	* 1.5779	* 0.7170 *
	* 1.4618	* 1.5182	* 1.3720	* 1.4995	* 1.3320	* 1.2320	* 1.1822	* 2.3698 *
9	* 1.2154	* 1.3512	* 1.3647	* 1.3507	* 1.3978	* 1.5408	* 1.5810	* 0.7302 *
	* 1.5182	* 1.3652	* 1.3578	* 1.3392	* 1.3323	* 1.2124	* 1.1799	* 2.3326 *
10	* 1.2673	* 1.3595	* 1.2480	* 1.3176	* 1.4826	* 1.4677	* 1.5653	* 0.6753 *
	* 1.3720	* 1.3623	* 1.4844	* 1.4100	* 1.2565	* 1.2725	* 1.1907	* 2.5020 *
11	* 1.2330	* 1.3494	* 1.3164	* 1.4547	* 1.4439	* 1.5623	* 1.0154	* 0.4681 *
	* 1.4995	* 1.3405	* 1.4113	* 1.2707	* 1.2916	* 1.1923	* 1.7007	* 3.6370 *
12	* 1.3552	* 1.3976	* 1.4822	* 1.4424	* 1.5623	* 1.5559	* 0.7704 *	
	* 1.3320	* 1.3325	* 1.2569	* 1.2930	* 1.1959	* 1.1985	* 2.1954 *	
13	* 1.5161	* 1.5415	* 1.4696	* 1.5619	* 1.5558	* 1.5719	* 0.6484 *	
	* 1.2320	* 1.2119	* 1.2710	* 1.1927	* 1.1986	* 1.1848	* 2.5952 *	
14	* 1.5779	* 1.5814	* 1.5656	* 1.0152	* 0.7690	* 0.6482 *		
	* 1.1822	* 1.1796	* 1.1904	* 1.7013	* 2.1975	* 2.5962 *		
15	* 0.7170	* 0.7309	* 0.6748	* 0.4539	* F-SUB-Q			
	* 2.3698	* 2.3314	* 2.5037	* 3.6901	* M-SUB-Q			



# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0547	* 1.0769	* 1.3234	* 1.0975	* 1.3724	* 1.2640	* 1.4517	* 0.6350
	* 1.7253	* 1.6863	* 1.3720	* 1.6579	* 1.3320	* 1.4529	* 1.2624	* 2.6377
9	* 1.0769	* 1.3297	* 1.1767	* 1.3608	* 1.1745	* 1.2831	* 1.4413	* 0.6429
	* 1.6863	* 1.3652	* 1.5453	* 1.3392	* 1.5564	* 1.4309	* 1.2716	* 2.6115
10	* 1.3234	* 1.1753	* 1.0421	* 1.1496	* 1.4327	* 1.2396	* 1.3501	* 0.5826
	* 1.3720	* 1.5472	* 1.7494	* 1.5903	* 1.2769	* 1.4782	* 1.3577	* 2.8587
11	* 1.0975	* 1.3594	* 1.1488	* 1.4400	* 1.2233	* 1.4145	* 0.8733	* 0.3954
	* 1.6579	* 1.3405	* 1.5915	* 1.2707	* 1.4976	* 1.2947	* 1.9469	* 4.2488
12	* 1.3724	* 1.1736	* 1.4323	* 1.2225	* 1.3217	* 1.4404	* 0.6874	*
	* 1.3320	* 1.5576	* 1.2772	* 1.4987	* 1.3887	* 1.2725	* 2.4235	*
13	* 1.2640	* 1.2837	* 1.2411	* 1.4142	* 1.4401	* 1.2911	* 0.5456	*
	* 1.4529	* 1.4303	* 1.4764	* 1.2950	* 1.2728	* 1.4196	* 3.0398	*
14	* 1.4517	* 1.4417	* 1.3501	* 0.8730	* 0.6863	* 0.5454	*	*
	* 1.2624	* 1.2713	* 1.3577	* 1.9477	* 2.4256	* 3.0411	*	*
15	* 0.6350	* 0.6434	* 0.5822	* 0.3837	* F-SUB-Q			
	* 2.6377	* 2.6103	* 2.8608	* 4.3084	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4291	* 0.4641	* 0.5567	* 0.4811	* 0.5696	* 0.4971	* 0.5315	* 0.2708
	* 4.1956	* 3.8743	* 3.2297	* 3.7477	* 3.1736	* 3.6527	* 3.4146	* 6.1352
9	* 0.4641	* 0.5463	* 0.4859	* 0.5636	* 0.4867	* 0.5009	* 0.5262	* 0.2700
	* 3.8743	* 3.2909	* 3.7075	* 3.1987	* 3.7168	* 3.6255	* 3.4490	* 6.1666
10	* 0.5567	* 0.4850	* 0.4467	* 0.4910	* 0.5824	* 0.4929	* 0.4856	* 0.2464
	* 3.2297	* 3.7144	* 4.0422	* 3.6845	* 3.1067	* 3.6804	* 3.7388	* 6.7048
11	* 0.4811	* 0.5630	* 0.4907	* 0.5772	* 0.5037	* 0.5497	* 0.3662	* 0.1676
	* 3.7477	* 3.2020	* 3.6869	* 3.1342	* 3.5996	* 3.2996	* 4.5975	* 9.9496
12	* 0.5696	* 0.4864	* 0.5822	* 0.5033	* 0.5094	* 0.5293	* 0.2925	*
	* 3.1736	* 3.7194	* 3.1079	* 3.6025	* 3.5650	* 3.4289	* 5.6474	*
13	* 0.4971	* 0.5011	* 0.4932	* 0.5496	* 0.5292	* 0.4639	* 0.2279	*
	* 3.6527	* 3.6245	* 3.6778	* 3.3004	* 3.4296	* 3.9135	* 7.2175	*
14	* 0.5315	* 0.5263	* 0.4856	* 0.3661	* 0.2921	* 0.2278	*	*
	* 3.4146	* 3.4484	* 3.7391	* 4.5998	* 5.6500	* 7.2208	*	*
15	* 0.2708	* 0.2703	* 0.2462	* 0.1641	* F-SUB-Q			
	* 6.1352	* 6.1637	* 6.7097	* 9.9946	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4313	* 0.4888	* 0.5749	* 0.5002	* 0.5573	* 0.4722	* 0.4736	* 0.2652
	* 4.0625	* 4.0274	* 3.3439	* 3.7826	* 3.3355	* 3.9098	* 3.8636	* 6.2042
9	* 0.4888	* 0.5602	* 0.5133	* 0.5655	* 0.4864	* 0.4638	* 0.4688	* 0.2618
	* 4.0274	* 3.5256	* 3.7340	* 3.3448	* 3.8507	* 3.9961	* 3.9247	* 6.3226
10	* 0.5749	* 0.5129	* 0.4695	* 0.4805	* 0.5452	* 0.4614	* 0.4359	* 0.2369
	* 3.3439	* 3.7361	* 4.1000	* 3.9864	* 3.5357	* 4.1678	* 4.3290	* 7.0387
11	* 0.5002	* 0.5653	* 0.4803	* 0.5386	* 0.4761	* 0.4880	* 0.3356	* 0.1672
	* 3.7826	* 3.3461	* 3.9883	* 3.5820	* 4.0318	* 3.8964	* 5.3235	* 10.3852
12	* 0.5573	* 0.4863	* 0.5451	* 0.4759	* 0.4285	* 0.4355	* 0.2752	*
	* 3.3355	* 3.8514	* 3.5364	* 4.0332	* 4.0734	* 4.0531	* 6.1270	*
13	* 0.4722	* 0.4638	* 0.4615	* 0.4880	* 0.4355	* 0.3846	* 0.2103	*
	* 3.9098	* 3.9960	* 4.1666	* 3.8964	* 4.0525	* 4.5280	* 7.7861	*
14	* 0.4736	* 0.4688	* 0.4360	* 0.3357	* 0.2751	* 0.2103	*	*
	* 3.8636	* 3.9241	* 4.3283	* 5.3230	* 6.1235	* 7.7868	*	*
15	* 0.2652	* 0.2620	* 0.2369	* 0.1649	F-SUB-Q			
	* 6.2042	* 6.3173	* 7.0384	* 10.3743	M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0330	* 1.0702	* 1.2660	* 1.0860	* 1.2358	* 1.0962	* 1.1804	* 0.6136
	* 1.8567	* 1.8787	* 1.5449	* 1.7782	* 1.5400	* 1.7232	* 1.5863	* 2.7466
9	* 1.0703	* 1.2539	* 1.1615	* 1.2566	* 1.0979	* 1.0819	* 1.1708	* 0.6098
	* 1.8787	* 1.6018	* 1.6767	* 1.5387	* 1.7444	* 1.7505	* 1.6066	* 2.7836
10	* 1.2660	* 1.1607	* 1.0315	* 1.0505	* 1.2264	* 1.0794	* 1.1019	* 0.5511
	* 1.5449	* 1.6778	* 1.9069	* 1.8599	* 1.6011	* 1.8225	* 1.7489	* 3.0944
11	* 1.0860	* 1.2561	* 1.0500	* 1.2348	* 1.0810	* 1.1568	* 0.7730	* 0.3917
	* 1.7782	* 1.5393	* 1.8605	* 1.5890	* 1.8112	* 1.6766	* 2.3466	* 4.5278
12	* 1.2358	* 1.0978	* 1.2262	* 1.0804	* 1.0385	* 1.1283	* 0.6372	*
	* 1.5400	* 1.7447	* 1.6014	* 1.8121	* 1.7633	* 1.6447	* 2.7035	*
13	* 1.0962	* 1.0819	* 1.0800	* 1.1568	* 1.1283	* 0.9983	* 0.5015	*
	* 1.7232	* 1.7502	* 1.8218	* 1.6766	* 1.6446	* 1.8345	* 3.3425	*
14	* 1.1804	* 1.1710	* 1.1021	* 0.7732	* 0.6369	* 0.5014	*	*
	* 1.5863	* 1.6063	* 1.7486	* 2.3462	* 2.7027	* 3.3429	*	*
15	* 0.6136	* 0.6102	* 0.5512	* 0.3866	F-SUB-Q			
	* 2.7466	* 2.7830	* 3.0940	* 4.5179	M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2798	* 1.2694	* 1.3184	* 1.2750	* 1.2880	* 1.3281	* 1.3356	* 0.7217 *
	* 1.5754	* 1.6079	* 1.5159	* 1.5398	* 1.4936	* 1.4443	* 1.4252	* 2.3748 *
9	* 1.2694	* 1.3685	* 1.3672	* 1.3448	* 1.3185	* 1.3200	* 1.3299	* 0.7248 *
	* 1.6079	* 1.4955	* 1.4641	* 1.4608	* 1.4904	* 1.4542	* 1.4377	* 2.3784 *
10	* 1.3184	* 1.3657	* 1.2531	* 1.2597	* 1.3412	* 1.3110	* 1.3145	* 0.6694 *
	* 1.5159	* 1.4658	* 1.5963	* 1.5855	* 1.4917	* 1.5190	* 1.4859	* 2.5872 *
11	* 1.2750	* 1.3441	* 1.2592	* 1.3506	* 1.3026	* 1.3416	* 0.9426	* 0.4810 *
	* 1.5398	* 1.4615	* 1.5860	* 1.4718	* 1.5288	* 1.4680	* 1.9535	* 3.7434 *
12	* 1.2880	* 1.3182	* 1.3409	* 1.3019	* 1.3029	* 1.3141	* 0.7598 *	
	* 1.4936	* 1.4907	* 1.4921	* 1.5295	* 1.4815	* 1.4701	* 2.3139 *	
13	* 1.3281	* 1.3200	* 1.3118	* 1.3416	* 1.3143	* 1.2545	* 0.6272 *	
	* 1.4443	* 1.4540	* 1.5182	* 1.4680	* 1.4699	* 1.5096	* 2.7312 *	
14	* 1.3356	* 1.3302	* 1.3148	* 0.9430	* 0.7593	* 0.6272 *		
	* 1.4252	* 1.4375	* 1.4855	* 1.9531	* 2.3136	* 2.7315 *		
15	* 0.7217	* 0.7253	* 0.6695	* 0.4768	* F-SUB-Q			
	* 2.3749	* 2.3778	* 2.5867	* 3.7191	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4170	* 1.3908	* 1.4615	* 1.3902	* 1.4409	* 1.4809	* 1.5202	* 0.7745 *
	* 1.4556	* 1.4961	* 1.3939	* 1.4361	* 1.3553	* 1.3146	* 1.2707	* 2.2457 *
9	* 1.3908	* 1.5368	* 1.5080	* 1.4988	* 1.4557	* 1.4814	* 1.5141	* 0.7833 *
	* 1.4961	* 1.3554	* 1.3500	* 1.3322	* 1.3755	* 1.3140	* 1.2817	* 2.2352 *
10	* 1.4615	* 1.5061	* 1.3816	* 1.3927	* 1.5190	* 1.4636	* 1.5049	* 0.7226 *
	* 1.3939	* 1.3526	* 1.4720	* 1.4632	* 1.3394	* 1.3810	* 1.3163	* 2.4333 *
11	* 1.3902	* 1.4980	* 1.3921	* 1.5281	* 1.4506	* 1.5353	* 1.0281	* 0.5188 *
	* 1.4361	* 1.3326	* 1.4639	* 1.3234	* 1.3945	* 1.3082	* 1.8230	* 3.5199 *
12	* 1.4409	* 1.4552	* 1.5186	* 1.4498	* 1.4630	* 1.5033	* 0.8230 *	
	* 1.3553	* 1.3759	* 1.3393	* 1.3952	* 1.3448	* 1.3148	* 2.1818 *	
13	* 1.4809	* 1.4816	* 1.4645	* 1.5352	* 1.5036	* 1.4541	* 0.6856 *	
	* 1.3146	* 1.3138	* 1.3801	* 1.3082	* 1.3146	* 1.3327	* 2.5549 *	
14	* 1.5202	* 1.5144	* 1.5054	* 1.0285	* 0.8223	* 0.6856 *		
	* 1.2707	* 1.2815	* 1.3159	* 1.8225	* 2.1818	* 2.5552 *		
15	* 0.7745	* 0.7838	* 0.7227	* 0.5131	* F-SUB-Q			
	* 2.2457	* 2.2345	* 2.4327	* 3.5051	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4783	* 1.4518	* 1.5440	* 1.4516	* 1.5309	* 1.5589	* 1.6246	* 0.8127 *
	* 1.4261	* 1.4618	* 1.3446	* 1.4015	* 1.2991	* 1.2641	* 1.2096	* 2.1815 *
9	* 1.4518	* 1.6258	* 1.5748	* 1.5898	* 1.5299	* 1.5678	* 1.6180	* 0.8222 *
	* 1.4618	* 1.3041	* 1.3149	* 1.2804	* 1.3324	* 1.2629	* 1.2201	* 2.1676 *
10	* 1.5440	* 1.5726	* 1.4404	* 1.4662	* 1.6231	* 1.5450	* 1.6110	* 0.7602 *
	* 1.3446	* 1.3178	* 1.4381	* 1.4180	* 1.2760	* 1.3317	* 1.2494	* 2.3529 *
11	* 1.4516	* 1.5890	* 1.4656	* 1.6317	* 1.5332	* 1.6454	* 1.0859	* 0.5427 *
	* 1.4015	* 1.2810	* 1.4188	* 1.2653	* 1.3472	* 1.2465	* 1.7592	* 3.4172 *
12	* 1.5309	* 1.5294	* 1.6230	* 1.5322	* 1.5534	* 1.6130	* 0.8679 *	
	* 1.2991	* 1.3328	* 1.2759	* 1.3481	* 1.2895	* 1.2532	* 2.1160 *	
13	* 1.5589	* 1.5683	* 1.5462	* 1.6454	* 1.6132	* 1.5693	* 0.7259 *	
	* 1.2641	* 1.2625	* 1.3307	* 1.2465	* 1.2530	* 1.2636	* 2.4717 *	
14	* 1.6246	* 1.6184	* 1.6116	* 1.0863	* 0.8672	* 0.7258 *		
	* 1.2096	* 1.2199	* 1.2489	* 1.7588	* 2.1162	* 2.4720 *		
15	* 0.8127	* 0.8228	* 0.7603	* 0.5359	* F-SUB-Q			
	* 2.1815	* 2.1668	* 2.3524	* 3.4089	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5115	* 1.4868	* 1.5903	* 1.4888	* 1.5837	* 1.6116	* 1.6882	* 0.8409 *
	* 1.4185	* 1.4520	* 1.3313	* 1.3954	* 1.2822	* 1.2473	* 1.1874	* 2.1523 *
9	* 1.4868	* 1.6742	* 1.6119	* 1.6436	* 1.5753	* 1.6224	* 1.6814	* 0.8494 *
	* 1.4520	* 1.2831	* 1.3089	* 1.2641	* 1.3196	* 1.2444	* 1.1973	* 2.1410 *
10	* 1.5903	* 1.6096	* 1.4733	* 1.5116	* 1.6867	* 1.5963	* 1.6753	* 0.7880 *
	* 1.3313	* 1.3119	* 1.4341	* 1.4037	* 1.2522	* 1.3146	* 1.2228	* 2.3137 *
11	* 1.4888	* 1.6426	* 1.5109	* 1.6941	* 1.5843	* 1.7128	* 1.1281	* 0.5601 *
	* 1.3954	* 1.2649	* 1.4046	* 1.2423	* 1.3281	* 1.2206	* 1.7193	* 3.3659 *
12	* 1.5837	* 1.5747	* 1.6867	* 1.5832	* 1.6120	* 1.6809	* 0.9013 *	
	* 1.2822	* 1.3201	* 1.2522	* 1.3290	* 1.2688	* 1.2298	* 2.0824 *	
13	* 1.6116	* 1.6229	* 1.5977	* 1.7127	* 1.6811	* 1.6418	* 0.7559 *	
	* 1.2473	* 1.2441	* 1.3136	* 1.2207	* 1.2296	* 1.2394	* 2.4356 *	
14	* 1.6882	* 1.6819	* 1.6759	* 1.1284	* 0.9004	* 0.7558 *		
	* 1.1874	* 1.1971	* 1.2224	* 1.7190	* 2.0827	* 2.4360 *		
15	* 0.8409	* 0.8500	* 0.7881	* 0.5530	* F-SUB-Q			
	* 2.1523	* 2.1402	* 2.3133	* 3.3581	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5438	* 1.5182	* 1.6357	* 1.5240	* 1.6354	* 1.6633	* 1.7524	* 0.8560
	* 1.4090	* 1.4383	* 1.3220	* 1.3951	* 1.2717	* 1.2370	* 1.1707	* 2.1646
9	* 1.5182	* 1.7224	* 1.6484	* 1.6962	* 1.6168	* 1.6755	* 1.7452	* 0.8663
	* 1.4383	* 1.2656	* 1.3064	* 1.2526	* 1.3138	* 1.2325	* 1.1801	* 2.1483
10	* 1.6357	* 1.6459	* 1.5052	* 1.5525	* 1.7486	* 1.6443	* 1.7389	* 0.8020
	* 1.3220	* 1.3096	* 1.4338	* 1.3888	* 1.2248	* 1.2994	* 1.2016	* 2.3225
11	* 1.5240	* 1.6950	* 1.5517	* 1.7545	* 1.6320	* 1.7786	* 1.1514	* 0.5679
	* 1.3951	* 1.2534	* 1.3896	* 1.2204	* 1.3096	* 1.1958	* 1.7055	* 3.3737
12	* 1.6354	* 1.6161	* 1.7485	* 1.6308	* 1.6724	* 1.7464	* 0.9183	*
	* 1.2717	* 1.3142	* 1.2249	* 1.3105	* 1.2502	* 1.2102	* 2.0865	*
13	* 1.6633	* 1.6760	* 1.6457	* 1.7784	* 1.7465	* 1.7120	* 0.7706	*
	* 1.2370	* 1.2322	* 1.2983	* 1.1959	* 1.2101	* 1.2149	* 2.4435	*
14	* 1.7524	* 1.7457	* 1.7396	* 1.1516	* 0.9173	* 0.7705	*	*
	* 1.1707	* 1.1799	* 1.2012	* 1.7054	* 2.0871	* 2.4439	*	*
15	* 0.8560	* 0.8669	* 0.8021	* 0.5588	* F-SUB-Q			
	* 2.1646	* 2.1474	* 2.3223	* 3.3773	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5607	* 1.5350	* 1.6602	* 1.5438	* 1.6664	* 1.6967	* 1.7939	* 0.8674
	* 1.4234	* 1.4547	* 1.3321	* 1.4129	* 1.2824	* 1.2452	* 1.1744	* 2.1935
9	* 1.5350	* 1.7488	* 1.6684	* 1.7269	* 1.6421	* 1.7103	* 1.7863	* 0.8782
	* 1.4547	* 1.2715	* 1.3205	* 1.2611	* 1.3244	* 1.2390	* 1.1832	* 2.1749
10	* 1.6602	* 1.6656	* 1.5224	* 1.5777	* 1.7875	* 1.6749	* 1.7801	* 0.8131
	* 1.3321	* 1.3239	* 1.4496	* 1.3975	* 1.2245	* 1.3033	* 1.2000	* 2.3464
11	* 1.5438	* 1.7257	* 1.5768	* 1.7918	* 1.6626	* 1.8211	* 1.1703	* 0.5739
	* 1.4129	* 1.2620	* 1.3983	* 1.2189	* 1.3115	* 1.1905	* 1.7137	* 3.3919
12	* 1.6664	* 1.6413	* 1.7873	* 1.6613	* 1.7134	* 1.7891	* 0.9319	*
	* 1.2824	* 1.3245	* 1.2246	* 1.3125	* 1.2452	* 1.2027	* 2.0917	*
13	* 1.6967	* 1.7108	* 1.6764	* 1.8209	* 1.7892	* 1.7591	* 0.7827	*
	* 1.2452	* 1.2386	* 1.3022	* 1.1906	* 1.2026	* 1.2076	* 2.4531	*
14	* 1.7939	* 1.7868	* 1.7807	* 1.1705	* 0.9308	* 0.7826	*	*
	* 1.1744	* 1.1829	* 1.1996	* 1.7136	* 2.0924	* 2.4536	*	*
15	* 0.8674	* 0.8788	* 0.8131	* 0.5639	* F-SUB-Q			
	* 2.1935	* 2.1740	* 2.3463	* 3.4004	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5747	* 1.5475	* 1.6818	* 1.5592	* 1.6944	* 1.7260	* 1.8318	* 0.8732
	* 1.4569	* 1.4759	* 1.3479	* 1.4398	* 1.3005	* 1.2615	* 1.1853	* 2.2448
9	* 1.5475	* 1.7725	* 1.6849	* 1.7545	* 1.6625	* 1.7407	* 1.8239	* 0.8853
	* 1.4759	* 1.2822	* 1.3416	* 1.2765	* 1.3429	* 1.2535	* 1.1934	* 2.2213
10	* 1.6818	* 1.6820	* 1.5364	* 1.5979	* 1.8224	* 1.7009	* 1.8178	* 0.8188
	* 1.3479	* 1.3452	* 1.4731	* 1.4098	* 1.2286	* 1.3111	* 1.2054	* 2.3942
11	* 1.5592	* 1.7531	* 1.5969	* 1.8255	* 1.6882	* 1.8596	* 1.1817	* 0.5766
	* 1.4398	* 1.2775	* 1.4106	* 1.2320	* 1.3292	* 1.1997	* 1.7332	* 3.4496
12	* 1.6944	* 1.6616	* 1.8222	* 1.6868	* 1.7494	* 1.8276	* 0.9395	*
	* 1.3005	* 1.3431	* 1.2287	* 1.3302	* 1.2578	* 1.2123	* 2.1330	*
13	* 1.7260	* 1.7413	* 1.7024	* 1.8594	* 1.8277	* 1.8015	* 0.7893	*
	* 1.2615	* 1.2531	* 1.3098	* 1.1998	* 1.2122	* 1.2127	* 2.4992	*
14	* 1.8318	* 1.8244	* 1.8184	* 1.1819	* 0.9383	* 0.7891	*	*
	* 1.1853	* 1.1932	* 1.2050	* 1.7332	* 2.1339	* 2.4997	*	*
15	* 0.8732	* 0.8860	* 0.8188	* 0.5657	F-SUB-Q			
	* 2.2448	* 2.2206	* 2.3943	* 3.4632	M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5602	* 1.5344	* 1.6627	* 1.5465	* 1.6814	* 1.7216	* 1.8244	* 0.8825
	* 1.5076	* 1.5303	* 1.4052	* 1.4996	* 1.3561	* 1.3084	* 1.2312	* 2.2962
9	* 1.5344	* 1.7526	* 1.6701	* 1.7391	* 1.6545	* 1.7373	* 1.8169	* 0.8914
	* 1.5303	* 1.3356	* 1.3947	* 1.3296	* 1.3911	* 1.2984	* 1.2383	* 2.2798
10	* 1.6627	* 1.6671	* 1.5236	* 1.5914	* 1.8123	* 1.6954	* 1.8115	* 0.8294
	* 1.4052	* 1.3986	* 1.5318	* 1.4568	* 1.2703	* 1.3526	* 1.2460	* 2.4377
11	* 1.5465	* 1.7376	* 1.5904	* 1.8146	* 1.6834	* 1.8525	* 1.1994	* 0.5833
	* 1.4996	* 1.3307	* 1.4577	* 1.2746	* 1.3686	* 1.2380	* 1.7536	* 3.5054
12	* 1.6814	* 1.6536	* 1.8121	* 1.6819	* 1.7506	* 1.8229	* 0.9530	*
	* 1.3561	* 1.3912	* 1.2704	* 1.3698	* 1.3033	* 1.2585	* 2.1671	*
13	* 1.7216	* 1.7379	* 1.6972	* 1.8523	* 1.8229	* 1.7995	* 0.8024	*
	* 1.3084	* 1.2979	* 1.3513	* 1.2381	* 1.2584	* 1.2579	* 2.5441	*
14	* 1.8244	* 1.8173	* 1.8120	* 1.1995	* 0.9518	* 0.8022	*	*
	* 1.2312	* 1.2380	* 1.2456	* 1.7537	* 2.1681	* 2.5447	*	*
15	* 0.8825	* 0.8920	* 0.8293	* 0.5735	F-SUB-Q			
	* 2.2962	* 2.2789	* 2.4380	* 3.5111	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5711	* 1.5425	* 1.6837	* 1.5581	* 1.7091	* 1.7495	* 1.8646	* 0.8769
	* 1.5479	* 1.5761	* 1.4360	* 1.5438	* 1.3855	* 1.3366	* 1.2505	* 2.3966
9	* 1.5425	* 1.7767	* 1.6839	* 1.7663	* 1.6704	* 1.7663	* 1.8566	* 0.8893
	* 1.5761	* 1.3649	* 1.4317	* 1.3573	* 1.4265	* 1.3250	* 1.2571	* 2.3685
10	* 1.6837	* 1.6807	* 1.5342	* 1.6070	* 1.8477	* 1.7181	* 1.8512	* 0.8235
	* 1.4360	* 1.4358	* 1.5746	* 1.4943	* 1.2901	* 1.3806	* 1.2615	* 2.5408
11	* 1.5581	* 1.7648	* 1.6059	* 1.8479	* 1.7055	* 1.8922	* 1.1949	* 0.5774
	* 1.5438	* 1.3584	* 1.4953	* 1.2936	* 1.3959	* 1.2519	* 1.8196	* 3.6516
12	* 1.7091	* 1.6695	* 1.8475	* 1.7039	* 1.7849	* 1.8619	* 0.9457	*
	* 1.3855	* 1.4267	* 1.2902	* 1.3971	* 1.3191	* 1.2693	* 2.2484	*
13	* 1.7495	* 1.7669	* 1.7198	* 1.8919	* 1.8619	* 1.8443	* 0.7957	*
	* 1.3366	* 1.3245	* 1.3792	* 1.2521	* 1.2693	* 1.2672	* 2.6415	*
14	* 1.8646	* 1.8571	* 1.8517	* 1.1949	* 0.9444	* 0.7955	*	*
	* 1.2505	* 1.2568	* 1.2611	* 1.8197	* 2.2497	* 2.6421	*	*
15	* 0.8769	* 0.8899	* 0.8234	* 0.5652	* F-SUB-Q			
	* 2.3966	* 2.3677	* 2.5413	* 3.6743	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5617	* 1.5326	* 1.6762	* 1.5499	* 1.7082	* 1.7528	* 1.8724	* 0.8745
	* 1.5481	* 1.5690	* 1.4315	* 1.5449	* 1.4024	* 1.3710	* 1.2828	* 2.4855
9	* 1.5326	* 1.7702	* 1.6757	* 1.7636	* 1.6663	* 1.7706	* 1.8643	* 0.8871
	* 1.5690	* 1.3583	* 1.4345	* 1.3631	* 1.4453	* 1.3594	* 1.2907	* 2.4586
10	* 1.6762	* 1.6717	* 1.5257	* 1.6037	* 1.8516	* 1.7187	* 1.8593	* 0.8221
	* 1.4315	* 1.4384	* 1.5750	* 1.5086	* 1.3103	* 1.4122	* 1.2992	* 2.6394
11	* 1.5499	* 1.7620	* 1.6026	* 1.8502	* 1.7060	* 1.9000	* 1.1959	* 0.5753
	* 1.5449	* 1.3643	* 1.5096	* 1.3177	* 1.4284	* 1.2848	* 1.8715	* 3.7914
12	* 1.7082	* 1.6653	* 1.8514	* 1.7044	* 1.7943	* 1.8704	* 0.9442	*
	* 1.4024	* 1.4462	* 1.3105	* 1.4297	* 1.3595	* 1.3069	* 2.3321	*
13	* 1.7528	* 1.7713	* 1.7205	* 1.8997	* 1.8703	* 1.8574	* 0.7951	*
	* 1.3710	* 1.3590	* 1.4108	* 1.2850	* 1.3069	* 1.3024	* 2.7329	*
14	* 1.8724	* 1.8648	* 1.8599	* 1.1959	* 0.9429	* 0.7949	*	*
	* 1.2828	* 1.2904	* 1.2988	* 1.8717	* 2.3335	* 2.7336	*	*
15	* 0.8745	* 0.8877	* 0.8219	* 0.5624	* F-SUB-Q			
	* 2.4855	* 2.4577	* 2.6400	* 3.8203	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5338	* 1.5057	* 1.6422	* 1.5229	* 1.6803	* 1.7338	* 1.8503	* 0.8738 *
	* 1.5364	* 1.5564	* 1.4242	* 1.5334	* 1.3910	* 1.3523	* 1.2666	* 2.4276 *
9	* 1.5057	* 1.7349	* 1.6474	* 1.7323	* 1.6431	* 1.7525	* 1.8427	* 0.8836 *
	* 1.5564	* 1.3508	* 1.4224	* 1.3527	* 1.4289	* 1.3397	* 1.2737	* 2.4084 *
10	* 1.6422	* 1.6422	* 1.4995	* 1.5825	* 1.8256	* 1.6982	* 1.8384	* 0.8229 *
	* 1.4242	* 1.4268	* 1.5619	* 1.4909	* 1.2966	* 1.3944	* 1.2814	* 2.5711 *
11	* 1.5229	* 1.7307	* 1.5813	* 1.8232	* 1.6859	* 1.8773	* 1.1994	* 0.5751 *
	* 1.5334	* 1.3539	* 1.4920	* 1.3052	* 1.4098	* 1.2707	* 1.8202	* 3.7155 *
12	* 1.6803	* 1.6426	* 1.8254	* 1.6843	* 1.7805	* 1.8503	* 0.9465	*
	* 1.3910	* 1.4298	* 1.2968	* 1.4106	* 1.3591	* 1.2982	* 2.2812	*
13	* 1.7338	* 1.7532	* 1.7001	* 1.8770	* 1.8502	* 1.8409	* 0.7989	*
	* 1.3523	* 1.3392	* 1.3929	* 1.2709	* 1.2982	* 1.3122	* 2.7087	*
14	* 1.8503	* 1.8432	* 1.8389	* 1.1993	* 0.9452	* 0.7987	*	
	* 1.2666	* 1.2733	* 1.2811	* 1.8206	* 2.2826	* 2.7095	*	
15	* 0.8738	* 0.8842	* 0.8226	* 0.5635	* F-SUB-Q			
	* 2.4276	* 2.4076	* 2.5718	* 3.7348	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5270	* 1.4961	* 1.6420	* 1.5162	* 1.6870	* 1.7429	* 1.8702	* 0.8590
	* 1.5034	* 1.5223	* 1.3843	* 1.4971	* 1.3502	* 1.3138	* 1.2237	* 2.3974
9	* 1.4961	* 1.7370	* 1.6428	* 1.7374	* 1.6411	* 1.7626	* 1.8623	* 0.8722
	* 1.5223	* 1.3127	* 1.3883	* 1.3137	* 1.3957	* 1.3009	* 1.2307	* 2.3684
10	* 1.6420	* 1.6374	* 1.4928	* 1.5796	* 1.8389	* 1.7019	* 1.8581	* 0.8087
	* 1.3843	* 1.3926	* 1.5255	* 1.4570	* 1.2571	* 1.3590	* 1.2380	* 2.5389
11	* 1.5162	* 1.7356	* 1.5784	* 1.8341	* 1.6897	* 1.8954	* 1.1824	* 0.5635
	* 1.4971	* 1.3149	* 1.4581	* 1.2676	* 1.3757	* 1.2290	* 1.7998	* 3.6719
12	* 1.6870	* 1.6408	* 1.8387	* 1.6882	* 1.7959	* 1.8685	* 0.9293	
	* 1.3502	* 1.3966	* 1.2573	* 1.3771	* 1.3144	* 1.2545	* 2.2620	
13	* 1.7429	* 1.7633	* 1.7038	* 1.8950	* 1.8685	* 1.8665	* 0.7843	
	* 1.3138	* 1.3005	* 1.3575	* 1.2293	* 1.2545	* 1.2621	* 2.6865	
14	* 1.8702	* 1.8629	* 1.8586	* 1.1823	* 0.9279	* 0.7841	*	
	* 1.2237	* 1.2304	* 1.2377	* 1.8002	* 2.2637	* 2.6873	*	
15	* 0.8590	* 0.8729	* 0.8085	* 0.5495	* F-SUB-Q			
	* 2.3974	* 2.3675	* 2.5398	* 3.7088	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5049	* 1.4733	* 1.6202	* 1.4945	* 1.6713	* 1.7324	* 1.8642	* 0.8464 *
	* 1.4566	* 1.4759	* 1.3393	* 1.4504	* 1.3017	* 1.2634	* 1.1734	* 2.3255 *
9	* 1.4733	* 1.7156	* 1.6209	* 1.7192	* 1.6239	* 1.7530	* 1.8564	* 0.8603 *
	* 1.4759	* 1.2684	* 1.3433	* 1.2671	* 1.3474	* 1.2504	* 1.1800	* 2.2948 *
10	* 1.6202	* 1.6154	* 1.4715	* 1.5623	* 1.8272	* 1.6881	* 1.8525	* 0.7972 *
	* 1.3393	* 1.3477	* 1.4776	* 1.4053	* 1.2078	* 1.3084	* 1.1862	* 2.4606 *
11	* 1.4945	* 1.7174	* 1.5610	* 1.8203	* 1.6762	* 1.8879	* 1.1684	* 0.5540 *
	* 1.4504	* 1.2684	* 1.4065	* 1.2194	* 1.3248	* 1.1797	* 1.7372	* 3.5662 *
12	* 1.6713	* 1.6236	* 1.8269	* 1.6745	* 1.7909	* 1.8623	* 0.9164	*
	* 1.3017	* 1.3478	* 1.2080	* 1.3262	* 1.2670	* 1.2055	* 2.1863	*
13	* 1.7324	* 1.7537	* 1.6901	* 1.8875	* 1.8622	* 1.8666	* 0.7740	*
	* 1.2634	* 1.2499	* 1.3069	* 1.1799	* 1.2056	* 1.2100	* 2.5921	*
14	* 1.8642	* 1.8570	* 1.8530	* 1.1683	* 0.9149	* 0.7738	*	
	* 1.1734	* 1.1797	* 1.1859	* 1.7377	* 2.1881	* 2.5930	*	
15	* 0.8464	* 0.8610	* 0.7969	* 0.5395	F-SUB-Q			
	* 2.3255	* 2.2939	* 2.4616	* 3.6068	M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4740	* 1.4418	* 1.5858	* 1.4632	* 1.6422	* 1.7086	* 1.8408	* 0.8340
	* 1.4246	* 1.4448	* 1.3109	* 1.4198	* 1.2697	* 1.2276	* 1.1387	* 2.2635
9	* 1.4418	* 1.6807	* 1.5888	* 1.6871	* 1.5963	* 1.7300	* 1.8334	* 0.8472
	* 1.4448	* 1.2401	* 1.3130	* 1.2368	* 1.3131	* 1.2139	* 1.1447	* 2.2345
10	* 1.5858	* 1.5832	* 1.4416	* 1.5348	* 1.7994	* 1.6620	* 1.8301	* 0.7864
	* 1.3109	* 1.3175	* 1.4452	* 1.3693	* 1.1732	* 1.2717	* 1.1496	* 2.3910
11	* 1.4632	* 1.6852	* 1.5335	* 1.7913	* 1.6506	* 1.8633	* 1.1552	* 0.5458
	* 1.4198	* 1.2382	* 1.3704	* 1.1849	* 1.2869	* 1.1425	* 1.6818	* 3.4688
12	* 1.6422	* 1.5960	* 1.7991	* 1.6489	* 1.7710	* 1.8393	* 0.9038	
	* 1.2697	* 1.3133	* 1.1734	* 1.2883	* 1.2236	* 1.1661	* 2.1198	
13	* 1.7086	* 1.7308	* 1.6640	* 1.8628	* 1.8391	* 1.8478	* 0.7644	
	* 1.2276	* 1.2134	* 1.2702	* 1.1428	* 1.1662	* 1.1664	* 2.5077	
14	* 1.8408	* 1.8340	* 1.8306	* 1.1550	* 0.9023	* 0.7642		
	* 1.1387	* 1.1444	* 1.1493	* 1.6823	* 2.1216	* 2.5085		
15	* 0.8340	* 0.8479	* 0.7861	* 0.5311	* F-SUB-Q			
	* 2.2635	* 2.2336	* 2.3921	* 3.5106	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4314	* 1.4004	* 1.5355	* 1.4207	* 1.5955	* 1.6689	* 1.7958	* 0.8226 *
	* 1.5211	* 1.5436	* 1.4056	* 1.5186	* 1.3573	* 1.3049	* 1.2117	* 2.3847 *
9	* 1.4004	* 1.6283	* 1.5437	* 1.6369	* 1.5563	* 1.6908	* 1.7891	* 0.8330 *
	* 1.5436	* 1.3282	* 1.4029	* 1.3231	* 1.3979	* 1.2894	* 1.2174	* 2.3612 *
10	* 1.5355	* 1.5382	* 1.4006	* 1.4958	* 1.7512	* 1.6213	* 1.7865	* 0.7768 *
	* 1.4056	* 1.4078	* 1.5444	* 1.4570	* 1.2492	* 1.3510	* 1.2213	* 2.5142 *
11	* 1.4207	* 1.6351	* 1.4945	* 1.7422	* 1.6113	* 1.8175	* 1.1431	* 0.5385 *
	* 1.5186	* 1.3246	* 1.4583	* 1.2616	* 1.3629	* 1.2123	* 1.7622	* 3.6504 *
12	* 1.5955	* 1.5560	* 1.7509	* 1.6098	* 1.7338	* 1.7955	* 0.8938 *	
	* 1.3573	* 1.3981	* 1.2494	* 1.3638	* 1.2912	* 1.2352	* 2.2200 *	
13	* 1.6689	* 1.6915	* 1.6233	* 1.8170	* 1.7953	* 1.8070	* 0.7576 *	
	* 1.3049	* 1.2888	* 1.3492	* 1.2126	* 1.2353	* 1.2317	* 2.6176 *	
14	* 1.7958	* 1.7896	* 1.7870	* 1.1429	* 0.8923	* 0.7573 *		
	* 1.2117	* 1.2171	* 1.2210	* 1.7628	* 2.2218	* 2.6186 *		
15	* 0.8226	* 0.8337	* 0.7765	* 0.5256	* F-SUB-Q			
	* 2.3847	* 2.3602	* 2.5154	* 3.6834	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4086	* 1.3749	* 1.5170	* 1.3966	* 1.5808	* 1.6548	* 1.7905	* 0.7957 *
	* 1.4761	* 1.5064	* 1.3646	* 1.4838	* 1.3169	* 1.2657	* 1.1684	* 2.3751 *
9	* 1.3749	* 1.6112	* 1.5210	* 1.6205	* 1.5339	* 1.6773	* 1.7836	* 0.8095 *
	* 1.5064	* 1.2861	* 1.3663	* 1.2824	* 1.3618	* 1.2495	* 1.1736	* 2.3404 *
10	* 1.5170	* 1.5153	* 1.3776	* 1.4726	* 1.7394	* 1.6030	* 1.7808	* 0.7509 *
	* 1.3646	* 1.3714	* 1.5070	* 1.4178	* 1.2034	* 1.3089	* 1.1756	* 2.5033 *
11	* 1.3966	* 1.6186	* 1.4713	* 1.7283	* 1.5920	* 1.8092	* 1.1086	* 0.5193 *
	* 1.4838	* 1.2839	* 1.4191	* 1.2142	* 1.3208	* 1.1626	* 1.7405	* 3.6427 *
12	* 1.5808	* 1.5336	* 1.7391	* 1.5903	* 1.7227	* 1.7872	* 0.8632 *	
	* 1.3169	* 1.3620	* 1.2036	* 1.3221	* 1.2326	* 1.1810	* 2.1955 *	
13	* 1.6548	* 1.6781	* 1.6051	* 1.8088	* 1.7870	* 1.8048	* 0.7308 *	
	* 1.2657	* 1.2489	* 1.3072	* 1.1629	* 1.1811	* 1.1713	* 2.5866 *	
14	* 1.7905	* 1.7842	* 1.7813	* 1.1084	* 0.8617	* 0.7305 *		
	* 1.1684	* 1.1733	* 1.1753	* 1.7410	* 2.1975	* 2.5875 *		
15	* 0.7957	* 0.8102	* 0.7506	* 0.5043	* F-SUB-Q			
	* 2.3751	* 2.3394	* 2.5045	* 3.6942	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3677	* 1.3334	* 1.4706	* 1.3542	* 1.5358	* 1.6139	* 1.7468	* 0.7715
	* 1.4541	* 1.4890	* 1.3497	* 1.4681	* 1.3005	* 1.2447	* 1.1486	* 2.3528
9	* 1.3334	* 1.5640	* 1.4776	* 1.5727	* 1.4911	* 1.6363	* 1.7404	* 0.7852
	* 1.4890	* 1.2698	* 1.3487	* 1.2670	* 1.3432	* 1.2281	* 1.1533	* 2.3173
10	* 1.4706	* 1.4720	* 1.3376	* 1.4299	* 1.6915	* 1.5600	* 1.7373	* 0.7284
	* 1.3497	* 1.3538	* 1.4885	* 1.3991	* 1.1849	* 1.2882	* 1.1548	* 2.4780
11	* 1.3542	* 1.5708	* 1.4286	* 1.6796	* 1.5490	* 1.7626	* 1.0784	* 0.5032
	* 1.4681	* 1.2685	* 1.4004	* 1.1953	* 1.2988	* 1.1412	* 1.7146	* 3.6098
12	* 1.5358	* 1.4908	* 1.6911	* 1.5472	* 1.6812	* 1.7415	* 0.8372	*
	* 1.3005	* 1.3435	* 1.1851	* 1.3001	* 1.2036	* 1.1576	* 2.1678	*
13	* 1.6139	* 1.6371	* 1.5621	* 1.7622	* 1.7413	* 1.7613	* 0.7086	*
	* 1.2447	* 1.2276	* 1.2865	* 1.1415	* 1.1577	* 1.1455	* 2.5524	*
14	* 1.7468	* 1.7408	* 1.7378	* 1.0782	* 0.8358	* 0.7084	*	*
	* 1.1486	* 1.1530	* 1.1545	* 1.7152	* 2.1698	* 2.5533	*	*
15	* 0.7715	* 0.7859	* 0.7280	* 0.4884	* F-SUB-Q			
	* 2.3528	* 2.3162	* 2.4794	* 3.6631	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3064	* 1.2731	* 1.3921	* 1.2916	* 1.4549	* 1.5412	* 1.6564	* 0.7489
	* 1.4677	* 1.5044	* 1.3758	* 1.4855	* 1.3250	* 1.2574	* 1.1686	* 2.3423
9	* 1.2731	* 1.4815	* 1.4112	* 1.4881	* 1.4246	* 1.5626	* 1.6514	* 0.7587
	* 1.5044	* 1.2929	* 1.3624	* 1.2919	* 1.3563	* 1.2405	* 1.1724	* 2.3175
10	* 1.3921	* 1.4058	* 1.2786	* 1.3644	* 1.6001	* 1.4882	* 1.6475	* 0.7078
	* 1.3758	* 1.3676	* 1.5027	* 1.4139	* 1.2070	* 1.3016	* 1.1742	* 2.4639
11	* 1.2916	* 1.4863	* 1.3633	* 1.5897	* 1.4787	* 1.6696	* 1.0504	* 0.4897
	* 1.4855	* 1.2934	* 1.4152	* 1.2164	* 1.3091	* 1.1600	* 1.6980	* 3.5848
12	* 1.4549	* 1.4243	* 1.5998	* 1.4771	* 1.6029	* 1.6505	* 0.8141	*
	* 1.3250	* 1.3566	* 1.2073	* 1.3101	* 1.2134	* 1.1752	* 2.1494	*
13	* 1.5412	* 1.5633	* 1.4902	* 1.6692	* 1.6503	* 1.6669	* 0.6901	*
	* 1.2574	* 1.2400	* 1.2998	* 1.1603	* 1.1754	* 1.1635	* 2.5257	*
14	* 1.6564	* 1.6518	* 1.6479	* 1.0502	* 0.8128	* 0.6899	*	*
	* 1.1686	* 1.1722	* 1.1739	* 1.6986	* 2.1513	* 2.5266	*	*
15	* 0.7489	* 0.7593	* 0.7075	* 0.4775	* F-SUB-Q			
	* 2.3423	* 2.3164	* 2.4653	* 3.6210	* M-SUB-Q			

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	* 1.1617	* 1.1421	* 1.2461	* 1.1710	* 1.2853	* 1.3619	* 1.4454	* 0.6600
	* 1.5667	* 1.5917	* 1.4591	* 1.5555	* 1.4237	* 1.3495	* 1.2702	* 2.5300
9	* 1.1421	* 1.3064	* 1.2659	* 1.3133	* 1.2634	* 1.3784	* 1.4402	* 0.6703
	* 1.5917	* 1.3912	* 1.4412	* 1.3888	* 1.4499	* 1.3336	* 1.2750	* 2.4973
10	* 1.2461	* 1.2612	* 1.1400	* 1.2109	* 1.3914	* 1.3154	* 1.4246	* 0.6165
	* 1.4591	* 1.4465	* 1.6000	* 1.5107	* 1.3154	* 1.3956	* 1.2878	* 2.6938
11	* 1.1710	* 1.3117	* 1.2098	* 1.3894	* 1.3079	* 1.4493	* 0.9148	* 0.4242
	* 1.5555	* 1.3904	* 1.5120	* 1.3183	* 1.4036	* 1.2652	* 1.8513	* 3.9451
12	* 1.2853	* 1.2632	* 1.3911	* 1.3065	* 1.4125	* 1.4361	* 0.7106	
	* 1.4237	* 1.4511	* 1.3157	* 1.4051	* 1.3016	* 1.2782	* 2.3385	
13	* 1.3619	* 1.3789	* 1.3170	* 1.4489	* 1.4360	* 1.4325	* 0.5923	
	* 1.3495	* 1.3330	* 1.3939	* 1.2656	* 1.2783	* 1.2803	* 2.7946	
14	* 1.4454	* 1.4405	* 1.4248	* 0.9146	* 0.7094	* 0.5921		
	* 1.2702	* 1.2747	* 1.2875	* 1.8520	* 2.3407	* 2.7957		
15	* 0.6600	* 0.6708	* 0.6160	* 0.4115	* F-SUB-Q			
	* 2.5300	* 2.4962	* 2.6956	* 4.0053	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9418	* 0.9647	* 1.2031	* 0.9905	* 1.2139	* 1.0987	* 1.2719	* 0.5618
	* 1.9012	* 1.8530	* 1.4861	* 1.8084	* 1.4821	* 1.6445	* 1.4185	* 2.9287
9	* 0.9647	* 1.1952	* 1.0547	* 1.2168	* 1.0366	* 1.1124	* 1.2611	* 0.5679
	* 1.8530	* 1.4960	* 1.6986	* 1.4743	* 1.7352	* 1.6239	* 1.4306	* 2.9040
10	* 1.2031	* 1.0522	* 0.9247	* 1.0051	* 1.2576	* 1.0745	* 1.1781	* 0.5136
	* 1.4861	* 1.7021	* 1.9399	* 1.7900	* 1.4316	* 1.6788	* 1.5316	* 3.1868
11	* 0.9905	* 1.2156	* 1.0044	* 1.2665	* 1.0688	* 1.2387	* 0.7603	* 0.3490
	* 1.8084	* 1.4758	* 1.7913	* 1.4217	* 1.6870	* 1.4551	* 2.1927	* 4.7310
12	* 1.2139	* 1.0359	* 1.2573	* 1.0676	* 1.1547	* 1.2675	* 0.6075	
	* 1.4821	* 1.7365	* 1.4320	* 1.6888	* 1.5641	* 1.4236	* 2.6936	
13	* 1.0987	* 1.1129	* 1.0757	* 1.2384	* 1.2672	* 1.1372	* 0.4833	
	* 1.6445	* 1.6233	* 1.6769	* 1.4554	* 1.4239	* 1.5872	* 3.3750	
14	* 1.2719	* 1.2614	* 1.1781	* 0.7600	* 0.6066	* 0.4831		
	* 1.4185	* 1.4304	* 1.5316	* 2.1937	* 2.6958	* 3.3763		
15	* 0.5618	* 0.5684	* 0.5132	* 0.3386	F-SUB-Q			
	* 2.9287	* 2.9029	* 3.1891	* 4.8015	M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3769	* 0.4074	* 0.4928	* 0.4224	* 0.4946	* 0.4250	* 0.4581	* 0.2342
	* 4.6997	* 4.3447	* 3.5920	* 4.1982	* 3.5954	* 4.2033	* 3.8987	* 6.9661
9	* 0.4074	* 0.4817	* 0.4267	* 0.4940	* 0.4205	* 0.4277	* 0.4532	* 0.2335
	* 4.3447	* 3.6744	* 4.1553	* 3.5916	* 4.2323	* 4.1778	* 3.9409	* 7.0062
10	* 0.4928	* 0.4259	* 0.3893	* 0.4215	* 0.5022	* 0.4218	* 0.4181	* 0.2129
	* 3.5920	* 4.1627	* 4.5595	* 4.2233	* 3.5467	* 4.2308	* 4.2732	* 7.6241
11	* 0.4224	* 0.4935	* 0.4212	* 0.4985	* 0.4318	* 0.4737	* 0.3135	* 0.1453
	* 4.1982	* 3.5950	* 4.2264	* 3.5720	* 4.1309	* 3.7669	* 5.2668	* 11.2756
12	* 0.4946	* 0.4202	* 0.5020	* 0.4315	* 0.4375	* 0.4577	* 0.2528	
	* 3.5954	* 4.2353	* 3.5480	* 4.1341	* 4.0851	* 3.9020	* 6.4173	
13	* 0.4250	* 0.4278	* 0.4221	* 0.4736	* 0.4576	* 0.4016	* 0.1981	
	* 4.2033	* 4.1766	* 4.2279	* 3.7678	* 3.9028	* 4.4494	* 8.1656	
14	* 0.4581	* 0.4533	* 0.4181	* 0.3134	* 0.2525	* 0.1980		
	* 3.8987	* 3.9402	* 4.2735	* 5.2696	* 6.4202	* 8.1691		
15	* 0.2342	* 0.2336	* 0.2128	* 0.1423	F-SUB-Q			
	* 6.9661	* 7.0033	* 7.6297	* 11.3374	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4079	* 0.4615	* 0.5413	* 0.4723	* 0.5251	* 0.4454	* 0.4498	* 0.2522 *
	* 4.1784	* 4.1680	* 3.4792	* 3.9321	* 3.4843	* 4.0773	* 4.0048	* 6.4060 *
9	* 0.4615	* 0.5281	* 0.4841	* 0.5335	* 0.4588	* 0.4386	* 0.4452	* 0.2486 *
	* 4.1680	* 3.6545	* 3.8853	* 3.4825	* 4.0123	* 4.1546	* 4.0671	* 6.5329 *
10	* 0.5413	* 0.4838	* 0.4437	* 0.4527	* 0.5137	* 0.4344	* 0.4151	* 0.2252 *
	* 3.4792	* 3.8881	* 4.2560	* 4.1564	* 3.6790	* 4.3463	* 4.4724	* 7.2686 *
11	* 0.4723	* 0.5334	* 0.4525	* 0.5065	* 0.4483	* 0.4631	* 0.3162	* 0.1600 *
	* 3.9321	* 3.4836	* 4.1584	* 3.7193	* 4.1804	* 4.0087	* 5.4918	*10.6462 *
12	* 0.5251	* 0.4587	* 0.5136	* 0.4482	* 0.4033	* 0.4142	* 0.2612	*
	* 3.4843	* 4.0130	* 3.6797	* 4.1820	* 4.1960	* 4.1562	* 6.2838	*
13	* 0.4454	* 0.4387	* 0.4345	* 0.4631	* 0.4142	* 0.3677	* 0.2011	*
	* 4.0773	* 4.1545	* 4.3450	* 4.0087	* 4.1556	* 4.6234	* 7.9379	*
14	* 0.4498	* 0.4452	* 0.4152	* 0.3163	* 0.2611	* 0.2010	*	*
	* 4.0048	* 4.0665	* 4.4718	* 5.4915	* 6.2803	* 7.9386	*	*
15	* 0.2522	* 0.2488	* 0.2252	* 0.1578	* F-SUB-Q			
	* 6.4060	* 6.5286	* 7.2684	*10.6332	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9742	* 1.0106	* 1.1914	* 1.0300	* 1.1632	* 1.0354	* 1.1134	* 0.5843 *
	* 1.9204	* 1.9421	* 1.6102	* 1.8412	* 1.6086	* 1.7952	* 1.6563	* 2.8331 *
9	* 1.0106	* 1.1778	* 1.0982	* 1.1822	* 1.0377	* 1.0220	* 1.1041	* 0.5805 *
	* 1.9421	* 1.6678	* 1.7479	* 1.6054	* 1.8144	* 1.8251	* 1.6777	* 2.8714 *
10	* 1.1914	* 1.0971	* 0.9738	* 0.9916	* 1.1509	* 1.0138	* 1.0407	* 0.5245 *
	* 1.6102	* 1.7497	* 1.9824	* 1.9391	* 1.6773	* 1.9043	* 1.8223	* 3.1937 *
11	* 1.0300	* 1.1818	* 0.9912	* 1.1571	* 1.0184	* 1.0886	* 0.7275	* 0.3748 *
	* 1.8412	* 1.6059	* 1.9400	* 1.6581	* 1.8774	* 1.7419	* 2.4273	* 4.6441 *
12	* 1.1632	* 1.0376	* 1.1507	* 1.0179	* 0.9821	* 1.0670	* 0.6057	*
	* 1.6086	* 1.8146	* 1.6776	* 1.8783	* 1.8216	* 1.7012	* 2.7723	*
13	* 1.0354	* 1.0220	* 1.0143	* 1.0886	* 1.0671	* 0.9489	* 0.4794	*
	* 1.7952	* 1.8249	* 1.9035	* 1.7419	* 1.7011	* 1.8882	* 3.4131	*
14	* 1.1134	* 1.1043	* 1.0409	* 0.7278	* 0.6054	* 0.4794	*	*
	* 1.6563	* 1.6774	* 1.8220	* 2.4269	* 2.7715	* 3.4134	*	*
15	* 0.5843	* 0.5809	* 0.5245	* 0.3700	* F-SUB-Q			
	* 2.8331	* 2.8713	* 3.1934	* 4.6332	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2231	* 1.2258	* 1.3136	* 1.2413	* 1.2824	* 1.2708	* 1.2897	* 0.6994 *
	* 1.6154	* 1.6312	* 1.4871	* 1.5535	* 1.4820	* 1.4858	* 1.4534	* 2.4085 *
9	* 1.2258	* 1.3519	* 1.3173	* 1.3382	* 1.2656	* 1.2589	* 1.2804	* 0.7012 *
	* 1.6312	* 1.4823	* 1.4827	* 1.4424	* 1.5153	* 1.5000	* 1.4730	* 2.4148 *
10	* 1.3136	* 1.3157	* 1.1958	* 1.2099	* 1.3224	* 1.2471	* 1.2628	* 0.6461 *
	* 1.4871	* 1.4844	* 1.6419	* 1.6194	* 1.4874	* 1.5720	* 1.5228	* 2.6329 *
11	* 1.2413	* 1.3376	* 1.2094	* 1.3276	* 1.2474	* 1.2966	* 0.8984	* 0.4642 *
	* 1.5535	* 1.4431	* 1.6202	* 1.4680	* 1.5635	* 1.4866	* 1.9973	* 3.8072 *
12	* 1.2824	* 1.2653	* 1.3221	* 1.2466	* 1.2398	* 1.2667	* 0.7354 *	
	* 1.4820	* 1.5155	* 1.4877	* 1.5645	* 1.5175	* 1.4926	* 2.3320 *	
13	* 1.2708	* 1.2591	* 1.2478	* 1.2966	* 1.2669	* 1.2070	* 0.6055 *	
	* 1.4858	* 1.4998	* 1.5712	* 1.4866	* 1.4924	* 1.5357	* 2.7635 *	
14	* 1.2897	* 1.2807	* 1.2632	* 0.8987	* 0.7349	* 0.6055 *		
	* 1.4534	* 1.4728	* 1.5224	* 1.9969	* 2.3316	* 2.7638 *		
15	* 0.6994	* 0.7016	* 0.6462	* 0.4601	* F-SUB-Q			
	* 2.4085	* 2.4147	* 2.6324	* 3.7824	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3665	* 1.3650	* 1.4972	* 1.3788	* 1.4640	* 1.4278	* 1.4830	* 0.7599 *
	* 1.4808	* 1.4951	* 1.3275	* 1.4223	* 1.3200	* 1.3425	* 1.2826	* 2.2493 *
9	* 1.3650	* 1.5454	* 1.4661	* 1.5246	* 1.4147	* 1.4234	* 1.4725	* 0.7664 *
	* 1.4951	* 1.3213	* 1.3552	* 1.2871	* 1.3827	* 1.3462	* 1.3003	* 2.2435 *
10	* 1.4972	* 1.4638	* 1.3315	* 1.3524	* 1.5188	* 1.4043	* 1.4566	* 0.7037 *
	* 1.3275	* 1.3571	* 1.4994	* 1.4746	* 1.3155	* 1.4189	* 1.3390	* 2.4538 *
11	* 1.3788	* 1.5238	* 1.3517	* 1.5248	* 1.3999	* 1.4978	* 0.9871	* 0.5040 *
	* 1.4223	* 1.2878	* 1.4754	* 1.3027	* 1.4179	* 1.3132	* 1.8514	* 3.5559 *
12	* 1.4640	* 1.4143	* 1.5184	* 1.3988	* 1.4068	* 1.4625	* 0.8046 *	
	* 1.3200	* 1.3830	* 1.3158	* 1.4187	* 1.3644	* 1.3232	* 2.1777 *	
13	* 1.4278	* 1.4237	* 1.4051	* 1.4978	* 1.4627	* 1.4069	* 0.6663 *	
	* 1.3425	* 1.3460	* 1.4180	* 1.3133	* 1.3230	* 1.3488	* 2.5690 *	
14	* 1.4830	* 1.4729	* 1.4570	* 0.9874	* 0.8040	* 0.6663 *		
	* 1.2826	* 1.3000	* 1.3386	* 1.8510	* 2.1777	* 2.5693 *		
15	* 0.7599	* 0.7669	* 0.7039	* 0.4984	* F-SUB-Q			
	* 2.2493	* 2.2433	* 2.4533	* 3.5409	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4364	* 1.4381	* 1.6024	* 1.4553	* 1.5700	* 1.5085	* 1.5910	* 0.8022
	* 1.4420	* 1.4489	* 1.2634	* 1.3735	* 1.2540	* 1.2862	* 1.2161	* 2.1710
9	* 1.4381	* 1.6501	* 1.5436	* 1.6312	* 1.4969	* 1.5113	* 1.5793	* 0.8085
	* 1.4489	* 1.2609	* 1.3108	* 1.2250	* 1.3324	* 1.2898	* 1.2323	* 2.1645
10	* 1.6024	* 1.5410	* 1.3984	* 1.4303	* 1.6306	* 1.4892	* 1.5635	* 0.7439
	* 1.2634	* 1.3127	* 1.4546	* 1.4210	* 1.2472	* 1.3641	* 1.2673	* 2.3612
11	* 1.4553	* 1.6303	* 1.4297	* 1.6369	* 1.4825	* 1.6104	* 1.0459	* 0.5294
	* 1.3735	* 1.2254	* 1.4218	* 1.2402	* 1.3663	* 1.2483	* 1.7842	* 3.4380
12	* 1.5700	* 1.4964	* 1.6302	* 1.4816	* 1.4990	* 1.5744	* 0.8526	*
	* 1.2540	* 1.3326	* 1.2475	* 1.3672	* 1.3052	* 1.2578	* 2.1037	*
13	* 1.5085	* 1.5117	* 1.4903	* 1.6103	* 1.5746	* 1.5208	* 0.7077	*
	* 1.2862	* 1.2894	* 1.3631	* 1.2483	* 1.2576	* 1.2774	* 2.4787	*
14	* 1.5910	* 1.5797	* 1.5640	* 1.0462	* 0.8519	* 0.7076	*	*
	* 1.2161	* 1.2320	* 1.2668	* 1.7839	* 2.1038	* 2.4790	*	*
15	* 0.8022	* 0.8091	* 0.7440	* 0.5227	* F-SUB-Q			
	* 2.1710	* 2.1641	* 2.3607	* 3.4297	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4765	* 1.4806	* 1.6638	* 1.5020	* 1.6330	* 1.5615	* 1.6564	* 0.8324
	* 1.4292	* 1.4326	* 1.2414	* 1.3595	* 1.2316	* 1.2677	* 1.1917	* 2.1355
9	* 1.4806	* 1.7097	* 1.5889	* 1.6943	* 1.5469	* 1.5654	* 1.6439	* 0.8376
	* 1.4326	* 1.2342	* 1.2989	* 1.2037	* 1.3172	* 1.2698	* 1.2052	* 2.1321
10	* 1.6638	* 1.5863	* 1.4370	* 1.4787	* 1.6975	* 1.5408	* 1.6274	* 0.7728
	* 1.2414	* 1.3010	* 1.4446	* 1.4039	* 1.2215	* 1.3454	* 1.2393	* 2.3168
11	* 1.5020	* 1.6933	* 1.4780	* 1.7035	* 1.5341	* 1.6780	* 1.0878	* 0.5475
	* 1.3595	* 1.2041	* 1.4049	* 1.2167	* 1.3473	* 1.2234	* 1.7451	* 3.3799
12	* 1.6330	* 1.5464	* 1.6970	* 1.5331	* 1.5612	* 1.6428	* 0.8871	*
	* 1.2316	* 1.3175	* 1.2218	* 1.3482	* 1.2862	* 1.2351	* 2.0706	*
13	* 1.5615	* 1.5658	* 1.5421	* 1.6779	* 1.6429	* 1.5911	* 0.7383	*
	* 1.2677	* 1.2695	* 1.3443	* 1.2234	* 1.2350	* 1.2543	* 2.4436	*
14	* 1.6564	* 1.6443	* 1.6279	* 1.0881	* 0.8863	* 0.7382	*	*
	* 1.1917	* 1.2050	* 1.2389	* 1.7449	* 2.0709	* 2.4440	*	*
15	* 0.8324	* 0.8382	* 0.7729	* 0.5405	* F-SUB-Q			
	* 2.1355	* 2.1318	* 2.3165	* 3.3715	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5133	* 1.5185	* 1.7230	* 1.5438	* 1.6932	* 1.6116	* 1.7207	* 0.8489 *
	* 1.4166	* 1.4166	* 1.2262	* 1.3552	* 1.2177	* 1.2576	* 1.1732	* 2.1447 *
9	* 1.5185	* 1.7673	* 1.6318	* 1.7549	* 1.5908	* 1.6161	* 1.7086	* 0.8557 *
	* 1.4166	* 1.2143	* 1.2941	* 1.1901	* 1.3126	* 1.2585	* 1.1848	* 2.1363 *
10	* 1.7230	* 1.6290	* 1.4721	* 1.5205	* 1.7613	* 1.5869	* 1.6894	* 0.7875 *
	* 1.2262	* 1.2963	* 1.4421	* 1.3954	* 1.2002	* 1.3260	* 1.2180	* 2.3236 *
11	* 1.5438	* 1.7537	* 1.5198	* 1.7667	* 1.5806	* 1.7426	* 1.1105	* 0.5555 *
	* 1.3552	* 1.1906	* 1.3963	* 1.1952	* 1.3307	* 1.2007	* 1.7329	* 3.3858 *
12	* 1.6932	* 1.5901	* 1.7607	* 1.5795	* 1.6188	* 1.7065	* 0.9046 *	
	* 1.2177	* 1.3129	* 1.2006	* 1.3317	* 1.2698	* 1.2173	* 2.0776 *	
13	* 1.6116	* 1.6166	* 1.5883	* 1.7425	* 1.7066	* 1.6582	* 0.7525 *	
	* 1.2576	* 1.2582	* 1.3248	* 1.2008	* 1.2173	* 1.2328	* 2.4555 *	
14	* 1.7207	* 1.7090	* 1.6899	* 1.1107	* 0.9037	* 0.7524 *		
	* 1.1732	* 1.1846	* 1.2176	* 1.7328	* 2.0781	* 2.4559 *		
15	* 0.8489	* 0.8563	* 0.7876	* 0.5466	* F-SUB-Q			
	* 2.1447	* 2.1361	* 2.3235	* 3.3889	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5345	* 1.5407	* 1.7588	* 1.5692	* 1.7298	* 1.6438	* 1.7638	* 0.8613
	* 1.4308	* 1.4315	* 1.2321	* 1.3704	* 1.2262	* 1.2671	* 1.1754	* 2.1719
9	* 1.5407	* 1.8016	* 1.6572	* 1.7917	* 1.6179	* 1.6491	* 1.7519	* 0.8685
	* 1.4315	* 1.2162	* 1.3071	* 1.1978	* 1.3253	* 1.2665	* 1.1865	* 2.1616
10	* 1.7588	* 1.6543	* 1.4923	* 1.5467	* 1.8008	* 1.6159	* 1.7290	* 0.7991
	* 1.2321	* 1.3095	* 1.4581	* 1.4031	* 1.1997	* 1.3325	* 1.2175	* 2.3471
11	* 1.5692	* 1.7904	* 1.5459	* 1.8058	* 1.6100	* 1.7840	* 1.1286	* 0.5617
	* 1.3704	* 1.1983	* 1.4040	* 1.1948	* 1.3350	* 1.1973	* 1.7437	* 3.4057
12	* 1.7298	* 1.6171	* 1.8002	* 1.6088	* 1.6573	* 1.7480	* 0.9186	*
	* 1.2262	* 1.3258	* 1.2000	* 1.3361	* 1.2685	* 1.2125	* 2.0845	*
13	* 1.6438	* 1.6496	* 1.6174	* 1.7839	* 1.7481	* 1.7024	* 0.7644	*
	* 1.2671	* 1.2661	* 1.3312	* 1.1974	* 1.2125	* 1.2293	* 2.4708	*
14	* 1.7638	* 1.7523	* 1.7295	* 1.1288	* 0.9175	* 0.7643	*	
	* 1.1754	* 1.1862	* 1.2171	* 1.7437	* 2.0852	* 2.4712	*	
15	* 0.8613	* 0.8691	* 0.7991	* 0.5519	* F-SUB-Q			
	* 2.1719	* 2.1614	* 2.3472	* 3.4136	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5525	* 1.5586	* 1.7908	* 1.5894	* 1.7630	* 1.6720	* 1.8039	* 0.8682
	* 1.4642	* 1.4484	* 1.2459	* 1.3960	* 1.2425	* 1.2855	* 1.1857	* 2.2225
9	* 1.5586	* 1.8328	* 1.6784	* 1.8249	* 1.6399	* 1.6778	* 1.7915	* 0.8765
	* 1.4484	* 1.2258	* 1.3290	* 1.2134	* 1.3458	* 1.2834	* 1.1961	* 2.2081
10	* 1.7908	* 1.6752	* 1.5091	* 1.5677	* 1.8366	* 1.6403	* 1.7655	* 0.8053
	* 1.2459	* 1.3315	* 1.4831	* 1.4188	* 1.2065	* 1.3427	* 1.2244	* 2.3960
11	* 1.5894	* 1.8234	* 1.5669	* 1.8414	* 1.6347	* 1.8217	* 1.1398	* 0.5646
	* 1.3960	* 1.2140	* 1.4196	* 1.2083	* 1.3559	* 1.2087	* 1.7658	* 3.4667
12	* 1.7630	* 1.6391	* 1.8359	* 1.6334	* 1.6910	* 1.7855	* 0.9264	*
	* 1.2425	* 1.3465	* 1.2066	* 1.3570	* 1.2841	* 1.2221	* 2.1284	*
13	* 1.6720	* 1.6784	* 1.6419	* 1.8215	* 1.7856	* 1.7424	* 0.7709	*
	* 1.2855	* 1.2830	* 1.3415	* 1.2089	* 1.2221	* 1.2372	* 2.5209	*
14	* 1.8039	* 1.7920	* 1.7660	* 1.1399	* 0.9253	* 0.7708	*	*
	* 1.1857	* 1.1958	* 1.2240	* 1.7658	* 2.1292	* 2.5214	*	*
15	* 0.8682	* 0.8771	* 0.8052	* 0.5540	* F-SUB-Q			
	* 2.2225	* 2.2079	* 2.3962	* 3.4797	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5439	* 1.5514	* 1.7779	* 1.5823	* 1.7519	* 1.6694	* 1.7998	* 0.8788
	* 1.5128	* 1.5026	* 1.2985	* 1.4534	* 1.2964	* 1.3343	* 1.2314	* 2.2740
9	* 1.5514	* 1.8189	* 1.6693	* 1.8130	* 1.6353	* 1.6761	* 1.7872	* 0.8838
	* 1.5026	* 1.2769	* 1.3826	* 1.2659	* 1.3960	* 1.3304	* 1.2414	* 2.2666
10	* 1.7779	* 1.6661	* 1.5009	* 1.5646	* 1.8277	* 1.6370	* 1.7603	* 0.8167
	* 1.2985	* 1.3852	* 1.5414	* 1.4668	* 1.2489	* 1.3862	* 1.2670	* 2.4406
11	* 1.5823	* 1.8115	* 1.5637	* 1.8323	* 1.6315	* 1.8160	* 1.1579	* 0.5719
	* 1.4534	* 1.2665	* 1.4677	* 1.2498	* 1.3963	* 1.2481	* 1.7880	* 3.5247
12	* 1.7519	* 1.6345	* 1.8269	* 1.6301	* 1.6928	* 1.7830	* 0.9403	*
	* 1.2964	* 1.3967	* 1.2490	* 1.3975	* 1.3326	* 1.2708	* 2.1643	*
13	* 1.6694	* 1.6766	* 1.6386	* 1.8158	* 1.7830	* 1.7406	* 0.7848	*
	* 1.3343	* 1.3300	* 1.3848	* 1.2482	* 1.2709	* 1.2854	* 2.5679	*
14	* 1.7998	* 1.7876	* 1.7608	* 1.1579	* 0.9392	* 0.7846	*	*
	* 1.2314	* 1.2411	* 1.2666	* 1.7882	* 2.1652	* 2.5685	*	*
15	* 0.8788	* 0.8844	* 0.8166	* 0.5625	* F-SUB-Q			
	* 2.2740	* 2.2663	* 2.4409	* 3.5291	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5595	* 1.5656	* 1.8111	* 1.5997	* 1.7864	* 1.6973	* 1.8436	* 0.8750
	* 1.5551	* 1.5478	* 1.3261	* 1.4971	* 1.3235	* 1.3656	* 1.2506	* 2.3734
9	* 1.5656	* 1.8523	* 1.6884	* 1.8477	* 1.6543	* 1.7045	* 1.8305	* 0.8834
	* 1.5478	* 1.3032	* 1.4218	* 1.2932	* 1.4345	* 1.3604	* 1.2601	* 2.3557
10	* 1.8111	* 1.6849	* 1.5151	* 1.5823	* 1.8660	* 1.6594	* 1.8007	* 0.8123
	* 1.3261	* 1.4247	* 1.5867	* 1.5069	* 1.2693	* 1.4184	* 1.2842	* 2.5450
11	* 1.5997	* 1.8461	* 1.5813	* 1.8702	* 1.6540	* 1.8570	* 1.1547	* 0.5669
	* 1.4971	* 1.2939	* 1.5079	* 1.2695	* 1.4273	* 1.2637	* 1.8576	* 3.6732
12	* 1.7864	* 1.6533	* 1.8652	* 1.6525	* 1.7268	* 1.8228	* 0.9351	*
	* 1.3235	* 1.4353	* 1.2694	* 1.4285	* 1.3499	* 1.2794	* 2.2457	*
13	* 1.6973	* 1.7051	* 1.6611	* 1.8568	* 1.8227	* 1.7850	* 0.7788	*
	* 1.3656	* 1.3599	* 1.4170	* 1.2638	* 1.2795	* 1.2959	* 2.6678	*
14	* 1.8436	* 1.8309	* 1.8012	* 1.1547	* 0.9339	* 0.7787	*	*
	* 1.2506	* 1.2598	* 1.2839	* 1.8579	* 2.2469	* 2.6684	*	*
15	* 0.8750	* 0.8840	* 0.8121	* 0.5550	* F-SUB-Q			
	* 2.3734	* 2.3554	* 2.5456	* 3.6952	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5568	* 1.5627	* 1.8132	* 1.5981	* 1.7904	* 1.7033	* 1.8561	* 0.8752
	* 1.5553	* 1.5421	* 1.3266	* 1.5027	* 1.3414	* 1.4127	* 1.2958	* 2.4726
9	* 1.5627	* 1.8543	* 1.6862	* 1.8513	* 1.6549	* 1.7115	* 1.8427	* 0.8836
	* 1.5421	* 1.3001	* 1.4271	* 1.2997	* 1.4580	* 1.4082	* 1.3053	* 2.4532
10	* 1.8132	* 1.6827	* 1.5120	* 1.5834	* 1.8736	* 1.6628	* 1.8117	* 0.8129
	* 1.3266	* 1.4301	* 1.5917	* 1.5304	* 1.2962	* 1.4614	* 1.3285	* 2.6458
11	* 1.5981	* 1.8496	* 1.5824	* 1.8772	* 1.6575	* 1.8682	* 1.1579	* 0.5661
	* 1.5027	* 1.3009	* 1.5314	* 1.2964	* 1.4714	* 1.3077	* 1.9249	* 3.8150
12	* 1.7904	* 1.6539	* 1.8728	* 1.6559	* 1.7381	* 1.8366	* 0.9359	*
	* 1.3414	* 1.4589	* 1.2968	* 1.4728	* 1.3931	* 1.3195	* 2.3301	*
13	* 1.7033	* 1.7121	* 1.6646	* 1.8679	* 1.8364	* 1.8000	* 0.7799	*
	* 1.4127	* 1.4077	* 1.4598	* 1.3079	* 1.3196	* 1.3335	* 2.7614	*
14	* 1.8561	* 1.8432	* 1.8122	* 1.1579	* 0.9346	* 0.7797	*	*
	* 1.2958	* 1.3050	* 1.3282	* 1.9253	* 2.3314	* 2.7621	*	*
15	* 0.8752	* 0.8842	* 0.8127	* 0.5534	* F-SUB-Q			
	* 2.4726	* 2.4528	* 2.6465	* 3.8436	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5370	* 1.5439	* 1.7859	* 1.5787	* 1.7656	* 1.6898	* 1.8403	* 0.8773
	* 1.5357	* 1.5214	* 1.3130	* 1.4835	* 1.3267	* 1.3893	* 1.2758	* 2.4167
9	* 1.5439	* 1.8271	* 1.6645	* 1.8255	* 1.6384	* 1.6988	* 1.8270	* 0.8831
	* 1.5214	* 1.2862	* 1.4095	* 1.2850	* 1.4357	* 1.3837	* 1.2862	* 2.4079
10	* 1.7859	* 1.6609	* 1.4931	* 1.5688	* 1.8523	* 1.6484	* 1.7962	* 0.8163
	* 1.3130	* 1.4126	* 1.5712	* 1.5064	* 1.2790	* 1.4383	* 1.3133	* 2.5903
11	* 1.5787	* 1.8238	* 1.5677	* 1.8554	* 1.6436	* 1.8513	* 1.1647	* 0.5678
	* 1.4835	* 1.2862	* 1.5074	* 1.2798	* 1.4481	* 1.2902	* 1.8697	* 3.7600
12	* 1.7656	* 1.6374	* 1.8514	* 1.6420	* 1.7292	* 1.8221	* 0.9406	*
	* 1.3267	* 1.4366	* 1.2796	* 1.4494	* 1.4004	* 1.3210	* 2.2932	*
13	* 1.6898	* 1.6994	* 1.6502	* 1.8510	* 1.8219	* 1.7884	* 0.7862	*
	* 1.3893	* 1.3832	* 1.4367	* 1.2905	* 1.3211	* 1.3516	* 2.7516	*
14	* 1.8403	* 1.8274	* 1.7966	* 1.1646	* 0.9393	* 0.7860	*	*
	* 1.2758	* 1.2859	* 1.3130	* 1.8701	* 2.2945	* 2.7524	*	*
15	* 0.8773	* 0.8837	* 0.8161	* 0.5563	* F-SUB-Q			
	* 2.4167	* 2.4076	* 2.5910	* 3.7786	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5378	* 1.5426	* 1.7986	* 1.5801	* 1.7804	* 1.7030	* 1.8675	* 0.8659
	* 1.4998	* 1.4853	* 1.2725	* 1.4457	* 1.2846	* 1.3471	* 1.2288	* 2.3817
9	* 1.5426	* 1.8408	* 1.6673	* 1.8402	* 1.6417	* 1.7129	* 1.8538	* 0.8750
	* 1.4853	* 1.2466	* 1.3741	* 1.2446	* 1.3992	* 1.3411	* 1.2388	* 2.3638
10	* 1.7987	* 1.6628	* 1.4930	* 1.5719	* 1.8725	* 1.6560	* 1.8212	* 0.8051
	* 1.2725	* 1.3771	* 1.5321	* 1.4682	* 1.2368	* 1.3990	* 1.2656	* 2.5533
11	* 1.5801	* 1.8384	* 1.5708	* 1.8746	* 1.6510	* 1.8758	* 1.1519	* 0.5581
	* 1.4457	* 1.2458	* 1.4693	* 1.2382	* 1.4088	* 1.2437	* 1.8445	* 3.7106
12	* 1.7804	* 1.6406	* 1.8722	* 1.6493	* 1.7489	* 1.8503	* 0.9276	*
	* 1.2846	* 1.4001	* 1.2374	* 1.4102	* 1.3509	* 1.2710	* 2.2671	*
13	* 1.7030	* 1.7135	* 1.6580	* 1.8755	* 1.8501	* 1.8186	* 0.7742	*
	* 1.3471	* 1.3406	* 1.3974	* 1.2439	* 1.2711	* 1.2965	* 2.7231	*
14	* 1.8675	* 1.8543	* 1.8216	* 1.1518	* 0.9262	* 0.7739	*	*
	* 1.2288	* 1.2385	* 1.2653	* 1.8449	* 2.2687	* 2.7238	*	*
15	* 0.8659	* 0.8756	* 0.8049	* 0.5442	* F-SUB-Q			
	* 2.3817	* 2.3634	* 2.5542	* 3.7468	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5239	* 1.5285	* 1.7868	* 1.5668	* 1.7710	* 1.6987	* 1.8693	* 0.8569 *
	* 1.4493	* 1.4350	* 1.2259	* 1.3959	* 1.2364	* 1.2947	* 1.1769	* 2.3060 *
9	* 1.5285	* 1.8298	* 1.6538	* 1.8303	* 1.6307	* 1.7094	* 1.8556	* 0.8667 *
	* 1.4350	* 1.2002	* 1.3265	* 1.1978	* 1.3486	* 1.2882	* 1.1864	* 2.2862 *
10	* 1.7868	* 1.6485	* 1.4792	* 1.5620	* 1.8694	* 1.6485	* 1.8226	* 0.7970 *
	* 1.2259	* 1.3300	* 1.4804	* 1.4143	* 1.1871	* 1.3460	* 1.2116	* 2.4703 *
11	* 1.5668	* 1.8284	* 1.5608	* 1.8692	* 1.6437	* 1.8762	* 1.1429	* 0.5508 *
	* 1.3959	* 1.1990	* 1.4153	* 1.1890	* 1.3558	* 1.1928	* 1.7785	* 3.5989 *
12	* 1.7710	* 1.6295	* 1.8691	* 1.6419	* 1.7503	* 1.8533	* 0.9186 *	
	* 1.2364	* 1.3496	* 1.1877	* 1.3572	* 1.3008	* 1.2200	* 2.1877 *	
13	* 1.6987	* 1.7101	* 1.6505	* 1.8758	* 1.8530	* 1.8252	* 0.7671 *	
	* 1.2947	* 1.2877	* 1.3444	* 1.1930	* 1.2202	* 1.2420	* 2.6249 *	
14	* 1.8693	* 1.8560	* 1.8231	* 1.1427	* 0.9172	* 0.7669 *		
	* 1.1769	* 1.1861	* 1.2113	* 1.7790	* 2.1894	* 2.6257 *		
15	* 0.8569	* 0.8674	* 0.7967	* 0.5364	* F-SUB-Q			
	* 2.3060	* 2.2857	* 2.4713	* 3.6389	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5012	* 1.5046	* 1.7593	* 1.5428	* 1.7461	* 1.6822	* 1.8537	* 0.8480 *
	* 1.4135	* 1.4003	* 1.1961	* 1.3622	* 1.2049	* 1.2564	* 1.1401	* 2.2405 *
9	* 1.5046	* 1.8033	* 1.6301	* 1.8045	* 1.6094	* 1.6938	* 1.8401	* 0.8573 *
	* 1.4003	* 1.1695	* 1.2930	* 1.1669	* 1.3124	* 1.2491	* 1.1492	* 2.2222 *
10	* 1.7593	* 1.6247	* 1.4570	* 1.5423	* 1.8500	* 1.6302	* 1.8081	* 0.7896 *
	* 1.1961	* 1.2972	* 1.4444	* 1.3749	* 1.1513	* 1.3061	* 1.1725	* 2.3967 *
11	* 1.5428	* 1.8026	* 1.5411	* 1.8485	* 1.6255	* 1.8602	* 1.1348	* 0.5449 *
	* 1.3622	* 1.1682	* 1.3760	* 1.1537	* 1.3149	* 1.1533	* 1.7190	* 3.4952 *
12	* 1.7461	* 1.6083	* 1.8496	* 1.6238	* 1.7380	* 1.8388	* 0.9101 *	
	* 1.2049	* 1.3134	* 1.1515	* 1.3163	* 1.2549	* 1.1778	* 2.1175 *	
13	* 1.6822	* 1.6945	* 1.6323	* 1.8597	* 1.8386	* 1.8142	* 0.7608 *	
	* 1.2564	* 1.2487	* 1.3045	* 1.1535	* 1.1780	* 1.1960	* 2.5357 *	
14	* 1.8537	* 1.8406	* 1.8086	* 1.1346	* 0.9087	* 0.7605 *		
	* 1.1401	* 1.1489	* 1.1722	* 1.7195	* 2.1192	* 2.5365 *		
15	* 0.8480	* 0.8579	* 0.7892	* 0.5303	* F-SUB-Q			
	* 2.2405	* 2.2217	* 2.3977	* 3.5362	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4658	* 1.4699	* 1.7111	* 1.5063	* 1.7009	* 1.6502	* 1.8154	* 0.8399 *
	* 1.5057	* 1.4915	* 1.2801	* 1.4529	* 1.2882	* 1.3336	* 1.2117	* 2.3569 *
9	* 1.4699	* 1.7561	* 1.5923	* 1.7588	* 1.5756	* 1.6625	* 1.8021	* 0.8466 *
	* 1.4915	* 1.2496	* 1.3781	* 1.2469	* 1.3954	* 1.3249	* 1.2212	* 2.3443 *
10	* 1.7111	* 1.5870	* 1.4230	* 1.5110	* 1.8088	* 1.5985	* 1.7723	* 0.7832 *
	* 1.2801	* 1.3826	* 1.5399	* 1.4597	* 1.2237	* 1.3848	* 1.2442	* 2.5165 *
11	* 1.5063	* 1.7569	* 1.5098	* 1.8062	* 1.5944	* 1.8227	* 1.1279	* 0.5399 *
	* 1.4529	* 1.2482	* 1.4608	* 1.2275	* 1.3928	* 1.2219	* 1.7984	* 3.6727 *
12	* 1.7009	* 1.5744	* 1.8085	* 1.5926	* 1.7088	* 1.8015	* 0.9034	*
	* 1.2882	* 1.3964	* 1.2239	* 1.3943	* 1.3226	* 1.2463	* 2.2156	*
13	* 1.6502	* 1.6632	* 1.6006	* 1.8223	* 1.8012	* 1.7815	* 0.7574	*
	* 1.3336	* 1.3244	* 1.3831	* 1.2222	* 1.2465	* 1.2617	* 2.6428	*
14	* 1.8154	* 1.8025	* 1.7727	* 1.1277	* 0.9020	* 0.7571	*	
	* 1.2117	* 1.2209	* 1.2439	* 1.7990	* 2.2172	* 2.6436	*	
15	* 0.8399	* 0.8472	* 0.7828	* 0.5271	* F-SUB-Q			
	* 2.3569	* 2.3438	* 2.5177	* 3.7047	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4473	* 1.4485	* 1.6983	* 1.4863	* 1.6921	* 1.6406	* 1.8157	* 0.8153 *
	* 1.4609	* 1.4548	* 1.2405	* 1.4179	* 1.2488	* 1.2930	* 1.1671	* 2.3437 *
9	* 1.4485	* 1.7454	* 1.5742	* 1.7492	* 1.5569	* 1.6537	* 1.8024	* 0.8254 *
	* 1.4548	* 1.2081	* 1.3413	* 1.2071	* 1.3590	* 1.2835	* 1.1759	* 2.3205 *
10	* 1.6983	* 1.5686	* 1.4042	* 1.4927	* 1.8044	* 1.5842	* 1.7729	* 0.7598 *
	* 1.2405	* 1.3460	* 1.5020	* 1.4196	* 1.1772	* 1.3421	* 1.1965	* 2.5020 *
11	* 1.4863	* 1.7473	* 1.4915	* 1.7999	* 1.5796	* 1.8217	* 1.0978	* 0.5222 *
	* 1.4179	* 1.2085	* 1.4207	* 1.1817	* 1.3484	* 1.1708	* 1.7749	* 3.6622 *
12	* 1.6921	* 1.5557	* 1.8040	* 1.5779	* 1.7036	* 1.8019	* 0.8763 *	
	* 1.2488	* 1.3601	* 1.1774	* 1.3499	* 1.2635	* 1.1891	* 2.1881	*
13	* 1.6406	* 1.6544	* 1.5863	* 1.8212	* 1.8016	* 1.7857	* 0.7330 *	
	* 1.2930	* 1.2830	* 1.3403	* 1.1711	* 1.1893	* 1.2004	* 2.6122 *	
14	* 1.8157	* 1.8029	* 1.7734	* 1.0976	* 0.8749	* 0.7328 *		
	* 1.1671	* 1.1756	* 1.1962	* 1.7755	* 2.1900	* 2.6130 *		
15	* 0.8153	* 0.8261	* 0.7594	* 0.5073	* F-SUB-Q			
	* 2.3437	* 2.3199	* 2.5032	* 3.7129	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4076	* 1.4072	* 1.6479	* 1.4437	* 1.6460	* 1.6033	* 1.7736	* 0.7922
	* 1.4396	* 1.4383	* 1.2282	* 1.4032	* 1.2341	* 1.2719	* 1.1483	* 2.3216
9	* 1.4072	* 1.6973	* 1.5322	* 1.7011	* 1.5154	* 1.6167	* 1.7606	* 0.8023
	* 1.4383	* 1.1931	* 1.3243	* 1.1926	* 1.3417	* 1.2619	* 1.1568	* 2.2974
10	* 1.6479	* 1.5266	* 1.3658	* 1.4530	* 1.7590	* 1.5453	* 1.7338	* 0.7386
	* 1.2282	* 1.3291	* 1.4843	* 1.4005	* 1.1588	* 1.3208	* 1.1751	* 2.4766
11	* 1.4437	* 1.6992	* 1.4518	* 1.7537	* 1.5408	* 1.7798	* 1.0707	* 0.5071
	* 1.4032	* 1.1939	* 1.4016	* 1.1640	* 1.3263	* 1.1488	* 1.7478	* 3.6291
12	* 1.6460	* 1.5142	* 1.7587	* 1.5390	* 1.6667	* 1.7592	* 0.8521	*
	* 1.2341	* 1.3427	* 1.1590	* 1.3279	* 1.2336	* 1.1654	* 2.1595	*
13	* 1.6033	* 1.6174	* 1.5474	* 1.7793	* 1.7589	* 1.7475	* 0.7126	*
	* 1.2719	* 1.2613	* 1.3190	* 1.1491	* 1.1656	* 1.1733	* 2.5765	*
14	* 1.7736	* 1.7610	* 1.7343	* 1.0705	* 0.8507	* 0.7124	*	*
	* 1.1483	* 1.1565	* 1.1749	* 1.7484	* 2.1614	* 2.5773	*	*
15	* 0.7922	* 0.8030	* 0.7382	* 0.4923	* F-SUB-Q			
	* 2.3216	* 2.2968	* 2.4779	* 3.6816	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3431	* 1.3419	* 1.5515	* 1.3742	* 1.5546	* 1.5320	* 1.6787	* 0.7685
	* 1.4574	* 1.4572	* 1.2608	* 1.4251	* 1.2632	* 1.2868	* 1.1726	* 2.3169
9	* 1.3419	* 1.6040	* 1.4615	* 1.6064	* 1.4459	* 1.5452	* 1.6666	* 0.7751
	* 1.4572	* 1.2197	* 1.3420	* 1.2205	* 1.3591	* 1.2762	* 1.1811	* 2.3022
10	* 1.5515	* 1.4562	* 1.3043	* 1.3868	* 1.6633	* 1.4763	* 1.6451	* 0.7178
	* 1.2608	* 1.3468	* 1.5027	* 1.4175	* 1.1832	* 1.3352	* 1.1966	* 2.4671
11	* 1.3742	* 1.6046	* 1.3856	* 1.6590	* 1.4716	* 1.6869	* 1.0436	* 0.4936
	* 1.4251	* 1.2218	* 1.4187	* 1.1874	* 1.3402	* 1.1693	* 1.7329	* 3.6100
12	* 1.5546	* 1.4448	* 1.6630	* 1.4701	* 1.5905	* 1.6638	* 0.8283	*
	* 1.2632	* 1.3602	* 1.1834	* 1.3418	* 1.2451	* 1.1872	* 2.1458	*
13	* 1.5320	* 1.5458	* 1.4783	* 1.6865	* 1.6636	* 1.6559	* 0.6948	*
	* 1.2868	* 1.2757	* 1.3334	* 1.1696	* 1.1874	* 1.1927	* 2.5514	*
14	* 1.6787	* 1.6670	* 1.6455	* 1.0434	* 0.8270	* 0.6945	*	*
	* 1.1726	* 1.1808	* 1.1963	* 1.7336	* 2.1476	* 2.5523	*	*
15	* 0.7685	* 0.7757	* 0.7174	* 0.4815	* F-SUB-Q			
	* 2.3169	* 2.3016	* 2.4684	* 3.6447	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2864	* 1.2805	* 1.4748	* 1.3132	* 1.4783	* 1.4689	* 1.6021	* 0.7215 *
	* 1.4797	* 1.4855	* 1.2898	* 1.4505	* 1.2922	* 1.3052	* 1.1958	* 2.4037 *
9	* 1.2805	* 1.5289	* 1.4006	* 1.5285	* 1.3800	* 1.4812	* 1.5879	* 0.7306 *
	* 1.4855	* 1.2440	* 1.3618	* 1.2472	* 1.3848	* 1.2946	* 1.2056	* 2.3787 *
10	* 1.4748	* 1.3955	* 1.2495	* 1.3222	* 1.5827	* 1.4110	* 1.5699	* 0.6725 *
	* 1.2898	* 1.3667	* 1.5258	* 1.4455	* 1.2083	* 1.3578	* 1.2190	* 2.5646 *
11	* 1.3132	* 1.5267	* 1.3211	* 1.5794	* 1.4069	* 1.6086	* 0.9823	* 0.4628 *
	* 1.4505	* 1.2486	* 1.4467	* 1.2118	* 1.3630	* 1.1910	* 1.7908	* 3.7520 *
12	* 1.4783	* 1.3789	* 1.5824	* 1.4054	* 1.5212	* 1.5853	* 0.7763 *	
	* 1.2922	* 1.3859	* 1.2086	* 1.3645	* 1.2632	* 1.2097	* 2.2266 *	
13	* 1.4689	* 1.4818	* 1.4130	* 1.6082	* 1.5851	* 1.5769	* 0.6473 *	
	* 1.3052	* 1.2940	* 1.3559	* 1.1913	* 1.2098	* 1.2154	* 2.6626 *	
14	* 1.6021	* 1.5883	* 1.5702	* 0.9820	* 0.7750	* 0.6471 *		
	* 1.1958	* 1.2053	* 1.2187	* 1.7915	* 2.2286	* 2.6635 *		
15	* 0.7215	* 0.7312	* 0.6721	* 0.4494	* F-SUB-Q			
	* 2.4037	* 2.3781	* 2.5661	* 3.8052	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1740	* 1.1741	* 1.3383	* 1.2094	* 1.3342	* 1.3364	* 1.4404	* 0.6638 *
	* 1.5865	* 1.5852	* 1.3900	* 1.5408	* 1.3998	* 1.4034	* 1.3012	* 2.5599 *
9	* 1.1741	* 1.3782	* 1.2828	* 1.3812	* 1.2619	* 1.3476	* 1.4266	* 0.6725 *
	* 1.5852	* 1.3499	* 1.4546	* 1.3485	* 1.4816	* 1.3919	* 1.3134	* 2.5329 *
10	* 1.3383	* 1.2782	* 1.1426	* 1.2070	* 1.4192	* 1.2867	* 1.4058	* 0.6155 *
	* 1.3900	* 1.4595	* 1.6327	* 1.5489	* 1.3178	* 1.4566	* 1.3317	* 2.7464 *
11	* 1.2094	* 1.3796	* 1.2059	* 1.4207	* 1.2832	* 1.4430	* 0.8978	* 0.4226 *
	* 1.5408	* 1.3500	* 1.5502	* 1.3171	* 1.4609	* 1.2981	* 1.9181	* 4.0301 *
12	* 1.3342	* 1.2609	* 1.4189	* 1.2817	* 1.3827	* 1.4249	* 0.7113 *	
	* 1.3998	* 1.4827	* 1.3181	* 1.4626	* 1.3576	* 1.3155	* 2.3790 *	
13	* 1.3364	* 1.3481	* 1.2883	* 1.4426	* 1.4248	* 1.4078	* 0.5887 *	
	* 1.4034	* 1.3913	* 1.4548	* 1.2984	* 1.3156	* 1.3305	* 2.8667 *	
14	* 1.4404	* 1.4269	* 1.4061	* 0.8976	* 0.7102	* 0.5885 *		
	* 1.3012	* 1.3131	* 1.3315	* 1.9189	* 2.3812	* 2.8677 *		
15	* 0.6638	* 0.6730	* 0.6151	* 0.4101	* F-SUB-Q			
	* 2.5599	* 2.5323	* 2.7483	* 4.0900	* M-SUB-Q			



# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9417	* 0.9627	* 1.2110	* 0.9941	* 1.1988	* 1.0641	* 1.2364	* 0.5536 *
	* 1.9468	* 1.9019	* 1.5120	* 1.8445	* 1.5314	* 1.7343	* 1.4906	* 3.0267 *
9	* 0.9627	* 1.1956	* 1.0560	* 1.2112	* 1.0170	* 1.0746	* 1.2244	* 0.5589 *
	* 1.9019	* 1.5309	* 1.7375	* 1.5133	* 1.8079	* 1.7172	* 1.5053	* 3.0049 *
10	* 1.2110	* 1.0535	* 0.9168	* 0.9777	* 1.2179	* 1.0374	* 1.1406	* 0.5042 *
	* 1.5120	* 1.7415	* 2.0025	* 1.8815	* 1.5100	* 1.7768	* 1.6157	* 3.3064 *
11	* 0.9941	* 1.2101	* 0.9769	* 1.2304	* 1.0332	* 1.1956	* 0.7348	* 0.3441 *
	* 1.8445	* 1.5147	* 1.8830	* 1.4951	* 1.7837	* 1.5408	* 2.3085	* 4.8847 *
12	* 1.1988	* 1.0162	* 1.2173	* 1.0322	* 1.1142	* 1.2295	* 0.5947 *	
	* 1.5314	* 1.8094	* 1.5108	* 1.7856	* 1.6568	* 1.5000	* 2.8042 *	
13	* 1.0641	* 1.0750	* 1.0385	* 1.1954	* 1.2293	* 1.1039	* 0.4742 *	
	* 1.7343	* 1.7166	* 1.7749	* 1.5411	* 1.5003	* 1.6709	* 3.5086 *	
14	* 1.2364	* 1.2246	* 1.1406	* 0.7346	* 0.5937	* 0.4741 *		
	* 1.4906	* 1.5050	* 1.6157	* 2.3096	* 2.8063	* 3.5099 *		
15	* 0.5536	* 0.5593	* 0.5038	* 0.3340	* F-SUB-Q			
	* 3.0267	* 3.0043	* 3.3088	* 4.9567	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3776	* 0.4078	* 0.4944	* 0.4210	* 0.4880	* 0.4125	* 0.4472	* 0.2297 *
	* 4.8039	* 4.4453	* 3.6667	* 4.3110	* 3.7269	* 4.4245	* 4.0802	* 7.2352 *
9	* 0.4078	* 0.4823	* 0.4252	* 0.4907	* 0.4130	* 0.4147	* 0.4421	* 0.2288 *
	* 4.4453	* 3.7584	* 4.2677	* 3.7001	* 4.4044	* 4.4019	* 4.1275	* 7.2808 *
10	* 0.4944	* 0.4245	* 0.3866	* 0.4112	* 0.4890	* 0.4081	* 0.4076	* 0.2086 *
	* 3.6667	* 4.2747	* 4.6989	* 4.4278	* 3.7239	* 4.4697	* 4.4778	* 7.9294 *
11	* 0.4210	* 0.4903	* 0.4109	* 0.4859	* 0.4181	* 0.4605	* 0.3035	* 0.1431 *
	* 4.3110	* 3.7034	* 4.4309	* 3.7479	* 4.3619	* 3.9614	* 5.5377	* 11.6568 *
12	* 0.4880	* 0.4128	* 0.4888	* 0.4178	* 0.4235	* 0.4457	* 0.2466 *	
	* 3.7269	* 4.4062	* 3.7255	* 4.3653	* 4.3130	* 4.0963	* 6.7048 *	
13	* 0.4125	* 0.4148	* 0.4084	* 0.4604	* 0.4456	* 0.3919	* 0.1941 *	
	* 4.4245	* 4.4008	* 4.4666	* 3.9622	* 4.0971	* 4.6606	* 8.5016 *	
14	* 0.4472	* 0.4422	* 0.4076	* 0.3034	* 0.2463	* 0.1941 *		
	* 4.0802	* 4.1269	* 4.4783	* 5.5407	* 6.7078	* 8.5051 *		
15	* 0.2297	* 0.2290	* 0.2084	* 0.1402	* F-SUB-Q			
	* 7.2352	* 7.2788	* 7.9352	* 11.7193	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4173	* 0.4726	* 0.5522	* 0.4862	* 0.5401	* 0.4623	* 0.4731	* 0.2698
	* 3.9300	* 3.9463	* 3.3658	* 3.7244	* 3.3584	* 3.8556	* 3.7853	* 5.9181
9	* 0.4726	* 0.5400	* 0.4963	* 0.5471	* 0.4732	* 0.4572	* 0.4686	* 0.2657
	* 3.9463	* 3.5236	* 3.6855	* 3.3602	* 3.7853	* 3.9123	* 3.8395	* 6.0482
10	* 0.5522	* 0.4959	* 0.4581	* 0.4667	* 0.5301	* 0.4514	* 0.4402	* 0.2415
	* 3.3658	* 3.6854	* 4.0265	* 3.9333	* 3.5328	* 4.0912	* 4.1878	* 6.6991
11	* 0.4862	* 0.5470	* 0.4665	* 0.5212	* 0.4636	* 0.4855	* 0.3318	* 0.1752
	* 3.7244	* 3.3612	* 3.9349	* 3.5578	* 3.9147	* 3.7766	* 5.1311	* 9.5908
12	* 0.5401	* 0.4731	* 0.5300	* 0.4634	* 0.4153	* 0.4375	* 0.2783	*
	* 3.3584	* 3.7856	* 3.5335	* 3.9152	* 3.9123	* 3.8774	* 5.7974	*
13	* 0.4623	* 0.4572	* 0.4515	* 0.4854	* 0.4375	* 0.3922	* 0.2177	*
	* 3.8556	* 3.9131	* 4.0916	* 3.7767	* 3.8769	* 4.2740	* 7.2302	*
14	* 0.4731	* 0.4686	* 0.4403	* 0.3319	* 0.2782	* 0.2176	*	*
	* 3.7853	* 3.8390	* 4.1874	* 5.1312	* 5.7911	* 7.2309	*	*
15	* 0.2698	* 0.2658	* 0.2415	* 0.1728	* F-SUB-Q			
	* 5.9181	* 6.0454	* 6.6994	* 9.5328	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9662	* 1.0036	* 1.1755	* 1.0292	* 1.1553	* 1.0388	* 1.1191	* 0.6052
	* 1.8831	* 1.8948	* 1.6113	* 1.7965	* 1.6047	* 1.7581	* 1.6372	* 2.7039
9	* 1.0036	* 1.1587	* 1.0923	* 1.1692	* 1.0373	* 1.0267	* 1.1102	* 0.6018
	* 1.8948	* 1.6680	* 1.7093	* 1.6051	* 1.7665	* 1.7785	* 1.6575	* 2.7375
10	* 1.1755	* 1.0913	* 0.9686	* 0.9909	* 1.1419	* 1.0165	* 1.0529	* 0.5444
	* 1.6113	* 1.7096	* 1.9463	* 1.8953	* 1.6747	* 1.8500	* 1.7898	* 3.0411
11	* 1.0292	* 1.1689	* 0.9905	* 1.1476	* 1.0196	* 1.0926	* 0.7359	* 0.3969
	* 1.7965	* 1.6055	* 1.8960	* 1.6466	* 1.8177	* 1.7136	* 2.3510	* 4.3278
12	* 1.1553	* 1.0371	* 1.1417	* 1.0191	* 0.9889	* 1.0777	* 0.6251	*
	* 1.6047	* 1.7666	* 1.6750	* 1.8182	* 1.7628	* 1.6628	* 2.6397	*
13	* 1.0388	* 1.0268	* 1.0169	* 1.0926	* 1.0778	* 0.9670	* 0.5017	*
	* 1.7581	* 1.7788	* 1.8500	* 1.7136	* 1.6627	* 1.8301	* 3.2155	*
14	* 1.1191	* 1.1104	* 1.0531	* 0.7361	* 0.6248	* 0.5016	*	*
	* 1.6372	* 1.6573	* 1.7896	* 2.3508	* 2.6375	* 3.2158	*	*
15	* 0.6052	* 0.6020	* 0.5444	* 0.3917	* F-SUB-Q			
	* 2.7039	* 2.7382	* 3.0410	* 4.2987	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2018	* 1.2213	* 1.3839	* 1.2484	* 1.3590	* 1.2686	* 1.3302	* 0.7276 *
	* 1.6019	* 1.5871	* 1.3894	* 1.5036	* 1.3839	* 1.4603	* 1.3964	* 2.2855 *
9	* 1.2213	* 1.3817	* 1.3152	* 1.3883	* 1.2669	* 1.2581	* 1.3201	* 0.7281 *
	* 1.5871	* 1.4224	* 1.4407	* 1.3715	* 1.4678	* 1.4723	* 1.4132	* 2.2951 *
10	* 1.3839	* 1.3138	* 1.1771	* 1.2071	* 1.3621	* 1.2411	* 1.2772	* 0.6708 *
	* 1.3894	* 1.4412	* 1.6266	* 1.5802	* 1.4240	* 1.5376	* 1.4928	* 2.5032 *
11	* 1.2484	* 1.3878	* 1.2067	* 1.3668	* 1.2429	* 1.3152	* 0.9059	* 0.4876 *
	* 1.5036	* 1.3720	* 1.5808	* 1.4072	* 1.5201	* 1.4479	* 1.9377	* 3.5720 *
12	* 1.3590	* 1.2667	* 1.3619	* 1.2422	* 1.2418	* 1.2963	* 0.7620 *	
	* 1.3839	* 1.4679	* 1.4243	* 1.5207	* 1.4764	* 1.4291	* 2.2089 *	
13	* 1.2686	* 1.2583	* 1.2417	* 1.3152	* 1.2964	* 1.2279	* 0.6301 *	
	* 1.4603	* 1.4724	* 1.5374	* 1.4479	* 1.4290	* 1.4907	* 2.6156 *	
14	* 1.3302	* 1.3204	* 1.2775	* 0.9062	* 0.7615	* 0.6301 *		
	* 1.3964	* 1.4130	* 1.4925	* 1.9375	* 2.2074	* 2.6159 *		
15	* 0.7276	* 0.7285	* 0.6709	* 0.4833	* F-SUB-Q			
	* 2.2855	* 2.2956	* 2.5029	* 3.5330	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3300	* 1.3535	* 1.5805	* 1.3858	* 1.5531	* 1.4108	* 1.5270	* 0.7887 *
	* 1.4806	* 1.4587	* 1.2338	* 1.3740	* 1.2275	* 1.3253	* 1.2307	* 2.1357 *
9	* 1.3535	* 1.5766	* 1.4566	* 1.5848	* 1.4064	* 1.4067	* 1.5151	* 0.7924 *
	* 1.4587	* 1.2687	* 1.3194	* 1.2176	* 1.3404	* 1.3328	* 1.2459	* 2.1360 *
10	* 1.5805	* 1.4548	* 1.2991	* 1.3389	* 1.5573	* 1.3831	* 1.4582	* 0.7259 *
	* 1.2338	* 1.3200	* 1.4953	* 1.4450	* 1.2619	* 1.4025	* 1.3225	* 2.3424 *
11	* 1.3858	* 1.5842	* 1.3383	* 1.5644	* 1.3810	* 1.5110	* 0.9864	* 0.5250 *
	* 1.3740	* 1.2180	* 1.4457	* 1.2520	* 1.3899	* 1.2838	* 1.8089	* 3.3575 *
12	* 1.5531	* 1.4062	* 1.5569	* 1.3800	* 1.3980	* 1.4988	* 0.8296 *	
	* 1.2275	* 1.3405	* 1.2622	* 1.3904	* 1.3375	* 1.2632	* 2.0691 *	
13	* 1.4108	* 1.4070	* 1.3839	* 1.5110	* 1.4989	* 1.4158	* 0.6869 *	
	* 1.3253	* 1.3328	* 1.4022	* 1.2838	* 1.2631	* 1.3208	* 2.4502 *	
14	* 1.5270	* 1.5154	* 1.4586	* 0.9867	* 0.8290	* 0.6868 *		
	* 1.2307	* 1.2456	* 1.3221	* 1.8087	* 2.0679	* 2.4505 *		
15	* 0.7887	* 0.7929	* 0.7260	* 0.5191	* F-SUB-Q			
	* 2.1357	* 2.1363	* 2.3421	* 3.3287	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3835	* 1.4125	* 1.6779	* 1.4497	* 1.6488	* 1.4765	* 1.6248	* 0.8249 *
	* 1.4543	* 1.4240	* 1.1807	* 1.3347	* 1.1742	* 1.2831	* 1.1721	* 2.0725 *
9	* 1.4125	* 1.6674	* 1.5200	* 1.6800	* 1.4711	* 1.4747	* 1.6108	* 0.8282 *
	* 1.4240	* 1.2211	* 1.2845	* 1.1664	* 1.3016	* 1.2893	* 1.1871	* 2.0738 *
10	* 1.6779	* 1.5180	* 1.3498	* 1.3979	* 1.6492	* 1.4466	* 1.5445	* 0.7596 *
	* 1.1807	* 1.2853	* 1.4622	* 1.4046	* 1.2090	* 1.3660	* 1.2659	* 2.2704 *
11	* 1.4497	* 1.6793	* 1.3973	* 1.6583	* 1.4423	* 1.6029	* 1.0321	* 0.5455 *
	* 1.3347	* 1.1667	* 1.4053	* 1.2050	* 1.3555	* 1.2340	* 1.7617	* 3.2734 *
12	* 1.6488	* 1.4709	* 1.6489	* 1.4411	* 1.4755	* 1.6001	* 0.8689 *	
	* 1.1742	* 1.3017	* 1.2092	* 1.3561	* 1.2949	* 1.2080	* 2.0174 *	
13	* 1.4765	* 1.4750	* 1.4475	* 1.6029	* 1.6001	* 1.5079	* 0.7206 *	
	* 1.2831	* 1.2893	* 1.3656	* 1.2340	* 1.2080	* 1.2669	* 2.3881 *	
14	* 1.6248	* 1.6111	* 1.5450	* 1.0324	* 0.8682	* 0.7205 *		
	* 1.1721	* 1.1868	* 1.2656	* 1.7615	* 2.0164	* 2.3884 *		
15	* 0.8249	* 0.8287	* 0.7597	* 0.5385	* F-SUB-Q			
	* 2.0725	* 2.0742	* 2.2702	* 3.2506	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4067	* 1.4395	* 1.7242	* 1.4794	* 1.6948	* 1.5079	* 1.6737	* 0.8464 *
	* 1.4543	* 1.4174	* 1.1695	* 1.3322	* 1.1634	* 1.2777	* 1.1567	* 2.0554 *
9	* 1.4395	* 1.7088	* 1.5482	* 1.7245	* 1.5012	* 1.5069	* 1.6589	* 0.8483 *
	* 1.4174	* 1.2074	* 1.2836	* 1.1567	* 1.2987	* 1.2827	* 1.1713	* 2.0595 *
10	* 1.7242	* 1.5460	* 1.3710	* 1.4243	* 1.6916	* 1.4746	* 1.5860	* 0.7804 *
	* 1.1695	* 1.2845	* 1.4650	* 1.4009	* 1.1976	* 1.3617	* 1.2520	* 2.2458 *
11	* 1.4794	* 1.7237	* 1.4235	* 1.7013	* 1.4703	* 1.6462	* 1.0595	* 0.5576 *
	* 1.3322	* 1.1570	* 1.4017	* 1.1965	* 1.3546	* 1.2245	* 1.7445	* 3.2471 *
12	* 1.6948	* 1.5009	* 1.6912	* 1.4693	* 1.5140	* 1.6510	* 0.8918 *	
	* 1.1634	* 1.2988	* 1.1979	* 1.3552	* 1.2931	* 1.1990	* 2.0107 *	
13	* 1.5079	* 1.5073	* 1.4756	* 1.6462	* 1.6510	* 1.5529	* 0.7426 *	
	* 1.2777	* 1.2827	* 1.3612	* 1.2245	* 1.1991	* 1.2608	* 2.3780 *	
14	* 1.6737	* 1.6593	* 1.5864	* 1.0596	* 0.8910	* 0.7425 *		
	* 1.1567	* 1.1711	* 1.2517	* 1.7445	* 2.0098	* 2.3783 *		
15	* 0.8464	* 0.8488	* 0.7804	* 0.5505	* F-SUB-Q			
	* 2.0554	* 2.0598	* 2.2457	* 3.2238	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4262	* 1.4607	* 1.7664	* 1.5033	* 1.7362	* 1.5359	* 1.7203	* 0.8535
	* 1.4531	* 1.4142	* 1.1648	* 1.3395	* 1.1606	* 1.2803	* 1.1482	* 2.0810
9	* 1.4607	* 1.7478	* 1.5720	* 1.7657	* 1.5246	* 1.5354	* 1.7046	* 0.8570
	* 1.4142	* 1.1959	* 1.2899	* 1.1539	* 1.3063	* 1.2841	* 1.1625	* 2.0805
10	* 1.7664	* 1.5697	* 1.3882	* 1.4452	* 1.7311	* 1.4980	* 1.6260	* 0.7859
	* 1.1648	* 1.2909	* 1.4755	* 1.4075	* 1.1913	* 1.3553	* 1.2421	* 2.2724
11	* 1.5033	* 1.7649	* 1.4443	* 1.7413	* 1.4934	* 1.6870	* 1.0678	* 0.5595
	* 1.3395	* 1.1543	* 1.4083	* 1.1861	* 1.3550	* 1.2146	* 1.7507	* 3.2808
12	* 1.7362	* 1.5243	* 1.7306	* 1.4924	* 1.5480	* 1.6981	* 0.8988	
	* 1.1606	* 1.3064	* 1.1916	* 1.3557	* 1.2920	* 1.1905	* 2.0384	
13	* 1.5359	* 1.5358	* 1.4992	* 1.6870	* 1.6980	* 1.5950	* 0.7468	
	* 1.2803	* 1.2841	* 1.3548	* 1.2146	* 1.1906	* 1.2557	* 2.4187	
14	* 1.7203	* 1.7050	* 1.6264	* 1.0679	* 0.8979	* 0.7467		
	* 1.1482	* 1.1623	* 1.2418	* 1.7507	* 2.0376	* 2.4191		
15	* 0.8535	* 0.8574	* 0.7859	* 0.5504	* F-SUB-Q			
	* 2.0810	* 2.0808	* 2.2725	* 3.2691	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4335	* 1.4697	* 1.7875	* 1.5137	* 1.7567	* 1.5493	* 1.7456	* 0.8580
	* 1.4774	* 1.4381	* 1.1781	* 1.3639	* 1.1770	* 1.3007	* 1.1592	* 2.1211
9	* 1.4697	* 1.7665	* 1.5819	* 1.7860	* 1.5344	* 1.5495	* 1.7293	* 0.8617
	* 1.4381	* 1.2083	* 1.3119	* 1.1698	* 1.3307	* 1.3030	* 1.1731	* 2.1190
10	* 1.7875	* 1.5794	* 1.3938	* 1.4536	* 1.7502	* 1.5078	* 1.6463	* 0.7900
	* 1.1781	* 1.3130	* 1.5019	* 1.4278	* 1.1993	* 1.3742	* 1.2509	* 2.3112
11	* 1.5137	* 1.7851	* 1.4527	* 1.7606	* 1.5033	* 1.7077	* 1.0739	* 0.5604
	* 1.3639	* 1.1701	* 1.4286	* 1.1968	* 1.3717	* 1.2220	* 1.7754	* 3.3220
12	* 1.7567	* 1.5341	* 1.7497	* 1.5022	* 1.5661	* 1.7235	* 0.9033	
	* 1.1770	* 1.3309	* 1.1996	* 1.3724	* 1.3041	* 1.1961	* 2.0612	
13	* 1.5493	* 1.5499	* 1.5090	* 1.7076	* 1.7234	* 1.6177	* 0.7507	
	* 1.3007	* 1.3029	* 1.3736	* 1.2220	* 1.1962	* 1.2656	* 2.4562	
14	* 1.7456	* 1.7296	* 1.6467	* 1.0739	* 0.9024	* 0.7506		
	* 1.1592	* 1.1729	* 1.2506	* 1.7755	* 2.0605	* 2.4566		
15	* 0.8580	* 0.8622	* 0.7899	* 0.5505	* F-SUB-Q			
	* 2.1211	* 2.1193	* 2.3114	* 3.3148	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4410	* 1.4773	* 1.8088	* 1.5225	* 1.7773	* 1.5621	* 1.7707	* 0.8587
	* 1.5162	* 1.4595	* 1.1967	* 1.3965	* 1.1994	* 1.3282	* 1.1762	* 2.1816
9	* 1.4773	* 1.7861	* 1.5911	* 1.8067	* 1.5426	* 1.5627	* 1.7538	* 0.8634
	* 1.4595	* 1.2206	* 1.3407	* 1.1909	* 1.3634	* 1.3290	* 1.1897	* 2.1757
10	* 1.8088	* 1.5885	* 1.3994	* 1.4609	* 1.7698	* 1.5168	* 1.6670	* 0.7897
	* 1.1967	* 1.3419	* 1.5354	* 1.4562	* 1.2151	* 1.3943	* 1.2647	* 2.3734
11	* 1.5225	* 1.8058	* 1.4600	* 1.7805	* 1.5122	* 1.7287	* 1.0755	* 0.5592
	* 1.3965	* 1.1914	* 1.4571	* 1.2151	* 1.4032	* 1.2416	* 1.8098	* 3.3990
12	* 1.7773	* 1.5423	* 1.7693	* 1.5110	* 1.5828	* 1.7485	* 0.9037	*
	* 1.1994	* 1.3635	* 1.2154	* 1.4040	* 1.3289	* 1.2126	* 2.1171	*
13	* 1.5621	* 1.5632	* 1.5181	* 1.7287	* 1.7484	* 1.6399	* 0.7509	*
	* 1.3282	* 1.3290	* 1.3936	* 1.2417	* 1.2127	* 1.2828	* 2.5212	*
14	* 1.7707	* 1.7541	* 1.6674	* 1.0755	* 0.9027	* 0.7508	*	*
	* 1.1762	* 1.1895	* 1.2645	* 1.8101	* 2.1166	* 2.5217	*	*
15	* 0.8587	* 0.8638	* 0.7896	* 0.5485	* F-SUB-Q			
	* 2.1816	* 2.1761	* 2.3738	* 3.3967	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4290	* 1.4676	* 1.7922	* 1.5114	* 1.7606	* 1.5520	* 1.7582	* 0.8659
	* 1.5699	* 1.5163	* 1.2491	* 1.4570	* 1.2550	* 1.3835	* 1.2256	* 2.2380
9	* 1.4676	* 1.7688	* 1.5781	* 1.7898	* 1.5322	* 1.5531	* 1.7410	* 0.8672
	* 1.5163	* 1.2726	* 1.3978	* 1.2449	* 1.4215	* 1.3828	* 1.2390	* 2.2395
10	* 1.7922	* 1.5754	* 1.3873	* 1.4508	* 1.7528	* 1.5044	* 1.6530	* 0.7987
	* 1.2491	* 1.3991	* 1.6009	* 1.5133	* 1.2662	* 1.4456	* 1.3136	* 2.4214
11	* 1.5114	* 1.7888	* 1.4501	* 1.7634	* 1.5010	* 1.7132	* 1.0876	* 0.5640
	* 1.4570	* 1.2455	* 1.5140	* 1.2604	* 1.4501	* 1.2854	* 1.8379	* 3.4662
12	* 1.7606	* 1.5319	* 1.7522	* 1.4998	* 1.5748	* 1.7358	* 0.9118	*
	* 1.2550	* 1.4217	* 1.2666	* 1.4509	* 1.3855	* 1.2661	* 2.1629	*
13	* 1.5520	* 1.5535	* 1.5057	* 1.7132	* 1.7356	* 1.6284	* 0.7622	*
	* 1.3835	* 1.3827	* 1.4448	* 1.2855	* 1.2662	* 1.3389	* 2.5726	*
14	* 1.7582	* 1.7413	* 1.6533	* 1.0876	* 0.9108	* 0.7621	*	*
	* 1.2256	* 1.2388	* 1.3134	* 1.8382	* 2.1625	* 2.5731	*	*
15	* 0.8659	* 0.8676	* 0.7985	* 0.5550	* F-SUB-Q			
	* 2.2380	* 2.2399	* 2.4219	* 3.4527	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4422	* 1.4801	* 1.8259	* 1.5261	* 1.7933	* 1.5721	* 1.7965	* 0.8606
	* 1.6166	* 1.5653	* 1.2765	* 1.5034	* 1.2842	* 1.4209	* 1.2475	* 2.3401
9	* 1.4801	* 1.8009	* 1.5942	* 1.8228	* 1.5456	* 1.5737	* 1.7786	* 0.8652
	* 1.5653	* 1.3016	* 1.4399	* 1.2735	* 1.4675	* 1.4187	* 1.2606	* 2.3317
10	* 1.8259	* 1.5914	* 1.3979	* 1.4629	* 1.7847	* 1.5202	* 1.6862	* 0.7919
	* 1.2765	* 1.4414	* 1.6516	* 1.5589	* 1.2910	* 1.4834	* 1.3338	* 2.5328
11	* 1.5261	* 1.8218	* 1.4622	* 1.7957	* 1.5160	* 1.7467	* 1.0810	* 0.5580
	* 1.5034	* 1.2741	* 1.5596	* 1.2840	* 1.4870	* 1.3051	* 1.9150	* 3.6212
12	* 1.7933	* 1.5452	* 1.7841	* 1.5147	* 1.5997	* 1.7737	* 0.9056	*
	* 1.2842	* 1.4678	* 1.2915	* 1.4879	* 1.4076	* 1.2773	* 2.2463	*
13	* 1.5721	* 1.5741	* 1.5216	* 1.7465	* 1.7735	* 1.6629	* 0.7528	*
	* 1.4209	* 1.4186	* 1.4825	* 1.3052	* 1.2775	* 1.3538	* 2.6840	*
14	* 1.7965	* 1.7789	* 1.6864	* 1.0810	* 0.9045	* 0.7526	*	*
	* 1.2475	* 1.2604	* 1.3337	* 1.9154	* 2.2460	* 2.6846	*	*
15	* 0.8606	* 0.8657	* 0.7917	* 0.5461	* F-SUB-Q			
	* 2.3401	* 2.3320	* 2.5335	* 3.6272	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4437	* 1.4824	* 1.8355	* 1.5288	* 1.8023	* 1.5777	* 1.8098	* 0.8621
	* 1.6433	* 1.5856	* 1.2999	* 1.5357	* 1.3228	* 1.4792	* 1.2933	* 2.4377
9	* 1.4824	* 1.8095	* 1.5966	* 1.8320	* 1.5478	* 1.5798	* 1.7915	* 0.8666
	* 1.5856	* 1.3203	* 1.4703	* 1.3024	* 1.5125	* 1.4753	* 1.3066	* 2.4285
10	* 1.8355	* 1.5937	* 1.3979	* 1.4652	* 1.7933	* 1.5228	* 1.6964	* 0.7934
	* 1.2999	* 1.4718	* 1.6839	* 1.6081	* 1.3367	* 1.5436	* 1.3808	* 2.6340
11	* 1.5288	* 1.8309	* 1.4644	* 1.8043	* 1.5188	* 1.7568	* 1.0844	* 0.5579
	* 1.5357	* 1.3032	* 1.6091	* 1.3343	* 1.5476	* 1.3526	* 1.9874	* 3.7625
12	* 1.8023	* 1.5475	* 1.7927	* 1.5175	* 1.6088	* 1.7870	* 0.9072	*
	* 1.3228	* 1.5128	* 1.3371	* 1.5486	* 1.4551	* 1.3186	* 2.3313	*
13	* 1.5777	* 1.5803	* 1.5243	* 1.7567	* 1.7868	* 1.6754	* 0.7542	*
	* 1.4792	* 1.4752	* 1.5427	* 1.3527	* 1.3187	* 1.3956	* 2.7799	*
14	* 1.8098	* 1.7918	* 1.6967	* 1.0843	* 0.9061	* 0.7540	*	*
	* 1.2933	* 1.3063	* 1.3807	* 1.9879	* 2.3311	* 2.7806	*	*
15	* 0.8621	* 0.8671	* 0.7931	* 0.5453	* F-SUB-Q			
	* 2.4377	* 2.4288	* 2.6349	* 3.7732	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4348	* 1.4753	* 1.8230	* 1.5206	* 1.7897	* 1.5711	* 1.8019	* 0.8684 *
	* 1.6092	* 1.5518	* 1.2748	* 1.5036	* 1.2973	* 1.4634	* 1.2906	* 2.4024 *
9	* 1.4753	* 1.7967	* 1.5868	* 1.8194	* 1.5402	* 1.5741	* 1.7833	* 0.8702 *
	* 1.5518	* 1.2954	* 1.4410	* 1.2773	* 1.4802	* 1.4611	* 1.3049	* 2.4038 *
10	* 1.8230	* 1.5838	* 1.3888	* 1.4584	* 1.7811	* 1.5138	* 1.6870	* 0.8013 *
	* 1.2748	* 1.4426	* 1.6506	* 1.5740	* 1.3115	* 1.5273	* 1.3832	* 2.5966 *
11	* 1.5206	* 1.8182	* 1.4576	* 1.7917	* 1.5112	* 1.7461	* 1.0951	* 0.5617 *
	* 1.5036	* 1.2781	* 1.5751	* 1.3119	* 1.5301	* 1.3510	* 1.9509	* 3.7339 *
12	* 1.7897	* 1.5398	* 1.7804	* 1.5099	* 1.6046	* 1.7790	* 0.9146	*
	* 1.2973	* 1.4804	* 1.3120	* 1.5311	* 1.4802	* 1.3398	* 2.3200	*
13	* 1.5711	* 1.5746	* 1.5153	* 1.7459	* 1.7788	* 1.6691	* 0.7643	*
	* 1.4634	* 1.4610	* 1.5264	* 1.3512	* 1.3400	* 1.4305	* 2.7883	*
14	* 1.8019	* 1.7836	* 1.6873	* 1.0949	* 0.9134	* 0.7642	*	
	* 1.2906	* 1.3046	* 1.3830	* 1.9515	* 2.3199	* 2.7891	*	
15	* 0.8684	* 0.8706	* 0.8010	* 0.5507	* F-SUB-Q			
	* 2.4024	* 2.4042	* 2.5975	* 3.7331	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4482	* 1.4882	* 1.8561	* 1.5356	* 1.8215	* 1.5916	* 1.8407	* 0.8631
	* 1.5628	* 1.5060	* 1.2256	* 1.4575	* 1.2475	* 1.4137	* 1.2360	* 2.3624
9	* 1.4882	* 1.8283	* 1.6028	* 1.8519	* 1.5537	* 1.5954	* 1.8215	* 0.8682
	* 1.5060	* 1.2460	* 1.3965	* 1.2282	* 1.4362	* 1.4105	* 1.2497	* 2.3544
10	* 1.8561	* 1.5996	* 1.3996	* 1.4710	* 1.8130	* 1.5299	* 1.7215	* 0.7946
	* 1.2256	* 1.3982	* 1.6031	* 1.5270	* 1.2601	* 1.4768	* 1.3251	* 2.5573
11	* 1.5356	* 1.8506	* 1.4702	* 1.8236	* 1.5262	* 1.7797	* 1.0891	* 0.5558
	* 1.4575	* 1.2290	* 1.5280	* 1.2595	* 1.4802	* 1.2942	* 1.9162	* 3.6784
12	* 1.8215	* 1.5533	* 1.8122	* 1.5248	* 1.6307	* 1.8176	* 0.9085	*
	* 1.2475	* 1.4364	* 1.2606	* 1.4813	* 1.4214	* 1.2795	* 2.2780	*
13	* 1.5916	* 1.5959	* 1.5315	* 1.7796	* 1.8174	* 1.7056	* 0.7558	*
	* 1.4137	* 1.4103	* 1.4758	* 1.2943	* 1.2797	* 1.3659	* 2.7479	*
14	* 1.8407	* 1.8218	* 1.7216	* 1.0889	* 0.9073	* 0.7557	*	
	* 1.2360	* 1.2495	* 1.3250	* 1.9168	* 2.2780	* 2.7486	*	
15	* 0.8631	* 0.8687	* 0.7943	* 0.5420	* F-SUB-Q			
	* 2.3624	* 2.3547	* 2.5584	* 3.6970	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4530	* 1.4940	* 1.8714	* 1.5421	* 1.8360	* 1.6019	* 1.8611	* 0.8630
	* 1.5062	* 1.4492	* 1.1755	* 1.4021	* 1.1967	* 1.3587	* 1.1834	* 2.2805
9	* 1.4940	* 1.8427	* 1.6092	* 1.8668	* 1.5597	* 1.6067	* 1.8414	* 0.8689
	* 1.4492	* 1.1954	* 1.3442	* 1.1781	* 1.3824	* 1.3549	* 1.1964	* 2.2704
10	* 1.8714	* 1.6059	* 1.4029	* 1.4769	* 1.8279	* 1.5367	* 1.7389	* 0.7945
	* 1.1755	* 1.3458	* 1.5440	* 1.4701	* 1.2094	* 1.4221	* 1.2689	* 2.4677
11	* 1.5421	* 1.8655	* 1.4760	* 1.8382	* 1.5331	* 1.7962	* 1.0905	* 0.5539
	* 1.4021	* 1.1789	* 1.4711	* 1.2097	* 1.4262	* 1.2419	* 1.8480	* 3.5584
12	* 1.8360	* 1.5593	* 1.8272	* 1.5316	* 1.6456	* 1.8381	* 0.9084	*
	* 1.1967	* 1.3826	* 1.2098	* 1.4273	* 1.3683	* 1.2276	* 2.1992	*
13	* 1.6019	* 1.6072	* 1.5384	* 1.7961	* 1.8378	* 1.7259	* 0.7559	*
	* 1.3587	* 1.3547	* 1.4211	* 1.2420	* 1.2278	* 1.3090	* 2.6516	*
14	* 1.8611	* 1.8417	* 1.7391	* 1.0903	* 0.9072	* 0.7557	*	*
	* 1.1834	* 1.1963	* 1.2689	* 1.8487	* 2.1993	* 2.6523	*	*
15	* 0.8630	* 0.8695	* 0.7941	* 0.5395	* F-SUB-Q			
	* 2.2805	* 2.2707	* 2.4689	* 3.5812	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4539	* 1.4953	* 1.8763	* 1.5433	* 1.8406	* 1.6065	* 1.8702	* 0.8655
	* 1.4597	* 1.4036	* 1.1360	* 1.3581	* 1.1567	* 1.3129	* 1.1405	* 2.2036
9	* 1.4953	* 1.8475	* 1.6102	* 1.8717	* 1.5611	* 1.6121	* 1.8502	* 0.8708
	* 1.4036	* 1.1554	* 1.3022	* 1.1385	* 1.3386	* 1.3081	* 1.1531	* 2.1953
10	* 1.8763	* 1.6068	* 1.4027	* 1.4786	* 1.8333	* 1.5383	* 1.7462	* 0.7972
	* 1.1360	* 1.3039	* 1.4974	* 1.4229	* 1.1678	* 1.3751	* 1.2232	* 2.3822
11	* 1.5433	* 1.8704	* 1.4777	* 1.8433	* 1.5352	* 1.8028	* 1.0964	* 0.5548
	* 1.3581	* 1.1393	* 1.4239	* 1.1674	* 1.3779	* 1.1966	* 1.7789	* 3.4397
12	* 1.8406	* 1.5606	* 1.8325	* 1.5337	* 1.6532	* 1.8473	* 0.9117	*
	* 1.1567	* 1.3388	* 1.1682	* 1.3789	* 1.3160	* 1.1800	* 2.1186	*
13	* 1.6065	* 1.6127	* 1.5400	* 1.8026	* 1.8470	* 1.7357	* 0.7590	*
	* 1.3129	* 1.3079	* 1.3741	* 1.1968	* 1.1802	* 1.2567	* 2.5510	*
14	* 1.8702	* 1.8505	* 1.7463	* 1.0962	* 0.9104	* 0.7588	*	*
	* 1.1405	* 1.1530	* 1.2231	* 1.7795	* 2.1188	* 2.5517	*	*
15	* 0.8655	* 0.8713	* 0.7968	* 0.5401	* F-SUB-Q			
	* 2.2036	* 2.1956	* 2.3834	* 3.4635	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4472	* 1.4898	* 1.8648	* 1.5365	* 1.8290	* 1.6024	* 1.8618	* 0.8713
	* 1.5369	* 1.4806	* 1.2011	* 1.4340	* 1.2231	* 1.3827	* 1.2029	* 2.2999
9	* 1.4898	* 1.8362	* 1.6020	* 1.8603	* 1.5551	* 1.6081	* 1.8416	* 0.8738
	* 1.4806	* 1.2213	* 1.3758	* 1.2036	* 1.4122	* 1.3774	* 1.2162	* 2.2982
10	* 1.8648	* 1.5986	* 1.3965	* 1.4738	* 1.8230	* 1.5314	* 1.7374	* 0.8045
	* 1.2011	* 1.3776	* 1.5815	* 1.5000	* 1.2332	* 1.4495	* 1.2900	* 2.4796
11	* 1.5365	* 1.8589	* 1.4729	* 1.8324	* 1.5304	* 1.7936	* 1.1071	* 0.5583
	* 1.4340	* 1.2044	* 1.5012	* 1.2319	* 1.4497	* 1.2607	* 1.8482	* 3.5890
12	* 1.8290	* 1.5547	* 1.8222	* 1.5288	* 1.6501	* 1.8394	* 0.9191	*
	* 1.2231	* 1.4125	* 1.2337	* 1.4509	* 1.3794	* 1.2401	* 2.2020	*
13	* 1.6024	* 1.6086	* 1.5332	* 1.7934	* 1.8391	* 1.7302	* 0.7684	*
	* 1.3827	* 1.3772	* 1.4484	* 1.2608	* 1.2403	* 1.3183	* 2.6378	*
14	* 1.8618	* 1.8419	* 1.7375	* 1.1068	* 0.9178	* 0.7682	*	*
	* 1.2029	* 1.2160	* 1.2900	* 1.8490	* 2.2023	* 2.6386	*	*
15	* 0.8713	* 0.8743	* 0.8040	* 0.5453	* F-SUB-Q			
	* 2.2999	* 2.2985	* 2.4809	* 3.6018	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4563	* 1.4985	* 1.8939	* 1.5474	* 1.8572	* 1.6191	* 1.8967	* 0.8611
	* 1.4813	* 1.4273	* 1.1472	* 1.3824	* 1.1700	* 1.3314	* 1.1486	* 2.2678
9	* 1.4985	* 1.8647	* 1.6148	* 1.8894	* 1.5649	* 1.6260	* 1.8760	* 0.8674
	* 1.4273	* 1.1657	* 1.3247	* 1.1501	* 1.3634	* 1.3252	* 1.1614	* 2.2561
10	* 1.8939	* 1.6111	* 1.4032	* 1.4832	* 1.8526	* 1.5451	* 1.7691	* 0.7933
	* 1.1472	* 1.3266	* 1.5280	* 1.4476	* 1.1784	* 1.3957	* 1.2321	* 2.4505
11	* 1.5474	* 1.8879	* 1.4822	* 1.8618	* 1.5422	* 1.8248	* 1.0960	* 0.5494
	* 1.3824	* 1.1509	* 1.4485	* 1.1761	* 1.3963	* 1.2024	* 1.8149	* 3.5577
12	* 1.8572	* 1.5644	* 1.8517	* 1.5406	* 1.6730	* 1.8744	* 0.9080	*
	* 1.1700	* 1.3637	* 1.1789	* 1.3975	* 1.3167	* 1.1793	* 2.1654	*
13	* 1.6191	* 1.6266	* 1.5469	* 1.8246	* 1.8740	* 1.7639	* 0.7557	*
	* 1.3314	* 1.3251	* 1.3945	* 1.2026	* 1.1796	* 1.2535	* 2.6060	*
14	* 1.8967	* 1.8764	* 1.7692	* 1.0957	* 0.9067	* 0.7555	*	*
	* 1.1486	* 1.1612	* 1.2320	* 1.8157	* 2.1658	* 2.6067	*	*
15	* 0.8611	* 0.8680	* 0.7928	* 0.5337	* F-SUB-Q			
	* 2.2678	* 2.2563	* 2.4519	* 3.5899	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4465	* 1.4882	* 1.8835	* 1.5370	* 1.8472	* 1.6136	* 1.8912	* 0.8533
	* 1.4386	* 1.3896	* 1.1153	* 1.3467	* 1.1378	* 1.2926	* 1.1139	* 2.2157
9	* 1.4882	* 1.8555	* 1.6047	* 1.8796	* 1.5548	* 1.6207	* 1.8705	* 0.8600
	* 1.3896	* 1.1321	* 1.2895	* 1.1178	* 1.3277	* 1.2863	* 1.1263	* 2.2032
10	* 1.8835	* 1.6010	* 1.3935	* 1.4744	* 1.8451	* 1.5374	* 1.7640	* 0.7863
	* 1.1153	* 1.2915	* 1.4889	* 1.4076	* 1.1437	* 1.3552	* 1.1944	* 2.3932
11	* 1.5370	* 1.8781	* 1.4734	* 1.8537	* 1.5347	* 1.8188	* 1.0900	* 0.5436
	* 1.3467	* 1.1187	* 1.4085	* 1.1403	* 1.3546	* 1.1639	* 1.7635	* 3.4797
12	* 1.8472	* 1.5543	* 1.8442	* 1.5330	* 1.6691	* 1.8690	* 0.9007	*
	* 1.1378	* 1.3281	* 1.1442	* 1.3558	* 1.2681	* 1.1384	* 2.1068	*
13	* 1.6136	* 1.6213	* 1.5394	* 1.8186	* 1.8686	* 1.7607	* 0.7492	*
	* 1.2926	* 1.2861	* 1.3540	* 1.1641	* 1.1386	* 1.2083	* 2.5346	*
14	* 1.8912	* 1.8709	* 1.7641	* 1.0897	* 0.8993	* 0.7490	*	*
	* 1.1139	* 1.1261	* 1.1943	* 1.7642	* 2.1072	* 2.5354	*	*
15	* 0.8533	* 0.8605	* 0.7858	* 0.5278	* F-SUB-Q			
	* 2.2157	* 2.2033	* 2.3946	* 3.5132	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4117	* 1.4500	* 1.8164	* 1.4961	* 1.7818	* 1.5754	* 1.8290	* 0.8445
	* 1.4317	* 1.3865	* 1.1240	* 1.3454	* 1.1467	* 1.2874	* 1.1193	* 2.1788
9	* 1.4500	* 1.7933	* 1.5627	* 1.8150	* 1.5155	* 1.5818	* 1.8090	* 0.8474
	* 1.3865	* 1.1381	* 1.2877	* 1.1251	* 1.3249	* 1.2814	* 1.1317	* 2.1756
10	* 1.8164	* 1.5590	* 1.3611	* 1.4386	* 1.7851	* 1.4997	* 1.7070	* 0.7803
	* 1.1240	* 1.2897	* 1.4827	* 1.4019	* 1.1483	* 1.3495	* 1.1989	* 2.3462
11	* 1.4961	* 1.8135	* 1.4376	* 1.7930	* 1.4989	* 1.7602	* 1.0850	* 0.5393
	* 1.3454	* 1.1260	* 1.4028	* 1.1443	* 1.3465	* 1.1666	* 1.7212	* 3.4132
12	* 1.7818	* 1.5149	* 1.7842	* 1.4972	* 1.6267	* 1.8068	* 0.8933	*
	* 1.1467	* 1.3252	* 1.1489	* 1.3477	* 1.2598	* 1.1404	* 2.0617	*
13	* 1.5754	* 1.5823	* 1.5016	* 1.7600	* 1.8064	* 1.7052	* 0.7469	*
	* 1.2874	* 1.2812	* 1.3483	* 1.1668	* 1.1406	* 1.2078	* 2.4658	*
14	* 1.8290	* 1.8093	* 1.7071	* 1.0847	* 0.8920	* 0.7467	*	*
	* 1.1193	* 1.1315	* 1.1989	* 1.7220	* 2.0621	* 2.4667	*	*
15	* 0.8445	* 0.8479	* 0.7799	* 0.5265	* F-SUB-Q			
	* 2.1788	* 2.1758	* 2.3476	* 3.4271	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3719	* 1.4052	* 1.7578	* 1.4519	* 1.7244	* 1.5347	* 1.7751	* 0.8052 *
	* 1.4408	* 1.3984	* 1.1348	* 1.3554	* 1.1578	* 1.2913	* 1.1263	* 2.2350 *
9	* 1.4052	* 1.7393	* 1.5206	* 1.7582	* 1.4700	* 1.5408	* 1.7555	* 0.8115 *
	* 1.3984	* 1.1462	* 1.2934	* 1.1348	* 1.3352	* 1.2853	* 1.1389	* 2.2220 *
10	* 1.7578	* 1.5170	* 1.3231	* 1.3956	* 1.7325	* 1.4614	* 1.6577	* 0.7423 *
	* 1.1348	* 1.2954	* 1.4918	* 1.4118	* 1.1550	* 1.3524	* 1.2056	* 2.4123 *
11	* 1.4519	* 1.7567	* 1.3946	* 1.7397	* 1.4586	* 1.7098	* 1.0390	* 0.5138 *
	* 1.3554	* 1.1357	* 1.4127	* 1.1510	* 1.3508	* 1.1717	* 1.7558	* 3.5047 *
12	* 1.7244	* 1.4695	* 1.7316	* 1.4569	* 1.5840	* 1.7521	* 0.8520 *	
	* 1.1578	* 1.3356	* 1.1556	* 1.3521	* 1.2609	* 1.1460	* 2.1106 *	
13	* 1.5347	* 1.5414	* 1.4633	* 1.7096	* 1.7517	* 1.6560	* 0.7066 *	
	* 1.2913	* 1.2851	* 1.3512	* 1.1719	* 1.1463	* 1.2115	* 2.5436 *	
14	* 1.7751	* 1.7558	* 1.6577	* 1.0387	* 0.8507	* 0.7064 *		
	* 1.1263	* 1.1387	* 1.2056	* 1.7566	* 2.1111	* 2.5444 *		
15	* 0.8052	* 0.8121	* 0.7418	* 0.4991	* F-SUB-Q			
	* 2.2350	* 2.2221	* 2.4139	* 3.5368	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2675	* 1.2953	* 1.5916	* 1.3403	* 1.5606	* 1.4143	* 1.6047	* 0.7435 *
	* 1.5317	* 1.4900	* 1.2305	* 1.4420	* 1.2562	* 1.3759	* 1.2227	* 2.3789 *
9	* 1.2953	* 1.5757	* 1.4073	* 1.5928	* 1.3564	* 1.4198	* 1.5871	* 0.7506 *
	* 1.4900	* 1.2422	* 1.3723	* 1.2299	* 1.4212	* 1.3696	* 1.2363	* 2.3611 *
10	* 1.5916	* 1.4040	* 1.2239	* 1.2865	* 1.5691	* 1.3490	* 1.5031	* 0.6848 *
	* 1.2305	* 1.3744	* 1.5841	* 1.5040	* 1.2513	* 1.4379	* 1.3054	* 2.5702 *
11	* 1.3403	* 1.5915	* 1.2855	* 1.5759	* 1.3479	* 1.5479	* 0.9605	* 0.4742 *
	* 1.4420	* 1.2309	* 1.5050	* 1.2467	* 1.4349	* 1.2695	* 1.8649	* 3.7345 *
12	* 1.5606	* 1.3559	* 1.5683	* 1.3464	* 1.4571	* 1.5837	* 0.7870 *	
	* 1.2562	* 1.4216	* 1.2520	* 1.4362	* 1.3433	* 1.2426	* 2.2432 *	
13	* 1.4143	* 1.4203	* 1.3508	* 1.5476	* 1.5834	* 1.4981	* 0.6494 *	
	* 1.3759	* 1.3694	* 1.4366	* 1.2697	* 1.2429	* 1.3125	* 2.7168 *	
14	* 1.6047	* 1.5873	* 1.5033	* 0.9602	* 0.7858	* 0.6492 *		
	* 1.2227	* 1.2361	* 1.3053	* 1.8658	* 2.2438	* 2.7177 *		
15	* 0.7435	* 0.7512	* 0.6843	* 0.4603	* F-SUB-Q			
	* 2.3789	* 2.3612	* 2.5720	* 3.7713	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0300	* 1.0572	* 1.3275	* 1.0927	* 1.3013	* 1.1358	* 1.3230	* 0.6161
	* 1.8591	* 1.8005	* 1.4549	* 1.7440	* 1.4859	* 1.6892	* 1.4625	* 2.8342
9	* 1.0572	* 1.3005	* 1.1547	* 1.3179	* 1.0992	* 1.1454	* 1.3090	* 0.6215
	* 1.8005	* 1.4849	* 1.6492	* 1.4662	* 1.7294	* 1.6737	* 1.4781	* 2.8154
10	* 1.3275	* 1.1523	* 0.9954	* 1.0450	* 1.2886	* 1.0985	* 1.2195	* 0.5605
	* 1.4549	* 1.6513	* 1.9205	* 1.8252	* 1.5027	* 1.7405	* 1.5862	* 3.1010
11	* 1.0927	* 1.3169	* 1.0443	* 1.3024	* 1.0945	* 1.2636	* 0.7888	* 0.3890
	* 1.7440	* 1.4673	* 1.8263	* 1.4873	* 1.7414	* 1.5334	* 2.2403	* 4.4986
12	* 1.3013	* 1.0988	* 1.2881	* 1.0935	* 1.1837	* 1.3089	* 0.6531	*
	* 1.4859	* 1.7298	* 1.5034	* 1.7426	* 1.6290	* 1.4816	* 2.6669	*
13	* 1.1358	* 1.1458	* 1.0997	* 1.2634	* 1.3087	* 1.1809	* 0.5258	*
	* 1.6892	* 1.6735	* 1.7393	* 1.5336	* 1.4819	* 1.6423	* 3.3118	*
14	* 1.3230	* 1.3092	* 1.2195	* 0.7885	* 0.6521	* 0.5256	*	*
	* 1.4625	* 1.4779	* 1.5864	* 2.2414	* 2.6674	* 3.3129	*	*
15	* 0.6161	* 0.6219	* 0.5600	* 0.3775	* F-SUB-Q			
	* 2.8342	* 2.8157	* 3.1034	* 4.5439	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4286	* 0.4606	* 0.5582	* 0.4749	* 0.5451	* 0.4578	* 0.5002	* 0.2617
	* 4.4203	* 4.0909	* 3.4254	* 3.9718	* 3.5123	* 4.1448	* 3.8298	* 6.6183
9	* 0.4606	* 0.5431	* 0.4787	* 0.5512	* 0.4607	* 0.4596	* 0.4944	* 0.2607
	* 4.0909	* 3.5203	* 3.9347	* 3.4714	* 4.0834	* 4.1259	* 3.8747	* 6.6583
10	* 0.5582	* 0.4779	* 0.4349	* 0.4538	* 0.5385	* 0.4487	* 0.4573	* 0.2380
	* 3.4254	* 3.9377	* 4.3509	* 4.1580	* 3.5593	* 4.2163	* 4.1893	* 7.2450
11	* 0.4749	* 0.5508	* 0.4536	* 0.5345	* 0.4593	* 0.5094	* 0.3371	* 0.1662
	* 3.9718	* 3.4738	* 4.1611	* 3.5880	* 4.1052	* 3.7656	* 5.1932	* 10.4523
12	* 0.5451	* 0.4606	* 0.5383	* 0.4590	* 0.4676	* 0.4958	* 0.2779	*
	* 3.5123	* 4.0844	* 3.5605	* 4.1072	* 4.0776	* 3.8720	* 6.2128	*
13	* 0.4578	* 0.4597	* 0.4490	* 0.5093	* 0.4957	* 0.4393	* 0.2213	*
	* 4.1448	* 4.1259	* 4.2150	* 3.7664	* 3.8727	* 4.3707	* 7.8020	*
14	* 0.5002	* 0.4945	* 0.4573	* 0.3369	* 0.2776	* 0.2212	*	*
	* 3.8298	* 3.8744	* 4.1900	* 5.1964	* 6.2121	* 7.8052	*	*
15	* 0.2617	* 0.2608	* 0.2378	* 0.1627	* F-SUB-Q			
	* 6.6183	* 6.6581	* 7.2509	* 10.4605	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4628	* 0.5262	* 0.6145	* 0.5439	* 0.6063	* 0.5248	* 0.5425	* 0.3177
	* 3.4362	* 3.5064	* 3.0610	* 3.2946	* 3.0361	* 3.3645	* 3.3533	* 5.0250
9	* 0.5262	* 0.6010	* 0.5540	* 0.6117	* 0.5324	* 0.5205	* 0.5380	* 0.3126
	* 3.5064	* 3.2036	* 3.2607	* 3.0451	* 3.3311	* 3.4058	* 3.3965	* 5.1949
10	* 0.6145	* 0.5536	* 0.5145	* 0.5251	* 0.5972	* 0.5129	* 0.5095	* 0.2858
	* 3.0610	* 3.2605	* 3.5514	* 3.4655	* 3.1775	* 3.5598	* 3.6701	* 5.6611
11	* 0.5439	* 0.6115	* 0.5249	* 0.5872	* 0.5238	* 0.5547	* 0.3832	* 0.2131
	* 3.2946	* 3.0457	* 3.4668	* 3.2030	* 3.4308	* 3.3597	* 4.4831	* 7.9250
12	* 0.6063	* 0.5323	* 0.5971	* 0.5236	* 0.4661	* 0.5026	* 0.3266	*
	* 3.0361	* 3.3313	* 3.1780	* 3.4313	* 3.3757	* 3.4111	* 4.9468	*
13	* 0.5248	* 0.5205	* 0.5130	* 0.5547	* 0.5026	* 0.4547	* 0.2596	*
	* 3.3645	* 3.4065	* 3.5602	* 3.3598	* 3.4108	* 3.7328	* 6.1165	*
14	* 0.5425	* 0.5380	* 0.5096	* 0.3832	* 0.3265	* 0.2595	*	*
	* 3.3533	* 3.3961	* 3.6699	* 4.4836	* 4.9371	* 6.1173	*	*
15	* 0.3177	* 0.3128	* 0.2858	* 0.2102	* F-SUB-Q			
	* 5.0250	* 5.1955	* 5.6621	* 7.7777	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0179	* 1.0584	* 1.2320	* 1.0899	* 1.2187	* 1.1087	* 1.2028	* 0.6723
	* 1.7647	* 1.7794	* 1.5604	* 1.6810	* 1.5452	* 1.6328	* 1.5490	* 2.4340
9	* 1.0584	* 1.2118	* 1.1514	* 1.2279	* 1.0996	* 1.1024	* 1.1942	* 0.6697
	* 1.7794	* 1.6185	* 1.6040	* 1.5501	* 1.6517	* 1.6437	* 1.5665	* 2.4854
10	* 1.2320	* 1.1503	* 1.0251	* 1.0532	* 1.2059	* 1.0892	* 1.1383	* 0.6081
	* 1.5604	* 1.6043	* 1.8240	* 1.7679	* 1.6091	* 1.7129	* 1.6795	* 2.7250
11	* 1.0899	* 1.2276	* 1.0529	* 1.2128	* 1.0867	* 1.1689	* 0.7999	* 0.4552
	* 1.6810	* 1.5503	* 1.7686	* 1.5783	* 1.6908	* 1.6234	* 2.1794	* 3.7961
12	* 1.2187	* 1.0995	* 1.2058	* 1.0862	* 1.0637	* 1.1629	* 0.6929	*
	* 1.5452	* 1.6518	* 1.6093	* 1.6912	* 1.6157	* 1.5641	* 2.3829	*
13	* 1.1087	* 1.1026	* 1.0896	* 1.1689	* 1.1629	* 1.0573	* 0.5645	*
	* 1.6328	* 1.6439	* 1.7129	* 1.6235	* 1.5640	* 1.7087	* 2.8820	*
14	* 1.2028	* 1.1944	* 1.1384	* 0.8000	* 0.6925	* 0.5644	*	*
	* 1.5490	* 1.5663	* 1.6794	* 2.1795	* 2.3789	* 2.8823	*	*
15	* 0.6723	* 0.6699	* 0.6081	* 0.4491	* F-SUB-Q			
	* 2.4340	* 2.4862	* 2.7252	* 3.7245	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2322	* 1.2578	* 1.4658	* 1.2934	* 1.4494	* 1.3205	* 1.4336	* 0.7963
	* 1.5457	* 1.5246	* 1.3304	* 1.4370	* 1.3171	* 1.3847	* 1.3157	* 2.0871
9	* 1.2578	* 1.4455	* 1.3559	* 1.4644	* 1.3144	* 1.3175	* 1.4227	* 0.7967
	* 1.5246	* 1.3780	* 1.3817	* 1.3172	* 1.4014	* 1.3933	* 1.3312	* 2.1175
10	* 1.4658	* 1.3545	* 1.2097	* 1.2509	* 1.4387	* 1.2956	* 1.3631	* 0.7370
	* 1.3304	* 1.3821	* 1.5687	* 1.5108	* 1.3675	* 1.4593	* 1.4216	* 2.2789
11	* 1.2934	* 1.4639	* 1.2504	* 1.4479	* 1.2914	* 1.4044	* 0.9661	* 0.5469
	* 1.4370	* 1.3174	* 1.5113	* 1.3459	* 1.4453	* 1.3763	* 1.8286	* 3.2023
12	* 1.4494	* 1.3142	* 1.4385	* 1.2906	* 1.3065	* 1.4069	* 0.8313	*
	* 1.3171	* 1.4015	* 1.3677	* 1.4457	* 1.3866	* 1.3371	* 2.0241	*
13	* 1.3205	* 1.3177	* 1.2962	* 1.4044	* 1.4069	* 1.3106	* 0.6951	*
	* 1.3847	* 1.3934	* 1.4591	* 1.3763	* 1.3370	* 1.4188	* 2.3897	*
14	* 1.4336	* 1.4229	* 1.3633	* 0.9663	* 0.8308	* 0.6951	*	*
	* 1.3157	* 1.3310	* 1.4215	* 1.8286	* 2.0209	* 2.3900	*	*
15	* 0.7963	* 0.7970	* 0.7370	* 0.5420	* F-SUB-Q			
	* 2.0871	* 2.1181	* 2.2789	* 3.1276	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3344	* 1.3644	* 1.6364	* 1.4062	* 1.6196	* 1.4441	* 1.6112	* 0.8487
	* 1.4580	* 1.4287	* 1.2064	* 1.3381	* 1.1924	* 1.2790	* 1.1828	* 1.9800
9	* 1.3644	* 1.6090	* 1.4700	* 1.6319	* 1.4280	* 1.4411	* 1.5986	* 0.8530
	* 1.4287	* 1.2575	* 1.2902	* 1.1953	* 1.3054	* 1.2873	* 1.1969	* 1.9999
10	* 1.6364	* 1.4683	* 1.3048	* 1.3571	* 1.6037	* 1.4127	* 1.5269	* 0.7835
	* 1.2064	* 1.2908	* 1.4727	* 1.4095	* 1.2413	* 1.3575	* 1.2809	* 2.1673
11	* 1.4062	* 1.6314	* 1.3566	* 1.6160	* 1.4053	* 1.5730	* 1.0311	* 0.5782
	* 1.3381	* 1.1955	* 1.4101	* 1.2264	* 1.3484	* 1.2474	* 1.7379	* 3.0614
12	* 1.6196	* 1.4278	* 1.6034	* 1.4045	* 1.4463	* 1.5922	* 0.8882	*
	* 1.1924	* 1.3054	* 1.2415	* 1.3488	* 1.2805	* 1.2059	* 1.9285	*
13	* 1.4441	* 1.4414	* 1.4135	* 1.5730	* 1.5922	* 1.4777	* 0.7423	*
	* 1.2790	* 1.2873	* 1.3572	* 1.2475	* 1.2059	* 1.2844	* 2.2817	*
14	* 1.6112	* 1.5988	* 1.5271	* 1.0313	* 0.8876	* 0.7423	*	*
	* 1.1828	* 1.1967	* 1.2807	* 1.7379	* 1.9256	* 2.2820	*	*
15	* 0.8487	* 0.8533	* 0.7835	* 0.5716	* F-SUB-Q			
	* 1.9800	* 2.0005	* 2.1673	* 2.9978	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3613	* 1.3953	* 1.6957	* 1.4411	* 1.6787	* 1.4836	* 1.6775	* 0.8735
	* 1.4565	* 1.4186	* 1.1795	* 1.3233	* 1.1653	* 1.2595	* 1.1490	* 1.9483
9	* 1.3953	* 1.6637	* 1.5029	* 1.6897	* 1.4628	* 1.4821	* 1.6639	* 0.8764
	* 1.4186	* 1.2339	* 1.2786	* 1.1690	* 1.2910	* 1.2663	* 1.1628	* 1.9702
10	* 1.6957	* 1.5010	* 1.3293	* 1.3884	* 1.6599	* 1.4472	* 1.5866	* 0.8067
	* 1.1795	* 1.2792	* 1.4650	* 1.3955	* 1.2140	* 1.3463	* 1.2459	* 2.1300
11	* 1.4411	* 1.6891	* 1.3879	* 1.6735	* 1.4399	* 1.6322	* 1.0595	* 0.5909
	* 1.3233	* 1.1692	* 1.3961	* 1.2051	* 1.3382	* 1.2210	* 1.7190	* 3.0290
12	* 1.6787	* 1.4626	* 1.6596	* 1.4391	* 1.4963	* 1.6618	* 0.9137	*
	* 1.1653	* 1.2910	* 1.2142	* 1.3387	* 1.2621	* 1.1770	* 1.9098	*
13	* 1.4836	* 1.4824	* 1.4482	* 1.6322	* 1.6618	* 1.5413	* 0.7658	*
	* 1.2595	* 1.2663	* 1.3459	* 1.2211	* 1.1770	* 1.2554	* 2.2566	*
14	* 1.6775	* 1.6642	* 1.5868	* 1.0596	* 0.9130	* 0.7657	*	*
	* 1.1490	* 1.1627	* 1.2457	* 1.7190	* 1.9070	* 2.2569	*	*
15	* 0.8735	* 0.8768	* 0.8067	* 0.5832	* F-SUB-Q			
	* 1.9483	* 1.9708	* 2.1301	* 2.9708	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3611	* 1.3981	* 1.7086	* 1.4447	* 1.6917	* 1.4906	* 1.6969	* 0.8825
	* 1.4745	* 1.4304	* 1.1875	* 1.3399	* 1.1736	* 1.2711	* 1.1510	* 1.9561
9	* 1.3981	* 1.6738	* 1.5041	* 1.7017	* 1.4664	* 1.4901	* 1.6828	* 0.8840
	* 1.4304	* 1.2379	* 1.2960	* 1.1776	* 1.3068	* 1.2766	* 1.1649	* 1.9809
10	* 1.7086	* 1.5021	* 1.3280	* 1.3902	* 1.6714	* 1.4500	* 1.6020	* 0.8162
	* 1.1875	* 1.2967	* 1.4874	* 1.4117	* 1.2214	* 1.3604	* 1.2483	* 2.1333
11	* 1.4447	* 1.7011	* 1.3896	* 1.6852	* 1.4431	* 1.6460	* 1.0706	* 0.5951
	* 1.3399	* 1.1779	* 1.4123	* 1.2152	* 1.3558	* 1.2313	* 1.7230	* 3.0414
12	* 1.6917	* 1.4662	* 1.6711	* 1.4422	* 1.5089	* 1.6824	* 0.9251	*
	* 1.1736	* 1.3069	* 1.2216	* 1.3563	* 1.2785	* 1.1870	* 1.9236	*
13	* 1.4906	* 1.4904	* 1.4510	* 1.6460	* 1.6824	* 1.5603	* 0.7768	*
	* 1.2711	* 1.2766	* 1.3600	* 1.2314	* 1.1871	* 1.2672	* 2.2760	*
14	* 1.6969	* 1.6830	* 1.6022	* 1.0707	* 0.9243	* 0.7767	*	*
	* 1.1510	* 1.1647	* 1.2481	* 1.7231	* 1.9210	* 2.2764	*	*
15	* 0.8825	* 0.8843	* 0.8162	* 0.5877	* F-SUB-Q			
	* 1.9561	* 1.9815	* 2.1334	* 2.9812	* M-SUB-Q			



# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3609	* 1.3982	* 1.7229	* 1.4466	* 1.7059	* 1.4975	* 1.7185	* 0.8785
	* 1.4871	* 1.4410	* 1.1969	* 1.3617	* 1.1849	* 1.2869	* 1.1555	* 1.9993
9	* 1.3982	* 1.6856	* 1.5051	* 1.7151	* 1.4673	* 1.4976	* 1.7039	* 0.8814
	* 1.4410	* 1.2392	* 1.3164	* 1.1889	* 1.3290	* 1.2912	* 1.1690	* 2.0205
10	* 1.7229	* 1.5030	* 1.3262	* 1.3903	* 1.6840	* 1.4522	* 1.6200	* 0.8122
	* 1.1969	* 1.3173	* 1.5131	* 1.4337	* 1.2289	* 1.3682	* 1.2512	* 2.1772
11	* 1.4466	* 1.7145	* 1.3897	* 1.6981	* 1.4447	* 1.6613	* 1.0647	* 0.5897
	* 1.3617	* 1.1891	* 1.4344	* 1.2188	* 1.3712	* 1.2379	* 1.7458	* 3.1014
12	* 1.7059	* 1.4671	* 1.6837	* 1.4437	* 1.5203	* 1.7042	* 0.9188	*
	* 1.1849	* 1.3291	* 1.2291	* 1.3718	* 1.2911	* 1.1917	* 1.9707	*
13	* 1.4975	* 1.4979	* 1.4533	* 1.6613	* 1.7041	* 1.5801	* 0.7718	*
	* 1.2869	* 1.2912	* 1.3677	* 1.2379	* 1.1918	* 1.2750	* 2.3342	*
14	* 1.7185	* 1.7041	* 1.6202	* 1.0647	* 0.9179	* 0.7717	*	*
	* 1.1555	* 1.1689	* 1.2510	* 1.7460	* 1.9683	* 2.3346	*	*
15	* 0.8785	* 0.8818	* 0.8121	* 0.5801	* F-SUB-Q			
	* 1.9993	* 2.0210	* 2.1776	* 3.0518	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3535	* 1.3914	* 1.7229	* 1.4405	* 1.7058	* 1.4947	* 1.7243	* 0.8746
	* 1.5202	* 1.4745	* 1.2196	* 1.3959	* 1.2106	* 1.3161	* 1.1751	* 2.0498
9	* 1.3914	* 1.6836	* 1.4977	* 1.7141	* 1.4606	* 1.4954	* 1.7095	* 0.8777
	* 1.4745	* 1.2633	* 1.3480	* 1.2144	* 1.3632	* 1.3190	* 1.1883	* 2.0702
10	* 1.7229	* 1.4955	* 1.3176	* 1.3831	* 1.6825	* 1.4461	* 1.6234	* 0.8083
	* 1.2196	* 1.3490	* 1.5486	* 1.4634	* 1.2470	* 1.3958	* 1.2686	* 2.2282
11	* 1.4405	* 1.7134	* 1.3824	* 1.6965	* 1.4384	* 1.6623	* 1.0602	* 0.5852
	* 1.3959	* 1.2146	* 1.4641	* 1.2386	* 1.3961	* 1.2524	* 1.7801	* 3.1587
12	* 1.7058	* 1.4604	* 1.6821	* 1.4373	* 1.5209	* 1.7099	* 0.9140	*
	* 1.2106	* 1.3633	* 1.2472	* 1.3967	* 1.3121	* 1.2060	* 2.0048	*
13	* 1.4947	* 1.4957	* 1.4472	* 1.6622	* 1.7098	* 1.5853	* 0.7681	*
	* 1.3161	* 1.3189	* 1.3952	* 1.2525	* 1.2061	* 1.2936	* 2.3840	*
14	* 1.7243	* 1.7097	* 1.6235	* 1.0602	* 0.9131	* 0.7679	*	*
	* 1.1751	* 1.1881	* 1.2685	* 1.7804	* 2.0024	* 2.3845	*	*
15	* 0.8746	* 0.8781	* 0.8082	* 0.5749	* F-SUB-Q			
	* 2.0498	* 2.0707	* 2.2287	* 3.1124	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3497	* 1.3872	* 1.7273	* 1.4368	* 1.7105	* 1.4948	* 1.7339	* 0.8689 *
	* 1.5683	* 1.5056	* 1.2444	* 1.4346	* 1.2392	* 1.3494	* 1.1979	* 2.1155 *
9	* 1.3872	* 1.6870	* 1.4937	* 1.7180	* 1.4564	* 1.4958	* 1.7189	* 0.8729 *
	* 1.5056	* 1.2826	* 1.3828	* 1.2424	* 1.4019	* 1.3509	* 1.2105	* 2.1329 *
10	* 1.7273	* 1.4915	* 1.3124	* 1.3786	* 1.6858	* 1.4428	* 1.6310	* 0.8017 *
	* 1.2444	* 1.3839	* 1.5884	* 1.4982	* 1.2695	* 1.4249	* 1.2880	* 2.2974 *
11	* 1.4368	* 1.7173	* 1.3780	* 1.7000	* 1.4348	* 1.6674	* 1.0537	* 0.5798 *
	* 1.4346	* 1.2427	* 1.4989	* 1.2666	* 1.4334	* 1.2770	* 1.8240	* 3.2430 *
12	* 1.7105	* 1.4561	* 1.6854	* 1.4337	* 1.5240	* 1.7192	* 0.9066	*
	* 1.2392	* 1.4020	* 1.2697	* 1.4340	* 1.3420	* 1.2279	* 2.0676	*
13	* 1.4948	* 1.4962	* 1.4439	* 1.6673	* 1.7191	* 1.5935	* 0.7609	*
	* 1.3494	* 1.3509	* 1.4243	* 1.2771	* 1.2280	* 1.3161	* 2.4597	*
14	* 1.7339	* 1.7191	* 1.6311	* 1.0537	* 0.9056	* 0.7608	*	
	* 1.1979	* 1.2103	* 1.2879	* 1.8245	* 2.0653	* 2.4602	*	
15	* 0.8689	* 0.8733	* 0.8015	* 0.5687	F-SUB-Q			
	* 2.1155	* 2.1334	* 2.2980	* 3.2004	M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3321	* 1.3714	* 1.7032	* 1.4189	* 1.6861	* 1.4777	* 1.7131	* 0.8726
	* 1.6242	* 1.5641	* 1.2989	* 1.4977	* 1.2971	* 1.4070	* 1.2492	* 2.1704
9	* 1.3714	* 1.6629	* 1.4739	* 1.6937	* 1.4394	* 1.4793	* 1.6980	* 0.8731
	* 1.5641	* 1.3368	* 1.4422	* 1.2994	* 1.4624	* 1.4066	* 1.2617	* 2.1961
10	* 1.7032	* 1.4717	* 1.2993	* 1.3623	* 1.6615	* 1.4237	* 1.6094	* 0.8079
	* 1.2989	* 1.4433	* 1.6492	* 1.5581	* 1.3231	* 1.4787	* 1.3389	* 2.3433
11	* 1.4189	* 1.6930	* 1.3618	* 1.6753	* 1.4168	* 1.6443	* 1.0611	* 0.5824
	* 1.4977	* 1.2996	* 1.5587	* 1.3143	* 1.4865	* 1.3288	* 1.8528	* 3.3081
12	* 1.6861	* 1.4392	* 1.6611	* 1.4158	* 1.5084	* 1.6977	* 0.9133	*
	* 1.2971	* 1.4625	* 1.3234	* 1.4872	* 1.4005	* 1.2836	* 2.1100	*
13	* 1.4777	* 1.4796	* 1.4249	* 1.6442	* 1.6976	* 1.5751	* 0.7701	*
	* 1.4070	* 1.4066	* 1.4780	* 1.3289	* 1.2837	* 1.3748	* 2.5070	*
14	* 1.7131	* 1.6982	* 1.6095	* 1.0610	* 0.9123	* 0.7699	*	
	* 1.2492	* 1.2615	* 1.3388	* 1.8534	* 2.1077	* 2.5076	*	
15	* 0.8726	* 0.8735	* 0.8077	* 0.5736	* F-SUB-Q			
	* 2.1704	* 2.1966	* 2.3441	* 3.2511	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3389	* 1.3770	* 1.7261	* 1.4266	* 1.7086	* 1.4901	* 1.7415	* 0.8644
	* 1.6720	* 1.6145	* 1.3284	* 1.5452	* 1.3285	* 1.4460	* 1.2731	* 2.2692
9	* 1.3770	* 1.6841	* 1.4824	* 1.7157	* 1.4456	* 1.4919	* 1.7260	* 0.8682
	* 1.6145	* 1.3682	* 1.4857	* 1.3307	* 1.5099	* 1.4446	* 1.2852	* 2.2861
10	* 1.7261	* 1.4800	* 1.2994	* 1.3673	* 1.6824	* 1.4322	* 1.6351	* 0.7984
	* 1.3284	* 1.4869	* 1.7095	* 1.6060	* 1.3510	* 1.5182	* 1.3604	* 2.4507
11	* 1.4266	* 1.7150	* 1.3667	* 1.6966	* 1.4246	* 1.6669	* 1.0503	* 0.5745
	* 1.5452	* 1.3310	* 1.6066	* 1.3407	* 1.5247	* 1.3507	* 1.9314	* 3.4566
12	* 1.7086	* 1.4454	* 1.6819	* 1.4236	* 1.5243	* 1.7254	* 0.9013	*
	* 1.3285	* 1.5101	* 1.3513	* 1.5255	* 1.4270	* 1.2989	* 2.1977	*
13	* 1.4901	* 1.4923	* 1.4334	* 1.6668	* 1.7253	* 1.5997	* 0.7573	*
	* 1.4460	* 1.4445	* 1.5174	* 1.3509	* 1.2990	* 1.3936	* 2.6200	*
14	* 1.7415	* 1.7262	* 1.6352	* 1.0502	* 0.9002	* 0.7571	*	
	* 1.2731	* 1.2850	* 1.3604	* 1.9320	* 2.1954	* 2.6207	*	
15	* 0.8644	* 0.8686	* 0.7981	* 0.5621	* F-SUB-Q			
	* 2.2692	* 2.2866	* 2.4518	* 3.4197	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3379	* 1.3765	* 1.7313	* 1.4262	* 1.7132	* 1.4917	* 1.7500	* 0.8646
	* 1.6952	* 1.6316	* 1.3492	* 1.5727	* 1.3631	* 1.5042	* 1.3190	* 2.3602
9	* 1.3765	* 1.6884	* 1.4814	* 1.7203	* 1.4448	* 1.4941	* 1.7342	* 0.8683
	* 1.6316	* 1.3848	* 1.5117	* 1.3582	* 1.5489	* 1.5009	* 1.3311	* 2.3776
10	* 1.7313	* 1.4790	* 1.2970	* 1.3663	* 1.6861	* 1.4312	* 1.6416	* 0.7990
	* 1.3492	* 1.5130	* 1.7362	* 1.6491	* 1.3935	* 1.5789	* 1.4071	* 2.5443
11	* 1.4262	* 1.7196	* 1.3657	* 1.7003	* 1.4239	* 1.6718	* 1.0516	* 0.5736
	* 1.5727	* 1.3587	* 1.6500	* 1.3894	* 1.5852	* 1.3970	* 2.0027	* 3.5863
12	* 1.7132	* 1.4446	* 1.6856	* 1.4228	* 1.5286	* 1.7334	* 0.9015	*
	* 1.3631	* 1.5490	* 1.3938	* 1.5861	* 1.4746	* 1.3404	* 2.2777	*
13	* 1.4917	* 1.4945	* 1.4325	* 1.6716	* 1.7332	* 1.6073	* 0.7579	*
	* 1.5042	* 1.5008	* 1.5780	* 1.3972	* 1.3405	* 1.4362	* 2.7089	*
14	* 1.7500	* 1.7344	* 1.6416	* 1.0514	* 0.9003	* 0.7577	*	
	* 1.3190	* 1.3309	* 1.4071	* 2.0034	* 2.2756	* 2.7096	*	
15	* 0.8646	* 0.8687	* 0.7986	* 0.5607	* F-SUB-Q			
	* 2.3602	* 2.3781	* 2.5455	* 3.5512	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3301	* 1.3704	* 1.7208	* 1.4183	* 1.7022	* 1.4851	* 1.7421	* 0.8715
	* 1.6621	* 1.5971	* 1.3230	* 1.5407	* 1.3366	* 1.4807	* 1.3095	* 2.3089
9	* 1.3704	* 1.6777	* 1.4723	* 1.7095	* 1.4377	* 1.4885	* 1.7261	* 0.8723
	* 1.5971	* 1.3584	* 1.4823	* 1.3318	* 1.5163	* 1.4787	* 1.3224	* 2.3363
10	* 1.7208	* 1.4699	* 1.2963	* 1.3598	* 1.6747	* 1.4219	* 1.6323	* 0.8072
	* 1.3230	* 1.4836	* 1.6942	* 1.6156	* 1.3673	* 1.5554	* 1.4020	* 2.4895
11	* 1.4183	* 1.7088	* 1.3592	* 1.6888	* 1.4157	* 1.6613	* 1.0622	* 0.5779
	* 1.5407	* 1.3324	* 1.6164	* 1.3642	* 1.5644	* 1.3924	* 1.9543	* 3.5281
12	* 1.7022	* 1.4375	* 1.6743	* 1.4147	* 1.5236	* 1.7248	* 0.9114	*
	* 1.3366	* 1.5165	* 1.3676	* 1.5653	* 1.4924	* 1.3553	* 2.2472	*
13	* 1.4851	* 1.4889	* 1.4233	* 1.6612	* 1.7246	* 1.6008	* 0.7688	*
	* 1.4807	* 1.4786	* 1.5545	* 1.3925	* 1.3555	* 1.4634	* 2.6941	*
14	* 1.7421	* 1.7263	* 1.6323	* 1.0620	* 0.9102	* 0.7686	*	*
	* 1.3095	* 1.3223	* 1.4021	* 1.9551	* 2.2451	* 2.6949	*	*
15	* 0.8715	* 0.8727	* 0.8068	* 0.5670	* F-SUB-Q			
	* 2.3089	* 2.3369	* 2.4907	* 3.4803	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3434	* 1.3832	* 1.7521	* 1.4333	* 1.7323	* 1.5039	* 1.7789	* 0.8669
	* 1.6143	* 1.5518	* 1.2739	* 1.4949	* 1.2873	* 1.4326	* 1.2563	* 2.2746
9	* 1.3832	* 1.7072	* 1.4880	* 1.7398	* 1.4509	* 1.5080	* 1.7624	* 0.8712
	* 1.5518	* 1.3089	* 1.4382	* 1.2829	* 1.4728	* 1.4300	* 1.2686	* 2.2919
10	* 1.7521	* 1.4855	* 1.2996	* 1.3716	* 1.7033	* 1.4370	* 1.6657	* 0.8014
	* 1.2739	* 1.4395	* 1.6555	* 1.5690	* 1.3167	* 1.5060	* 1.3448	* 2.4558
11	* 1.4333	* 1.7390	* 1.3709	* 1.7179	* 1.4302	* 1.6929	* 1.0567	* 0.5725
	* 1.4949	* 1.2834	* 1.5699	* 1.3122	* 1.5148	* 1.3368	* 1.9215	* 3.4844
12	* 1.7323	* 1.4507	* 1.7028	* 1.4290	* 1.5469	* 1.7609	* 0.9033	*
	* 1.2873	* 1.4730	* 1.3170	* 1.5157	* 1.4370	* 1.2977	* 2.2142	*
13	* 1.5039	* 1.5084	* 1.4384	* 1.6926	* 1.7607	* 1.6339	* 0.7594	*
	* 1.4326	* 1.4299	* 1.5051	* 1.3369	* 1.2979	* 1.4008	* 2.6629	*
14	* 1.7789	* 1.7626	* 1.6657	* 1.0564	* 0.9021	* 0.7592	*	*
	* 1.2563	* 1.2685	* 1.3448	* 1.9224	* 2.2122	* 2.6637	*	*
15	* 0.8669	* 0.8716	* 0.8009	* 0.5584	* F-SUB-Q			
	* 2.2746	* 2.2924	* 2.4572	* 3.4578	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3520	* 1.3929	* 1.7721	* 1.4436	* 1.7512	* 1.5168	* 1.8026	* 0.8696
	* 1.5598	* 1.4977	* 1.2258	* 1.4427	* 1.2392	* 1.3825	* 1.2080	* 2.2001
9	* 1.3929	* 1.7258	* 1.4984	* 1.7589	* 1.4606	* 1.5218	* 1.7857	* 0.8747
	* 1.4977	* 1.2599	* 1.3885	* 1.2349	* 1.4223	* 1.3792	* 1.2198	* 2.2145
10	* 1.7721	* 1.4958	* 1.3066	* 1.3804	* 1.7210	* 1.4466	* 1.6864	* 0.8030
	* 1.2258	* 1.3899	* 1.5985	* 1.5153	* 1.2684	* 1.4556	* 1.2930	* 2.3759
11	* 1.4436	* 1.7581	* 1.3798	* 1.7358	* 1.4398	* 1.7130	* 1.0608	* 0.5725
	* 1.4427	* 1.2354	* 1.5161	* 1.2647	* 1.4648	* 1.2879	* 1.8594	* 3.3697
12	* 1.7512	* 1.4604	* 1.7205	* 1.4387	* 1.5635	* 1.7840	* 0.9057	*
	* 1.2392	* 1.4225	* 1.2686	* 1.4657	* 1.3888	* 1.2502	* 2.1443	*
13	* 1.5168	* 1.5222	* 1.4481	* 1.7127	* 1.7838	* 1.6560	* 0.7611	*
	* 1.3825	* 1.3792	* 1.4547	* 1.2881	* 1.2503	* 1.3481	* 2.5788	*
14	* 1.8026	* 1.7859	* 1.6864	* 1.0605	* 0.9045	* 0.7609	*	*
	* 1.2080	* 1.2197	* 1.2930	* 1.8603	* 2.1425	* 2.5796	*	*
15	* 0.8696	* 0.8751	* 0.8026	* 0.5577	* F-SUB-Q			
	* 2.2001	* 2.2149	* 2.3773	* 3.3485	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3603	* 1.4021	* 1.7879	* 1.4528	* 1.7659	* 1.5284	* 1.8205	* 0.8772
	* 1.5104	* 1.4491	* 1.1828	* 1.3959	* 1.1960	* 1.3350	* 1.1630	* 2.1216
9	* 1.4021	* 1.7407	* 1.5075	* 1.7741	* 1.4698	* 1.5340	* 1.8033	* 0.8815
	* 1.4491	* 1.2162	* 1.3439	* 1.1917	* 1.3759	* 1.3308	* 1.1744	* 2.1373
10	* 1.7879	* 1.5048	* 1.3137	* 1.3890	* 1.7349	* 1.4547	* 1.7018	* 0.8114
	* 1.1828	* 1.3453	* 1.5486	* 1.4660	* 1.2237	* 1.4069	* 1.2452	* 2.2864
11	* 1.4528	* 1.7733	* 1.3883	* 1.7499	* 1.4485	* 1.7283	* 1.0720	* 0.5768
	* 1.3959	* 1.1922	* 1.4668	* 1.2193	* 1.4146	* 1.2402	* 1.7878	* 3.2508
12	* 1.7659	* 1.4696	* 1.7344	* 1.4473	* 1.5773	* 1.8015	* 0.9144	*
	* 1.1960	* 1.3760	* 1.2239	* 1.4154	* 1.3355	* 1.2009	* 2.0614	*
13	* 1.5284	* 1.5344	* 1.4562	* 1.7280	* 1.8013	* 1.6724	* 0.7694	*
	* 1.3350	* 1.3308	* 1.4059	* 1.2403	* 1.2011	* 1.2938	* 2.4735	*
14	* 1.8205	* 1.8035	* 1.7017	* 1.0717	* 0.9131	* 0.7692	*	*
	* 1.1630	* 1.1743	* 1.2452	* 1.7887	* 2.0598	* 2.4743	*	*
15	* 0.8772	* 0.8820	* 0.8109	* 0.5616	* F-SUB-Q			
	* 2.1216	* 2.1377	* 2.2879	* 3.2318	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3651	* 1.4096	* 1.7947	* 1.4594	* 1.7717	* 1.5365	* 1.8279	* 0.8912
	* 1.5884	* 1.5236	* 1.2452	* 1.4691	* 1.2594	* 1.4019	* 1.2223	* 2.2046
9	* 1.4096	* 1.7471	* 1.5129	* 1.7807	* 1.4770	* 1.5422	* 1.8103	* 0.8925
	* 1.5236	* 1.2805	* 1.4156	* 1.2546	* 1.4469	* 1.3973	* 1.2342	* 2.2283
10	* 1.7947	* 1.5101	* 1.3292	* 1.3960	* 1.7406	* 1.4593	* 1.7069	* 0.8259
	* 1.2452	* 1.4171	* 1.6189	* 1.5410	* 1.2875	* 1.4792	* 1.3091	* 2.3704
11	* 1.4594	* 1.7798	* 1.3953	* 1.7553	* 1.4548	* 1.7348	* 1.0915	* 0.5855
	* 1.4691	* 1.2552	* 1.5418	* 1.2819	* 1.4848	* 1.3023	* 1.8513	* 3.3775
12	* 1.7717	* 1.4767	* 1.7401	* 1.4537	* 1.5862	* 1.8086	* 0.9320	*
	* 1.2594	* 1.4470	* 1.2878	* 1.4856	* 1.3963	* 1.2580	* 2.1297	*
13	* 1.5365	* 1.5426	* 1.4609	* 1.7345	* 1.8084	* 1.6795	* 0.7864	*
	* 1.4019	* 1.3972	* 1.4782	* 1.3025	* 1.2582	* 1.3539	* 2.5452	*
14	* 1.8279	* 1.8105	* 1.7068	* 1.0911	* 0.9306	* 0.7862	*	*
	* 1.2223	* 1.2341	* 1.3092	* 1.8522	* 2.1280	* 2.5460	*	*
15	* 0.8912	* 0.8929	* 0.8254	* 0.5722	* F-SUB-Q			
	* 2.2046	* 2.2288	* 2.3720	* 3.3455	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3891	* 1.4334	* 1.8432	* 1.4859	* 1.8189	* 1.5671	* 1.8808	* 0.8901
	* 1.5241	* 1.4640	* 1.1853	* 1.4114	* 1.2008	* 1.3477	* 1.1648	* 2.1666
9	* 1.4334	* 1.7933	* 1.5417	* 1.8282	* 1.5021	* 1.5739	* 1.8627	* 0.8956
	* 1.4640	* 1.2189	* 1.3584	* 1.1952	* 1.3926	* 1.3424	* 1.1762	* 2.1792
10	* 1.8432	* 1.5387	* 1.3395	* 1.4190	* 1.7862	* 1.4866	* 1.7555	* 0.8225
	* 1.1853	* 1.3600	* 1.5706	* 1.4837	* 1.2280	* 1.4220	* 1.2482	* 2.3353
11	* 1.4859	* 1.8273	* 1.4183	* 1.8016	* 1.4809	* 1.7828	* 1.0912	* 0.5824
	* 1.4114	* 1.1958	* 1.4846	* 1.2216	* 1.4271	* 1.2409	* 1.8148	* 3.3300
12	* 1.8189	* 1.5018	* 1.7856	* 1.4796	* 1.6229	* 1.8613	* 0.9278	*
	* 1.2008	* 1.3928	* 1.2283	* 1.4281	* 1.3308	* 1.1942	* 2.0935	*
13	* 1.5671	* 1.5743	* 1.4883	* 1.7824	* 1.8610	* 1.7283	* 0.7792	*
	* 1.3477	* 1.3422	* 1.4210	* 1.2411	* 1.1944	* 1.2847	* 2.5110	*
14	* 1.8808	* 1.8629	* 1.7554	* 1.0909	* 0.9265	* 0.7790	*	*
	* 1.1648	* 1.1761	* 1.2482	* 1.8157	* 2.0919	* 2.5117	*	*
15	* 0.8901	* 0.8961	* 0.8219	* 0.5658	* F-SUB-Q			
	* 2.1666	* 2.1795	* 2.3370	* 3.3176	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4006	* 1.4460	* 1.8646	* 1.4992	* 1.8392	* 1.5839	* 1.9046	* 0.8958 *
	* 1.4636	* 1.4087	* 1.1373	* 1.3587	* 1.1528	* 1.2944	* 1.1161	* 2.0920 *
9	* 1.4460	* 1.8142	* 1.5559	* 1.8496	* 1.5155	* 1.5909	* 1.8860	* 0.9016 *
	* 1.4087	* 1.1690	* 1.3071	* 1.1468	* 1.3405	* 1.2891	* 1.1271	* 2.1037 *
10	* 1.8646	* 1.5528	* 1.3503	* 1.4317	* 1.8072	* 1.5004	* 1.7764	* 0.8276 *
	* 1.1373	* 1.3087	* 1.5135	* 1.4268	* 1.1775	* 1.3660	* 1.1963	* 2.2560 *
11	* 1.4992	* 1.8486	* 1.4310	* 1.8227	* 1.4950	* 1.8049	* 1.1012	* 0.5849 *
	* 1.3587	* 1.1474	* 1.4274	* 1.1699	* 1.3692	* 1.1864	* 1.7437	* 3.2266 *
12	* 1.8392	* 1.5152	* 1.8067	* 1.4936	* 1.6424	* 1.8849	* 0.9346	*
	* 1.1528	* 1.3407	* 1.1779	* 1.3701	* 1.2692	* 1.1396	* 2.0143	*
13	* 1.5839	* 1.5914	* 1.5022	* 1.8045	* 1.8846	* 1.7502	* 0.7842	*
	* 1.2944	* 1.2890	* 1.3649	* 1.1867	* 1.1398	* 1.2269	* 2.4194	*
14	* 1.9046	* 1.8862	* 1.7763	* 1.1008	* 0.9332	* 0.7840	*	
	* 1.1161	* 1.1270	* 1.1964	* 1.7446	* 2.0128	* 2.4201	*	
15	* 0.8958	* 0.9021	* 0.8270	* 0.5680	F-SUB-Q			
	* 2.0920	* 2.1040	* 2.2577	* 3.2164	M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3932	* 1.4387	* 1.8421	* 1.4908	* 1.8169	* 1.5770	* 1.8825	* 0.9044 *
	* 1.4346	* 1.3813	* 1.1228	* 1.3335	* 1.1385	* 1.2681	* 1.1006	* 2.0218 *
9	* 1.4387	* 1.7937	* 1.5467	* 1.8284	* 1.5080	* 1.5832	* 1.8638	* 0.9064 *
	* 1.3813	* 1.1530	* 1.2833	* 1.1315	* 1.3147	* 1.2633	* 1.1115	* 2.0417 *
10	* 1.8421	* 1.5436	* 1.3567	* 1.4256	* 1.7886	* 1.4922	* 1.7543	* 0.8382 *
	* 1.1228	* 1.2849	* 1.4709	* 1.3970	* 1.1600	* 1.3384	* 1.1803	* 2.1727 *
11	* 1.4908	* 1.8274	* 1.4248	* 1.8032	* 1.4888	* 1.7848	* 1.1179	* 0.5913 *
	* 1.3335	* 1.1321	* 1.3977	* 1.1516	* 1.3389	* 1.1665	* 1.6736	* 3.1135 *
12	* 1.8169	* 1.5077	* 1.7879	* 1.4875	* 1.6331	* 1.8625	* 0.9487	*
	* 1.1385	* 1.3149	* 1.1603	* 1.3397	* 1.2393	* 1.1200	* 1.9311	*
13	* 1.5770	* 1.5837	* 1.4939	* 1.7844	* 1.8622	* 1.7296	* 0.7983	*
	* 1.2681	* 1.2632	* 1.3374	* 1.1667	* 1.1202	* 1.2052	* 2.3108	*
14	* 1.8825	* 1.8640	* 1.7542	* 1.1175	* 0.9473	* 0.7980	*	
	* 1.1006	* 1.1114	* 1.1803	* 1.6745	* 1.9297	* 2.3116	*	
15	* 0.9044	* 0.9068	* 0.8377	* 0.5780	* F-SUB-Q			
	* 2.0218	* 2.0421	* 2.1743	* 3.0833	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3844	* 1.4259	* 1.8298	* 1.4783	* 1.8045	* 1.5691	* 1.8713	* 0.8802
	* 1.4152	* 1.3660	* 1.1074	* 1.3185	* 1.1230	* 1.2483	* 1.0837	* 2.0355
9	* 1.4259	* 1.7837	* 1.5395	* 1.8172	* 1.4960	* 1.5755	* 1.8526	* 0.8866
	* 1.3660	* 1.1358	* 1.2638	* 1.1154	* 1.2989	* 1.2432	* 1.0945	* 2.0450
10	* 1.8298	* 1.5363	* 1.3347	* 1.4142	* 1.7794	* 1.4860	* 1.7445	* 0.8141
	* 1.1074	* 1.2654	* 1.4655	* 1.3794	* 1.1412	* 1.3155	* 1.1615	* 2.1917
11	* 1.4783	* 1.8162	* 1.4135	* 1.7938	* 1.4808	* 1.7751	* 1.0933	* 0.5748
	* 1.3185	* 1.1160	* 1.3801	* 1.1329	* 1.3169	* 1.1462	* 1.6751	* 3.1386
12	* 1.8045	* 1.4957	* 1.7788	* 1.4794	* 1.6260	* 1.8507	* 0.9223	*
	* 1.1230	* 1.2991	* 1.1416	* 1.3179	* 1.2157	* 1.1008	* 1.9430	*
13	* 1.5691	* 1.5760	* 1.4878	* 1.7747	* 1.8504	* 1.7182	* 0.7705	*
	* 1.2483	* 1.2431	* 1.3145	* 1.1465	* 1.1010	* 1.1842	* 2.3404	*
14	* 1.8713	* 1.8528	* 1.7444	* 1.0929	* 0.9209	* 0.7702	*	*
	* 1.0837	* 1.0944	* 1.1616	* 1.6760	* 1.9415	* 2.3412	*	*
15	* 0.8802	* 0.8871	* 0.8135	* 0.5585	* F-SUB-Q			
	* 2.0355	* 2.0454	* 2.1935	* 3.1271	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3106	* 1.3461	* 1.7015	* 1.3955	* 1.6773	* 1.4802	* 1.7375	* 0.8280
	* 1.4707	* 1.4235	* 1.1711	* 1.3742	* 1.1881	* 1.3008	* 1.1465	* 2.1280
9	* 1.3461	* 1.6619	* 1.4582	* 1.6918	* 1.4126	* 1.4869	* 1.7206	* 0.8351
	* 1.4235	* 1.1988	* 1.3126	* 1.1780	* 1.3531	* 1.2949	* 1.1575	* 2.1354
10	* 1.7015	* 1.4553	* 1.2646	* 1.3359	* 1.6586	* 1.4071	* 1.6202	* 0.7650
	* 1.1711	* 1.3142	* 1.5225	* 1.4359	* 1.2032	* 1.3652	* 1.2283	* 2.2943
11	* 1.3955	* 1.6908	* 1.3352	* 1.6714	* 1.4021	* 1.6517	* 1.0333	* 0.5417
	* 1.3742	* 1.1786	* 1.4366	* 1.1947	* 1.3667	* 1.2094	* 1.7417	* 3.2774
12	* 1.6773	* 1.4123	* 1.6580	* 1.4008	* 1.5324	* 1.7181	* 0.8693	*
	* 1.1881	* 1.3534	* 1.2036	* 1.3677	* 1.2656	* 1.1632	* 2.0252	*
13	* 1.4802	* 1.4873	* 1.4087	* 1.6513	* 1.7178	* 1.5943	* 0.7235	*
	* 1.3008	* 1.2948	* 1.3642	* 1.2097	* 1.1634	* 1.2514	* 2.4480	*
14	* 1.7375	* 1.7208	* 1.6200	* 1.0329	* 0.8680	* 0.7233	*	*
	* 1.1465	* 1.1574	* 1.2285	* 1.7427	* 2.0237	* 2.4488	*	*
15	* 0.8280	* 0.8355	* 0.7643	* 0.5259	* F-SUB-Q			
	* 2.1280	* 2.1359	* 2.2963	* 3.2677	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0991	* 1.1244	* 1.4008	* 1.1653	* 1.3814	* 1.2236	* 1.4284	* 0.6962
	* 1.7302	* 1.6809	* 1.4023	* 1.6226	* 1.4219	* 1.5515	* 1.3740	* 2.4970
9	* 1.1244	* 1.3676	* 1.2264	* 1.3910	* 1.1734	* 1.2344	* 1.4154	* 0.7035
	* 1.6809	* 1.4360	* 1.5387	* 1.4123	* 1.6063	* 1.5377	* 1.3864	* 2.5010
10	* 1.4008	* 1.2242	* 1.0625	* 1.1155	* 1.3637	* 1.1799	* 1.3290	* 0.6373
	* 1.4023	* 1.5402	* 1.7871	* 1.6956	* 1.4419	* 1.6050	* 1.4753	* 2.7173
11	* 1.1653	* 1.3902	* 1.1149	* 1.3792	* 1.1728	* 1.3532	* 0.8672	* 0.4542
	* 1.6226	* 1.4130	* 1.6964	* 1.4263	* 1.6100	* 1.4527	* 2.0458	* 3.8602
12	* 1.3814	* 1.1732	* 1.3632	* 1.1718	* 1.2801	* 1.4155	* 0.7338	
	* 1.4219	* 1.6066	* 1.4424	* 1.6111	* 1.4919	* 1.3902	* 2.3650	
13	* 1.2236	* 1.2347	* 1.1810	* 1.3529	* 1.4152	* 1.2875	* 0.5987	
	* 1.5515	* 1.5377	* 1.6041	* 1.4529	* 1.3904	* 1.5254	* 2.9170	
14	* 1.4284	* 1.4155	* 1.3288	* 0.8668	* 0.7327	* 0.5985		
	* 1.3740	* 1.3863	* 1.4756	* 2.0471	* 2.3633	* 2.9181		
15	* 0.6962	* 0.7039	* 0.6368	* 0.4408	* F-SUB-Q			
	* 2.4970	* 2.5016	* 2.7198	* 3.8505	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4838	* 0.5161	* 0.6228	* 0.5332	* 0.6131	* 0.5237	* 0.5750	* 0.3095
	* 3.8832	* 3.6193	* 3.1171	* 3.5039	* 3.1672	* 3.5784	* 3.3717	* 5.5594
9	* 0.5161	* 0.6068	* 0.5362	* 0.6174	* 0.5193	* 0.5262	* 0.5693	* 0.3089
	* 3.6193	* 3.1998	* 3.4754	* 3.1453	* 3.5862	* 3.5611	* 3.4054	* 5.6392
10	* 0.6228	* 0.5354	* 0.4907	* 0.5117	* 0.6053	* 0.5103	* 0.5313	* 0.2835
	* 3.1171	* 3.4776	* 3.8242	* 3.6515	* 3.2091	* 3.6650	* 3.6476	* 6.0482
11	* 0.5332	* 0.6171	* 0.5114	* 0.6009	* 0.5212	* 0.5817	* 0.3907	* 0.2030
	* 3.5039	* 3.1470	* 3.6538	* 3.2348	* 3.5779	* 3.3398	* 4.4903	* 8.5605
12	* 0.6131	* 0.5191	* 0.6052	* 0.5208	* 0.5367	* 0.5705	* 0.3273	
	* 3.1672	* 3.5868	* 3.2099	* 3.5796	* 3.5109	* 3.4062	* 5.2471	
13	* 0.5237	* 0.5263	* 0.5106	* 0.5815	* 0.5704	* 0.5105	* 0.2644	
	* 3.5784	* 3.5612	* 3.6638	* 3.3404	* 3.4068	* 3.8060	* 6.5387	
14	* 0.5750	* 0.5693	* 0.5311	* 0.3905	* 0.3269	* 0.2643		
	* 3.3717	* 3.4052	* 3.6486	* 4.4935	* 5.2419	* 6.5415		
15	* 0.3095	* 0.3091	* 0.2833	* 0.1988	* F-SUB-Q			
	* 5.5594	* 5.6395	* 6.0541	* 8.4605	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5472	* 0.6274	* 0.7300	* 0.6498	* 0.7265	* 0.6392	* 0.6698	* 0.4101
	* 2.7343	* 2.8790	* 2.6117	* 2.6902	* 2.5708	* 2.7012	* 2.7613	* 3.7268
9	* 0.6274	* 0.7149	* 0.6607	* 0.7291	* 0.6414	* 0.6366	* 0.6654	* 0.4036
	* 2.8790	* 2.7268	* 2.6694	* 2.5839	* 2.7039	* 2.7280	* 2.7906	* 3.9311
10	* 0.7300	* 0.6603	* 0.6198	* 0.6335	* 0.7191	* 0.6277	* 0.6378	* 0.3728
	* 2.6117	* 2.6692	* 2.8881	* 2.8119	* 2.6729	* 2.8396	* 2.9742	* 4.2471
11	* 0.6498	* 0.7289	* 0.6333	* 0.7076	* 0.6348	* 0.6817	* 0.4813	* 0.2904
	* 2.6902	* 2.5842	* 2.8128	* 2.6871	* 2.7644	* 2.7715	* 3.5295	* 5.6680
12	* 0.7265	* 0.6413	* 0.7190	* 0.6346	* 0.5584	* 0.6231	* 0.4191	*
	* 2.5708	* 2.7043	* 2.6733	* 2.7640	* 2.6339	* 2.7790	* 3.6984	*
13	* 0.6392	* 0.6366	* 0.6279	* 0.6817	* 0.6231	* 0.5697	* 0.3411	*
	* 2.7012	* 2.7284	* 2.8399	* 2.7716	* 2.7789	* 3.0137	* 4.6064	*
14	* 0.6698	* 0.6655	* 0.6378	* 0.4813	* 0.4189	* 0.3411	*	*
	* 2.7613	* 2.7905	* 2.9744	* 3.5319	* 3.6965	* 4.6081	*	*
15	* 0.4101	* 0.4038	* 0.3727	* 0.2863	* F-SUB-Q			
	* 3.7268	* 3.9421	* 4.2480	* 5.5642	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0934	* 1.1347	* 1.3114	* 1.1707	* 1.3072	* 1.2082	* 1.3229	* 0.7779
	* 1.5970	* 1.6264	* 1.4914	* 1.5364	* 1.4663	* 1.4696	* 1.4358	* 2.0200
9	* 1.1347	* 1.2886	* 1.2336	* 1.3098	* 1.1879	* 1.2114	* 1.3157	* 0.7768
	* 1.6264	* 1.5452	* 1.4671	* 1.4746	* 1.4992	* 1.4711	* 1.4491	* 2.0993
10	* 1.3114	* 1.2326	* 1.1060	* 1.1401	* 1.2971	* 1.1948	* 1.2663	* 0.7099
	* 1.4914	* 1.4672	* 1.6625	* 1.6044	* 1.5204	* 1.5357	* 1.5362	* 2.2912
11	* 1.1707	* 1.3095	* 1.1398	* 1.3060	* 1.1806	* 1.2796	* 0.9032	* 0.5545
	* 1.5364	* 1.4748	* 1.6049	* 1.4862	* 1.5233	* 1.5029	* 1.8949	* 3.0478
12	* 1.3072	* 1.1878	* 1.2969	* 1.1801	* 1.1684	* 1.2836	* 0.7987	*
	* 1.4663	* 1.4993	* 1.5206	* 1.5234	* 1.4281	* 1.4378	* 1.9839	*
13	* 1.2082	* 1.2115	* 1.1952	* 1.2796	* 1.2836	* 1.1877	* 0.6648	*
	* 1.4696	* 1.4713	* 1.5357	* 1.5030	* 1.4378	* 1.5468	* 2.4236	*
14	* 1.3229	* 1.3158	* 1.2663	* 0.9031	* 0.7982	* 0.6647	*	*
	* 1.4358	* 1.4490	* 1.5362	* 1.8962	* 1.9834	* 2.4244	*	*
15	* 0.7779	* 0.7770	* 0.7098	* 0.5469	* F-SUB-Q			
	* 2.0200	* 2.1056	* 2.2915	* 2.9920	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2617	* 1.2828	* 1.5109	* 1.3223	* 1.5070	* 1.3785	* 1.5303	* 0.8870 *
	* 1.4777	* 1.4641	* 1.3126	* 1.3792	* 1.2884	* 1.3016	* 1.2561	* 1.7982 *
9	* 1.2828	* 1.4826	* 1.3808	* 1.5064	* 1.3476	* 1.3786	* 1.5214	* 0.8874 *
	* 1.4641	* 1.3630	* 1.3292	* 1.2985	* 1.3394	* 1.3085	* 1.2683	* 1.8619 *
10	* 1.5109	* 1.3796	* 1.2378	* 1.2863	* 1.4934	* 1.3503	* 1.4619	* 0.8291 *
	* 1.3126	* 1.3295	* 1.5074	* 1.4427	* 1.3385	* 1.3754	* 1.3472	* 1.9876 *
11	* 1.3223	* 1.5061	* 1.2859	* 1.5052	* 1.3394	* 1.4819	* 1.0459	* 0.6379 *
	* 1.3792	* 1.2987	* 1.4431	* 1.3129	* 1.3647	* 1.3192	* 1.6661	* 2.6862 *
12	* 1.5070	* 1.3475	* 1.4932	* 1.3387	* 1.3779	* 1.5127	* 0.9236	*
	* 1.2884	* 1.3395	* 1.3387	* 1.3649	* 1.2911	* 1.2652	* 1.7479	*
13	* 1.3785	* 1.3787	* 1.3509	* 1.4818	* 1.5127	* 1.4025	* 0.7860	*
	* 1.3016	* 1.3086	* 1.3752	* 1.3193	* 1.2652	* 1.3503	* 2.0940	*
14	* 1.5303	* 1.5215	* 1.4620	* 1.0460	* 0.9230	* 0.7859	*	
	* 1.2561	* 1.2682	* 1.3472	* 1.6671	* 1.7476	* 2.0947	*	
15	* 0.8870	* 0.8875	* 0.8291	* 0.6321	* F-SUB-Q			
	* 1.7982	* 1.8676	* 1.9877	* 2.6247	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3208	* 1.3456	* 1.6188	* 1.3891	* 1.6157	* 1.4573	* 1.6544	* 0.9163
	* 1.4413	* 1.4164	* 1.2378	* 1.3262	* 1.2131	* 1.2418	* 1.1713	* 1.7568
9	* 1.3456	* 1.5858	* 1.4474	* 1.6135	* 1.4132	* 1.4566	* 1.6444	* 0.9232
	* 1.4164	* 1.2917	* 1.2812	* 1.2236	* 1.2896	* 1.2490	* 1.1829	* 1.8059
10	* 1.6188	* 1.4459	* 1.2913	* 1.3489	* 1.6002	* 1.4207	* 1.5787	* 0.8557
	* 1.2378	* 1.2816	* 1.4597	* 1.3905	* 1.2645	* 1.3231	* 1.2575	* 1.9437
11	* 1.3891	* 1.6133	* 1.3486	* 1.6151	* 1.4090	* 1.5948	* 1.0850	* 0.6545
	* 1.3262	* 1.2238	* 1.3910	* 1.2425	* 1.3165	* 1.2428	* 1.6185	* 2.6434
12	* 1.6157	* 1.4131	* 1.6000	* 1.4083	* 1.4730	* 1.6444	* 0.9564	*
	* 1.2131	* 1.2897	* 1.2646	* 1.3168	* 1.2346	* 1.1873	* 1.7157	*
13	* 1.4573	* 1.4568	* 1.4214	* 1.5948	* 1.6444	* 1.5266	* 0.8143	*
	* 1.2418	* 1.2491	* 1.3229	* 1.2429	* 1.1873	* 1.2656	* 2.0591	*
14	* 1.6544	* 1.6446	* 1.5787	* 1.0850	* 0.9557	* 0.8142	*	
	* 1.1713	* 1.1828	* 1.2575	* 1.6196	* 1.7156	* 2.0599	*	
15	* 0.9163	* 0.9235	* 0.8557	* 0.6469	* F-SUB-Q			
	* 1.7568	* 1.8113	* 1.9438	* 2.5892	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3173	* 1.3443	* 1.6312	* 1.3899	* 1.6284	* 1.4613	* 1.6764	* 0.9232
	* 1.4695	* 1.4355	* 1.2416	* 1.3399	* 1.2160	* 1.2499	* 1.1659	* 1.7608
9	* 1.3443	* 1.5962	* 1.4443	* 1.6261	* 1.4133	* 1.4617	* 1.6661	* 0.9268
	* 1.4355	* 1.2982	* 1.2978	* 1.2268	* 1.3031	* 1.2561	* 1.1776	* 1.8164
10	* 1.6312	* 1.4427	* 1.2866	* 1.3484	* 1.6125	* 1.4210	* 1.5979	* 0.8627
	* 1.2416	* 1.2983	* 1.4806	* 1.4061	* 1.2680	* 1.3368	* 1.2524	* 1.9464
11	* 1.3899	* 1.6259	* 1.3480	* 1.6282	* 1.4107	* 1.6108	* 1.0862	* 0.6546
	* 1.3399	* 1.2270	* 1.4066	* 1.2510	* 1.3345	* 1.2476	* 1.6398	* 2.6678
12	* 1.6284	* 1.4131	* 1.6123	* 1.4100	* 1.4875	* 1.6697	* 0.9621	*
	* 1.2160	* 1.3032	* 1.2681	* 1.3348	* 1.2445	* 1.1890	* 1.7336	*
13	* 1.4613	* 1.4619	* 1.4218	* 1.6107	* 1.6697	* 1.5517	* 0.8216	*
	* 1.2499	* 1.2562	* 1.3366	* 1.2476	* 1.1890	* 1.2669	* 2.0782	*
14	* 1.6764	* 1.6663	* 1.5979	* 1.0861	* 0.9614	* 0.8215	*	*
	* 1.1659	* 1.1775	* 1.2524	* 1.6410	* 1.7336	* 2.0790	*	*
15	* 0.9232	* 0.9270	* 0.8626	* 0.6460	* F-SUB-Q			
	* 1.7608	* 1.8220	* 1.9466	* 2.6170	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2975	* 1.3261	* 1.6140	* 1.3708	* 1.6116	* 1.4438	* 1.6653	* 0.9187
	* 1.5035	* 1.4649	* 1.2691	* 1.3749	* 1.2433	* 1.2788	* 1.1858	* 1.7894
9	* 1.3261	* 1.5784	* 1.4221	* 1.6091	* 1.3945	* 1.4454	* 1.6551	* 0.9204
	* 1.4649	* 1.3204	* 1.3332	* 1.2543	* 1.3363	* 1.2834	* 1.1974	* 1.8491
10	* 1.6140	* 1.4205	* 1.2675	* 1.3297	* 1.5956	* 1.4014	* 1.5858	* 0.8593
	* 1.2691	* 1.3338	* 1.5147	* 1.4408	* 1.2948	* 1.3656	* 1.2731	* 1.9746
11	* 1.3708	* 1.6089	* 1.3293	* 1.6112	* 1.3919	* 1.5961	* 1.0821	* 0.6496
	* 1.3749	* 1.2545	* 1.4413	* 1.2794	* 1.3685	* 1.2765	* 1.6667	* 2.7120
12	* 1.6116	* 1.3944	* 1.5953	* 1.3911	* 1.4754	* 1.6597	* 0.9596	*
	* 1.2433	* 1.3363	* 1.2950	* 1.3689	* 1.2786	* 1.2179	* 1.7663	*
13	* 1.4438	* 1.4457	* 1.4022	* 1.5960	* 1.6596	* 1.5438	* 0.8218	*
	* 1.2788	* 1.2835	* 1.3654	* 1.2766	* 1.2179	* 1.2980	* 2.1201	*
14	* 1.6653	* 1.6552	* 1.5858	* 1.0820	* 0.9588	* 0.8216	*	*
	* 1.1858	* 1.1974	* 1.2731	* 1.6679	* 1.7664	* 2.1209	*	*
15	* 0.9187	* 0.9206	* 0.8591	* 0.6418	* F-SUB-Q			
	* 1.7894	* 1.8548	* 1.9748	* 2.6574	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2850	* 1.3130	* 1.6081	* 1.3581	* 1.6055	* 1.4343	* 1.6657	* 0.9046
	* 1.5252	* 1.4833	* 1.2902	* 1.4075	* 1.2663	* 1.3053	* 1.2014	* 1.8427
9	* 1.3130	* 1.5713	* 1.4081	* 1.6025	* 1.3810	* 1.4366	* 1.6556	* 0.9084
	* 1.4833	* 1.3306	* 1.3640	* 1.2774	* 1.3689	* 1.3083	* 1.2125	* 1.8993
10	* 1.6081	* 1.4064	* 1.2527	* 1.3167	* 1.5889	* 1.3892	* 1.5857	* 0.8464
	* 1.2902	* 1.3647	* 1.5563	* 1.4700	* 1.3068	* 1.3867	* 1.2867	* 2.0299
11	* 1.3581	* 1.6023	* 1.3163	* 1.6049	* 1.3795	* 1.5929	* 1.0628	* 0.6375
	* 1.4075	* 1.2775	* 1.4704	* 1.2946	* 1.3928	* 1.2946	* 1.7005	* 2.7843
12	* 1.6055	* 1.3808	* 1.5886	* 1.3787	* 1.4697	* 1.6606	* 0.9420	*
	* 1.2663	* 1.3690	* 1.3069	* 1.3932	* 1.2997	* 1.2320	* 1.8229	*
13	* 1.4343	* 1.4368	* 1.3901	* 1.5927	* 1.6605	* 1.5456	* 0.8060	*
	* 1.3053	* 1.3083	* 1.3863	* 1.2948	* 1.2321	* 1.3147	* 2.1916	*
14	* 1.6657	* 1.6557	* 1.5857	* 1.0626	* 0.9411	* 0.8059	*	*
	* 1.2014	* 1.2125	* 1.2868	* 1.7020	* 1.8232	* 2.1925	*	*
15	* 0.9047	* 0.9086	* 0.8461	* 0.6272	* F-SUB-Q			
	* 1.8427	* 1.9052	* 2.0303	* 2.7398	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2724	* 1.3002	* 1.5979	* 1.3450	* 1.5952	* 1.4231	* 1.6599	* 0.8957
	* 1.5584	* 1.5185	* 1.3145	* 1.4451	* 1.2974	* 1.3382	* 1.2260	* 1.8934
9	* 1.3002	* 1.5606	* 1.3937	* 1.5919	* 1.3673	* 1.4267	* 1.6498	* 0.8998
	* 1.5185	* 1.3582	* 1.3959	* 1.3079	* 1.4068	* 1.3393	* 1.2367	* 1.9498
10	* 1.5979	* 1.3919	* 1.2390	* 1.3039	* 1.5782	* 1.3764	* 1.5795	* 0.8384
	* 1.3145	* 1.3966	* 1.5913	* 1.5026	* 1.3305	* 1.4146	* 1.3086	* 2.0802
11	* 1.3450	* 1.5917	* 1.3035	* 1.5942	* 1.3666	* 1.5851	* 1.0533	* 0.6296
	* 1.4451	* 1.3081	* 1.5031	* 1.3171	* 1.4193	* 1.3112	* 1.7335	* 2.8389
12	* 1.5952	* 1.3672	* 1.5779	* 1.3657	* 1.4612	* 1.6548	* 0.9320	*
	* 1.2974	* 1.4069	* 1.3306	* 1.4197	* 1.3232	* 1.2499	* 1.8565	*
13	* 1.4231	* 1.4269	* 1.3773	* 1.5849	* 1.6547	* 1.5409	* 0.7980	*
	* 1.3382	* 1.3394	* 1.4142	* 1.3113	* 1.2500	* 1.3363	* 2.2400	*
14	* 1.6599	* 1.6499	* 1.5794	* 1.0530	* 0.9310	* 0.7978	*	*
	* 1.2260	* 1.2366	* 1.3087	* 1.7352	* 1.8569	* 2.2409	*	*
15	* 0.8957	* 0.9000	* 0.8382	* 0.6186	* F-SUB-Q			
	* 1.8934	* 1.9559	* 2.0807	* 2.7974	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2664	* 1.2932	* 1.5967	* 1.3381	* 1.5938	* 1.4185	* 1.6628	* 0.8862
	* 1.6037	* 1.5514	* 1.3394	* 1.4831	* 1.3276	* 1.3716	* 1.2502	* 1.9551
9	* 1.2932	* 1.5589	* 1.3863	* 1.5902	* 1.3598	* 1.4228	* 1.6527	* 0.8926
	* 1.5514	* 1.3806	* 1.4289	* 1.3373	* 1.4454	* 1.3711	* 1.2601	* 2.0072
10	* 1.5967	* 1.3845	* 1.2318	* 1.2968	* 1.5762	* 1.3699	* 1.5818	* 0.8288
	* 1.3394	* 1.4298	* 1.6288	* 1.5353	* 1.3556	* 1.4418	* 1.3275	* 2.1448
11	* 1.3381	* 1.5900	* 1.2964	* 1.5925	* 1.3599	* 1.5856	* 1.0479	* 0.6224
	* 1.4831	* 1.3374	* 1.5359	* 1.3459	* 1.4551	* 1.3364	* 1.7745	* 2.9107
12	* 1.5938	* 1.3596	* 1.5759	* 1.3590	* 1.4592	* 1.6576	* 0.9219	*
	* 1.3276	* 1.4455	* 1.3558	* 1.4555	* 1.3517	* 1.2719	* 1.9121	*
13	* 1.4185	* 1.4231	* 1.3708	* 1.5854	* 1.6574	* 1.5437	* 0.7894	*
	* 1.3716	* 1.3712	* 1.4414	* 1.3365	* 1.2720	* 1.3581	* 2.3045	*
14	* 1.6628	* 1.6528	* 1.5816	* 1.0475	* 0.9209	* 0.7892	*	*
	* 1.2502	* 1.2601	* 1.3276	* 1.7763	* 1.9126	* 2.3055	*	*
15	* 0.8862	* 0.8927	* 0.8284	* 0.6105	* F-SUB-Q			
	* 1.9551	* 2.0134	* 2.1456	* 2.8729	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2505	* 1.2794	* 1.5750	* 1.3217	* 1.5718	* 1.4035	* 1.6423	* 0.8925
	* 1.6568	* 1.6035	* 1.3931	* 1.5413	* 1.3836	* 1.4234	* 1.2995	* 1.9932
9	* 1.2794	* 1.5377	* 1.3685	* 1.5682	* 1.3447	* 1.4085	* 1.6322	* 0.8935
	* 1.6035	* 1.4317	* 1.4848	* 1.3924	* 1.5010	* 1.4214	* 1.3090	* 2.0578
10	* 1.5750	* 1.3667	* 1.2271	* 1.2827	* 1.5543	* 1.3520	* 1.5609	* 0.8369
	* 1.3931	* 1.4857	* 1.6754	* 1.5868	* 1.4027	* 1.4914	* 1.3761	* 2.1757
11	* 1.3217	* 1.5681	* 1.2823	* 1.5702	* 1.3438	* 1.5647	* 1.0575	* 0.6262
	* 1.5413	* 1.3926	* 1.5873	* 1.3931	* 1.5045	* 1.3901	* 1.7922	* 2.9540
12	* 1.5718	* 1.3446	* 1.5541	* 1.3430	* 1.4441	* 1.6364	* 0.9314	*
	* 1.3836	* 1.5012	* 1.4028	* 1.5049	* 1.4052	* 1.3248	* 1.9410	*
13	* 1.4035	* 1.4088	* 1.3529	* 1.5644	* 1.6362	* 1.5247	* 0.7989	*
	* 1.4234	* 1.4214	* 1.4910	* 1.3903	* 1.3249	* 1.4135	* 2.3396	*
14	* 1.6423	* 1.6323	* 1.5607	* 1.0572	* 0.9304	* 0.7987	*	*
	* 1.2995	* 1.3090	* 1.3763	* 1.7939	* 1.9416	* 2.3407	*	*
15	* 0.8925	* 0.8936	* 0.8365	* 0.6173	* F-SUB-Q			
	* 1.9932	* 2.0642	* 2.1766	* 2.9011	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2575	* 1.2843	* 1.5942	* 1.3284	* 1.5904	* 1.4131	* 1.6665	* 0.8830
	* 1.6978	* 1.6489	* 1.4224	* 1.5841	* 1.4134	* 1.4597	* 1.3218	* 2.0791
9	* 1.2843	* 1.5556	* 1.3756	* 1.5865	* 1.3497	* 1.4187	* 1.6564	* 0.8884
	* 1.6489	* 1.4610	* 1.5261	* 1.4219	* 1.5445	* 1.4561	* 1.3306	* 2.1349
10	* 1.5942	* 1.3737	* 1.2207	* 1.2872	* 1.5718	* 1.3599	* 1.5842	* 0.8272
	* 1.4224	* 1.5271	* 1.7394	* 1.6298	* 1.4279	* 1.5266	* 1.3955	* 2.2671
11	* 1.3284	* 1.5863	* 1.2868	* 1.5884	* 1.3502	* 1.5853	* 1.0423	* 0.6178
	* 1.5841	* 1.4221	* 1.6303	* 1.4174	* 1.5391	* 1.4069	* 1.8655	* 3.0797
12	* 1.5904	* 1.3496	* 1.5715	* 1.3493	* 1.4573	* 1.6608	* 0.9178	*
	* 1.4134	* 1.5447	* 1.4280	* 1.5396	* 1.4305	* 1.3394	* 2.0176	*
13	* 1.4131	* 1.4190	* 1.3608	* 1.5851	* 1.6606	* 1.5475	* 0.7863	*
	* 1.4597	* 1.4562	* 1.5262	* 1.4071	* 1.3395	* 1.4310	* 2.4375	*
14	* 1.6665	* 1.6565	* 1.5840	* 1.0418	* 0.9167	* 0.7861	*	*
	* 1.3218	* 1.3306	* 1.3957	* 1.8677	* 2.0183	* 2.4387	*	*
15	* 0.8830	* 0.8885	* 0.8267	* 0.6045	* F-SUB-Q			
	* 2.0791	* 2.1415	* 2.2682	* 3.0467	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2576	* 1.2845	* 1.5987	* 1.3284	* 1.5944	* 1.4150	* 1.6736	* 0.8839
	* 1.7603	* 1.7033	* 1.4730	* 1.6438	* 1.4650	* 1.5127	* 1.3655	* 2.1538
9	* 1.2845	* 1.5596	* 1.3752	* 1.5903	* 1.3495	* 1.4212	* 1.6635	* 0.8891
	* 1.7033	* 1.5137	* 1.5832	* 1.4736	* 1.6044	* 1.5077	* 1.3740	* 2.2112
10	* 1.5987	* 1.3732	* 1.2195	* 1.2870	* 1.5752	* 1.3597	* 1.5903	* 0.8291
	* 1.4730	* 1.5842	* 1.8000	* 1.6915	* 1.4772	* 1.5786	* 1.4385	* 2.3421
11	* 1.3284	* 1.5901	* 1.2866	* 1.5918	* 1.3501	* 1.5904	* 1.0432	* 0.6175
	* 1.6438	* 1.4737	* 1.6921	* 1.4665	* 1.5943	* 1.4507	* 1.9290	* 3.1820
12	* 1.5944	* 1.3494	* 1.5749	* 1.3492	* 1.4609	* 1.6677	* 0.9188	*
	* 1.4650	* 1.6046	* 1.4773	* 1.5948	* 1.4740	* 1.3782	* 2.0827	*
13	* 1.4150	* 1.4214	* 1.3606	* 1.5901	* 1.6676	* 1.5543	* 0.7871	*
	* 1.5127	* 1.5077	* 1.5782	* 1.4509	* 1.3783	* 1.4705	* 2.5118	*
14	* 1.6736	* 1.6635	* 1.5901	* 1.0429	* 0.9177	* 0.7869	*	*
	* 1.3655	* 1.3740	* 1.4387	* 1.9314	* 2.0835	* 2.5130	*	*
15	* 0.8839	* 0.8893	* 0.8286	* 0.6038	* F-SUB-Q			
	* 2.1538	* 2.2181	* 2.3433	* 3.1506	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2512	* 1.2800	* 1.5896	* 1.3217	* 1.5849	* 1.4102	* 1.6662	* 0.8927
	* 1.6959	* 1.6379	* 1.4221	* 1.5824	* 1.4266	* 1.4972	* 1.3656	* 2.1066
9	* 1.2800	* 1.5507	* 1.3674	* 1.5809	* 1.3439	* 1.4167	* 1.6561	* 0.8941
	* 1.6379	* 1.4589	* 1.5255	* 1.4310	* 1.5532	* 1.4936	* 1.3750	* 2.1741
10	* 1.5896	* 1.3655	* 1.2266	* 1.2820	* 1.5656	* 1.3515	* 1.5821	* 0.8380
	* 1.4221	* 1.5265	* 1.7179	* 1.6473	* 1.4590	* 1.5681	* 1.4431	* 2.2931
11	* 1.3217	* 1.5807	* 1.2816	* 1.5820	* 1.3441	* 1.5818	* 1.0595	* 0.6234
	* 1.5824	* 1.4312	* 1.6479	* 1.4525	* 1.5880	* 1.4655	* 1.8904	* 3.1185
12	* 1.5849	* 1.3438	* 1.5653	* 1.3432	* 1.4564	* 1.6597	* 0.9313	*
	* 1.4266	* 1.5535	* 1.4591	* 1.5885	* 1.5126	* 1.4124	* 2.0633	*
13	* 1.4102	* 1.4169	* 1.3525	* 1.5816	* 1.6595	* 1.5476	* 0.7990	*
	* 1.4972	* 1.4936	* 1.5678	* 1.4657	* 1.4125	* 1.5177	* 2.5121	*
14	* 1.6662	* 1.6561	* 1.5818	* 1.0590	* 0.9302	* 0.7988	*	
	* 1.3656	* 1.3749	* 1.4433	* 1.8925	* 2.0642	* 2.5134	*	
15	* 0.8927	* 0.8943	* 0.8375	* 0.6127	F-SUB-Q			
	* 2.1066	* 2.1809	* 2.2944	* 3.0713	M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2631	* 1.2903	* 1.6152	* 1.3340	* 1.6097	* 1.4254	* 1.6974	* 0.8867
	* 1.6198	* 1.5659	* 1.3485	* 1.5108	* 1.3531	* 1.4269	* 1.2910	* 2.0434
9	* 1.2903	* 1.5747	* 1.3800	* 1.6053	* 1.3544	* 1.4327	* 1.6871	* 0.8928
	* 1.5659	* 1.3845	* 1.4568	* 1.3575	* 1.4848	* 1.4224	* 1.2996	* 2.0977
10	* 1.6152	* 1.3780	* 1.2226	* 1.2918	* 1.5890	* 1.3650	* 1.6118	* 0.8315
	* 1.3485	* 1.4579	* 1.6577	* 1.5743	* 1.3837	* 1.4941	* 1.3631	* 2.2257
11	* 1.3340	* 1.6052	* 1.2913	* 1.6062	* 1.3555	* 1.6086	* 1.0486	* 0.6176
	* 1.5108	* 1.3577	* 1.5749	* 1.3760	* 1.5141	* 1.3869	* 1.8348	* 3.0289
12	* 1.6097	* 1.3543	* 1.5887	* 1.3545	* 1.4756	* 1.6908	* 0.9214	*
	* 1.3531	* 1.4850	* 1.3838	* 1.5147	* 1.4373	* 1.3344	* 2.0053	*
13	* 1.4254	* 1.4330	* 1.3660	* 1.6084	* 1.6906	* 1.5771	* 0.7896	*
	* 1.4269	* 1.4225	* 1.4936	* 1.3870	* 1.3346	* 1.4332	* 2.4443	*
14	* 1.6974	* 1.6872	* 1.6115	* 1.0482	* 0.9202	* 0.7894	*	
	* 1.2910	* 1.2996	* 1.3634	* 1.8372	* 2.0064	* 2.4456	*	
15	* 0.8867	* 0.8929	* 0.8309	* 0.6025	* F-SUB-Q			
	* 2.0434	* 2.1043	* 2.2271	* 3.0057	* M-SUB-Q			



# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2711	* 1.2986	* 1.6312	* 1.3426	* 1.6252	* 1.4363	* 1.7172	* 0.8882
	* 1.5654	* 1.5125	* 1.2972	* 1.4586	* 1.3015	* 1.3746	* 1.2383	* 1.9801
9	* 1.2986	* 1.5900	* 1.3883	* 1.6206	* 1.3625	* 1.4443	* 1.7069	* 0.8967
	* 1.5125	* 1.3326	* 1.4072	* 1.3060	* 1.4336	* 1.3695	* 1.2463	* 2.0271
10	* 1.6312	* 1.3862	* 1.2291	* 1.2994	* 1.6035	* 1.3737	* 1.6304	* 0.8328
	* 1.2972	* 1.4083	* 1.6024	* 1.5196	* 1.3306	* 1.4390	* 1.3068	* 2.1560
11	* 1.3426	* 1.6205	* 1.2990	* 1.6210	* 1.3638	* 1.6256	* 1.0552	* 0.6182
	* 1.4586	* 1.3061	* 1.5202	* 1.3224	* 1.4590	* 1.3307	* 1.7674	* 2.9336
12	* 1.6252	* 1.3623	* 1.6033	* 1.3628	* 1.4893	* 1.7106	* 0.9233	*
	* 1.3015	* 1.4338	* 1.3308	* 1.4596	* 1.3789	* 1.2770	* 1.9382	*
13	* 1.4363	* 1.4446	* 1.3746	* 1.6253	* 1.7104	* 1.5963	* 0.7909	*
	* 1.3746	* 1.3695	* 1.4386	* 1.3308	* 1.2772	* 1.3700	* 2.3612	*
14	* 1.7172	* 1.7070	* 1.6301	* 1.0544	* 0.9220	* 0.7907	*	*
	* 1.2383	* 1.2463	* 1.3071	* 1.7698	* 1.9393	* 2.3625	*	*
15	* 0.8882	* 0.8968	* 0.8322	* 0.6022	* F-SUB-Q			
	* 1.9801	* 2.0336	* 2.1575	* 2.9154	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2785	* 1.3067	* 1.6442	* 1.3504	* 1.6376	* 1.4464	* 1.7329	* 0.8981
	* 1.5241	* 1.4714	* 1.2593	* 1.4190	* 1.2630	* 1.3336	* 1.1984	* 1.9129
9	* 1.3067	* 1.6023	* 1.3959	* 1.6329	* 1.3706	* 1.4551	* 1.7225	* 0.9043
	* 1.4714	* 1.2940	* 1.3696	* 1.2676	* 1.3938	* 1.3280	* 1.2061	* 1.9633
10	* 1.6442	* 1.3938	* 1.2366	* 1.3071	* 1.6151	* 1.3833	* 1.6445	* 0.8438
	* 1.2593	* 1.3707	* 1.5605	* 1.4768	* 1.2907	* 1.3951	* 1.2644	* 2.0779
11	* 1.3504	* 1.6327	* 1.3067	* 1.6330	* 1.3716	* 1.6386	* 1.0643	* 0.6237
	* 1.4190	* 1.2677	* 1.4773	* 1.2817	* 1.4158	* 1.2880	* 1.7121	* 2.8380
12	* 1.6376	* 1.3704	* 1.6150	* 1.3707	* 1.5010	* 1.7258	* 0.9333	*
	* 1.2630	* 1.3940	* 1.2908	* 1.4164	* 1.3330	* 1.2332	* 1.8688	*
13	* 1.4464	* 1.4554	* 1.3843	* 1.6384	* 1.7256	* 1.6107	* 0.8001	*
	* 1.3335	* 1.3280	* 1.3947	* 1.2882	* 1.2334	* 1.3217	* 2.2727	*
14	* 1.7329	* 1.7225	* 1.6442	* 1.0638	* 0.9320	* 0.7998	*	*
	* 1.1984	* 1.2061	* 1.2647	* 1.7140	* 1.8699	* 2.2739	*	*
15	* 0.8981	* 0.9044	* 0.8432	* 0.6074	* F-SUB-Q			
	* 1.9129	* 1.9695	* 2.0794	* 2.8214	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2848	* 1.3156	* 1.6522	* 1.3580	* 1.6452	* 1.4561	* 1.7420	* 0.9156 *
	* 1.6139	* 1.5559	* 1.3338	* 1.5021	* 1.3371	* 1.4071	* 1.2656	* 1.9927 *
9	* 1.3156	* 1.6099	* 1.4028	* 1.6405	* 1.3793	* 1.4649	* 1.7314	* 0.9179 *
	* 1.5559	* 1.3706	* 1.4508	* 1.3423	* 1.4733	* 1.4009	* 1.2736	* 2.0536 *
10	* 1.6522	* 1.4006	* 1.2586	* 1.3156	* 1.6224	* 1.3928	* 1.6520	* 0.8609 *
	* 1.3338	* 1.4520	* 1.6322	* 1.5591	* 1.3654	* 1.4708	* 1.3352	* 2.1617 *
11	* 1.3580	* 1.6403	* 1.3152	* 1.6401	* 1.3803	* 1.6464	* 1.0902	* 0.6355 *
	* 1.5021	* 1.3424	* 1.5596	* 1.3546	* 1.4921	* 1.3588	* 1.7727	* 2.9548 *
12	* 1.6452	* 1.3792	* 1.6223	* 1.3794	* 1.5117	* 1.7344	* 0.9552	*
	* 1.3371	* 1.4735	* 1.3655	* 1.4927	* 1.3993	* 1.2980	* 1.9337	*
13	* 1.4561	* 1.4652	* 1.3937	* 1.6462	* 1.7342	* 1.6195	* 0.8198	*
	* 1.4071	* 1.4009	* 1.4703	* 1.3591	* 1.2982	* 1.3897	* 2.3458	*
14	* 1.7420	* 1.7314	* 1.6517	* 1.0896	* 0.9539	* 0.8195	*	
	* 1.2656	* 1.2736	* 1.3355	* 1.7748	* 1.9348	* 2.3472	*	
15	* 0.9156	* 0.9180	* 0.8602	* 0.6217	* F-SUB-Q			
	* 1.9927	* 2.0602	* 2.1633	* 2.9239	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3112	* 1.3406	* 1.6988	* 1.3858	* 1.6911	* 1.4876	* 1.7950	* 0.9171
	* 1.5599	* 1.5097	* 1.2833	* 1.4569	* 1.2880	* 1.3622	* 1.2142	* 1.9667
9	* 1.3406	* 1.6543	* 1.4320	* 1.6858	* 1.4055	* 1.4977	* 1.7842	* 0.9250
	* 1.5097	* 1.3189	* 1.4063	* 1.2931	* 1.4317	* 1.3550	* 1.2216	* 2.0144
10	* 1.6988	* 1.4297	* 1.2652	* 1.3402	* 1.6667	* 1.4219	* 1.7029	* 0.8598
	* 1.2833	* 1.4075	* 1.6054	* 1.5143	* 1.3147	* 1.4236	* 1.2794	* 2.1388
11	* 1.3858	* 1.6857	* 1.3398	* 1.6852	* 1.4071	* 1.6947	* 1.0897	* 0.6348
	* 1.4569	* 1.2932	* 1.5148	* 1.3029	* 1.4448	* 1.3013	* 1.7475	* 2.9204
12	* 1.6911	* 1.4053	* 1.6666	* 1.4061	* 1.5482	* 1.7877	* 0.9526	
	* 1.2880	* 1.4319	* 1.3148	* 1.4454	* 1.3415	* 1.2389	* 1.9109	
13	* 1.4876	* 1.4980	* 1.4229	* 1.6943	* 1.7875	* 1.6690	* 0.8158	
	* 1.3622	* 1.3549	* 1.4231	* 1.3016	* 1.2391	* 1.3253	* 2.3199	
14	* 1.7950	* 1.7842	* 1.7025	* 1.0887	* 0.9512	* 0.8155		
	* 1.2142	* 1.2216	* 1.2797	* 1.7501	* 1.9122	* 2.3212		
15	* 0.9171	* 0.9251	* 0.8590	* 0.6168	* F-SUB-Q			
	* 1.9667	* 2.0208	* 2.1405	* 2.9097	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3319	* 1.3622	* 1.7309	* 1.4084	* 1.7228	* 1.5143	* 1.8311	* 0.9316 *
	* 1.4952	* 1.4505	* 1.2298	* 1.4003	* 1.2345	* 1.3087	* 1.1641	* 1.8973 *
9	* 1.3622	* 1.6851	* 1.4555	* 1.7173	* 1.4284	* 1.5247	* 1.8201	* 0.9396 *
	* 1.4505	* 1.2637	* 1.3513	* 1.2393	* 1.3758	* 1.3016	* 1.1713	* 1.9434 *
10	* 1.7309	* 1.4532	* 1.2847	* 1.3618	* 1.6978	* 1.4470	* 1.7367	* 0.8733 *
	* 1.2298	* 1.3525	* 1.5444	* 1.4537	* 1.2589	* 1.3678	* 1.2271	* 2.0639 *
11	* 1.4084	* 1.7171	* 1.3613	* 1.7167	* 1.4306	* 1.7278	* 1.1079	* 0.6438 *
	* 1.4003	* 1.2394	* 1.4542	* 1.2468	* 1.3861	* 1.2444	* 1.6812	* 2.8251 *
12	* 1.7228	* 1.4282	* 1.6978	* 1.4296	* 1.5778	* 1.8238	* 0.9681	*
	* 1.2345	* 1.3760	* 1.2590	* 1.3867	* 1.2805	* 1.1832	* 1.8371	*
13	* 1.5143	* 1.5250	* 1.4480	* 1.7274	* 1.8236	* 1.7026	* 0.8285	*
	* 1.3087	* 1.3016	* 1.3673	* 1.2447	* 1.1834	* 1.2668	* 2.2329	*
14	* 1.8311	* 1.8201	* 1.7362	* 1.1071	* 0.9667	* 0.8282	*	
	* 1.1641	* 1.1713	* 1.2274	* 1.6837	* 1.8384	* 2.2342	*	
15	* 0.9316	* 0.9397	* 0.8725	* 0.6252	* F-SUB-Q			
	* 1.8973	* 1.9495	* 2.0656	* 2.8165	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3424	* 1.3755	* 1.7387	* 1.4203	* 1.7304	* 1.5304	* 1.8396	* 0.9575 *
	* 1.4545	* 1.4094	* 1.2011	* 1.3629	* 1.2055	* 1.2693	* 1.1351	* 1.8094 *
9	* 1.3755	* 1.6932	* 1.4687	* 1.7253	* 1.4431	* 1.5401	* 1.8283	* 0.9599 *
	* 1.4094	* 1.2336	* 1.3142	* 1.2101	* 1.3361	* 1.2629	* 1.1420	* 1.8646 *
10	* 1.7387	* 1.4663	* 1.3174	* 1.3755	* 1.7069	* 1.4627	* 1.7428	* 0.9005 *
	* 1.2011	* 1.3154	* 1.4792	* 1.4105	* 1.2260	* 1.3253	* 1.1970	* 1.9610 *
11	* 1.4203	* 1.7251	* 1.3750	* 1.7252	* 1.4462	* 1.7359	* 1.1471	* 0.6619 *
	* 1.3629	* 1.2102	* 1.4110	* 1.2145	* 1.3415	* 1.2096	* 1.5916	* 2.6915 *
12	* 1.7304	* 1.4429	* 1.7068	* 1.4451	* 1.5943	* 1.8317	* 1.0010	*
	* 1.2055	* 1.3363	* 1.2261	* 1.3421	* 1.2357	* 1.1493	* 1.7365	*
13	* 1.5304	* 1.5404	* 1.4637	* 1.7355	* 1.8314	* 1.7102	* 0.8569	*
	* 1.2693	* 1.2629	* 1.3248	* 1.2099	* 1.1494	* 1.2305	* 2.1074	*
14	* 1.8396	* 1.8283	* 1.7423	* 1.1465	* 0.9996	* 0.8566	*	
	* 1.1351	* 1.1420	* 1.1973	* 1.5935	* 1.7376	* 2.1087	*	
15	* 0.9575	* 0.9600	* 0.8997	* 0.6479	* F-SUB-Q			
	* 1.8094	* 1.8704	* 1.9626	* 2.6620	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3635	* 1.3921	* 1.7678	* 1.4398	* 1.7594	* 1.5548	* 1.8724	* 0.9517 *
	* 1.4101	* 1.3715	* 1.1630	* 1.3241	* 1.1671	* 1.2289	* 1.0961	* 1.7908 *
9	* 1.3921	* 1.7222	* 1.4933	* 1.7543	* 1.4622	* 1.5643	* 1.8610	* 0.9596 *
	* 1.3715	* 1.1939	* 1.2728	* 1.1715	* 1.2982	* 1.2228	* 1.1028	* 1.8344 *
10	* 1.7678	* 1.4908	* 1.3154	* 1.3931	* 1.7376	* 1.4849	* 1.7739	* 0.8939 *
	* 1.1630	* 1.2741	* 1.4591	* 1.3702	* 1.1838	* 1.2833	* 1.1554	* 1.9425 *
11	* 1.4398	* 1.7541	* 1.3925	* 1.7561	* 1.4675	* 1.7668	* 1.1408	* 0.6576 *
	* 1.3241	* 1.1716	* 1.3707	* 1.1726	* 1.2988	* 1.1660	* 1.5726	* 2.6634 *
12	* 1.7594	* 1.4621	* 1.7375	* 1.4663	* 1.6205	* 1.8650	* 0.9938	*
	* 1.1671	* 1.2985	* 1.1839	* 1.2994	* 1.1917	* 1.1066	* 1.7170	*
13	* 1.5548	* 1.5646	* 1.4859	* 1.7664	* 1.8647	* 1.7369	* 0.8471	*
	* 1.2289	* 1.2227	* 1.2828	* 1.1662	* 1.1068	* 1.1861	* 2.0907	*
14	* 1.8724	* 1.8610	* 1.7735	* 1.1402	* 0.9923	* 0.8468	*	
	* 1.0961	* 1.1028	* 1.1558	* 1.5744	* 1.7182	* 2.0919	*	
15	* 0.9517	* 0.9597	* 0.8931	* 0.6392	* F-SUB-Q			
	* 1.7908	* 1.8401	* 1.9442	* 2.6529	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3343	* 1.3556	* 1.7055	* 1.4023	* 1.6974	* 1.5141	* 1.8034	* 0.9196 *
	* 1.4223	* 1.3904	* 1.1895	* 1.3424	* 1.1935	* 1.2442	* 1.1213	* 1.8270 *
9	* 1.3556	* 1.6637	* 1.4611	* 1.6926	* 1.4254	* 1.5247	* 1.7928	* 0.9311 *
	* 1.3904	* 1.2197	* 1.2843	* 1.1982	* 1.3144	* 1.2368	* 1.1277	* 1.8638 *
10	* 1.7055	* 1.4587	* 1.2857	* 1.3580	* 1.6809	* 1.4496	* 1.7093	* 0.8647 *
	* 1.1895	* 1.2855	* 1.4735	* 1.3867	* 1.2060	* 1.2958	* 1.1812	* 1.9796 *
11	* 1.4023	* 1.6921	* 1.3575	* 1.6980	* 1.4345	* 1.7055	* 1.1113	* 0.6386 *
	* 1.3424	* 1.1984	* 1.3872	* 1.1952	* 1.3094	* 1.1889	* 1.5906	* 2.7040 *
12	* 1.6974	* 1.4253	* 1.6808	* 1.4333	* 1.5774	* 1.7967	* 0.9643	*
	* 1.1935	* 1.3146	* 1.2061	* 1.3100	* 1.2049	* 1.1297	* 1.7426	*
13	* 1.5141	* 1.5250	* 1.4507	* 1.7052	* 1.7964	* 1.6684	* 0.8175	*
	* 1.2442	* 1.2368	* 1.2954	* 1.1891	* 1.1299	* 1.2137	* 2.1319	*
14	* 1.8034	* 1.7928	* 1.7089	* 1.1106	* 0.9628	* 0.8172	*	
	* 1.1213	* 1.1277	* 1.1816	* 1.5925	* 1.7439	* 2.1331	*	
15	* 0.9196	* 0.9313	* 0.8638	* 0.6203	* F-SUB-Q			
	* 1.8270	* 1.8695	* 1.9815	* 2.6952	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 445 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1784	* 1.1878	* 1.4551	* 1.2293	* 1.4480	* 1.3183	* 1.5353	* 0.8029 *
	* 1.5904	* 1.5673	* 1.3766	* 1.5123	* 1.3812	* 1.4101	* 1.2985	* 2.0650 *
9	* 1.1878	* 1.4259	* 1.2907	* 1.4488	* 1.2439	* 1.3326	* 1.5268	* 0.8135 *
	* 1.5673	* 1.4049	* 1.4356	* 1.3819	* 1.4871	* 1.3964	* 1.3054	* 2.1050 *
10	* 1.4551	* 1.2887	* 1.1368	* 1.1925	* 1.4413	* 1.2754	* 1.4588	* 0.7452 *
	* 1.3766	* 1.4367	* 1.6460	* 1.5587	* 1.3875	* 1.4556	* 1.3645	* 2.2668 *
11	* 1.2293	* 1.4483	* 1.1921	* 1.4564	* 1.2643	* 1.4574	* 0.9717	* 0.5570 *
	* 1.5123	* 1.3821	* 1.5593	* 1.3750	* 1.4655	* 1.3717	* 1.7939	* 3.0615 *
12	* 1.4480	* 1.2438	* 1.4412	* 1.2634	* 1.3871	* 1.5320	* 0.8444	*
	* 1.3812	* 1.4874	* 1.3876	* 1.4661	* 1.3503	* 1.3053	* 1.9623	*
13	* 1.3183	* 1.3328	* 1.2764	* 1.4570	* 1.5318	* 1.4217	* 0.7037	*
	* 1.4101	* 1.3964	* 1.4549	* 1.3720	* 1.3055	* 1.4024	* 2.4419	*
14	* 1.5353	* 1.5268	* 1.4583	* 0.9711	* 0.8431	* 0.7035	*	
	* 1.2985	* 1.3054	* 1.3649	* 1.7962	* 1.9636	* 2.4433	*	
15	* 0.8029	* 0.8137	* 0.7444	* 0.5406	* F-SUB-Q			
	* 2.0650	* 2.1114	* 2.2691	* 3.0539	* M-SUB-Q			

AT 100% POWER, 445 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5680	* 0.5973	* 0.7116	* 0.6155	* 0.7075	* 0.6208	* 0.6845	* 0.3880
	* 3.2550	* 3.0748	* 2.7764	* 2.9799	* 2.7877	* 2.9505	* 2.8688	* 4.2195
9	* 0.5973	* 0.6972	* 0.6187	* 0.7086	* 0.6048	* 0.6254	* 0.6800	* 0.3884
	* 3.0748	* 2.8341	* 2.9528	* 2.7865	* 3.0163	* 2.9315	* 2.8872	* 4.3547
10	* 0.7116	* 0.6180	* 0.5750	* 0.5998	* 0.7043	* 0.6061	* 0.6454	* 0.3607
	* 2.7764	* 2.9541	* 3.2107	* 3.0564	* 2.7993	* 3.0186	* 3.0394	* 4.6262
11	* 0.6155	* 0.7083	* 0.5996	* 0.6998	* 0.6158	* 0.6907	* 0.4783	* 0.2697
	* 2.9799	* 2.7875	* 3.0575	* 2.8206	* 2.9660	* 2.8514	* 3.5949	* 6.2539
12	* 0.7075	* 0.6047	* 0.7042	* 0.6154	* 0.6426	* 0.6832	* 0.4100	
	* 2.7877	* 3.0168	* 2.7997	* 2.9668	* 2.8694	* 2.8821	* 3.9893	
13	* 0.6208	* 0.6255	* 0.6065	* 0.6905	* 0.6831	* 0.6206	* 0.3385	
	* 2.9505	* 2.9318	* 3.0179	* 2.8520	* 2.8826	* 3.1685	* 5.0142	
14	* 0.6845	* 0.6800	* 0.6452	* 0.4780	* 0.4094	* 0.3383		
	* 2.8688	* 2.8873	* 3.0407	* 3.5998	* 3.9911	* 5.0175		
15	* 0.3880	* 0.3886	* 0.3603	* 0.2644	* F-SUB-Q			
	* 4.2195	* 4.3669	* 4.6311	* 6.1772	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3889	* 0.4979	* 0.6077	* 0.5359	* 0.6191	* 0.5319	* 0.5421	* 0.2969
	* 4.3400	* 3.9940	* 3.2436	* 3.6507	* 3.1590	* 3.6999	* 3.6935	* 6.1036
9	* 0.4979	* 0.5772	* 0.5469	* 0.6124	* 0.5334	* 0.5198	* 0.5331	* 0.2920
	* 3.9940	* 3.4628	* 3.6087	* 3.2074	* 3.6718	* 3.7867	* 3.7565	* 6.2231
10	* 0.6077	* 0.5466	* 0.4938	* 0.5140	* 0.5846	* 0.4970	* 0.4781	* 0.2589
	* 3.2436	* 3.6108	* 4.0998	* 3.8272	* 3.3558	* 3.9409	* 4.0906	* 6.8280
11	* 0.5359	* 0.6121	* 0.5138	* 0.5517	* 0.4862	* 0.4868	* 0.3471	* 0.1733
	* 3.6507	* 3.2084	* 3.8288	* 3.6042	* 4.0653	* 3.9831	* 5.2203	* 10.1969
12	* 0.6191	* 0.5333	* 0.5845	* 0.4860	* 0.3808	* 0.3791	* 0.2524	*
	* 3.1590	* 3.6724	* 3.3565	* 4.0669	* 4.1837	* 4.1354	* 6.4295	*
13	* 0.5319	* 0.5199	* 0.4972	* 0.4868	* 0.3790	* 0.3094	* 0.1774	*
	* 3.6999	* 3.7865	* 3.9395	* 3.9831	* 4.1350	* 4.6504	* 8.2196	*
14	* 0.5421	* 0.5332	* 0.4782	* 0.3472	* 0.2523	* 0.1774	*	*
	* 3.6935	* 3.7558	* 4.0897	* 5.2196	* 6.4258	* 8.2204	*	*
15	* 0.2969	* 0.2924	* 0.2589	* 0.1708	* F-SUB-Q			
	* 6.1036	* 6.2174	* 6.8275	* 10.1764	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9039	* 1.1033	* 1.3528	* 1.1723	* 1.3795	* 1.2516	* 1.3719	* 0.6905
	* 1.9597	* 1.8612	* 1.5042	* 1.7320	* 1.4665	* 1.6246	* 1.4990	* 2.6997
9	* 1.1033	* 1.3157	* 1.2608	* 1.3702	* 1.2114	* 1.2423	* 1.3536	* 0.6827
	* 1.8612	* 1.5614	* 1.6168	* 1.4786	* 1.6721	* 1.6394	* 1.5062	* 2.7112
10	* 1.3528	* 1.2598	* 1.1021	* 1.1490	* 1.3353	* 1.1809	* 1.2339	* 0.6070
	* 1.5042	* 1.6181	* 1.8774	* 1.7685	* 1.5174	* 1.7171	* 1.6371	* 3.0016
11	* 1.1723	* 1.3698	* 1.1485	* 1.2817	* 1.1146	* 1.1696	* 0.8124	* 0.4091
	* 1.7320	* 1.4790	* 1.7692	* 1.5945	* 1.8307	* 1.6961	* 2.3100	* 4.4697
12	* 1.3795	* 1.2112	* 1.3350	* 1.1140	* 0.8867	* 0.9675	* 0.5883	*
	* 1.4665	* 1.6723	* 1.5178	* 1.8316	* 1.7823	* 1.6613	* 2.8321	*
13	* 1.2516	* 1.2424	* 1.1815	* 1.1697	* 0.9674	* 0.8158	* 0.4269	*
	* 1.6246	* 1.6392	* 1.7164	* 1.6961	* 1.6611	* 1.8627	* 3.5163	*
14	* 1.3719	* 1.3539	* 1.2342	* 0.8127	* 0.5880	* 0.4268	*	*
	* 1.4990	* 1.5059	* 1.6367	* 2.3095	* 2.8313	* 3.5167	*	*
15	* 0.6905	* 0.6832	* 0.6071	* 0.4037	* F-SUB-Q			
	* 2.6997	* 2.7102	* 3.0011	* 4.4562	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0639	* 1.2396	* 1.2964	* 1.3205	* 1.3536	* 1.4871	* 1.4921	* 0.7891 *
	* 1.7016	* 1.7055	* 1.6124	* 1.5789	* 1.5334	* 1.3988	* 1.3924	* 2.3813 *
9	* 1.2396	* 1.3446	* 1.4213	* 1.3588	* 1.4168	* 1.4907	* 1.4883	* 0.7904 *
	* 1.7055	* 1.5670	* 1.4767	* 1.5317	* 1.4703	* 1.3948	* 1.3945	* 2.3797 *
10	* 1.2964	* 1.4187	* 1.3156	* 1.3190	* 1.3793	* 1.4163	* 1.4333	* 0.7212 *
	* 1.6124	* 1.4795	* 1.5995	* 1.5822	* 1.5086	* 1.4712	* 1.4454	* 2.5858 *
11	* 1.3205	* 1.3582	* 1.3185	* 1.3006	* 1.2955	* 1.3001	* 0.9732	* 0.4963 *
	* 1.5789	* 1.5323	* 1.5829	* 1.6144	* 1.6062	* 1.5612	* 1.9874	* 3.7910 *
12	* 1.3536	* 1.4167	* 1.3794	* 1.2952	* 1.0574	* 1.0796	* 0.6854	*
	* 1.5334	* 1.4703	* 1.5085	* 1.6069	* 1.5343	* 1.5528	* 2.5108	*
13	* 1.4871	* 1.4910	* 1.4171	* 1.3003	* 1.0796	* 1.0224	* 0.5288	*
	* 1.3988	* 1.3946	* 1.4703	* 1.5612	* 1.5525	* 1.5753	* 2.9429	*
14	* 1.4921	* 1.4886	* 1.4338	* 0.9736	* 0.6849	* 0.5287	*	
	* 1.3924	* 1.3942	* 1.4449	* 1.9869	* 2.5105	* 2.9433	*	
15	* 0.7891	* 0.7910	* 0.7214	* 0.4920	* F-SUB-Q			
	* 2.3813	* 2.3788	* 2.5851	* 3.7626	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1526	* 1.3081	* 1.3885	* 1.3923	* 1.4816	* 1.6359	* 1.6587	* 0.8266 *
	* 1.6193	* 1.6829	* 1.5042	* 1.5464	* 1.4451	* 1.3043	* 1.2843	* 2.3296 *
9	* 1.3081	* 1.4709	* 1.5333	* 1.4645	* 1.5418	* 1.6462	* 1.6575	* 0.8348 *
	* 1.6829	* 1.4839	* 1.4159	* 1.4703	* 1.3959	* 1.2977	* 1.2858	* 2.3140 *
10	* 1.3885	* 1.5301	* 1.4249	* 1.4144	* 1.5313	* 1.5623	* 1.6128	* 0.7641 *
	* 1.5042	* 1.4189	* 1.5260	* 1.5307	* 1.4055	* 1.3788	* 1.3249	* 2.5147 *
11	* 1.3923	* 1.4638	* 1.4136	* 1.4301	* 1.4200	* 1.4651	* 1.0493	* 0.5298 *
	* 1.5464	* 1.4710	* 1.5316	* 1.5145	* 1.5111	* 1.4411	* 1.9141	* 3.6785 *
12	* 1.4816	* 1.5417	* 1.5314	* 1.4195	* 1.1706	* 1.2263	* 0.7380 *	
	* 1.4451	* 1.3960	* 1.4054	* 1.5118	* 1.4356	* 1.4377	* 2.4472 *	
13	* 1.6359	* 1.6466	* 1.5635	* 1.4652	* 1.2263	* 1.1957	* 0.5823 *	
	* 1.3043	* 1.2974	* 1.3777	* 1.4411	* 1.4374	* 1.4297	* 2.8294 *	
14	* 1.6587	* 1.6578	* 1.6134	* 1.0498	* 0.7374	* 0.5822 *		
	* 1.2843	* 1.2855	* 1.3244	* 1.9135	* 2.4472	* 2.8297 *		
15	* 0.8266	* 0.8354	* 0.7643	* 0.5241	* F-SUB-Q			
	* 2.3296	* 2.3130	* 2.5140	* 3.6592	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2316	* 1.3590	* 1.4358	* 1.4254	* 1.5457	* 1.7069	* 1.7454	* 0.8531
	* 1.6366	* 1.7069	* 1.5699	* 1.5665	* 1.4340	* 1.2945	* 1.2637	* 2.3390
9	* 1.3590	* 1.5325	* 1.5804	* 1.5244	* 1.6016	* 1.7194	* 1.7457	* 0.8637
	* 1.7069	* 1.4927	* 1.4328	* 1.4677	* 1.3941	* 1.2872	* 1.2650	* 2.3192
10	* 1.4358	* 1.5765	* 1.4673	* 1.4680	* 1.6094	* 1.6326	* 1.7100	* 0.7948
	* 1.5699	* 1.4363	* 1.5482	* 1.5367	* 1.3885	* 1.3667	* 1.2960	* 2.5082
11	* 1.4254	* 1.5235	* 1.4671	* 1.5144	* 1.5124	* 1.5738	* 1.1073	* 0.5520
	* 1.5665	* 1.4684	* 1.5376	* 1.4962	* 1.5012	* 1.4142	* 1.8953	* 3.6682
12	* 1.5457	* 1.6015	* 1.6096	* 1.5118	* 1.2784	* 1.3625	* 0.7907	*
	* 1.4340	* 1.3941	* 1.3884	* 1.5021	* 1.4164	* 1.4112	* 2.4414	*
13	* 1.7069	* 1.7198	* 1.6340	* 1.5740	* 1.3625	* 1.3470	* 0.6360	*
	* 1.2945	* 1.2869	* 1.3655	* 1.4143	* 1.4109	* 1.3923	* 2.8091	*
14	* 1.7454	* 1.7461	* 1.7107	* 1.1077	* 0.7900	* 0.6359	*	
	* 1.2637	* 1.2647	* 1.2955	* 1.8947	* 2.4417	* 2.8095	*	
15	* 0.8531	* 0.8644	* 0.7950	* 0.5450	* F-SUB-Q			
	* 2.3390	* 2.3181	* 2.5075	* 3.6556	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3631	* 1.4049	* 1.4639	* 1.4463	* 1.5803	* 1.7480	* 1.7949	* 0.8737
	* 1.6750	* 1.7510	* 1.6114	* 1.6109	* 1.4561	* 1.3070	* 1.2707	* 2.3651
9	* 1.4049	* 1.5719	* 1.6094	* 1.5598	* 1.6400	* 1.7633	* 1.7969	* 0.8844
	* 1.7510	* 1.5308	* 1.4726	* 1.4989	* 1.4228	* 1.2994	* 1.2716	* 2.3441
10	* 1.4639	* 1.6066	* 1.4933	* 1.5063	* 1.6590	* 1.6796	* 1.7706	* 0.8191
	* 1.6114	* 1.4764	* 1.5926	* 1.5700	* 1.4114	* 1.3850	* 1.3048	* 2.5279
11	* 1.4463	* 1.5589	* 1.5055	* 1.5811	* 1.5930	* 1.6622	* 1.1578	* 0.5705
	* 1.6109	* 1.4997	* 1.5709	* 1.5121	* 1.5189	* 1.4228	* 1.9174	* 3.7261
12	* 1.5803	* 1.6400	* 1.6593	* 1.5924	* 1.4394	* 1.5322	* 0.8465	
	* 1.4561	* 1.4228	* 1.4113	* 1.5199	* 1.4319	* 1.4237	* 2.4669	
13	* 1.7480	* 1.7638	* 1.6812	* 1.6624	* 1.5324	* 1.5107	* 0.6942	
	* 1.3070	* 1.2989	* 1.3837	* 1.4229	* 1.4235	* 1.4017	* 2.8421	
14	* 1.7949	* 1.7974	* 1.7714	* 1.1582	* 0.8456	* 0.6941		
	* 1.2707	* 1.2713	* 1.3042	* 1.9170	* 2.4674	* 2.8426		
15	* 0.8737	* 0.8851	* 0.8192	* 0.5632	* F-SUB-Q			
	* 2.3651	* 2.3429	* 2.5274	* 3.7135	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4946	* 1.4548	* 1.5002	* 1.4723	* 1.6217	* 1.7930	* 1.8501	* 0.8835
	* 1.7064	* 1.7839	* 1.6619	* 1.6674	* 1.4885	* 1.3322	* 1.2884	* 2.4413
9	* 1.4548	* 1.6191	* 1.6464	* 1.6002	* 1.6810	* 1.8116	* 1.8535	* 0.8968
	* 1.7839	* 1.5790	* 1.5244	* 1.5425	* 1.4650	* 1.3242	* 1.2899	* 2.4176
10	* 1.5002	* 1.6435	* 1.5252	* 1.5554	* 1.7168	* 1.7331	* 1.8351	* 0.8311
	* 1.6619	* 1.5286	* 1.6512	* 1.6265	* 1.4440	* 1.4161	* 1.3258	* 2.6158
11	* 1.4723	* 1.5993	* 1.5545	* 1.6623	* 1.6627	* 1.7589	* 1.1924	* 0.5809
	* 1.6674	* 1.5434	* 1.6276	* 1.5255	* 1.5335	* 1.4287	* 1.9856	* 3.8751
12	* 1.6217	* 1.6809	* 1.7173	* 1.6620	* 1.6450	* 1.6949	* 0.8890	*
	* 1.4885	* 1.4650	* 1.4439	* 1.5345	* 1.4445	* 1.4356	* 2.5323	*
13	* 1.7930	* 1.8122	* 1.7347	* 1.7588	* 1.6951	* 1.6741	* 0.7405	*
	* 1.3322	* 1.3237	* 1.4147	* 1.4288	* 1.4354	* 1.4072	* 2.9150	*
14	* 1.8501	* 1.8539	* 1.8359	* 1.1927	* 0.8880	* 0.7404	*	*
	* 1.2884	* 1.2896	* 1.3253	* 1.9852	* 2.5331	* 2.9155	*	*
15	* 0.8835	* 0.8975	* 0.8312	* 0.5714	* F-SUB-Q			
	* 2.4413	* 2.4164	* 2.6154	* 3.8758	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5502	* 1.4907	* 1.5256	* 1.4863	* 1.6451	* 1.8206	* 1.8837	* 0.8909
	* 1.7638	* 1.8470	* 1.7463	* 1.7542	* 1.5525	* 1.3846	* 1.3351	* 2.5524
9	* 1.4907	* 1.6460	* 1.6676	* 1.6280	* 1.7065	* 1.8424	* 1.8883	* 0.9053
	* 1.8470	* 1.6599	* 1.6048	* 1.6175	* 1.5344	* 1.3759	* 1.3370	* 2.5276
10	* 1.5256	* 1.6645	* 1.5434	* 1.5887	* 1.7594	* 1.7682	* 1.8771	* 0.8411
	* 1.7463	* 1.6095	* 1.7403	* 1.7092	* 1.5074	* 1.4751	* 1.3757	* 2.7359
11	* 1.4863	* 1.6269	* 1.5877	* 1.7214	* 1.7123	* 1.8299	* 1.2207	* 0.5895
	* 1.7542	* 1.6185	* 1.7105	* 1.5601	* 1.5691	* 1.4554	* 2.0508	* 4.0681
12	* 1.6451	* 1.7064	* 1.7597	* 1.7116	* 1.7457	* 1.7902	* 0.9217	*
	* 1.5525	* 1.5345	* 1.5072	* 1.5702	* 1.4726	* 1.4604	* 2.5938	*
13	* 1.8206	* 1.8430	* 1.7700	* 1.8297	* 1.7904	* 1.7833	* 0.7763	*
	* 1.3846	* 1.3754	* 1.4736	* 1.4555	* 1.4603	* 1.4320	* 2.9934	*
14	* 1.8837	* 1.8888	* 1.8778	* 1.2210	* 0.9206	* 0.7761	*	*
	* 1.3350	* 1.3367	* 1.3752	* 2.0506	* 2.5949	* 2.9940	*	*
15	* 0.8909	* 0.9061	* 0.8411	* 0.5790	* F-SUB-Q			
	* 2.5524	* 2.5262	* 2.7357	* 4.0747	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5772	* 1.5112	* 1.5472	* 1.4969	* 1.6676	* 1.8450	* 1.9149	* 0.8936 *
	* 1.8481	* 1.9342	* 1.8465	* 1.8596	* 1.6309	* 1.4521	* 1.3954	* 2.7000 *
9	* 1.5112	* 1.6678	* 1.6840	* 1.6529	* 1.7270	* 1.8693	* 1.9204	* 0.9097 *
	* 1.9342	* 1.7381	* 1.7015	* 1.7081	* 1.6209	* 1.4426	* 1.3979	* 2.6728 *
10	* 1.5472	* 1.6806	* 1.5575	* 1.6132	* 1.7973	* 1.7977	* 1.9142	* 0.8457 *
	* 1.8465	* 1.7066	* 1.8478	* 1.7838	* 1.5851	* 1.5502	* 1.4398	* 2.8972 *
11	* 1.4969	* 1.6518	* 1.6121	* 1.7648	* 1.7479	* 1.8829	* 1.2378	* 0.5939 *
	* 1.8596	* 1.7092	* 1.7849	* 1.6152	* 1.6263	* 1.5015	* 2.1251	* 4.3179 *
12	* 1.6676	* 1.7269	* 1.7972	* 1.7466	* 1.8148	* 1.8537	* 0.9406 *	
	* 1.6309	* 1.6210	* 1.5849	* 1.6275	* 1.5217	* 1.5065	* 2.7041 *	
13	* 1.8450	* 1.8700	* 1.7995	* 1.8827	* 1.8539	* 1.8599	* 0.7973 *	
	* 1.4521	* 1.4421	* 1.5485	* 1.5017	* 1.5064	* 1.4709	* 3.1155 *	
14	* 1.9149	* 1.9209	* 1.9150	* 1.2380	* 0.9394	* 0.7971 *		
	* 1.3954	* 1.3975	* 1.4392	* 2.1250	* 2.7054	* 3.1162 *		
15	* 0.8936	* 0.9104	* 0.8457	* 0.5825	* F-SUB-Q			
	* 2.7000	* 2.6713	* 2.8972	* 4.3311	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5638	* 1.4965	* 1.5251	* 1.4794	* 1.6476	* 1.8320	* 1.8979	* 0.8993 *
	* 1.9616	* 2.0494	* 2.0044	* 2.0174	* 1.7668	* 1.5634	* 1.5045	* 2.8694 *
9	* 1.4965	* 1.6463	* 1.6650	* 1.6331	* 1.7154	* 1.8581	* 1.9044	* 0.9124 *
	* 2.0494	* 1.8536	* 1.8306	* 1.8534	* 1.7516	* 1.5525	* 1.5071	* 2.8462 *
10	* 1.5251	* 1.6616	* 1.5412	* 1.6079	* 1.7879	* 1.7892	* 1.9027	* 0.8546 *
	* 2.0044	* 1.8345	* 1.9775	* 1.8841	* 1.6797	* 1.6652	* 1.5525	* 3.0664 *
11	* 1.4794	* 1.6320	* 1.6070	* 1.7584	* 1.7578	* 1.8799	* 1.2569	* 0.6010 *
	* 2.0174	* 1.8547	* 1.8851	* 1.7159	* 1.7104	* 1.5913	* 2.2001	* 4.4870 *
12	* 1.6476	* 1.7153	* 1.7876	* 1.7570	* 1.8280	* 1.8569	* 0.9585	*
	* 1.7668	* 1.7517	* 1.6799	* 1.7112	* 1.6161	* 1.6043	* 2.8234	*
13	* 1.8320	* 1.8588	* 1.7911	* 1.8797	* 1.8570	* 1.8716	* 0.8175	*
	* 1.5634	* 1.5519	* 1.6634	* 1.5915	* 1.6042	* 1.5637	* 3.2468	*
14	* 1.8979	* 1.9049	* 1.9034	* 1.2570	* 0.9572	* 0.8173	*	
	* 1.5045	* 1.5068	* 1.5518	* 2.2001	* 2.8250	* 3.2476	*	
15	* 0.8993	* 0.9132	* 0.8545	* 0.5908	* F-SUB-Q			
	* 2.8694	* 2.8448	* 3.0666	* 4.4908	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5726	* 1.5025	* 1.5416	* 1.4851	* 1.6710	* 1.8546	* 1.9311	* 0.8900 *
	* 2.0579	* 2.1546	* 2.0946	* 2.1561	* 1.8683	* 1.6553	* 1.5842	* 3.0972 *
9	* 1.5025	* 1.6639	* 1.6748	* 1.6563	* 1.7284	* 1.8822	* 1.9378	* 0.9068 *
	* 2.1546	* 1.9375	* 1.9239	* 1.9331	* 1.8413	* 1.6432	* 1.5873	* 3.0646 *
10	* 1.5416	* 1.6712	* 1.5486	* 1.6182	* 1.8214	* 1.8124	* 1.9375	* 0.8459 *
	* 2.0946	* 1.9283	* 2.0812	* 1.9789	* 1.7428	* 1.7380	* 1.6162	* 3.3169 *
11	* 1.4851	* 1.6551	* 1.6170	* 1.7869	* 1.7691	* 1.9174	* 1.2508	* 0.5945 *
	* 2.1561	* 1.9345	* 1.9803	* 1.7835	* 1.7939	* 1.6480	* 2.3359	* 4.7878 *
12	* 1.6710	* 1.7282	* 1.8211	* 1.7677	* 1.8669	* 1.8976	* 0.9526 *	
	* 1.8683	* 1.8414	* 1.7431	* 1.7953	* 1.6806	* 1.6607	* 2.9942 *	
13	* 1.8546	* 1.8830	* 1.8144	* 1.9171	* 1.8977	* 1.9223	* 0.8135 *	
	* 1.6553	* 1.6425	* 1.7361	* 1.6482	* 1.6607	* 1.6197	* 3.4621 *	
14	* 1.9311	* 1.9383	* 1.9382	* 1.2509	* 0.9513	* 0.8133 *		
	* 1.5842	* 1.5869	* 1.6156	* 2.3360	* 2.9961	* 3.4630 *		
15	* 0.8900	* 0.9076	* 0.8458	* 0.5818	* F-SUB-Q			
	* 3.0972	* 3.0629	* 3.3173	* 4.8135	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5581	* 1.4873	* 1.5291	* 1.4711	* 1.6642	* 1.8495	* 1.9294	* 0.8838 *
	* 2.0942	* 2.1858	* 2.1179	* 2.1919	* 1.9382	* 1.7460	* 1.6732	* 3.3280 *
9	* 1.4873	* 1.6517	* 1.6598	* 1.6484	* 1.7187	* 1.8787	* 1.9363	* 0.9007 *
	* 2.1858	* 1.9613	* 1.9518	* 1.9639	* 1.8851	* 1.7216	* 1.6690	* 3.2764 *
10	* 1.5291	* 1.6561	* 1.5345	* 1.6093	* 1.8200	* 1.8084	* 1.9376	* 0.8413 *
	* 2.1179	* 1.9562	* 2.1104	* 2.0205	* 1.7935	* 1.7959	* 1.6749	* 3.4901 *
11	* 1.4711	* 1.6471	* 1.6081	* 1.7833	* 1.7653	* 1.9190	* 1.2483	* 0.5909 *
	* 2.1919	* 1.9655	* 2.0220	* 1.8351	* 1.8549	* 1.7074	* 2.4216	* 5.0272 *
12	* 1.6642	* 1.7185	* 1.8196	* 1.7638	* 1.8731	* 1.9013	* 0.9496 *	
	* 1.9382	* 1.8853	* 1.7938	* 1.8565	* 1.7698	* 1.7349	* 3.1442 *	
13	* 1.8495	* 1.8795	* 1.8104	* 1.9187	* 1.9013	* 1.9330	* 0.8127 *	
	* 1.7460	* 1.7209	* 1.7939	* 1.7077	* 1.7348	* 1.7062	* 3.6672 *	
14	* 1.9294	* 1.9368	* 1.9383	* 1.2483	* 0.9482	* 0.8125 *		
	* 1.6732	* 1.6686	* 1.6744	* 2.4219	* 3.1463	* 3.6682 *		
15	* 0.8838	* 0.9014	* 0.8411	* 0.5776	* F-SUB-Q			
	* 3.3280	* 3.2747	* 3.4909	* 5.0602	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5238	* 1.4535	* 1.4908	* 1.4388	* 1.6300	* 1.8201	* 1.8965	* 0.8788
	* 2.0988	* 2.1917	* 2.1285	* 2.1958	* 1.9370	* 1.7361	* 1.6656	* 3.2675
9	* 1.4535	* 1.6122	* 1.6229	* 1.6120	* 1.6887	* 1.8502	* 1.9038	* 0.8930
	* 2.1917	* 1.9691	* 1.9558	* 1.9685	* 1.8807	* 1.7124	* 1.6623	* 3.2283
10	* 1.4908	* 1.6192	* 1.5016	* 1.5842	* 1.7870	* 1.7804	* 1.9066	* 0.8388
	* 2.1285	* 1.9606	* 2.1131	* 2.0173	* 1.7937	* 1.7892	* 1.6697	* 3.4285
11	* 1.4388	* 1.6107	* 1.5832	* 1.7510	* 1.7459	* 1.8881	* 1.2466	* 0.5888
	* 2.1958	* 1.9701	* 2.0189	* 1.8362	* 1.8378	* 1.7057	* 2.3800	* 4.9452
12	* 1.6300	* 1.6885	* 1.7866	* 1.7449	* 1.8515	* 1.8725	* 0.9484	*
	* 1.9370	* 1.8809	* 1.7938	* 1.8388	* 1.7666	* 1.7334	* 3.0954	*
13	* 1.8201	* 1.8510	* 1.7824	* 1.8877	* 1.8725	* 1.9087	* 0.8144	*
	* 1.7361	* 1.7117	* 1.7872	* 1.7060	* 1.7334	* 1.7126	* 3.6155	*
14	* 1.8965	* 1.9043	* 1.9073	* 1.2466	* 0.9469	* 0.8141	*	*
	* 1.6656	* 1.6619	* 1.6691	* 2.3804	* 3.0976	* 3.6167	*	*
15	* 0.8788	* 0.8938	* 0.8385	* 0.5768	* F-SUB-Q			
	* 3.2675	* 3.2265	* 3.4295	* 4.9669	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5120	* 1.4403	* 1.4872	* 1.4267	* 1.6334	* 1.8219	* 1.9078	* 0.8602
	* 2.0241	* 2.1091	* 2.0317	* 2.1113	* 1.8663	* 1.6743	* 1.5978	* 3.1930
9	* 1.4403	* 1.6092	* 1.6121	* 1.6136	* 1.6801	* 1.8529	* 1.9149	* 0.8777
	* 2.1091	* 1.8859	* 1.8844	* 1.8898	* 1.8266	* 1.6562	* 1.5986	* 3.1496
10	* 1.4872	* 1.6080	* 1.4898	* 1.5718	* 1.7943	* 1.7812	* 1.9174	* 0.8209
	* 2.0317	* 1.8883	* 2.0357	* 1.9573	* 1.7357	* 1.7356	* 1.6105	* 3.3519
11	* 1.4267	* 1.6122	* 1.5705	* 1.7524	* 1.7345	* 1.8967	* 1.2243	* 0.5752
	* 2.1113	* 1.8914	* 1.9589	* 1.7776	* 1.8040	* 1.6531	* 2.3415	* 4.8206
12	* 1.6334	* 1.6800	* 1.7939	* 1.7328	* 1.8597	* 1.8829	* 0.9282	*
	* 1.8663	* 1.8269	* 1.7354	* 1.8060	* 1.7217	* 1.6771	* 3.0295	*
13	* 1.8219	* 1.8537	* 1.7833	* 1.8963	* 1.8828	* 1.9272	* 0.7971	*
	* 1.6743	* 1.6555	* 1.7336	* 1.6535	* 1.6771	* 1.6507	* 3.5285	*
14	* 1.9078	* 1.9154	* 1.9181	* 1.2242	* 0.9267	* 0.7968	*	*
	* 1.5978	* 1.5982	* 1.6100	* 2.3419	* 3.0319	* 3.5297	*	*
15	* 0.8602	* 0.8784	* 0.8206	* 0.5608	* F-SUB-Q			
	* 3.1930	* 3.1478	* 3.3532	* 4.8654	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4855	* 1.4139	* 1.4640	* 1.4015	* 1.6148	* 1.8036	* 1.8934	* 0.8442 *
	* 1.8725	* 1.9536	* 1.8795	* 1.9607	* 1.7268	* 1.5552	* 1.4802	* 2.9735 *
9	* 1.4139	* 1.5853	* 1.5853	* 1.5932	* 1.6564	* 1.8352	* 1.9004	* 0.8623 *
	* 1.9536	* 1.7435	* 1.7463	* 1.7449	* 1.6900	* 1.5352	* 1.4790	* 2.9267 *
10	* 1.4640	* 1.5804	* 1.4641	* 1.5487	* 1.7772	* 1.7624	* 1.9031	* 0.8062 *
	* 1.8795	* 1.7503	* 1.8873	* 1.8073	* 1.5956	* 1.6035	* 1.4836	* 3.1203 *
11	* 1.4015	* 1.5918	* 1.5474	* 1.7320	* 1.7137	* 1.8806	* 1.2052	* 0.5639 *
	* 1.9607	* 1.7464	* 1.8088	* 1.6366	* 1.6614	* 1.5173	* 2.1651	* 4.4877 *
12	* 1.6148	* 1.6562	* 1.7768	* 1.7119	* 1.8467	* 1.8681	* 0.9121	*
	* 1.7268	* 1.6903	* 1.5954	* 1.6630	* 1.5773	* 1.5384	* 2.8099	*
13	* 1.8036	* 1.8361	* 1.7647	* 1.8802	* 1.8680	* 1.9189	* 0.7842	*
	* 1.5552	* 1.5346	* 1.6016	* 1.5177	* 1.5385	* 1.5076	* 3.2670	*
14	* 1.8934	* 1.9009	* 1.9037	* 1.2051	* 0.9106	* 0.7839	*	
	* 1.4802	* 1.4787	* 1.4832	* 2.1656	* 2.8123	* 3.2681	*	
15	* 0.8442	* 0.8631	* 0.8059	* 0.5490	F-SUB-Q			
	* 2.9735	* 2.9251	* 3.1216	* 4.5353	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4524	* 1.3813	* 1.4315	* 1.3703	* 1.5848	* 1.7735	* 1.8638	* 0.8298 *
	* 1.7582	* 1.8364	* 1.7669	* 1.8450	* 1.6130	* 1.4514	* 1.3800	* 2.7816 *
9	* 1.3813	* 1.5513	* 1.5509	* 1.5615	* 1.6242	* 1.8057	* 1.8708	* 0.8471 *
	* 1.8364	* 1.6374	* 1.6412	* 1.6372	* 1.5854	* 1.4302	* 1.3776	* 2.7359 *
10	* 1.4315	* 1.5452	* 1.4315	* 1.5179	* 1.7464	* 1.7326	* 1.8738	* 0.7935 *
	* 1.7669	* 1.6456	* 1.7744	* 1.6934	* 1.4890	* 1.5000	* 1.3858	* 2.9132 *
11	* 1.3703	* 1.5600	* 1.5166	* 1.7007	* 1.6826	* 1.8502	* 1.1882	* 0.5545 *
	* 1.8450	* 1.6386	* 1.6948	* 1.5281	* 1.5511	* 1.4133	* 2.0173	* 4.2023 *
12	* 1.5848	* 1.6240	* 1.7460	* 1.6810	* 1.8200	* 1.8389	* 0.8974	*
	* 1.6130	* 1.5856	* 1.4893	* 1.5521	* 1.4656	* 1.4323	* 2.6223	*
13	* 1.7735	* 1.8065	* 1.7350	* 1.8498	* 1.8388	* 1.8929	* 0.7726	*
	* 1.4514	* 1.4295	* 1.4981	* 1.4136	* 1.4324	* 1.3990	* 3.0426	*
14	* 1.8638	* 1.8713	* 1.8744	* 1.1881	* 0.8959	* 0.7723	*	
	* 1.3800	* 1.3772	* 1.3854	* 2.0179	* 2.6247	* 3.0437	*	
15	* 0.8298	* 0.8479	* 0.7931	* 0.5395	F-SUB-Q			
	* 2.7816	* 2.7344	* 2.9146	* 4.2498	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4103	* 1.3409	* 1.3867	* 1.3312	* 1.5395	* 1.7293	* 1.8153	* 0.8178 *
	* 1.8080	* 1.8893	* 1.8221	* 1.8910	* 1.6571	* 1.4858	* 1.4144	* 2.8229 *
9	* 1.3409	* 1.5039	* 1.5064	* 1.5150	* 1.5820	* 1.7616	* 1.8224	* 0.8323 *
	* 1.8893	* 1.6854	* 1.6842	* 1.6824	* 1.6209	* 1.4619	* 1.4107	* 2.7831 *
10	* 1.3867	* 1.5006	* 1.3905	* 1.4810	* 1.6986	* 1.6895	* 1.8263	* 0.7834 *
	* 1.8221	* 1.6904	* 1.8215	* 1.7377	* 1.5297	* 1.5330	* 1.4159	* 2.9430 *
11	* 1.3312	* 1.5136	* 1.4799	* 1.6542	* 1.6465	* 1.8023	* 1.1740	* 0.5469 *
	* 1.8910	* 1.6840	* 1.7392	* 1.5688	* 1.5779	* 1.4480	* 2.0421	* 4.2583 *
12	* 1.5395	* 1.5818	* 1.6982	* 1.6455	* 1.7782	* 1.7916	* 0.8866	*
	* 1.6571	* 1.6211	* 1.5300	* 1.5790	* 1.4928	* 1.4650	* 2.6521	*
13	* 1.7293	* 1.7625	* 1.6917	* 1.8018	* 1.7915	* 1.8473	* 0.7649	*
	* 1.4858	* 1.4612	* 1.5311	* 1.4483	* 1.4651	* 1.4267	* 3.0677	*
14	* 1.8153	* 1.8229	* 1.8269	* 1.1739	* 0.8851	* 0.7646	*	
	* 1.4144	* 1.4103	* 1.4155	* 2.0427	* 2.6545	* 3.0688	*	
15	* 0.8178	* 0.8330	* 0.7830	* 0.5336	F-SUB-Q			
	* 2.8229	* 2.7816	* 2.9445	* 4.2934	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3928	* 1.3229	* 1.3781	* 1.3132	* 1.5326	* 1.7171	* 1.8120	* 0.7923
	* 1.6918	* 1.7739	* 1.7004	* 1.7837	* 1.5515	* 1.3948	* 1.3209	* 2.7212
9	* 1.3229	* 1.4949	* 1.4890	* 1.5075	* 1.5621	* 1.7499	* 1.8187	* 0.8100
	* 1.7739	* 1.5730	* 1.5827	* 1.5709	* 1.5258	* 1.3709	* 1.3170	* 2.6692
10	* 1.3781	* 1.4829	* 1.3721	* 1.4584	* 1.6922	* 1.6753	* 1.8213	* 0.7582
	* 1.7004	* 1.5877	* 1.7139	* 1.6334	* 1.4244	* 1.4359	* 1.3189	* 2.8335
11	* 1.3132	* 1.5060	* 1.4571	* 1.6458	* 1.6229	* 1.7950	* 1.1401	* 0.5285
	* 1.7837	* 1.5724	* 1.6349	* 1.4678	* 1.4912	* 1.3509	* 1.9508	* 4.0944
12	* 1.5326	* 1.5619	* 1.6918	* 1.6212	* 1.7682	* 1.7849	* 0.8578	
	* 1.5515	* 1.5261	* 1.4248	* 1.4927	* 1.3905	* 1.3674	* 2.5535	
13	* 1.7171	* 1.7508	* 1.6777	* 1.7946	* 1.7848	* 1.8457	* 0.7389	
	* 1.3948	* 1.3702	* 1.4339	* 1.3512	* 1.3675	* 1.3266	* 2.9600	
14	* 1.8120	* 1.8192	* 1.8219	* 1.1400	* 0.8563	* 0.7386		
	* 1.3209	* 1.3167	* 1.3185	* 1.9513	* 2.5560	* 2.9610		
15	* 0.7923	* 0.8107	* 0.7579	* 0.5131	* F-SUB-Q			
	* 2.7212	* 2.6678	* 2.8350	* 4.1491	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3616	* 1.2925	* 1.3478	* 1.2824	* 1.4995	* 1.6814	* 1.7751	* 0.7720 *
	* 1.6175	* 1.7005	* 1.6316	* 1.7172	* 1.4922	* 1.3401	* 1.2686	* 2.6330 *
9	* 1.2925	* 1.4631	* 1.4563	* 1.4739	* 1.5262	* 1.7138	* 1.7815	* 0.7893 *
	* 1.7005	* 1.5082	* 1.5196	* 1.5089	* 1.4670	* 1.3162	* 1.2645	* 2.5811 *
10	* 1.3478	* 1.4502	* 1.3410	* 1.4241	* 1.6554	* 1.6392	* 1.7833	* 0.7389 *
	* 1.6316	* 1.5240	* 1.6466	* 1.5678	* 1.3621	* 1.3773	* 1.2644	* 2.7374 *
11	* 1.2824	* 1.4725	* 1.4227	* 1.6096	* 1.5861	* 1.7561	* 1.1136	* 0.5147 *
	* 1.7172	* 1.5103	* 1.5693	* 1.4028	* 1.4254	* 1.2890	* 1.8716	* 3.9512 *
12	* 1.4995	* 1.5260	* 1.6550	* 1.5844	* 1.7318	* 1.7462	* 0.8359 *	
	* 1.4922	* 1.4672	* 1.3625	* 1.4269	* 1.3236	* 1.3036	* 2.4487 *	
13	* 1.6814	* 1.7147	* 1.6417	* 1.7557	* 1.7460	* 1.8070	* 0.7196 *	
	* 1.3401	* 1.3155	* 1.3754	* 1.2893	* 1.3037	* 1.2669	* 2.8432 *	
14	* 1.7751	* 1.7820	* 1.7839	* 1.1135	* 0.8344	* 0.7194 *		
	* 1.2686	* 1.2642	* 1.2640	* 1.8721	* 2.4511	* 2.8443 *		
15	* 0.7720	* 0.7901	* 0.7385	* 0.4994	* F-SUB-Q			
	* 2.6330	* 2.5797	* 2.7390	* 4.0065	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3151	* 1.2485	* 1.2924	* 1.2383	* 1.4355	* 1.6178	* 1.6972	* 0.7564 *
	* 1.5871	* 1.6692	* 1.6148	* 1.6887	* 1.4809	* 1.3226	* 1.2599	* 2.5576 *
9	* 1.2485	* 1.4044	* 1.4065	* 1.4099	* 1.4716	* 1.6488	* 1.7035	* 0.7698 *
	* 1.6692	* 1.4905	* 1.4930	* 1.4969	* 1.4435	* 1.2986	* 1.2555	* 2.5183 *
10	* 1.2924	* 1.4008	* 1.2957	* 1.3747	* 1.5819	* 1.5771	* 1.7043	* 0.7244 *
	* 1.6148	* 1.4970	* 1.6173	* 1.5413	* 1.3490	* 1.3574	* 1.2545	* 2.6552 *
11	* 1.2383	* 1.4084	* 1.3736	* 1.5389	* 1.5328	* 1.6786	* 1.0931	* 0.5052 *
	* 1.6887	* 1.4984	* 1.5427	* 1.3857	* 1.3926	* 1.2745	* 1.8073	* 3.8254 *
12	* 1.4355	* 1.4715	* 1.5814	* 1.5317	* 1.6637	* 1.6687	* 0.8205 *	
	* 1.4809	* 1.4437	* 1.3494	* 1.3935	* 1.2976	* 1.2872	* 2.3598 *	
13	* 1.6178	* 1.6497	* 1.5793	* 1.6782	* 1.6685	* 1.7221	* 0.7064 *	
	* 1.3226	* 1.2980	* 1.3557	* 1.2749	* 1.2873	* 1.2512	* 2.7345 *	
14	* 1.6972	* 1.7040	* 1.7048	* 1.0929	* 0.8191	* 0.7061 *		
	* 1.2599	* 1.2551	* 1.2541	* 1.8079	* 2.3619	* 2.7355 *		
15	* 0.7564	* 0.7706	* 0.7240	* 0.4924	* F-SUB-Q			
	* 2.5576	* 2.5169	* 2.6568	* 3.8615	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2901	* 1.2249	* 1.2705	* 1.2205	* 1.4028	* 1.5785	* 1.6514	* 0.7252
	* 1.5501	* 1.6304	* 1.5744	* 1.6427	* 1.4530	* 1.2989	* 1.2408	* 2.5623
9	* 1.2249	* 1.3786	* 1.3833	* 1.3799	* 1.4360	* 1.6072	* 1.6566	* 0.7408
	* 1.6304	* 1.4548	* 1.4540	* 1.4655	* 1.4173	* 1.2762	* 1.2370	* 2.5134
10	* 1.2705	* 1.3780	* 1.2719	* 1.3391	* 1.5401	* 1.5351	* 1.6518	* 0.6916
	* 1.5744	* 1.4580	* 1.5793	* 1.5129	* 1.3254	* 1.3353	* 1.2394	* 2.6705
11	* 1.2205	* 1.3786	* 1.3378	* 1.5012	* 1.4874	* 1.6297	* 1.0463	* 0.4820
	* 1.6427	* 1.4669	* 1.5143	* 1.3613	* 1.3747	* 1.2547	* 1.8084	* 3.8496
12	* 1.4028	* 1.4358	* 1.5396	* 1.4857	* 1.6196	* 1.6201	* 0.7834	*
	* 1.4530	* 1.4176	* 1.3258	* 1.3761	* 1.2715	* 1.2662	* 2.3657	*
13	* 1.5785	* 1.6080	* 1.5372	* 1.6293	* 1.6200	* 1.6648	* 0.6700	*
	* 1.2989	* 1.2756	* 1.3335	* 1.2551	* 1.2663	* 1.2341	* 2.7563	*
14	* 1.6514	* 1.6570	* 1.6523	* 1.0461	* 0.7820	* 0.6697	*	*
	* 1.2408	* 1.2367	* 1.2391	* 1.8090	* 2.3680	* 2.7574	*	*
15	* 0.7252	* 0.7415	* 0.6911	* 0.4678	* F-SUB-Q			
	* 2.5623	* 2.5119	* 2.6722	* 3.9026	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2146	* 1.1671	* 1.2204	* 1.1871	* 1.3164	* 1.4775	* 1.5380	* 0.6955
	* 1.5931	* 1.6548	* 1.4939	* 1.6337	* 1.4497	* 1.3412	* 1.2877	* 2.5876
9	* 1.1671	* 1.3006	* 1.3157	* 1.3059	* 1.3557	* 1.5017	* 1.5408	* 0.7082
	* 1.6548	* 1.4867	* 1.4791	* 1.4581	* 1.4512	* 1.3201	* 1.2854	* 2.5475
10	* 1.2204	* 1.3106	* 1.2016	* 1.2740	* 1.4387	* 1.4287	* 1.5236	* 0.6546
	* 1.4939	* 1.4841	* 1.6174	* 1.5369	* 1.3700	* 1.3867	* 1.2987	* 2.7342
11	* 1.1871	* 1.3046	* 1.2728	* 1.4098	* 1.4017	* 1.5170	* 0.9857	* 0.4521
	* 1.6337	* 1.4596	* 1.5383	* 1.3846	* 1.4085	* 1.3012	* 1.8571	* 3.9810
12	* 1.3164	* 1.3555	* 1.4383	* 1.4002	* 1.5201	* 1.5123	* 0.7460	*
	* 1.4497	* 1.4514	* 1.3704	* 1.4100	* 1.3063	* 1.3088	* 2.4026	*
13	* 1.4775	* 1.5024	* 1.4305	* 1.5166	* 1.5122	* 1.5277	* 0.6276	*
	* 1.3412	* 1.3195	* 1.3850	* 1.3015	* 1.3089	* 1.2970	* 2.8457	*
14	* 1.5380	* 1.5412	* 1.5239	* 0.9854	* 0.7447	* 0.6274	*	*
	* 1.2877	* 1.2851	* 1.2984	* 1.8578	* 2.4049	* 2.8469	*	*
15	* 0.6955	* 0.7088	* 0.6542	* 0.4385	* F-SUB-Q			
	* 2.5876	* 2.5462	* 2.7361	* 4.0390	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0045	* 1.0265	* 1.2621	* 1.0491	* 1.3184	* 1.2199	* 1.4015	* 0.6112 *
	* 1.8787	* 1.8359	* 1.4939	* 1.8049	* 1.4497	* 1.5814	* 1.3751	* 2.8774 *
9	* 1.0265	* 1.2674	* 1.1243	* 1.3023	* 1.1265	* 1.2381	* 1.3913	* 0.6186 *
	* 1.8359	* 1.4867	* 1.6821	* 1.4581	* 1.6943	* 1.5579	* 1.3853	* 2.8496 *
10	* 1.2621	* 1.1225	* 0.9947	* 1.1034	* 1.3765	* 1.1930	* 1.3018	* 0.5604 *
	* 1.4939	* 1.6841	* 1.9047	* 1.7320	* 1.3912	* 1.6106	* 1.4804	* 3.1210 *
11	* 1.0491	* 1.3009	* 1.1026	* 1.3831	* 1.1772	* 1.3607	* 0.8405	* 0.3791 *
	* 1.8049	* 1.4596	* 1.7333	* 1.3846	* 1.6319	* 1.4118	* 2.1242	* 4.6443 *
12	* 1.3184	* 1.1256	* 1.3762	* 1.1764	* 1.2738	* 1.3876	* 0.6603	*
	* 1.4497	* 1.6956	* 1.3916	* 1.6330	* 1.5160	* 1.3892	* 2.6488	*
13	* 1.2199	* 1.2386	* 1.1945	* 1.3604	* 1.3873	* 1.2446	* 0.5240	*
	* 1.5814	* 1.5573	* 1.6086	* 1.4121	* 1.3895	* 1.5511	* 3.3279	*
14	* 1.4015	* 1.3917	* 1.3019	* 0.8402	* 0.6593	* 0.5238	*	
	* 1.3751	* 1.3850	* 1.4804	* 2.1251	* 2.6510	* 3.3292	*	
15	* 0.6112	* 0.6191	* 0.5600	* 0.3679	* F-SUB-Q			
	* 2.8774	* 2.8483	* 3.1233	* 4.7093	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4035	* 0.4370	* 0.5241	* 0.4547	* 0.5395	* 0.4732	* 0.5061	* 0.2576 *
	* 4.5715	* 4.2206	* 3.5188	* 4.0824	* 3.4569	* 3.9803	* 3.7225	* 6.6940 *
9	* 0.4370	* 0.5140	* 0.4583	* 0.5321	* 0.4610	* 0.4769	* 0.5010	* 0.2569 *
	* 4.2206	* 3.5858	* 4.0387	* 3.4849	* 4.0493	* 3.9512	* 3.7607	* 6.7294 *
10	* 0.5241	* 0.4574	* 0.4215	* 0.4654	* 0.5520	* 0.4682	* 0.4619	* 0.2343 *
	* 3.5188	* 4.0463	* 4.4039	* 4.0156	* 3.3864	* 4.0131	* 4.0795	* 7.3201 *
11	* 0.4547	* 0.5316	* 0.4651	* 0.5467	* 0.4782	* 0.5220	* 0.3481	* 0.1590 *
	* 4.0824	* 3.4885	* 4.0183	* 3.4168	* 3.9253	* 3.6004	* 5.0185	* 10.8724 *
12	* 0.5395	* 0.4606	* 0.5518	* 0.4778	* 0.4844	* 0.5030	* 0.2777	*
	* 3.4569	* 4.0521	* 3.3877	* 3.9284	* 3.8946	* 3.7458	* 6.1723	*
13	* 0.4732	* 0.4770	* 0.4685	* 0.5219	* 0.5029	* 0.4412	* 0.2164	*
	* 3.9803	* 3.9500	* 4.0103	* 3.6012	* 3.7466	* 4.2784	* 7.8988	*
14	* 0.5061	* 0.5011	* 0.4619	* 0.3480	* 0.2774	* 0.2164	*	
	* 3.7225	* 3.7600	* 4.0798	* 5.0210	* 6.1751	* 7.9024	*	
15	* 0.2576	* 0.2571	* 0.2341	* 0.1557	* F-SUB-Q			
	* 6.6940	* 6.7262	* 7.3254	* 10.9212	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3496	* 0.4423	* 0.5432	* 0.4779	* 0.5475	* 0.4681	* 0.4782	* 0.2620 *
	* 4.7936	* 4.4875	* 3.6225	* 4.0961	* 3.5632	* 4.1922	* 4.1715	* 6.8773 *
9	* 0.4423	* 0.5156	* 0.4852	* 0.5444	* 0.4715	* 0.4583	* 0.4702	* 0.2577 *
	* 4.4875	* 3.8671	* 4.0602	* 3.5991	* 4.1409	* 4.2797	* 4.2441	* 7.0138 *
10	* 0.5432	* 0.4848	* 0.4395	* 0.4535	* 0.5165	* 0.4373	* 0.4229	* 0.2283 *
	* 3.6225	* 4.0626	* 4.5921	* 4.3420	* 3.7901	* 4.4692	* 4.6117	* 7.7050 *
11	* 0.4779	* 0.5442	* 0.4532	* 0.4876	* 0.4266	* 0.4297	* 0.3044	* 0.1531 *
	* 4.0961	* 3.6003	* 4.3443	* 4.0705	* 4.6275	* 4.4394	* 5.9241	* 11.4958 *
12	* 0.5475	* 0.4714	* 0.5164	* 0.4264	* 0.3360	* 0.3360	* 0.2228	*
	* 3.5633	* 4.1414	* 3.7910	* 4.6295	* 4.6568	* 4.5961	* 7.1400	*
13	* 0.4681	* 0.4583	* 0.4374	* 0.4298	* 0.3360	* 0.2759	* 0.1575	*
	* 4.1922	* 4.2795	* 4.4676	* 4.4394	* 4.5955	* 5.1357	* 9.0807	*
14	* 0.4782	* 0.4703	* 0.4230	* 0.3044	* 0.2227	* 0.1575	*	*
	* 4.1715	* 4.2433	* 4.6107	* 5.9234	* 7.1359	* 9.0816	*	*
15	* 0.2620	* 0.2580	* 0.2283	* 0.1509	F-SUB-Q			
	* 6.8773	* 7.0076	* 7.7044	* 11.4844	M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8266	* 0.9997	* 1.2377	* 1.0720	* 1.2479	* 1.1250	* 1.2300	* 0.6220 *
	* 2.1381	* 2.0483	* 1.6398	* 1.8885	* 1.6161	* 1.8007	* 1.6649	* 2.9766 *
9	* 0.9997	* 1.1962	* 1.1394	* 1.2464	* 1.0994	* 1.1122	* 1.2126	* 0.6143 *
	* 2.0483	* 1.7115	* 1.7841	* 1.6220	* 1.8379	* 1.8242	* 1.6750	* 2.9946 *
10	* 1.2377	* 1.1386	* 0.9982	* 1.0287	* 1.2022	* 1.0573	* 1.1048	* 0.5455 *
	* 1.6398	* 1.7854	* 2.0642	* 1.9698	* 1.6808	* 1.9121	* 1.8228	* 3.3220 *
11	* 1.0720	* 1.2459	* 1.0282	* 1.1537	* 0.9949	* 1.0484	* 0.7237	* 0.3678 *
	* 1.8885	* 1.6224	* 1.9706	* 1.7661	* 2.0349	* 1.8666	* 2.5775	* 4.9475 *
12	* 1.2479	* 1.0992	* 1.2020	* 0.9944	* 0.7985	* 0.8710	* 0.5294	*
	* 1.6161	* 1.8382	* 1.6812	* 2.0360	* 1.9565	* 1.8221	* 3.0912	*
13	* 1.1250	* 1.1124	* 1.0578	* 1.0485	* 0.8710	* 0.7373	* 0.3852	*
	* 1.8007	* 1.8240	* 1.9112	* 1.8666	* 1.8219	* 2.0340	* 3.8286	*
14	* 1.2300	* 1.2129	* 1.1051	* 0.7240	* 0.5291	* 0.3852	*	*
	* 1.6649	* 1.6746	* 1.8224	* 2.5770	* 3.0903	* 3.8290	*	*
15	* 0.6220	* 0.6147	* 0.5456	* 0.3630	F-SUB-Q			
	* 2.9766	* 2.9937	* 3.3214	* 4.9368	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0063	* 1.1842	* 1.2889	* 1.2694	* 1.3201	* 1.3758	* 1.3980	* 0.7358 *
	* 1.8126	* 1.7794	* 1.6186	* 1.6390	* 1.5674	* 1.5069	* 1.4814	* 2.5398 *
9	* 1.1842	* 1.3094	* 1.3428	* 1.3419	* 1.3188	* 1.3722	* 1.3854	* 0.7355 *
	* 1.7794	* 1.6047	* 1.5583	* 1.5468	* 1.5736	* 1.5103	* 1.4939	* 2.5439 *
10	* 1.2889	* 1.3403	* 1.2256	* 1.2371	* 1.3193	* 1.3026	* 1.3322	* 0.6680 *
	* 1.6186	* 1.5608	* 1.7107	* 1.6826	* 1.5754	* 1.5954	* 1.5506	* 2.7768 *
11	* 1.2694	* 1.3413	* 1.2365	* 1.2662	* 1.1978	* 1.2277	* 0.8925	* 0.4566 *
	* 1.6390	* 1.5473	* 1.6833	* 1.6510	* 1.7123	* 1.6361	* 2.1527	* 4.0993 *
12	* 1.3201	* 1.3186	* 1.3189	* 1.1972	* 0.9817	* 1.0157	* 0.6387	*
	* 1.5674	* 1.5739	* 1.5758	* 1.7131	* 1.6444	* 1.6367	* 2.6476	*
13	* 1.3758	* 1.3724	* 1.3034	* 1.2278	* 1.0157	* 0.9479	* 0.4890	*
	* 1.5069	* 1.5101	* 1.5944	* 1.6361	* 1.6365	* 1.6746	* 3.1283	*
14	* 1.3980	* 1.3857	* 1.3326	* 0.8928	* 0.6383	* 0.4889	*	
	* 1.4814	* 1.4937	* 1.5501	* 2.1522	* 2.6472	* 3.1286	*	
15	* 0.7358	* 0.7360	* 0.6682	* 0.4526	F-SUB-Q			
	* 2.5398	* 2.5430	* 2.7761	* 4.0728	M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1201	* 1.2954	* 1.4348	* 1.3916	* 1.4844	* 1.5464	* 1.5972	* 0.7936 *
	* 1.6873	* 1.6907	* 1.5057	* 1.5458	* 1.4369	* 1.3760	* 1.3303	* 2.4146 *
9	* 1.2954	* 1.4820	* 1.4906	* 1.5052	* 1.4639	* 1.5478	* 1.5834	* 0.7986 *
	* 1.6907	* 1.4700	* 1.4508	* 1.4249	* 1.4658	* 1.3763	* 1.3427	* 2.4069 *
10	* 1.4348	* 1.4875	* 1.3612	* 1.3711	* 1.5072	* 1.4650	* 1.5348	* 0.7256 *
	* 1.5057	* 1.4539	* 1.5918	* 1.5737	* 1.4263	* 1.4660	* 1.3880	* 2.6342 *
11	* 1.3916	* 1.5046	* 1.3703	* 1.4435	* 1.3404	* 1.4211	* 0.9841	* 0.4976 *
	* 1.5458	* 1.4255	* 1.5747	* 1.4969	* 1.5739	* 1.4700	* 2.0264	* 3.8950 *
12	* 1.4844	* 1.4638	* 1.5072	* 1.3399	* 1.1112	* 1.1836	* 0.7053	*
	* 1.4369	* 1.4658	* 1.4262	* 1.5748	* 1.5001	* 1.4759	* 2.5146	*
13	* 1.5464	* 1.5481	* 1.4660	* 1.4212	* 1.1836	* 1.1294	* 0.5488	*
	* 1.3760	* 1.3760	* 1.4649	* 1.4700	* 1.4757	* 1.4896	* 2.9460	*
14	* 1.5972	* 1.5837	* 1.5355	* 0.9846	* 0.7047	* 0.5487	*	
	* 1.3303	* 1.3424	* 1.3874	* 2.0258	* 2.5146	* 2.9464	*	
15	* 0.7936	* 0.7992	* 0.7258	* 0.4921	F-SUB-Q			
	* 2.4146	* 2.4060	* 2.6335	* 3.8787	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2112	* 1.3779	* 1.5287	* 1.4629	* 1.5838	* 1.6411	* 1.7120	* 0.8355
	* 1.6725	* 1.6686	* 1.4723	* 1.5276	* 1.3948	* 1.3433	* 1.2852	* 2.3768
9	* 1.3779	* 1.5876	* 1.5710	* 1.6073	* 1.5500	* 1.6438	* 1.6980	* 0.8424
	* 1.6686	* 1.4378	* 1.4339	* 1.3867	* 1.4364	* 1.3431	* 1.2978	* 2.3667
10	* 1.5287	* 1.5674	* 1.4321	* 1.4539	* 1.6247	* 1.5587	* 1.6547	* 0.7687
	* 1.4723	* 1.4373	* 1.5790	* 1.5448	* 1.3760	* 1.4324	* 1.3360	* 2.5816
11	* 1.4629	* 1.6063	* 1.4530	* 1.5607	* 1.4495	* 1.5526	* 1.0554	* 0.5271
	* 1.5276	* 1.3873	* 1.5458	* 1.4486	* 1.5386	* 1.4176	* 1.9729	* 3.8225
12	* 1.5838	* 1.5499	* 1.6247	* 1.4489	* 1.2215	* 1.3274	* 0.7680	*
	* 1.3948	* 1.4365	* 1.3760	* 1.5396	* 1.4554	* 1.4235	* 2.4646	*
13	* 1.6411	* 1.6443	* 1.5599	* 1.5528	* 1.3274	* 1.2834	* 0.6072	*
	* 1.3433	* 1.3427	* 1.4312	* 1.4177	* 1.4233	* 1.4292	* 2.8795	*
14	* 1.7120	* 1.6984	* 1.6554	* 1.0558	* 0.7673	* 0.6071	*	*
	* 1.2852	* 1.2975	* 1.3354	* 1.9724	* 2.4649	* 2.8799	*	*
15	* 0.8355	* 0.8430	* 0.7689	* 0.5205	* F-SUB-Q			
	* 2.3768	* 2.3656	* 2.5810	* 3.8132	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3480	* 1.4502	* 1.5937	* 1.5130	* 1.6464	* 1.7026	* 1.7851	* 0.8687
	* 1.6867	* 1.6805	* 1.4819	* 1.5448	* 1.3954	* 1.3408	* 1.2765	* 2.3707
9	* 1.4502	* 1.6638	* 1.6265	* 1.6763	* 1.6103	* 1.7086	* 1.7717	* 0.8750
	* 1.6805	* 1.4480	* 1.4502	* 1.3920	* 1.4464	* 1.3395	* 1.2888	* 2.3615
10	* 1.5937	* 1.6225	* 1.4819	* 1.5154	* 1.7068	* 1.6258	* 1.7356	* 0.8031
	* 1.4819	* 1.4538	* 1.5993	* 1.5539	* 1.3765	* 1.4395	* 1.3287	* 2.5688
11	* 1.5130	* 1.6752	* 1.5144	* 1.6528	* 1.5457	* 1.6609	* 1.1178	* 0.5522
	* 1.5448	* 1.3926	* 1.5548	* 1.4437	* 1.5394	* 1.4093	* 1.9702	* 3.8320
12	* 1.6464	* 1.6102	* 1.7068	* 1.5451	* 1.3803	* 1.4982	* 0.8328	*
	* 1.3954	* 1.4465	* 1.3765	* 1.5404	* 1.4552	* 1.4188	* 2.4605	*
13	* 1.7026	* 1.7092	* 1.6272	* 1.6611	* 1.4982	* 1.4504	* 0.6705	*
	* 1.3408	* 1.3390	* 1.4381	* 1.4094	* 1.4186	* 1.4232	* 2.8793	*
14	* 1.7851	* 1.7722	* 1.7363	* 1.1182	* 0.8320	* 0.6704	*	*
	* 1.2765	* 1.2885	* 1.3281	* 1.9698	* 2.4609	* 2.8797	*	*
15	* 0.8687	* 0.8757	* 0.8033	* 0.5451	* F-SUB-Q			
	* 2.3707	* 2.3605	* 2.5682	* 3.8230	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4875	* 1.5130	* 1.6606	* 1.5618	* 1.7081	* 1.7629	* 1.8588	* 0.8882
	* 1.7011	* 1.7312	* 1.5089	* 1.5811	* 1.4133	* 1.3555	* 1.2823	* 2.4236
9	* 1.5130	* 1.7426	* 1.6824	* 1.7452	* 1.6679	* 1.7719	* 1.8460	* 0.8969
	* 1.7312	* 1.4749	* 1.4842	* 1.4139	* 1.4753	* 1.3540	* 1.2956	* 2.4119
10	* 1.6606	* 1.6780	* 1.5318	* 1.5739	* 1.7895	* 1.6923	* 1.8169	* 0.8236
	* 1.5089	* 1.4881	* 1.6402	* 1.5916	* 1.3935	* 1.4602	* 1.3377	* 2.6321
11	* 1.5618	* 1.7439	* 1.5728	* 1.7591	* 1.6374	* 1.7769	* 1.1632	* 0.5680
	* 1.5811	* 1.4146	* 1.5927	* 1.4419	* 1.5432	* 1.4040	* 2.0209	* 3.9471
12	* 1.7081	* 1.6677	* 1.7896	* 1.6361	* 1.5874	* 1.6868	* 0.8859	
	* 1.4133	* 1.4754	* 1.3934	* 1.5444	* 1.4581	* 1.4196	* 2.5056	
13	* 1.7629	* 1.7725	* 1.6938	* 1.7769	* 1.6869	* 1.6312	* 0.7239	
	* 1.3555	* 1.3535	* 1.4587	* 1.4041	* 1.4194	* 1.4195	* 2.9337	
14	* 1.8588	* 1.8464	* 1.8176	* 1.1635	* 0.8850	* 0.7238		
	* 1.2823	* 1.2953	* 1.3371	* 2.0206	* 2.5063	* 2.9342		
15	* 0.8882	* 0.8976	* 0.8237	* 0.5589	F-SUB-Q			
	* 2.4236	* 2.4108	* 2.6317	* 3.9512	M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5731	* 1.5614	* 1.7033	* 1.5931	* 1.7469	* 1.8028	* 1.9072	* 0.9033
	* 1.7502	* 1.7898	* 1.5719	* 1.6498	* 1.4648	* 1.4008	* 1.3200	* 2.5154
9	* 1.5614	* 1.7940	* 1.7189	* 1.7900	* 1.7069	* 1.8146	* 1.8952	* 0.9130
	* 1.7898	* 1.5373	* 1.5504	* 1.4698	* 1.5353	* 1.3987	* 1.3343	* 2.5035
10	* 1.7033	* 1.7152	* 1.5645	* 1.6219	* 1.8485	* 1.7381	* 1.8728	* 0.8403
	* 1.5719	* 1.5547	* 1.7162	* 1.6596	* 1.4441	* 1.5127	* 1.3790	* 2.7335
11	* 1.5931	* 1.7886	* 1.6209	* 1.8332	* 1.7066	* 1.8673	* 1.2011	* 0.5812
	* 1.6498	* 1.4706	* 1.6609	* 1.4669	* 1.5736	* 1.4239	* 2.0752	* 4.1144
12	* 1.7469	* 1.7067	* 1.8484	* 1.7052	* 1.7241	* 1.8097	* 0.9290	
	* 1.4648	* 1.5354	* 1.4440	* 1.5748	* 1.4810	* 1.4377	* 2.5544	
13	* 1.8028	* 1.8153	* 1.7398	* 1.8671	* 1.8098	* 1.7624	* 0.7678	
	* 1.4008	* 1.3982	* 1.5111	* 1.4241	* 1.4377	* 1.4391	* 2.9995	
14	* 1.9072	* 1.8957	* 1.8736	* 1.2013	* 0.9279	* 0.7677		
	* 1.3200	* 1.3340	* 1.3784	* 2.0750	* 2.5553	* 3.0001		
15	* 0.9033	* 0.9138	* 0.8404	* 0.5710	F-SUB-Q			
	* 2.5154	* 2.5023	* 2.7332	* 4.1246	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6151	* 1.5917	* 1.7375	* 1.6165	* 1.7803	* 1.8360	* 1.9494	* 0.9115
	* 1.8291	* 1.8480	* 1.6547	* 1.7406	* 1.5341	* 1.4641	* 1.3740	* 2.6483
9	* 1.5917	* 1.8337	* 1.7474	* 1.8276	* 1.7373	* 1.8501	* 1.9380	* 0.9230
	* 1.8480	* 1.5971	* 1.6367	* 1.5439	* 1.6157	* 1.4616	* 1.3894	* 2.6346
10	* 1.7375	* 1.7440	* 1.5893	* 1.6581	* 1.9031	* 1.7798	* 1.9208	* 0.8499
	* 1.6547	* 1.6414	* 1.8146	* 1.7424	* 1.5060	* 1.5846	* 1.4371	* 2.8812
11	* 1.6165	* 1.8260	* 1.6570	* 1.8935	* 1.7570	* 1.9364	* 1.2256	* 0.5892
	* 1.7406	* 1.5447	* 1.7435	* 1.5139	* 1.6281	* 1.4653	* 2.1404	* 4.3468
12	* 1.7803	* 1.7371	* 1.9029	* 1.7555	* 1.8091	* 1.8909	* 0.9560	*
	* 1.5341	* 1.6158	* 1.5061	* 1.6294	* 1.5280	* 1.4798	* 2.6560	*
13	* 1.8360	* 1.8508	* 1.7816	* 1.9362	* 1.8910	* 1.8547	* 0.7954	*
	* 1.4641	* 1.4611	* 1.5829	* 1.4655	* 1.4797	* 1.4756	* 3.1150	*
14	* 1.9494	* 1.9384	* 1.9216	* 1.2258	* 0.9548	* 0.7953	*	*
	* 1.3740	* 1.3890	* 1.4365	* 2.1403	* 2.6571	* 3.1156	*	*
15	* 0.9115	* 0.9237	* 0.8499	* 0.5780	F-SUB-Q			
	* 2.6483	* 2.6335	* 2.8811	* 4.3637	M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6111	* 1.5857	* 1.7233	* 1.6063	* 1.7671	* 1.8297	* 1.9397	* 0.9217
	* 1.9300	* 1.9583	* 1.7932	* 1.8841	* 1.6587	* 1.5732	* 1.4780	* 2.8046
9	* 1.5857	* 1.8195	* 1.7375	* 1.8150	* 1.7331	* 1.8457	* 1.9298	* 0.9300
	* 1.9583	* 1.7012	* 1.7718	* 1.6744	* 1.7427	* 1.5700	* 1.4943	* 2.7971
10	* 1.7233	* 1.7336	* 1.5807	* 1.6587	* 1.9009	* 1.7809	* 1.9166	* 0.8626
	* 1.7932	* 1.7770	* 1.9524	* 1.8404	* 1.5922	* 1.6919	* 1.5462	* 3.0408
11	* 1.6063	* 1.8134	* 1.6576	* 1.8958	* 1.7629	* 1.9430	* 1.2506	* 0.5991
	* 1.8841	* 1.6753	* 1.8416	* 1.6010	* 1.7145	* 1.5466	* 2.2126	* 4.5076
12	* 1.7671	* 1.7329	* 1.9007	* 1.7614	* 1.8328	* 1.9059	* 0.9805	*
	* 1.6587	* 1.7428	* 1.5924	* 1.7158	* 1.6214	* 1.5732	* 2.7608	*
13	* 1.8297	* 1.8464	* 1.7827	* 1.9427	* 1.9060	* 1.8773	* 0.8208	*
	* 1.5732	* 1.5695	* 1.6902	* 1.5468	* 1.5732	* 1.5673	* 3.2409	*
14	* 1.9397	* 1.9302	* 1.9173	* 1.2507	* 0.9793	* 0.8206	*	*
	* 1.4780	* 1.4940	* 1.5457	* 2.2126	* 2.7620	* 3.2417	*	*
15	* 0.9217	* 0.9308	* 0.8625	* 0.5891	F-SUB-Q			
	* 2.8046	* 2.7958	* 3.0410	* 4.5148	M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6244	* 1.5952	* 1.7452	* 1.6174	* 1.7932	* 1.8547	* 1.9775	* 0.9145 *
	* 2.0294	* 2.0659	* 1.8774	* 2.0152	* 1.7584	* 1.6667	* 1.5562	* 3.0257 *
9	* 1.5952	* 1.8446	* 1.7525	* 1.8423	* 1.7496	* 1.8722	* 1.9674	* 0.9268 *
	* 2.0659	* 1.7816	* 1.8633	* 1.7611	* 1.8378	* 1.6627	* 1.5738	* 3.0087 *
10	* 1.7452	* 1.7475	* 1.5917	* 1.6761	* 1.9391	* 1.8063	* 1.9565	* 0.8562 *
	* 1.8774	* 1.8690	* 2.0569	* 1.9337	* 1.6568	* 1.7695	* 1.6114	* 3.2859 *
11	* 1.6174	* 1.8406	* 1.6749	* 1.9344	* 1.7894	* 1.9885	* 1.2475	* 0.5940 *
	* 2.0152	* 1.7627	* 1.9350	* 1.6642	* 1.7905	* 1.6023	* 2.3507	* 4.8098 *
12	* 1.7932	* 1.7493	* 1.9389	* 1.7877	* 1.8770	* 1.9539	* 0.9774 *	
	* 1.7584	* 1.8380	* 1.6570	* 1.7920	* 1.6827	* 1.6249	* 2.9296 *	
13	* 1.8547	* 1.8730	* 1.8082	* 1.9882	* 1.9539	* 1.9343	* 0.8194 *	
	* 1.6667	* 1.6621	* 1.7675	* 1.6025	* 1.6249	* 1.6198	* 3.4496 *	
14	* 1.9775	* 1.9680	* 1.9572	* 1.2476	* 0.9761	* 0.8192 *		
	* 1.5562	* 1.5734	* 1.6108	* 2.3509	* 2.9313	* 3.4504 *		
15	* 0.9145	* 0.9275	* 0.8560	* 0.5815	* F-SUB-Q			
	* 3.0257	* 3.0074	* 3.2862	* 4.8395	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6115	* 1.5814	* 1.7332	* 1.6044	* 1.7860	* 1.8503	* 1.9772	* 0.9093 *
	* 2.0342	* 2.0602	* 1.8737	* 2.0203	* 1.8144	* 1.7551	* 1.6422	* 3.2489 *
9	* 1.5814	* 1.8331	* 1.7397	* 1.8342	* 1.7410	* 1.8692	* 1.9676	* 0.9218 *
	* 2.0602	* 1.7756	* 1.8695	* 1.7723	* 1.8719	* 1.7400	* 1.6526	* 3.2154 *
10	* 1.7332	* 1.7342	* 1.5789	* 1.6690	* 1.9384	* 1.8024	* 1.9583	* 0.8527 *
	* 1.8737	* 1.8754	* 2.0601	* 1.9606	* 1.6912	* 1.8201	* 1.6688	* 3.4590 *
11	* 1.6044	* 1.8324	* 1.6678	* 1.9334	* 1.7867	* 1.9930	* 1.2464	* 0.5913 *
	* 2.0203	* 1.7741	* 1.9620	* 1.7037	* 1.8433	* 1.6554	* 2.4335	* 5.0509 *
12	* 1.7860	* 1.7408	* 1.9382	* 1.7851	* 1.8857	* 1.9610	* 0.9762 *	
	* 1.8144	* 1.8721	* 1.6914	* 1.8450	* 1.7584	* 1.6900	* 3.0737 *	
13	* 1.8503	* 1.8699	* 1.8044	* 1.9926	* 1.9610	* 1.9479	* 0.8201 *	
	* 1.7551	* 1.7393	* 1.8182	* 1.6557	* 1.6900	* 1.7038	* 3.6574 *	
14	* 1.9772	* 1.9682	* 1.9589	* 1.2465	* 0.9749	* 0.8199 *		
	* 1.6422	* 1.6522	* 1.6682	* 2.4337	* 3.0756	* 3.6583 *		
15	* 0.9093	* 0.9226	* 0.8525	* 0.5780	* F-SUB-Q			
	* 3.2489	* 3.2140	* 3.4597	* 5.0888	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5762	* 1.5470	* 1.6906	* 1.5694	* 1.7479	* 1.8198	* 1.9428	* 0.9046 *
	* 2.0403	* 2.0664	* 1.8860	* 2.0245	* 1.8145	* 1.7465	* 1.6356	* 3.1846 *
9	* 1.5470	* 1.7884	* 1.7025	* 1.7933	* 1.7100	* 1.8397	* 1.9340	* 0.9142 *
	* 2.0664	* 1.7862	* 1.8758	* 1.7800	* 1.8714	* 1.7321	* 1.6468	* 3.1690 *
10	* 1.6906	* 1.6970	* 1.5451	* 1.6399	* 1.9023	* 1.7721	* 1.9261	* 0.8501 *
	* 1.8860	* 1.8819	* 2.0667	* 1.9597	* 1.6936	* 1.8194	* 1.6662	* 3.3998 *
11	* 1.5694	* 1.7915	* 1.6387	* 1.8973	* 1.7582	* 1.9606	* 1.2451	* 0.5894 *
	* 2.0245	* 1.7818	* 1.9612	* 1.7077	* 1.8417	* 1.6561	* 2.3943	* 4.9739 *
12	* 1.7479	* 1.7097	* 1.9020	* 1.7566	* 1.8642	* 1.9325	* 0.9761 *	
	* 1.8145	* 1.8717	* 1.6938	* 1.8428	* 1.7679	* 1.6934	* 3.0272 *	
13	* 1.8198	* 1.8404	* 1.7741	* 1.9602	* 1.9324	* 1.9240	* 0.8225 *	
	* 1.7465	* 1.7314	* 1.8174	* 1.6564	* 1.6935	* 1.7127	* 3.6051 *	
14	* 1.9428	* 1.9346	* 1.9267	* 1.2450	* 0.9747	* 0.8222 *		
	* 1.6356	* 1.6464	* 1.6656	* 2.3947	* 3.0290	* 3.6061 *		
15	* 0.9046	* 0.9149	* 0.8498	* 0.5774	* F-SUB-Q			
	* 3.1846	* 3.1677	* 3.4007	* 4.9997	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5602	* 1.5284	* 1.6806	* 1.5534	* 1.7438	* 1.8168	* 1.9503	* 0.8841 *
	* 1.9649	* 1.9864	* 1.8019	* 1.9474	* 1.7449	* 1.6844	* 1.5677	* 3.1009 *
9	* 1.5284	* 1.7798	* 1.6874	* 1.7877	* 1.6973	* 1.8376	* 1.9414	* 0.8973 *
	* 1.9864	* 1.7087	* 1.8033	* 1.7044	* 1.8068	* 1.6733	* 1.5830	* 3.0729 *
10	* 1.6806	* 1.6817	* 1.5291	* 1.6272	* 1.9041	* 1.7653	* 1.9339	* 0.8308 *
	* 1.8019	* 1.8092	* 1.9859	* 1.8927	* 1.6300	* 1.7599	* 1.5970	* 3.3044 *
11	* 1.5534	* 1.7858	* 1.6259	* 1.8973	* 1.7516	* 1.9673	* 1.2205	* 0.5747 *
	* 1.9474	* 1.7061	* 1.8941	* 1.6483	* 1.7861	* 1.5978	* 2.3384	* 4.8156 *
12	* 1.7438	* 1.6970	* 1.9039	* 1.7499	* 1.8693	* 1.9404	* 0.9538 *	
	* 1.7449	* 1.8071	* 1.6303	* 1.7879	* 1.7150	* 1.6327	* 2.9593 *	
13	* 1.8168	* 1.8384	* 1.7674	* 1.9669	* 1.9403	* 1.9399	* 0.8039 *	
	* 1.6844	* 1.6727	* 1.7579	* 1.5981	* 1.6328	* 1.6430	* 3.5147 *	
14	* 1.9503	* 1.9420	* 1.9346	* 1.2204	* 0.9523	* 0.8036 *		
	* 1.5677	* 1.5827	* 1.5966	* 2.3389	* 2.9615	* 3.5158 *		
15	* 0.8841	* 0.8981	* 0.8306	* 0.5603	* F-SUB-Q			
	* 3.1009	* 3.0716	* 3.3055	* 4.8639	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5270	* 1.4948	* 1.6470	* 1.5206	* 1.7150	* 1.7916	* 1.9288	* 0.8653
	* 1.8336	* 1.8569	* 1.6758	* 1.8100	* 1.6123	* 1.5560	* 1.4444	* 2.8818
9	* 1.4948	* 1.7456	* 1.6531	* 1.7564	* 1.6672	* 1.8131	* 1.9201	* 0.8791
	* 1.8569	* 1.5911	* 1.6776	* 1.5805	* 1.6777	* 1.5438	* 1.4560	* 2.8505
10	* 1.6470	* 1.6473	* 1.4969	* 1.5979	* 1.8779	* 1.7379	* 1.9132	* 0.8136
	* 1.6758	* 1.6832	* 1.8496	* 1.7615	* 1.5097	* 1.6340	* 1.4741	* 3.0738
11	* 1.5206	* 1.7544	* 1.5965	* 1.8693	* 1.7248	* 1.9449	* 1.1978	* 0.5616
	* 1.8100	* 1.5822	* 1.7629	* 1.5250	* 1.6558	* 1.4734	* 2.1787	* 4.5079
12	* 1.7150	* 1.6669	* 1.8776	* 1.7231	* 1.8503	* 1.9198	* 0.9347	*
	* 1.6123	* 1.6780	* 1.5099	* 1.6576	* 1.5836	* 1.5065	* 2.7555	*
13	* 1.7916	* 1.8139	* 1.7400	* 1.9445	* 1.9197	* 1.9259	* 0.7887	*
	* 1.5560	* 1.5432	* 1.6321	* 1.4737	* 1.5066	* 1.5132	* 3.2744	*
14	* 1.9288	* 1.9207	* 1.9138	* 1.1977	* 0.9332	* 0.7885	*	*
	* 1.4444	* 1.4557	* 1.4737	* 2.1792	* 2.7577	* 3.2755	*	*
15	* 0.8653	* 0.8799	* 0.8133	* 0.5469	* F-SUB-Q			
	* 2.8818	* 2.8493	* 3.0750	* 4.5590	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4845	* 1.4520	* 1.6003	* 1.4777	* 1.6719	* 1.7522	* 1.8886	* 0.8465
	* 1.7151	* 1.7357	* 1.5713	* 1.7003	* 1.5107	* 1.4550	* 1.3493	* 2.6994
9	* 1.4520	* 1.6970	* 1.6080	* 1.7103	* 1.6259	* 1.7743	* 1.8805	* 0.8595
	* 1.7357	* 1.4871	* 1.5721	* 1.4802	* 1.5695	* 1.4410	* 1.3585	* 2.6687
10	* 1.6003	* 1.6022	* 1.4555	* 1.5577	* 1.8345	* 1.6971	* 1.8742	* 0.7969
	* 1.5713	* 1.5775	* 1.7330	* 1.6436	* 1.4068	* 1.5265	* 1.3726	* 2.8689
11	* 1.4777	* 1.7083	* 1.5564	* 1.8250	* 1.6849	* 1.9038	* 1.1753	* 0.5496
	* 1.7003	* 1.4818	* 1.6450	* 1.4253	* 1.5463	* 1.3745	* 2.0233	* 4.2000
12	* 1.6719	* 1.6256	* 1.8342	* 1.6831	* 1.8147	* 1.8808	* 0.9154	*
	* 1.5107	* 1.5698	* 1.4071	* 1.5480	* 1.4814	* 1.4089	* 2.5761	*
13	* 1.7522	* 1.7751	* 1.6993	* 1.9034	* 1.8807	* 1.8909	* 0.7736	*
	* 1.4550	* 1.4404	* 1.5246	* 1.3749	* 1.4090	* 1.4131	* 3.0667	*
14	* 1.8886	* 1.8810	* 1.8748	* 1.1751	* 0.9139	* 0.7733	*	*
	* 1.3493	* 1.3582	* 1.3722	* 2.0238	* 2.5783	* 3.0677	*	*
15	* 0.8465	* 0.8602	* 0.7966	* 0.5348	* F-SUB-Q			
	* 2.6994	* 2.6675	* 2.8701	* 4.2505	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4302	* 1.3992	* 1.5372	* 1.4233	* 1.6108	* 1.6962	* 1.8259	* 0.8285 *
	* 1.7616	* 1.7870	* 1.6230	* 1.7514	* 1.5597	* 1.4959	* 1.3890	* 2.7500 *
9	* 1.3992	* 1.6307	* 1.5496	* 1.6458	* 1.5718	* 1.7185	* 1.8188	* 0.8386 *
	* 1.7870	* 1.5352	* 1.6186	* 1.5261	* 1.6114	* 1.4794	* 1.3968	* 2.7255 *
10	* 1.5372	* 1.5439	* 1.4028	* 1.5062	* 1.7698	* 1.6412	* 1.8133	* 0.7811 *
	* 1.6230	* 1.6244	* 1.7844	* 1.6863	* 1.4444	* 1.5620	* 1.4079	* 2.9107 *
11	* 1.4233	* 1.6438	* 1.5051	* 1.7599	* 1.6302	* 1.8407	* 1.1535	* 0.5384 *
	* 1.7514	* 1.5279	* 1.6878	* 1.4597	* 1.5765	* 1.4032	* 2.0440	* 4.2635 *
12	* 1.6108	* 1.5715	* 1.7695	* 1.6286	* 1.7607	* 1.8201	* 0.8984	*
	* 1.5597	* 1.6117	* 1.4446	* 1.5776	* 1.4978	* 1.4315	* 2.5890	*
13	* 1.6962	* 1.7193	* 1.6434	* 1.8402	* 1.8199	* 1.8328	* 0.7609	*
	* 1.4959	* 1.4788	* 1.5599	* 1.4035	* 1.4316	* 1.4314	* 3.0644	*
14	* 1.8259	* 1.8193	* 1.8138	* 1.1533	* 0.8970	* 0.7606	*	
	* 1.3890	* 1.3965	* 1.4075	* 2.0446	* 2.5911	* 3.0655	*	
15	* 0.8285	* 0.8393	* 0.7808	* 0.5255	* F-SUB-Q			
	* 2.7500	* 2.7244	* 2.9121	* 4.3020	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3956	* 1.3623	* 1.5060	* 1.3874	* 1.5821	* 1.6662	* 1.8037	* 0.7947
	* 1.6635	* 1.6964	* 1.5350	* 1.6673	* 1.4760	* 1.4156	* 1.3072	* 2.6698
9	* 1.3623	* 1.5998	* 1.5135	* 1.6152	* 1.5353	* 1.6890	* 1.7965	* 0.8081
	* 1.6964	* 1.4472	* 1.5357	* 1.4415	* 1.5294	* 1.3984	* 1.3139	* 2.6326
10	* 1.5060	* 1.5077	* 1.3681	* 1.4693	* 1.7421	* 1.6079	* 1.7908	* 0.7489
	* 1.5350	* 1.5414	* 1.6951	* 1.5981	* 1.3566	* 1.4758	* 1.3209	* 2.8220
11	* 1.3874	* 1.6133	* 1.4680	* 1.7303	* 1.5964	* 1.8155	* 1.1091	* 0.5151
	* 1.6673	* 1.4432	* 1.5996	* 1.3725	* 1.4925	* 1.3151	* 1.9674	* 4.1314
12	* 1.5821	* 1.5350	* 1.7418	* 1.5946	* 1.7332	* 1.7952	* 0.8605	*
	* 1.4760	* 1.5297	* 1.3568	* 1.4941	* 1.3970	* 1.3385	* 2.5010	*
13	* 1.6662	* 1.6898	* 1.6101	* 1.8150	* 1.7951	* 1.8137	* 0.7280	*
	* 1.4156	* 1.3978	* 1.4739	* 1.3154	* 1.3387	* 1.3311	* 2.9562	*
14	* 1.8037	* 1.7970	* 1.7914	* 1.1089	* 0.8591	* 0.7277	*	
	* 1.3072	* 1.3136	* 1.3205	* 1.9680	* 2.5033	* 2.9572	*	
15	* 0.7947	* 0.8089	* 0.7486	* 0.5003	* F-SUB-Q			
	* 2.6698	* 2.6314	* 2.8234	* 4.1896	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3436	* 1.3100	* 1.4477	* 1.3339	* 1.5234	* 1.6098	* 1.7432	* 0.7642
	* 1.6123	* 1.6509	* 1.4962	* 1.6265	* 1.4388	* 1.3752	* 1.2695	* 2.6112
9	* 1.3100	* 1.5397	* 1.4577	* 1.5539	* 1.4791	* 1.6322	* 1.7366	* 0.7774
	* 1.6509	* 1.4075	* 1.4940	* 1.4040	* 1.4877	* 1.3574	* 1.2752	* 2.5732
10	* 1.4477	* 1.4520	* 1.3170	* 1.4142	* 1.6787	* 1.5504	* 1.7308	* 0.7205
	* 1.4962	* 1.4997	* 1.6498	* 1.5527	* 1.3152	* 1.4295	* 1.2800	* 2.7556
11	* 1.3339	* 1.5520	* 1.4129	* 1.6664	* 1.5391	* 1.7523	* 1.0696	* 0.4953
	* 1.6265	* 1.4057	* 1.5542	* 1.3284	* 1.4435	* 1.2693	* 1.9078	* 4.0305
12	* 1.5234	* 1.4789	* 1.6784	* 1.5373	* 1.6754	* 1.7333	* 0.8278	
	* 1.4388	* 1.4880	* 1.3154	* 1.4450	* 1.3424	* 1.2901	* 2.4250	
13	* 1.6098	* 1.6330	* 1.5526	* 1.7519	* 1.7331	* 1.7534	* 0.7001	
	* 1.3752	* 1.3568	* 1.4276	* 1.2696	* 1.2903	* 1.2813	* 2.8669	
14	* 1.7432	* 1.7371	* 1.7314	* 1.0694	* 0.8263	* 0.6999	*	
	* 1.2695	* 1.2749	* 1.2796	* 1.9084	* 2.4273	* 2.8679	*	
15	* 0.7642	* 0.7781	* 0.7201	* 0.4807	F-SUB-Q			
	* 2.6112	* 2.5719	* 2.7570	* 4.0898	M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2728	* 1.2405	* 1.3589	* 1.2617	* 1.4306	* 1.5230	* 1.6376	* 0.7358
	* 1.6101	* 1.6506	* 1.5095	* 1.6296	* 1.4526	* 1.3775	* 1.2807	* 2.5763
9	* 1.2405	* 1.4460	* 1.3802	* 1.4576	* 1.4006	* 1.5442	* 1.6324	* 0.7451
	* 1.6506	* 1.4184	* 1.4942	* 1.4175	* 1.4878	* 1.3593	* 1.2853	* 2.5499
10	* 1.3589	* 1.3749	* 1.2484	* 1.3397	* 1.5737	* 1.4657	* 1.6260	* 0.6945
	* 1.5095	* 1.4999	* 1.6485	* 1.5527	* 1.3259	* 1.4296	* 1.2895	* 2.7138
11	* 1.2617	* 1.4558	* 1.3387	* 1.5630	* 1.4556	* 1.6446	* 1.0328	* 0.4783
	* 1.6296	* 1.4192	* 1.5542	* 1.3370	* 1.4388	* 1.2760	* 1.8693	* 3.9598
12	* 1.4306	* 1.4004	* 1.5734	* 1.4541	* 1.5823	* 1.6276	* 0.7984	
	* 1.4526	* 1.4881	* 1.3262	* 1.4398	* 1.3370	* 1.2944	* 2.3750	
13	* 1.5230	* 1.5449	* 1.4678	* 1.6441	* 1.6274	* 1.6438	* 0.6763	
	* 1.3775	* 1.3587	* 1.4277	* 1.2764	* 1.2946	* 1.2851	* 2.7988	
14	* 1.6376	* 1.6329	* 1.6266	* 1.0326	* 0.7971	* 0.6761		
	* 1.2807	* 1.2850	* 1.2891	* 1.8699	* 2.3770	* 2.7998		
15	* 0.7358	* 0.7457	* 0.6942	* 0.4664	* F-SUB-Q			
	* 2.5763	* 2.5487	* 2.7152	* 3.9997	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2169	* 1.1831	* 1.2947	* 1.2066	* 1.3591	* 1.4526	* 1.5566	* 0.6887
	* 1.6110	* 1.6557	* 1.5163	* 1.6305	* 1.4637	* 1.3818	* 1.2892	* 2.6398
9	* 1.1831	* 1.3769	* 1.3210	* 1.3850	* 1.3336	* 1.4717	* 1.5514	* 0.7002
	* 1.6557	* 1.4248	* 1.4934	* 1.4271	* 1.4946	* 1.3642	* 1.2938	* 2.6019
10	* 1.2947	* 1.3159	* 1.1938	* 1.2710	* 1.4905	* 1.3953	* 1.5420	* 0.6484
	* 1.5163	* 1.4991	* 1.6494	* 1.5621	* 1.3375	* 1.4348	* 1.3002	* 2.7872
11	* 1.2066	* 1.3833	* 1.2698	* 1.4816	* 1.3847	* 1.5591	* 0.9670	* 0.4467
	* 1.6306	* 1.4288	* 1.5635	* 1.3468	* 1.4465	* 1.2846	* 1.9098	* 4.0667
12	* 1.3591	* 1.3333	* 1.4902	* 1.3831	* 1.5047	* 1.5427	* 0.7448	*
	* 1.4637	* 1.4949	* 1.3378	* 1.4482	* 1.3397	* 1.3026	* 2.4337	*
13	* 1.4526	* 1.4724	* 1.3973	* 1.5587	* 1.5425	* 1.5549	* 0.6275	*
	* 1.3818	* 1.3636	* 1.4329	* 1.2850	* 1.3027	* 1.2944	* 2.8817	*
14	* 1.5566	* 1.5518	* 1.5424	* 0.9668	* 0.7435	* 0.6272	*	*
	* 1.2892	* 1.2935	* 1.2999	* 1.9104	* 2.4360	* 2.8828	*	*
15	* 0.6887	* 0.7008	* 0.6480	* 0.4336	* F-SUB-Q			
	* 2.6398	* 2.6005	* 2.7889	* 4.1257	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1132	* 1.0944	* 1.1964	* 1.1246	* 1.2418	* 1.3214	* 1.4031	* 0.6379
	* 1.7018	* 1.7290	* 1.5850	* 1.6898	* 1.5470	* 1.4667	* 1.3812	* 2.7583
9	* 1.0944	* 1.2537	* 1.2171	* 1.2644	* 1.2204	* 1.3373	* 1.3979	* 0.6477
	* 1.7290	* 1.5112	* 1.5654	* 1.5093	* 1.5757	* 1.4496	* 1.3866	* 2.7233
10	* 1.1964	* 1.2125	* 1.0945	* 1.1668	* 1.3443	* 1.2725	* 1.3809	* 0.5953
	* 1.5850	* 1.5712	* 1.7383	* 1.6426	* 1.4310	* 1.5185	* 1.4021	* 2.9395
11	* 1.1246	* 1.2629	* 1.1658	* 1.3421	* 1.2647	* 1.4020	* 0.8845	* 0.4082
	* 1.6898	* 1.5110	* 1.6440	* 1.4341	* 1.5273	* 1.3778	* 2.0180	* 4.3125
12	* 1.2418	* 1.2202	* 1.3440	* 1.2634	* 1.3690	* 1.3910	* 0.6858	*
	* 1.5470	* 1.5773	* 1.4313	* 1.5290	* 1.4189	* 1.3929	* 2.5544	*
13	* 1.3214	* 1.3379	* 1.2741	* 1.4016	* 1.3908	* 1.3873	* 0.5714	*
	* 1.4667	* 1.4490	* 1.5166	* 1.3782	* 1.3930	* 1.3984	* 3.0586	*
14	* 1.4031	* 1.3982	* 1.3812	* 0.8843	* 0.6846	* 0.5712	*	*
	* 1.3812	* 1.3863	* 1.4019	* 2.0187	* 2.5568	* 3.0598	*	*
15	* 0.6379	* 0.6482	* 0.5949	* 0.3960	* F-SUB-Q			
	* 2.7583	* 2.7221	* 2.9414	* 4.3782	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8949	* 0.9177	* 1.1450	* 0.9432	* 1.1619	* 1.0560	* 1.2231	* 0.5387 *
	* 2.0634	* 2.0107	* 1.6130	* 1.9630	* 1.6094	* 1.7867	* 1.5422	* 3.1900 *
9	* 0.9177	* 1.1370	* 1.0046	* 1.1610	* 0.9908	* 1.0690	* 1.2126	* 0.5444 *
	* 2.0107	* 1.6237	* 1.8436	* 1.6009	* 1.8844	* 1.7648	* 1.5558	* 3.1640 *
10	* 1.1450	* 1.0022	* 0.8802	* 0.9614	* 1.2040	* 1.0299	* 1.1315	* 0.4920 *
	* 1.6130	* 1.8471	* 2.1059	* 1.9446	* 1.5562	* 1.8253	* 1.6670	* 3.4741 *
11	* 0.9432	* 1.1599	* 0.9607	* 1.2121	* 1.0237	* 1.1871	* 0.7289	* 0.3333 *
	* 1.9630	* 1.6025	* 1.9460	* 1.5455	* 1.8343	* 1.5833	* 2.3881	* 5.1645 *
12	* 1.1619	* 0.9901	* 1.2038	* 1.0226	* 1.1086	* 1.2166	* 0.5815	*
	* 1.6094	* 1.8858	* 1.5566	* 1.8362	* 1.7039	* 1.5508	* 2.9384	*
13	* 1.0560	* 1.0694	* 1.0311	* 1.1868	* 1.2164	* 1.0926	* 0.4625	*
	* 1.7867	* 1.7641	* 1.8232	* 1.5836	* 1.5511	* 1.7304	* 3.6881	*
14	* 1.2231	* 1.2128	* 1.1315	* 0.7287	* 0.5806	* 0.4624	*	
	* 1.5422	* 1.5554	* 1.6670	* 2.3891	* 2.9408	* 3.6895	*	
15	* 0.5387	* 0.5448	* 0.4917	* 0.3234	* F-SUB-Q			
	* 3.1900	* 3.1627	* 3.4765	* 5.2414	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3537	* 0.3826	* 0.4631	* 0.3975	* 0.4668	* 0.4030	* 0.4345	* 0.2220 *
	* 5.1047	* 4.7189	* 3.9017	* 4.5605	* 3.9072	* 4.5723	* 4.2433	* 7.5901 *
9	* 0.3826	* 0.4523	* 0.4014	* 0.4651	* 0.3970	* 0.4055	* 0.4298	* 0.2213 *
	* 4.7189	* 3.9911	* 4.5136	* 3.9023	* 4.5995	* 4.5452	* 4.2900	* 7.6352 *
10	* 0.4631	* 0.4007	* 0.3662	* 0.3978	* 0.4744	* 0.3992	* 0.3962	* 0.2017 *
	* 3.9017	* 4.5217	* 4.9534	* 4.5918	* 3.8575	* 4.6042	* 4.6551	* 8.3127 *
11	* 0.3975	* 0.4646	* 0.3975	* 0.4707	* 0.4085	* 0.4482	* 0.2970	* 0.1373 *
	* 4.5605	* 3.9061	* 4.5952	* 3.8850	* 4.4952	* 4.1023	* 5.7393	* 12.3064 *
12	* 0.4668	* 0.3967	* 0.4742	* 0.4082	* 0.4146	* 0.4334	* 0.2393	*
	* 3.9072	* 4.6033	* 3.8589	* 4.4988	* 4.4539	* 4.2543	* 7.0016	*
13	* 0.4030	* 0.4057	* 0.3995	* 0.4481	* 0.4333	* 0.3807	* 0.1875	*
	* 4.5723	* 4.5439	* 4.6010	* 4.1032	* 4.2552	* 4.8546	* 8.9217	*
14	* 0.4345	* 0.4299	* 0.3961	* 0.2969	* 0.2390	* 0.1874	*	
	* 4.2433	* 4.2893	* 4.6555	* 5.7423	* 7.0048	* 8.9255	*	
15	* 0.2220	* 0.2214	* 0.2015	* 0.1345	* F-SUB-Q			
	* 7.5901	* 7.6320	* 8.3186	* 12.3735	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3333	* 0.4178	* 0.5168	* 0.4543	* 0.5181	* 0.4422	* 0.4545	* 0.2494
	* 4.9386	* 4.7049	* 3.7710	* 4.2746	* 3.7353	* 4.4009	* 4.3482	* 7.1404
9	* 0.4178	* 0.4909	* 0.4606	* 0.5170	* 0.4465	* 0.4336	* 0.4469	* 0.2450
	* 4.7049	* 4.0269	* 4.2473	* 3.7590	* 4.3370	* 4.4837	* 4.4241	* 7.2876
10	* 0.5168	* 0.4603	* 0.4174	* 0.4286	* 0.4890	* 0.4120	* 0.4023	* 0.2170
	* 3.7710	* 4.2508	* 4.7825	* 4.5506	* 3.9649	* 4.6970	* 4.8027	* 8.0141
11	* 0.4543	* 0.5168	* 0.4284	* 0.4609	* 0.3993	* 0.4071	* 0.2863	* 0.1462
	* 4.2746	* 3.7600	* 4.5530	* 4.2672	* 4.8419	* 4.5962	* 6.2044	* 11.8748
12	* 0.5181	* 0.4464	* 0.4889	* 0.3991	* 0.3158	* 0.3189	* 0.2108	*
	* 3.7353	* 4.3375	* 3.9658	* 4.8440	* 4.8320	* 4.7418	* 7.3684	*
13	* 0.4422	* 0.4336	* 0.4121	* 0.4071	* 0.3189	* 0.2629	* 0.1499	*
	* 4.4009	* 4.4835	* 4.6954	* 4.5963	* 4.7412	* 5.2801	* 9.3214	*
14	* 0.4545	* 0.4470	* 0.4024	* 0.2864	* 0.2108	* 0.1499	*	*
	* 4.3482	* 4.4232	* 4.8018	* 6.2039	* 7.3643	* 9.3223	*	*
15	* 0.2494	* 0.2454	* 0.2170	* 0.1442	F-SUB-Q			
	* 7.1404	* 7.2824	* 8.0137	* 11.8609	M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.7866	* 0.9450	* 1.1776	* 1.0244	* 1.1832	* 1.0638	* 1.1621	* 0.5933
	* 2.2129	* 2.1441	* 1.7069	* 1.9583	* 1.6904	* 1.8878	* 1.7476	* 3.0867
9	* 0.9450	* 1.1325	* 1.0834	* 1.1833	* 1.0440	* 1.0498	* 1.1449	* 0.5855
	* 2.1441	* 1.7881	* 1.8621	* 1.6949	* 1.9184	* 1.9160	* 1.7591	* 3.1067
10	* 1.1776	* 1.0821	* 0.9468	* 0.9705	* 1.1321	* 0.9945	* 1.0427	* 0.5191
	* 1.7069	* 1.8642	* 2.1534	* 2.0690	* 1.7674	* 2.0124	* 1.9128	* 3.4505
11	* 1.0244	* 1.1828	* 0.9700	* 1.0849	* 0.9302	* 0.9848	* 0.6796	* 0.3513
	* 1.9583	* 1.6953	* 2.0701	* 1.8575	* 2.1192	* 1.9493	* 2.7032	* 5.1098
12	* 1.1832	* 1.0438	* 1.1319	* 0.9297	* 0.7513	* 0.8211	* 0.5015	*
	* 1.6904	* 1.9188	* 1.7678	* 2.1204	* 2.0344	* 1.8932	* 3.1858	*
13	* 1.0638	* 1.0500	* 0.9950	* 0.9849	* 0.8210	* 0.6991	* 0.3663	*
	* 1.8878	* 1.9157	* 2.0115	* 1.9492	* 1.8931	* 2.1054	* 3.9323	*
14	* 1.1621	* 1.1452	* 1.0430	* 0.6798	* 0.5013	* 0.3662	*	*
	* 1.7476	* 1.7587	* 1.9124	* 2.7027	* 3.1849	* 3.9327	*	*
15	* 0.5933	* 0.5859	* 0.5192	* 0.3468	F-SUB-Q			
	* 3.0867	* 3.1064	* 3.4500	* 5.0980	M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9722	* 1.1531	* 1.3043	* 1.2458	* 1.3137	* 1.3177	* 1.3528	* 0.7142 *
	* 1.8583	* 1.8055	* 1.5819	* 1.6537	* 1.5617	* 1.5592	* 1.5183	* 2.5877 *
9	* 1.1531	* 1.3062	* 1.3098	* 1.3475	* 1.2820	* 1.3093	* 1.3322	* 0.7127 *
	* 1.8055	* 1.5897	* 1.5791	* 1.5267	* 1.6035	* 1.5683	* 1.5395	* 2.5950 *
10	* 1.3043	* 1.3082	* 1.1748	* 1.1926	* 1.3063	* 1.2365	* 1.2784	* 0.6450 *
	* 1.5819	* 1.5811	* 1.7644	* 1.7271	* 1.5739	* 1.6621	* 1.5994	* 2.8412 *
11	* 1.2458	* 1.3468	* 1.1919	* 1.2491	* 1.1432	* 1.1835	* 0.8481	* 0.4397 *
	* 1.6537	* 1.5272	* 1.7281	* 1.6492	* 1.7602	* 1.6631	* 2.2277	* 4.1948 *
12	* 1.3137	* 1.2817	* 1.3060	* 1.1425	* 0.9343	* 0.9832	* 0.6153	*
	* 1.5617	* 1.6038	* 1.5743	* 1.7611	* 1.6899	* 1.6680	* 2.6784	*
13	* 1.3177	* 1.3095	* 1.2372	* 1.1836	* 0.9831	* 0.9045	* 0.4685	*
	* 1.5592	* 1.5680	* 1.6611	* 1.6631	* 1.6678	* 1.7125	* 3.1806	*
14	* 1.3528	* 1.3325	* 1.2789	* 0.8484	* 0.6149	* 0.4684	*	
	* 1.5183	* 1.5392	* 1.5989	* 2.2272	* 2.6780	* 3.1810	*	
15	* 0.7142	* 0.7132	* 0.6452	* 0.4359	F-SUB-Q			
	* 2.5877	* 2.5947	* 2.8405	* 4.1676	M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0923	* 1.2811	* 1.4943	* 1.3911	* 1.5065	* 1.4915	* 1.5606	* 0.7801 *
	* 1.7147	* 1.6835	* 1.4270	* 1.5291	* 1.4016	* 1.4129	* 1.3486	* 2.4270 *
9	* 1.2811	* 1.5032	* 1.4655	* 1.5433	* 1.4351	* 1.4867	* 1.5373	* 0.7827 *
	* 1.6835	* 1.4284	* 1.4574	* 1.3745	* 1.4776	* 1.4183	* 1.3694	* 2.4251 *
10	* 1.4943	* 1.4633	* 1.3169	* 1.3399	* 1.5103	* 1.3996	* 1.4835	* 0.7069 *
	* 1.4270	* 1.4596	* 1.6242	* 1.5888	* 1.4068	* 1.5158	* 1.4196	* 2.6682 *
11	* 1.3911	* 1.5424	* 1.3390	* 1.4439	* 1.2895	* 1.3796	* 0.9409	* 0.4820 *
	* 1.5291	* 1.3750	* 1.5898	* 1.4743	* 1.6056	* 1.4797	* 2.0798	* 3.9555 *
12	* 1.5065	* 1.4348	* 1.5099	* 1.2884	* 1.0618	* 1.1537	* 0.6840	*
	* 1.4016	* 1.4779	* 1.4072	* 1.6066	* 1.5285	* 1.4896	* 2.5168	*
13	* 1.4915	* 1.4870	* 1.4007	* 1.3797	* 1.1536	* 1.0772	* 0.5268	*
	* 1.4129	* 1.4180	* 1.5147	* 1.4798	* 1.4894	* 1.5146	* 2.9740	*
14	* 1.5606	* 1.5377	* 1.4840	* 0.9413	* 0.6835	* 0.5267	*	
	* 1.3486	* 1.3691	* 1.4191	* 2.0793	* 2.5168	* 2.9743	*	
15	* 0.7801	* 0.7833	* 0.7071	* 0.4767	F-SUB-Q			
	* 2.4270	* 2.4247	* 2.6676	* 3.9390	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1789	* 1.3721	* 1.6113	* 1.4769	* 1.6215	* 1.5882	* 1.6794	* 0.8263
	* 1.6881	* 1.6425	* 1.3751	* 1.4934	* 1.3471	* 1.3732	* 1.2966	* 2.3725
9	* 1.3721	* 1.6215	* 1.5547	* 1.6610	* 1.5246	* 1.5834	* 1.6555	* 0.8296
	* 1.6425	* 1.3823	* 1.4276	* 1.3228	* 1.4398	* 1.3788	* 1.3164	* 2.3702
10	* 1.6113	* 1.5522	* 1.3942	* 1.4270	* 1.6340	* 1.4919	* 1.6027	* 0.7521
	* 1.3751	* 1.4299	* 1.5976	* 1.5493	* 1.3502	* 1.4754	* 1.3620	* 2.6015
11	* 1.4769	* 1.6600	* 1.4260	* 1.5668	* 1.3892	* 1.5073	* 1.0104	* 0.5122
	* 1.4934	* 1.3233	* 1.5504	* 1.4198	* 1.5645	* 1.4225	* 2.0171	* 3.8655
12	* 1.6215	* 1.5243	* 1.6335	* 1.3879	* 1.1592	* 1.2846	* 0.7446	*
	* 1.3471	* 1.4401	* 1.3506	* 1.5655	* 1.4788	* 1.4317	* 2.4551	*
13	* 1.5882	* 1.5839	* 1.4931	* 1.5074	* 1.2844	* 1.2129	* 0.5809	*
	* 1.3732	* 1.3784	* 1.4742	* 1.4226	* 1.4316	* 1.4504	* 2.8970	*
14	* 1.6794	* 1.6559	* 1.6033	* 1.0107	* 0.7440	* 0.5808	*	*
	* 1.2966	* 1.3161	* 1.3615	* 2.0167	* 2.4552	* 2.8974	*	*
15	* 0.8263	* 0.8303	* 0.7522	* 0.5056	* F-SUB-Q			
	* 2.3725	* 2.3696	* 2.6009	* 3.8561	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2937	* 1.4495	* 1.6905	* 1.5359	* 1.6940	* 1.6495	* 1.7541	* 0.8615
	* 1.6951	* 1.6431	* 1.3728	* 1.5007	* 1.3408	* 1.3688	* 1.2852	* 2.3589
9	* 1.4495	* 1.7061	* 1.6167	* 1.7382	* 1.5847	* 1.6471	* 1.7320	* 0.8639
	* 1.6431	* 1.3835	* 1.4369	* 1.3198	* 1.4448	* 1.3733	* 1.3017	* 2.3589
10	* 1.6905	* 1.6139	* 1.4481	* 1.4892	* 1.7192	* 1.5570	* 1.6819	* 0.7872
	* 1.3728	* 1.4394	* 1.6105	* 1.5561	* 1.3468	* 1.4814	* 1.3526	* 2.5818
11	* 1.5359	* 1.7370	* 1.4882	* 1.6587	* 1.4757	* 1.6103	* 1.0703	* 0.5373
	* 1.5007	* 1.3204	* 1.5573	* 1.4130	* 1.5646	* 1.4144	* 2.0106	* 3.8652
12	* 1.6940	* 1.5843	* 1.7186	* 1.4747	* 1.2883	* 1.4200	* 0.8064	*
	* 1.3408	* 1.4452	* 1.3472	* 1.5657	* 1.4791	* 1.4267	* 2.4491	*
13	* 1.6495	* 1.6476	* 1.5583	* 1.6104	* 1.4198	* 1.3582	* 0.6399	*
	* 1.3688	* 1.3729	* 1.4802	* 1.4144	* 1.4266	* 1.4444	* 2.8925	*
14	* 1.7541	* 1.7325	* 1.6825	* 1.0706	* 0.8057	* 0.6398	*	*
	* 1.2852	* 1.3013	* 1.3521	* 2.0103	* 2.4495	* 2.8929	*	*
15	* 0.8615	* 0.8646	* 0.7874	* 0.5305	* F-SUB-Q			
	* 2.3589	* 2.3584	* 2.5813	* 3.8556	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4268	* 1.5154	* 1.7691	* 1.5906	* 1.7649	* 1.7074	* 1.8273	* 0.8820 *
	* 1.7054	* 1.6857	* 1.3893	* 1.5305	* 1.3529	* 1.3836	* 1.2874	* 2.4079 *
9	* 1.5154	* 1.7942	* 1.6767	* 1.8140	* 1.6417	* 1.7071	* 1.8090	* 0.8867 *
	* 1.6857	* 1.4031	* 1.4664	* 1.3349	* 1.4720	* 1.3882	* 1.3044	* 2.4045 *
10	* 1.7691	* 1.6737	* 1.5001	* 1.5488	* 1.8045	* 1.6203	* 1.7606	* 0.8080 *
	* 1.3893	* 1.4691	* 1.6477	* 1.5882	* 1.3617	* 1.5075	* 1.3611	* 2.6414 *
11	* 1.5906	* 1.8127	* 1.5476	* 1.7647	* 1.5697	* 1.7236	* 1.1142	* 0.5531 *
	* 1.5305	* 1.3355	* 1.5895	* 1.4110	* 1.5703	* 1.4110	* 2.0612	* 3.9769 *
12	* 1.7649	* 1.6409	* 1.8039	* 1.5685	* 1.4518	* 1.6028	* 0.8600	*
	* 1.3529	* 1.4724	* 1.3621	* 1.5715	* 1.4842	* 1.4286	* 2.4963	*
13	* 1.7074	* 1.7077	* 1.6218	* 1.7236	* 1.6027	* 1.5363	* 0.6926	*
	* 1.3836	* 1.3878	* 1.5061	* 1.4111	* 1.4285	* 1.4438	* 2.9530	*
14	* 1.8273	* 1.8095	* 1.7612	* 1.1144	* 0.8591	* 0.6925	*	
	* 1.2874	* 1.3040	* 1.3605	* 2.0610	* 2.4970	* 2.9535	*	
15	* 0.8820	* 0.8873	* 0.8081	* 0.5442	* F-SUB-Q			
	* 2.4079	* 2.4041	* 2.6411	* 3.9804	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5405	* 1.5713	* 1.8223	* 1.6278	* 1.8111	* 1.7459	* 1.8782	* 0.8982
	* 1.7536	* 1.7520	* 1.4416	* 1.5944	* 1.3991	* 1.4300	* 1.3227	* 2.4959
9	* 1.5713	* 1.8561	* 1.7179	* 1.8648	* 1.6830	* 1.7479	* 1.8606	* 0.9038
	* 1.7520	* 1.4582	* 1.5290	* 1.3838	* 1.5317	* 1.4346	* 1.3407	* 2.4927
10	* 1.8223	* 1.7146	* 1.5361	* 1.5913	* 1.8645	* 1.6663	* 1.8154	* 0.8253
	* 1.4416	* 1.5320	* 1.7213	* 1.6548	* 1.4109	* 1.5621	* 1.4029	* 2.7406
11	* 1.6278	* 1.8633	* 1.5900	* 1.8464	* 1.6418	* 1.8149	* 1.1524	* 0.5668
	* 1.5944	* 1.3845	* 1.6563	* 1.4362	* 1.6041	* 1.4329	* 2.1139	* 4.1430
12	* 1.8111	* 1.6822	* 1.8638	* 1.6405	* 1.6398	* 1.7458	* 0.9068	*
	* 1.3991	* 1.5321	* 1.4114	* 1.6053	* 1.5113	* 1.4483	* 2.5466	*
13	* 1.7459	* 1.7485	* 1.6680	* 1.8147	* 1.7458	* 1.6783	* 0.7395	*
	* 1.4300	* 1.4341	* 1.5606	* 1.4330	* 1.4484	* 1.4675	* 3.0250	*
14	* 1.8782	* 1.8611	* 1.8161	* 1.1526	* 0.9057	* 0.7394	*	
	* 1.3227	* 1.3404	* 1.4024	* 2.1138	* 2.5474	* 3.0255	*	
15	* 0.8982	* 0.9044	* 0.8254	* 0.5569	* F-SUB-Q			
	* 2.4959	* 2.4922	* 2.7405	* 4.1525	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5941	* 1.6099	* 1.8668	* 1.6565	* 1.8510	* 1.7780	* 1.9227	* 0.9074 *
	* 1.8290	* 1.8051	* 1.5132	* 1.6814	* 1.4631	* 1.4953	* 1.3750	* 2.6259 *
9	* 1.6099	* 1.9058	* 1.7501	* 1.9080	* 1.7153	* 1.7820	* 1.9059	* 0.9146 *
	* 1.8051	* 1.5189	* 1.6131	* 1.4509	* 1.6132	* 1.5001	* 1.3943	* 2.6217 *
10	* 1.8668	* 1.7466	* 1.5645	* 1.6262	* 1.9150	* 1.7104	* 1.8632	* 0.8357 *
	* 1.5132	* 1.6164	* 1.8186	* 1.7449	* 1.4779	* 1.6373	* 1.4618	* 2.8875 *
11	* 1.6565	* 1.9064	* 1.6252	* 1.9106	* 1.6943	* 1.8890	* 1.1782	* 0.5755 *
	* 1.6814	* 1.4516	* 1.7465	* 1.4833	* 1.6628	* 1.4768	* 2.1836	* 4.3757 *
12	* 1.8510	* 1.7144	* 1.9142	* 1.6928	* 1.7339	* 1.8362	* 0.9375	*
	* 1.4631	* 1.6137	* 1.4780	* 1.6642	* 1.5619	* 1.4895	* 2.6506	*
13	* 1.7780	* 1.7826	* 1.7122	* 1.8887	* 1.8363	* 1.7784	* 0.7707	*
	* 1.4953	* 1.4995	* 1.6357	* 1.4770	* 1.4895	* 1.5075	* 3.1453	*
14	* 1.9227	* 1.9064	* 1.8639	* 1.1783	* 0.9364	* 0.7705	*	
	* 1.3750	* 1.3939	* 1.4613	* 2.1836	* 2.6517	* 3.1459	*	
15	* 0.9074	* 0.9153	* 0.8357	* 0.5646	* F-SUB-Q			
	* 2.6259	* 2.6212	* 2.8875	* 4.3920	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5992	* 1.6122	* 1.8580	* 1.6522	* 1.8405	* 1.7741	* 1.9166	* 0.9189 *
	* 1.9306	* 1.9136	* 1.6426	* 1.8192	* 1.5818	* 1.6065	* 1.4778	* 2.7782 *
9	* 1.6122	* 1.8991	* 1.7451	* 1.8989	* 1.7145	* 1.7799	* 1.9006	* 0.9231 *
	* 1.9136	* 1.6181	* 1.7474	* 1.5725	* 1.7417	* 1.6111	* 1.4989	* 2.7818 *
10	* 1.8580	* 1.7415	* 1.5614	* 1.6317	* 1.9149	* 1.7167	* 1.8613	* 0.8495 *
	* 1.6426	* 1.7509	* 1.9618	* 1.8519	* 1.5644	* 1.7372	* 1.5725	* 3.0463 *
11	* 1.6522	* 1.8972	* 1.6307	* 1.9149	* 1.7056	* 1.9008	* 1.2051	* 0.5865 *
	* 1.8192	* 1.5734	* 1.8530	* 1.5695	* 1.7515	* 1.5605	* 2.2590	* 4.5397 *
12	* 1.8405	* 1.7136	* 1.9140	* 1.7041	* 1.7647	* 1.8591	* 0.9649	*
	* 1.5818	* 1.7422	* 1.5646	* 1.7530	* 1.6594	* 1.5855	* 2.7582	*
13	* 1.7741	* 1.7805	* 1.7185	* 1.9006	* 1.8591	* 1.8077	* 0.7992	*
	* 1.6065	* 1.6105	* 1.7353	* 1.5607	* 1.5856	* 1.6033	* 3.2739	*
14	* 1.9166	* 1.9011	* 1.8620	* 1.2052	* 0.9637	* 0.7991	*	
	* 1.4778	* 1.4985	* 1.5720	* 2.2591	* 2.7593	* 3.2746	*	
15	* 0.9189	* 0.9238	* 0.8495	* 0.5768	* F-SUB-Q			
	* 2.7782	* 2.7813	* 3.0464	* 4.5454	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6186	* 1.6274	* 1.8920	* 1.6690	* 1.8740	* 1.7994	* 1.9583	* 0.9138 *
	* 2.0325	* 2.0197	* 1.7225	* 1.9462	* 1.6751	* 1.7039	* 1.5549	* 2.9973 *
9	* 1.6274	* 1.9343	* 1.7642	* 1.9337	* 1.7336	* 1.8063	* 1.9424	* 0.9217 *
	* 2.0197	* 1.6937	* 1.8459	* 1.6693	* 1.8529	* 1.7083	* 1.5772	* 2.9916 *
10	* 1.8920	* 1.7604	* 1.5764	* 1.6522	* 1.9571	* 1.7424	* 1.9028	* 0.8448 *
	* 1.7225	* 1.8498	* 2.0685	* 1.9488	* 1.6292	* 1.8207	* 1.6425	* 3.2912 *
11	* 1.6690	* 1.9320	* 1.6511	* 1.9583	* 1.7336	* 1.9500	* 1.2044	* 0.5827 *
	* 1.9462	* 1.6702	* 1.9500	* 1.6325	* 1.8335	* 1.6186	* 2.4030	* 4.8463 *
12	* 1.8740	* 1.7326	* 1.9563	* 1.7320	* 1.8119	* 1.9115	* 0.9655	*
	* 1.6751	* 1.8540	* 1.6294	* 1.8351	* 1.7243	* 1.6367	* 2.9276	*
13	* 1.7994	* 1.8070	* 1.7444	* 1.9497	* 1.9114	* 1.8678	* 0.8003	*
	* 1.7039	* 1.7076	* 1.8188	* 1.6188	* 1.6368	* 1.6587	* 3.4877	*
14	* 1.9583	* 1.9429	* 1.9034	* 1.2044	* 0.9642	* 0.8001	*	
	* 1.5549	* 1.5768	* 1.6420	* 2.4032	* 2.9291	* 3.4885	*	
15	* 0.9138	* 0.9223	* 0.8447	* 0.5705	* F-SUB-Q			
	* 2.9973	* 2.9910	* 3.2916	* 4.8751	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6126	* 1.6206	* 1.8883	* 1.6624	* 1.8715	* 1.7983	* 1.9630	* 0.9112
	* 2.0335	* 2.0113	* 1.7213	* 1.9530	* 1.7345	* 1.8093	* 1.6579	* 3.2289
9	* 1.6206	* 1.9310	* 1.7569	* 1.9312	* 1.7293	* 1.8064	* 1.9473	* 0.9192
	* 2.0113	* 1.6875	* 1.8515	* 1.6833	* 1.8861	* 1.8035	* 1.6731	* 3.2212
10	* 1.8883	* 1.7530	* 1.5693	* 1.6501	* 1.9613	* 1.7425	* 1.9083	* 0.8436
	* 1.7213	* 1.8556	* 2.0742	* 1.9854	* 1.6730	* 1.8850	* 1.7157	* 3.4964
11	* 1.6624	* 1.9294	* 1.6490	* 1.9623	* 1.7350	* 1.9594	* 1.2063	* 0.5816
	* 1.9530	* 1.6849	* 1.9868	* 1.6751	* 1.8993	* 1.6856	* 2.5085	* 5.1322
12	* 1.8715	* 1.7282	* 1.9610	* 1.7333	* 1.8248	* 1.9264	* 0.9674	
	* 1.7345	* 1.8873	* 1.6738	* 1.9011	* 1.8194	* 1.7235	* 3.0973	
13	* 1.7983	* 1.8071	* 1.7445	* 1.9591	* 1.9262	* 1.8859	* 0.8037	
	* 1.8093	* 1.8028	* 1.8829	* 1.6859	* 1.7237	* 1.7521	* 3.6998	
14	* 1.9630	* 1.9478	* 1.9088	* 1.2063	* 0.9661	* 0.8035		
	* 1.6579	* 1.6727	* 1.7152	* 2.5088	* 3.0990	* 3.7007		
15	* 0.9112	* 0.9199	* 0.8434	* 0.5686	* F-SUB-Q			
	* 3.2289	* 3.2204	* 3.4971	* 5.1702	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5855	* 1.5947	* 1.8508	* 1.6343	* 1.8360	* 1.7738	* 1.9348	* 0.9093
	* 2.0309	* 2.0071	* 1.7252	* 1.9485	* 1.7323	* 1.7961	* 1.6473	* 3.1704
9	* 1.5947	* 1.8934	* 1.7257	* 1.8948	* 1.7038	* 1.7830	* 1.9195	* 0.9146
	* 2.0071	* 1.6908	* 1.8516	* 1.6842	* 1.8814	* 1.7912	* 1.6639	* 3.1697
10	* 1.8508	* 1.7218	* 1.5428	* 1.6280	* 1.9313	* 1.7197	* 1.8822	* 0.8436
	* 1.7252	* 1.8558	* 2.0734	* 1.9783	* 1.6720	* 1.8791	* 1.7098	* 3.4284
11	* 1.6343	* 1.8929	* 1.6268	* 1.9312	* 1.7130	* 1.9338	* 1.2089	* 0.5816
	* 1.9485	* 1.6859	* 1.9797	* 1.6748	* 1.8932	* 1.6829	* 2.4629	* 5.0428
12	* 1.8360	* 1.7027	* 1.9310	* 1.7113	* 1.8096	* 1.9049	* 0.9702	*
	* 1.7323	* 1.8826	* 1.6727	* 1.8951	* 1.8242	* 1.7241	* 3.0454	*
13	* 1.7738	* 1.7837	* 1.7217	* 1.9334	* 1.9047	* 1.8684	* 0.8091	*
	* 1.7961	* 1.7905	* 1.8769	* 1.6832	* 1.7243	* 1.7667	* 3.6669	*
14	* 1.9348	* 1.9200	* 1.8827	* 1.2089	* 0.9689	* 0.8089	*	*
	* 1.6473	* 1.6635	* 1.7093	* 2.4634	* 3.0471	* 3.6680	*	*
15	* 0.9093	* 0.9153	* 0.8434	* 0.5700	* F-SUB-Q			
	* 3.1704	* 3.1690	* 3.4292	* 5.0676	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5767	* 1.5829	* 1.8521	* 1.6255	* 1.8393	* 1.7751	* 1.9495	* 0.8921
	* 1.9627	* 1.9389	* 1.6561	* 1.8825	* 1.6676	* 1.7308	* 1.5771	* 3.0889
9	* 1.5829	* 1.8953	* 1.7177	* 1.8977	* 1.6962	* 1.7853	* 1.9341	* 0.9009
	* 1.9389	* 1.6239	* 1.7877	* 1.6187	* 1.8186	* 1.7304	* 1.5968	* 3.0746
10	* 1.8521	* 1.7128	* 1.5333	* 1.6213	* 1.9412	* 1.7169	* 1.8957	* 0.8274
	* 1.6561	* 1.7918	* 1.9982	* 1.9140	* 1.6104	* 1.8196	* 1.6390	* 3.3335
11	* 1.6255	* 1.8957	* 1.6201	* 1.9400	* 1.7108	* 1.9474	* 1.1889	* 0.5689
	* 1.8825	* 1.6203	* 1.9154	* 1.6143	* 1.8369	* 1.6239	* 2.4058	* 4.8826
12	* 1.8393	* 1.6951	* 1.9409	* 1.7090	* 1.8200	* 1.9233	* 0.9523	*
	* 1.6676	* 1.8198	* 1.6112	* 1.8388	* 1.7698	* 1.6611	* 2.9753	*
13	* 1.7751	* 1.7860	* 1.7190	* 1.9470	* 1.9231	* 1.8898	* 0.7934	*
	* 1.7308	* 1.7298	* 1.8175	* 1.6243	* 1.6613	* 1.6947	* 3.5755	*
14	* 1.9494	* 1.9346	* 1.8963	* 1.1888	* 0.9509	* 0.7932	*	*
	* 1.5771	* 1.5964	* 1.6386	* 2.4064	* 2.9774	* 3.5766	*	*
15	* 0.8921	* 0.9016	* 0.8272	* 0.5549	* F-SUB-Q			
	* 3.0889	* 3.0739	* 3.3346	* 4.9301	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5513	* 1.5570	* 1.8260	* 1.5998	* 1.8166	* 1.7564	* 1.9355	* 0.8766 *
	* 1.8234	* 1.8034	* 1.5318	* 1.7423	* 1.5375	* 1.5982	* 1.4515	* 2.8635 *
9	* 1.5570	* 1.8697	* 1.6912	* 1.8731	* 1.6722	* 1.7674	* 1.9203	* 0.8861 *
	* 1.8034	* 1.5047	* 1.6573	* 1.4943	* 1.6838	* 1.5941	* 1.4670	* 2.8450 *
10	* 1.8260	* 1.6856	* 1.5082	* 1.5993	* 1.9231	* 1.6963	* 1.8823	* 0.8136 *
	* 1.5318	* 1.6613	* 1.8543	* 1.7743	* 1.4863	* 1.6843	* 1.5092	* 3.0926 *
11	* 1.5998	* 1.8710	* 1.5980	* 1.9206	* 1.6905	* 1.9331	* 1.1713	* 0.5581 *
	* 1.7423	* 1.4961	* 1.7757	* 1.4894	* 1.6974	* 1.4923	* 2.2341	* 4.5604 *
12	* 1.8166	* 1.6710	* 1.9228	* 1.6886	* 1.8080	* 1.9123	* 0.9372	*
	* 1.5375	* 1.6849	* 1.4865	* 1.6992	* 1.6293	* 1.5271	* 2.7608	*
13	* 1.7564	* 1.7681	* 1.6985	* 1.9327	* 1.9120	* 1.8830	* 0.7815	*
	* 1.5982	* 1.5935	* 1.6823	* 1.4926	* 1.5273	* 1.5563	* 3.3206	*
14	* 1.9355	* 1.9208	* 1.8829	* 1.1712	* 0.9357	* 0.7813	*	
	* 1.4515	* 1.4667	* 1.5089	* 2.2347	* 2.7629	* 3.3216	*	
15	* 0.8766	* 0.8869	* 0.8133	* 0.5436	* F-SUB-Q			
	* 2.8635	* 2.8443	* 3.0939	* 4.6110	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5163	* 1.5206	* 1.7833	* 1.5629	* 1.7783	* 1.7244	* 1.9027	* 0.8610 *
	* 1.7008	* 1.6809	* 1.4319	* 1.6300	* 1.4372	* 1.4913	* 1.3527	* 2.6749 *
9	* 1.5206	* 1.8276	* 1.6535	* 1.8330	* 1.6371	* 1.7362	* 1.8878	* 0.8699 *
	* 1.6809	* 1.4014	* 1.5482	* 1.3963	* 1.5714	* 1.4851	* 1.3658	* 2.6571 *
10	* 1.7833	* 1.6479	* 1.4740	* 1.5666	* 1.8873	* 1.6637	* 1.8514	* 0.8000 *
	* 1.4319	* 1.5534	* 1.7321	* 1.6518	* 1.3825	* 1.5682	* 1.4022	* 2.8794 *
11	* 1.5629	* 1.8311	* 1.5653	* 1.8840	* 1.6581	* 1.9006	* 1.1541	* 0.5484 *
	* 1.6300	* 1.3974	* 1.6530	* 1.3873	* 1.5823	* 1.3896	* 2.0716	* 4.2394 *
12	* 1.7783	* 1.6359	* 1.8870	* 1.6562	* 1.7803	* 1.8817	* 0.9218	*
	* 1.4372	* 1.5726	* 1.3824	* 1.5841	* 1.5197	* 1.4258	* 2.5770	*
13	* 1.7244	* 1.7369	* 1.6659	* 1.9001	* 1.8814	* 1.8561	* 0.7697	*
	* 1.4913	* 1.4845	* 1.5662	* 1.3899	* 1.4260	* 1.4490	* 3.0999	*
14	* 1.9027	* 1.8883	* 1.8519	* 1.1540	* 0.9203	* 0.7695	*	
	* 1.3527	* 1.3654	* 1.4019	* 2.0722	* 2.5791	* 3.1008	*	
15	* 0.8610	* 0.8706	* 0.7997	* 0.5338	* F-SUB-Q			
	* 2.6749	* 2.6565	* 2.8806	* 4.2890	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4683	* 1.4744	* 1.7196	* 1.5130	* 1.7187	* 1.6762	* 1.8460	* 0.8459 *
	* 1.7421	* 1.7220	* 1.4750	* 1.6738	* 1.4818	* 1.5299	* 1.3898	* 2.7193 *
9	* 1.4744	* 1.7645	* 1.6014	* 1.7716	* 1.5888	* 1.6885	* 1.8317	* 0.8521 *
	* 1.7220	* 1.4420	* 1.5886	* 1.4361	* 1.6093	* 1.5214	* 1.4022	* 2.7075 *
10	* 1.7196	* 1.5959	* 1.4277	* 1.5217	* 1.8288	* 1.6169	* 1.7981	* 0.7872 *
	* 1.4750	* 1.5938	* 1.7775	* 1.6898	* 1.4154	* 1.6024	* 1.4352	* 2.9154 *
11	* 1.5130	* 1.7697	* 1.5204	* 1.8248	* 1.6117	* 1.8456	* 1.1376	* 0.5394 *
	* 1.6738	* 1.4377	* 1.6911	* 1.4204	* 1.6125	* 1.4153	* 2.0878	* 4.2938 *
12	* 1.7187	* 1.5876	* 1.8285	* 1.6099	* 1.7345	* 1.8269	* 0.9078	*
	* 1.4818	* 1.6105	* 1.4157	* 1.6143	* 1.5361	* 1.4469	* 2.5858	*
13	* 1.6762	* 1.6892	* 1.6191	* 1.8451	* 1.8266	* 1.8062	* 0.7603	*
	* 1.5299	* 1.5208	* 1.6004	* 1.4157	* 1.4472	* 1.4680	* 3.0969	*
14	* 1.8460	* 1.8322	* 1.7986	* 1.1374	* 0.9064	* 0.7601	*	
	* 1.3898	* 1.4018	* 1.4349	* 2.0884	* 2.5878	* 3.0980	*	
15	* 0.8459	* 0.8528	* 0.7869	* 0.5266	* F-SUB-Q			
	* 2.7193	* 2.7069	* 2.9166	* 4.3310	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4370	* 1.4388	* 1.6914	* 1.4796	* 1.6941	* 1.6505	* 1.8287	* 0.8141
	* 1.6431	* 1.6351	* 1.3925	* 1.5912	* 1.3994	* 1.4471	* 1.3065	* 2.6360
9	* 1.4388	* 1.7378	* 1.5689	* 1.7458	* 1.5556	* 1.6636	* 1.8145	* 0.8237
	* 1.6351	* 1.3568	* 1.5058	* 1.3547	* 1.5265	* 1.4374	* 1.3173	* 2.6117
10	* 1.6914	* 1.5632	* 1.3964	* 1.4897	* 1.8072	* 1.5875	* 1.7818	* 0.7573
	* 1.3925	* 1.5111	* 1.6876	* 1.5992	* 1.3265	* 1.5125	* 1.3449	* 2.8224
11	* 1.4796	* 1.7439	* 1.4884	* 1.8015	* 1.5826	* 1.8271	* 1.0974	* 0.5176
	* 1.5912	* 1.3565	* 1.6005	* 1.3329	* 1.5223	* 1.3241	* 2.0068	* 4.1567
12	* 1.6941	* 1.5544	* 1.8069	* 1.5808	* 1.7127	* 1.8101	* 0.8732	
	* 1.3994	* 1.5277	* 1.3268	* 1.5240	* 1.4316	* 1.3478	* 2.4920	
13	* 1.6505	* 1.6643	* 1.5898	* 1.8267	* 1.8097	* 1.7933	* 0.7297	
	* 1.4471	* 1.4368	* 1.5104	* 1.3244	* 1.3480	* 1.3635	* 2.9844	
14	* 1.8287	* 1.8150	* 1.7823	* 1.0972	* 0.8718	* 0.7295		
	* 1.3065	* 1.3170	* 1.3445	* 2.0075	* 2.4942	* 2.9853		
15	* 0.8141	* 0.8244	* 0.7570	* 0.5027	* F-SUB-Q			
	* 2.6360	* 2.6110	* 2.8238	* 4.2141	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3853	* 1.3854	* 1.6264	* 1.4243	* 1.6328	* 1.5976	* 1.7689	* 0.7843 *
	* 1.5939	* 1.5923	* 1.3592	* 1.5530	* 1.3650	* 1.4060	* 1.2698	* 2.5779 *
9	* 1.3854	* 1.6746	* 1.5132	* 1.6823	* 1.5003	* 1.6107	* 1.7554	* 0.7938 *
	* 1.5923	* 1.3203	* 1.4656	* 1.3205	* 1.4860	* 1.3955	* 1.2799	* 2.5524 *
10	* 1.6264	* 1.5076	* 1.3462	* 1.4369	* 1.7453	* 1.5341	* 1.7259	* 0.7300 *
	* 1.3592	* 1.4709	* 1.6435	* 1.5536	* 1.2858	* 1.4659	* 1.3029	* 2.7556 *
11	* 1.4243	* 1.6804	* 1.4356	* 1.7390	* 1.5293	* 1.7681	* 1.0608	* 0.4986 *
	* 1.5530	* 1.3220	* 1.5549	* 1.2920	* 1.4733	* 1.2774	* 1.9452	* 4.0552 *
12	* 1.6328	* 1.4991	* 1.7450	* 1.5276	* 1.6595	* 1.7504	* 0.8418 *	
	* 1.3650	* 1.4872	* 1.2860	* 1.4750	* 1.3754	* 1.2994	* 2.4157 *	
13	* 1.5976	* 1.6115	* 1.5363	* 1.7677	* 1.7501	* 1.7382	* 0.7035 *	
	* 1.4060	* 1.3948	* 1.4639	* 1.2777	* 1.2997	* 1.3120	* 2.8935 *	
14	* 1.7689	* 1.7559	* 1.7264	* 1.0606	* 0.8404	* 0.7033 *		
	* 1.2698	* 1.2795	* 1.3026	* 1.9459	* 2.4178	* 2.8944 *		
15	* 0.7843	* 0.7945	* 0.7296	* 0.4840	* F-SUB-Q			
	* 2.5779	* 2.5517	* 2.7570	* 4.1137	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3104	* 1.3113	* 1.5175	* 1.3439	* 1.5281	* 1.5122	* 1.6584	* 0.7544 *
	* 1.5970	* 1.5967	* 1.3816	* 1.5621	* 1.3846	* 1.4103	* 1.2857	* 2.5498 *
9	* 1.3113	* 1.5684	* 1.4305	* 1.5743	* 1.4187	* 1.5250	* 1.6458	* 0.7605 *
	* 1.5967	* 1.3364	* 1.4707	* 1.3383	* 1.4907	* 1.3990	* 1.2955	* 2.5346 *
10	* 1.5175	* 1.4253	* 1.2744	* 1.3593	* 1.6351	* 1.4522	* 1.6220	* 0.7035 *
	* 1.3816	* 1.4759	* 1.6473	* 1.5563	* 1.2994	* 1.4668	* 1.3145	* 2.7190 *
11	* 1.3439	* 1.5724	* 1.3581	* 1.6300	* 1.4471	* 1.6602	* 1.0250	* 0.4816 *
	* 1.5621	* 1.3398	* 1.5576	* 1.3048	* 1.4728	* 1.2862	* 1.9084	* 3.9910 *
12	* 1.5281	* 1.4175	* 1.6348	* 1.4456	* 1.5684	* 1.6393	* 0.8116 *	
	* 1.3846	* 1.4919	* 1.2997	* 1.4746	* 1.3718	* 1.3074	* 2.3713 *	
13	* 1.5122	* 1.5257	* 1.4542	* 1.6598	* 1.6391	* 1.6314	* 0.6802 *	
	* 1.4103	* 1.3984	* 1.4648	* 1.2865	* 1.3076	* 1.3173	* 2.8277 *	
14	* 1.6584	* 1.6463	* 1.6224	* 1.0248	* 0.8103	* 0.6800 *		
	* 1.2857	* 1.2952	* 1.3142	* 1.9091	* 2.3733	* 2.8287 *		
15	* 0.7544	* 0.7611	* 0.7032	* 0.4697	* F-SUB-Q			
	* 2.5498	* 2.5340	* 2.7205	* 4.0293	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2442	* 1.2388	* 1.4298	* 1.2728	* 1.4401	* 1.4363	* 1.5680	* 0.7023
	* 1.6112	* 1.6177	* 1.4047	* 1.5802	* 1.4082	* 1.4229	* 1.3040	* 2.6305
9	* 1.2388	* 1.4817	* 1.3587	* 1.4845	* 1.3418	* 1.4481	* 1.5533	* 0.7109
	* 1.6177	* 1.3546	* 1.4832	* 1.3593	* 1.5097	* 1.4116	* 1.3154	* 2.6040
10	* 1.4298	* 1.3536	* 1.2102	* 1.2843	* 1.5417	* 1.3752	* 1.5335	* 0.6537
	* 1.4047	* 1.4886	* 1.6622	* 1.5768	* 1.3187	* 1.4824	* 1.3316	* 2.8098
11	* 1.2728	* 1.4828	* 1.2832	* 1.5378	* 1.3710	* 1.5686	* 0.9564	* 0.4480
	* 1.5802	* 1.3609	* 1.5782	* 1.3227	* 1.4883	* 1.3015	* 1.9595	* 4.1207
12	* 1.4401	* 1.3407	* 1.5414	* 1.3694	* 1.4859	* 1.5475	* 0.7543	*
	* 1.4082	* 1.5109	* 1.3190	* 1.4900	* 1.3821	* 1.3231	* 2.4428	*
13	* 1.4363	* 1.4487	* 1.3772	* 1.5682	* 1.5473	* 1.5392	* 0.6285	*
	* 1.4229	* 1.4110	* 1.4803	* 1.3018	* 1.3233	* 1.3326	* 2.9280	*
14	* 1.5680	* 1.5537	* 1.5339	* 0.9562	* 0.7530	* 0.6283	*	*
	* 1.3040	* 1.3151	* 1.3313	* 1.9603	* 2.4450	* 2.9290	*	*
15	* 0.7023	* 0.7115	* 0.6534	* 0.4350	* F-SUB-Q			
	* 2.6305	* 2.6033	* 2.8115	* 4.1790	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1258	* 1.1261	* 1.2858	* 1.1619	* 1.2873	* 1.2947	* 1.3969	* 0.6408
	* 1.7221	* 1.7208	* 1.5091	* 1.6733	* 1.5212	* 1.5262	* 1.4155	* 2.7936
9	* 1.1261	* 1.3237	* 1.2335	* 1.3283	* 1.2160	* 1.3055	* 1.3827	* 0.6490
	* 1.7208	* 1.4654	* 1.5794	* 1.4645	* 1.6102	* 1.5139	* 1.4293	* 2.7649
10	* 1.2858	* 1.2291	* 1.0971	* 1.1621	* 1.3700	* 1.2429	* 1.3609	* 0.5936
	* 1.5091	* 1.5845	* 1.7732	* 1.6842	* 1.4338	* 1.5856	* 1.4510	* 3.0001
11	* 1.1619	* 1.3267	* 1.1611	* 1.3709	* 1.2391	* 1.3944	* 0.8668	* 0.4060
	* 1.6733	* 1.4663	* 1.6857	* 1.4331	* 1.5901	* 1.4140	* 2.0923	* 4.4109
12	* 1.2873	* 1.2151	* 1.3697	* 1.2378	* 1.3381	* 1.3784	* 0.6856	*
	* 1.5212	* 1.6115	* 1.4341	* 1.5920	* 1.4807	* 1.4341	* 2.6005	*
13	* 1.2948	* 1.3061	* 1.2445	* 1.3940	* 1.3783	* 1.3618	* 0.5672	*
	* 1.5262	* 1.5133	* 1.5835	* 1.4144	* 1.4342	* 1.4540	* 3.1400	*
14	* 1.3969	* 1.3831	* 1.3612	* 0.8666	* 0.6844	* 0.5670	*	*
	* 1.4155	* 1.4289	* 1.4507	* 2.0931	* 2.6028	* 3.1411	*	*
15	* 0.6408	* 0.6495	* 0.5932	* 0.3940	* F-SUB-Q			
	* 2.7936	* 2.7643	* 3.0021	* 4.4763	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8952	* 0.9163	* 1.1529	* 0.9466	* 1.1442	* 1.0212	* 1.1874	* 0.5301
	* 2.1122	* 2.0631	* 1.6407	* 2.0020	* 1.6631	* 1.8859	* 1.6221	* 3.3009
9	* 0.9163	* 1.1373	* 1.0060	* 1.1539	* 0.9711	* 1.0312	* 1.1756	* 0.5349
	* 2.0631	* 1.6610	* 1.8853	* 1.6426	* 1.9638	* 1.8677	* 1.6384	* 3.2781
10	* 1.1529	* 1.0036	* 0.8725	* 0.9329	* 1.1639	* 0.9929	* 1.0938	* 0.4823
	* 1.6407	* 1.8897	* 2.1738	* 2.0448	* 1.6416	* 1.9332	* 1.7603	* 3.6093
11	* 0.9466	* 1.1529	* 0.9322	* 1.1753	* 0.9882	* 1.1442	* 0.7034	* 0.3281
	* 2.0020	* 1.6441	* 2.0464	* 1.6253	* 1.9405	* 1.6777	* 2.5167	* 5.3406
12	* 1.1442	* 0.9703	* 1.1636	* 0.9872	* 1.0681	* 1.1786	* 0.5684	*
	* 1.6631	* 1.9654	* 1.6424	* 1.9425	* 1.8061	* 1.6352	* 3.0623	*
13	* 1.0212	* 1.0316	* 0.9940	* 1.1440	* 1.1784	* 1.0590	* 0.4532	*
	* 1.8859	* 1.8670	* 1.9312	* 1.6780	* 1.6356	* 1.8232	* 3.8385	*
14	* 1.1874	* 1.1759	* 1.0938	* 0.7032	* 0.5675	* 0.4530	*	*
	* 1.6221	* 1.6381	* 1.7603	* 2.5178	* 3.0647	* 3.8399	*	*
15	* 0.5301	* 0.5354	* 0.4820	* 0.3184	* F-SUB-Q			
	* 3.3009	* 3.2775	* 3.6118	* 5.4191	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3544	* 0.3830	* 0.4646	* 0.3959	* 0.4601	* 0.3905	* 0.4235	* 0.2174
	* 5.2188	* 4.8291	* 3.9839	* 4.6849	* 4.0533	* 4.8193	* 4.4471	* 7.8969
9	* 0.3830	* 0.4530	* 0.3998	* 0.4618	* 0.3892	* 0.3925	* 0.4186	* 0.2165
	* 4.8291	* 4.0830	* 4.6372	* 4.0224	* 4.7897	* 4.7954	* 4.4995	* 7.9484
10	* 0.4646	* 0.3992	* 0.3635	* 0.3876	* 0.4614	* 0.3856	* 0.3856	* 0.1972
	* 3.9839	* 4.6448	* 5.1071	* 4.8183	* 4.0533	* 4.8700	* 4.8854	* 8.6611
11	* 0.3959	* 0.4614	* 0.3873	* 0.4583	* 0.3949	* 0.4350	* 0.2870	* 0.1350
	* 4.6849	* 4.0260	* 4.8217	* 4.0797	* 4.7496	* 4.3192	* 6.0434	* 12.7475
12	* 0.4601	* 0.3890	* 0.4612	* 0.3946	* 0.4007	* 0.4214	* 0.2330	*
	* 4.0533	* 4.7917	* 4.0550	* 4.7552	* 4.7084	* 4.4719	* 7.3267	*
13	* 0.3905	* 0.3927	* 0.3859	* 0.4349	* 0.4213	* 0.3709	* 0.1834	*
	* 4.8193	* 4.7942	* 4.8665	* 4.3202	* 4.4728	* 5.0918	* 9.3043	*
14	* 0.4235	* 0.4187	* 0.3855	* 0.2868	* 0.2327	* 0.1833	*	*
	* 4.4471	* 4.4988	* 4.8858	* 6.0467	* 7.3300	* 9.3081	*	*
15	* 0.2174	* 0.2166	* 0.1971	* 0.1322	* F-SUB-Q			
	* 7.8969	* 7.9462	* 8.6673	* 12.8154	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3474	* 0.4358	* 0.5398	* 0.4772	* 0.5429	* 0.4665	* 0.4856	* 0.2711
	* 4.6838	* 4.4892	* 3.6560	* 4.0648	* 3.6155	* 4.1938	* 4.1250	* 6.6220
9	* 0.4358	* 0.5127	* 0.4819	* 0.5411	* 0.4686	* 0.4583	* 0.4774	* 0.2657
	* 4.4892	* 3.9009	* 4.0488	* 3.6367	* 4.1118	* 4.2551	* 4.1935	* 6.7729
10	* 0.5398	* 0.4815	* 0.4383	* 0.4486	* 0.5124	* 0.4334	* 0.4320	* 0.2359
	* 3.6560	* 4.0487	* 4.5423	* 4.3316	* 3.8283	* 4.4514	* 4.5269	* 7.4341
11	* 0.4772	* 0.5409	* 0.4484	* 0.4824	* 0.4140	* 0.4316	* 0.3038	* 0.1618
	* 4.0648	* 3.6375	* 4.3336	* 4.1189	* 4.5869	* 4.3826	* 5.8437	* 10.7651
12	* 0.5429	* 0.4686	* 0.5123	* 0.4138	* 0.3280	* 0.3402	* 0.2270	*
	* 3.6155	* 4.1120	* 3.8291	* 4.5878	* 4.5658	* 4.4771	* 6.8838	*
13	* 0.4665	* 0.4583	* 0.4336	* 0.4316	* 0.3401	* 0.2844	* 0.1638	*
	* 4.1938	* 4.2558	* 4.4517	* 4.3827	* 4.4766	* 4.9426	* 8.6095	*
14	* 0.4856	* 0.4775	* 0.4320	* 0.3038	* 0.2269	* 0.1637	*	*
	* 4.1250	* 4.1929	* 4.5264	* 5.8438	* 6.8764	* 8.6103	*	*
15	* 0.2711	* 0.2660	* 0.2359	* 0.1596	F-SUB-Q			
	* 6.6220	* 6.7694	* 7.4343	* 10.7008	M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.7906	* 0.9511	* 1.1894	* 1.0447	* 1.1994	* 1.0833	* 1.1866	* 0.6246
	* 2.1817	* 2.1174	* 1.7078	* 1.9151	* 1.6888	* 1.8599	* 1.7364	* 2.9599
9	* 0.9511	* 1.1364	* 1.0990	* 1.1953	* 1.0619	* 1.0726	* 1.1687	* 0.6165
	* 2.1174	* 1.7985	* 1.8262	* 1.6954	* 1.8749	* 1.8797	* 1.7466	* 2.9755
10	* 1.1894	* 1.0978	* 0.9576	* 0.9833	* 1.1405	* 1.0084	* 1.0666	* 0.5464
	* 1.7078	* 1.8268	* 2.1258	* 2.0313	* 1.7718	* 1.9761	* 1.8891	* 3.3013
11	* 1.0447	* 1.1951	* 0.9828	* 1.0911	* 0.9344	* 0.9990	* 0.6945	* 0.3758
	* 1.9151	* 1.6958	* 2.0322	* 1.8605	* 2.0705	* 1.9338	* 2.6395	* 4.7847
12	* 1.1994	* 1.0618	* 1.1402	* 0.9339	* 0.7561	* 0.8379	* 0.5223	*
	* 1.6888	* 1.8750	* 1.7721	* 2.0712	* 1.9863	* 1.8671	* 3.0616	*
13	* 1.0833	* 1.0728	* 1.0089	* 0.9990	* 0.8379	* 0.7228	* 0.3860	*
	* 1.8599	* 1.8799	* 1.9760	* 1.9338	* 1.8670	* 2.0608	* 3.7448	*
14	* 1.1866	* 1.1689	* 1.0668	* 0.6947	* 0.5220	* 0.3859	*	*
	* 1.7364	* 1.7463	* 1.8888	* 2.6393	* 3.0591	* 3.7452	*	*
15	* 0.6246	* 0.6168	* 0.5465	* 0.3709	F-SUB-Q			
	* 2.9599	* 2.9760	* 3.3011	* 4.7528	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9721	* 1.1658	* 1.4089	* 1.2777	* 1.4199	* 1.3358	* 1.4183	* 0.7549 *
	* 1.8496	* 1.7677	* 1.4745	* 1.6023	* 1.4588	* 1.5384	* 1.4618	* 2.4630 *
9	* 1.1658	* 1.3621	* 1.3337	* 1.4288	* 1.3078	* 1.3247	* 1.3975	* 0.7514 *
	* 1.7677	* 1.5303	* 1.5369	* 1.4498	* 1.5576	* 1.5481	* 1.4806	* 2.4743 *
10	* 1.4089	* 1.3321	* 1.1741	* 1.2070	* 1.3690	* 1.2388	* 1.3078	* 0.6786 *
	* 1.4745	* 1.5376	* 1.7553	* 1.6911	* 1.5094	* 1.6456	* 1.5746	* 2.7110 *
11	* 1.2777	* 1.4285	* 1.2064	* 1.3021	* 1.1444	* 1.2099	* 0.8621	* 0.4659 *
	* 1.6023	* 1.4502	* 1.6919	* 1.5881	* 1.7237	* 1.6318	* 2.1781	* 3.9518 *
12	* 1.4199	* 1.3076	* 1.3687	* 1.1436	* 0.9313	* 1.0132	* 0.6409 *	
	* 1.4588	* 1.5577	* 1.5097	* 1.7243	* 1.6570	* 1.6038	* 2.5552 *	
13	* 1.3358	* 1.3249	* 1.2395	* 1.2100	* 1.0132	* 0.9204	* 0.4883 *	
	* 1.5384	* 1.5482	* 1.6453	* 1.6318	* 1.6037	* 1.6771	* 3.0377 *	
14	* 1.4183	* 1.3978	* 1.3081	* 0.8623	* 0.6404	* 0.4883 *		
	* 1.4618	* 1.4804	* 1.5742	* 2.1778	* 2.5534	* 3.0381 *		
15	* 0.7549	* 0.7519	* 0.6788	* 0.4618	* F-SUB-Q			
	* 2.4630	* 2.4746	* 2.7106	* 3.9089	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0776	* 1.2920	* 1.6145	* 1.4229	* 1.6274	* 1.4970	* 1.6322	* 0.8210 *
	* 1.7187	* 1.6419	* 1.3215	* 1.4776	* 1.3057	* 1.4021	* 1.2950	* 2.3103 *
9	* 1.2920	* 1.5575	* 1.4823	* 1.6369	* 1.4562	* 1.4846	* 1.6078	* 0.8206 *
	* 1.6419	* 1.3743	* 1.4198	* 1.2983	* 1.4357	* 1.4117	* 1.3138	* 2.3149 *
10	* 1.6145	* 1.4803	* 1.3007	* 1.3425	* 1.5705	* 1.3811	* 1.4982	* 0.7375 *
	* 1.3215	* 1.4207	* 1.6259	* 1.5617	* 1.3511	* 1.5157	* 1.4073	* 2.5552 *
11	* 1.4229	* 1.6365	* 1.3418	* 1.4932	* 1.2776	* 1.3936	* 0.9438	* 0.5048 *
	* 1.4776	* 1.2987	* 1.5625	* 1.4214	* 1.5843	* 1.4563	* 2.0458	* 3.7493 *
12	* 1.6274	* 1.4559	* 1.5702	* 1.2765	* 1.0395	* 1.1693	* 0.7035 *	
	* 1.3057	* 1.4358	* 1.3514	* 1.5850	* 1.5103	* 1.4261	* 2.4053 *	
13	* 1.4970	* 1.4849	* 1.3820	* 1.3938	* 1.1692	* 1.0728	* 0.5385 *	
	* 1.4021	* 1.4117	* 1.5152	* 1.4563	* 1.4261	* 1.4946	* 2.8591 *	
14	* 1.6322	* 1.6081	* 1.4986	* 0.9441	* 0.7029	* 0.5384 *		
	* 1.2950	* 1.3135	* 1.4069	* 2.0455	* 2.4039	* 2.8594 *		
15	* 0.8210	* 0.8211	* 0.7376	* 0.4991	* F-SUB-Q			
	* 2.3103	* 2.3150	* 2.5548	* 3.7172	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1386	* 1.3586	* 1.7190	* 1.4924	* 1.7302	* 1.5696	* 1.7385	* 0.8604 *
	* 1.7048	* 1.6163	* 1.2802	* 1.4515	* 1.2633	* 1.3770	* 1.2504	* 2.2712 *
9	* 1.3586	* 1.6527	* 1.5518	* 1.7393	* 1.5263	* 1.5581	* 1.7125	* 0.8597 *
	* 1.6163	* 1.3398	* 1.3995	* 1.2579	* 1.4097	* 1.3860	* 1.2695	* 2.2767 *
10	* 1.7190	* 1.5495	* 1.3568	* 1.4083	* 1.6695	* 1.4472	* 1.5905	* 0.7745 *
	* 1.2802	* 1.4005	* 1.6113	* 1.5353	* 1.3098	* 1.4904	* 1.3654	* 2.5098 *
11	* 1.4924	* 1.7388	* 1.4075	* 1.5901	* 1.3463	* 1.4909	* 0.9950	* 0.5285 *
	* 1.4515	* 1.2583	* 1.5362	* 1.3826	* 1.5612	* 1.4141	* 2.0047	* 3.6930 *
12	* 1.7302	* 1.5260	* 1.6691	* 1.3451	* 1.1047	* 1.2653	* 0.7484	*
	* 1.2633	* 1.4098	* 1.3101	* 1.5619	* 1.4777	* 1.3777	* 2.3662	*
13	* 1.5696	* 1.5585	* 1.4483	* 1.4910	* 1.2652	* 1.1682	* 0.5778	*
	* 1.3770	* 1.3859	* 1.4899	* 1.4141	* 1.3777	* 1.4484	* 2.8111	*
14	* 1.7385	* 1.7129	* 1.5909	* 0.9953	* 0.7477	* 0.5777	*	*
	* 1.2504	* 1.2692	* 1.3650	* 2.0045	* 2.3651	* 2.8114	*	*
15	* 0.8604	* 0.8602	* 0.7747	* 0.5217	F-SUB-Q			
	* 2.2712	* 2.2769	* 2.5094	* 3.6673	M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1912	* 1.4076	* 1.7756	* 1.5293	* 1.7821	* 1.6046	* 1.7923	* 0.8848 *
	* 1.7253	* 1.6294	* 1.2889	* 1.4711	* 1.2703	* 1.3877	* 1.2499	* 2.2774 *
9	* 1.4076	* 1.7072	* 1.5891	* 1.7913	* 1.5624	* 1.5950	* 1.7663	* 0.8830 *
	* 1.6294	* 1.3531	* 1.4207	* 1.2671	* 1.4281	* 1.3956	* 1.2687	* 2.2858 *
10	* 1.7756	* 1.5866	* 1.3874	* 1.4451	* 1.7236	* 1.4835	* 1.6397	* 0.7996 *
	* 1.2889	* 1.4218	* 1.6387	* 1.5574	* 1.3215	* 1.5134	* 1.3708	* 2.5115 *
11	* 1.5293	* 1.7908	* 1.4442	* 1.6482	* 1.3951	* 1.5577	* 1.0344	* 0.5458 *
	* 1.4711	* 1.2674	* 1.5584	* 1.3923	* 1.5806	* 1.4219	* 2.0200	* 3.7274 *
12	* 1.7821	* 1.5621	* 1.7232	* 1.3937	* 1.1641	* 1.3529	* 0.7897	*
	* 1.2703	* 1.4282	* 1.3218	* 1.5814	* 1.4958	* 1.3862	* 2.3876	*
13	* 1.6046	* 1.5954	* 1.4847	* 1.5578	* 1.3527	* 1.2564	* 0.6191	*
	* 1.3877	* 1.3955	* 1.5127	* 1.4219	* 1.3862	* 1.4610	* 2.8328	*
14	* 1.7923	* 1.7667	* 1.6402	* 1.0346	* 0.7889	* 0.6190	*	*
	* 1.2499	* 1.2684	* 1.3704	* 2.0199	* 2.3866	* 2.8331	*	*
15	* 0.8848	* 0.8836	* 0.7997	* 0.5390	F-SUB-Q			
	* 2.2774	* 2.2861	* 2.5113	* 3.7006	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2817	* 1.4521	* 1.8322	* 1.5619	* 1.8306	* 1.6366	* 1.8440	* 0.8943
	* 1.7482	* 1.6862	* 1.3156	* 1.5136	* 1.2950	* 1.4170	* 1.2636	* 2.3444
9	* 1.4521	* 1.7679	* 1.6251	* 1.8432	* 1.5930	* 1.6289	* 1.8184	* 0.8946
	* 1.6862	* 1.3841	* 1.4626	* 1.2933	* 1.4689	* 1.4252	* 1.2837	* 2.3498
10	* 1.8322	* 1.6225	* 1.4171	* 1.4783	* 1.7798	* 1.5197	* 1.6908	* 0.8096
	* 1.3156	* 1.4639	* 1.6916	* 1.6051	* 1.3503	* 1.5543	* 1.3935	* 2.5932
11	* 1.5619	* 1.8422	* 1.4772	* 1.7192	* 1.4523	* 1.6383	* 1.0603	* 0.5545
	* 1.5136	* 1.2937	* 1.6062	* 1.4016	* 1.6051	* 1.4321	* 2.0922	* 3.8697
12	* 1.8306	* 1.5927	* 1.7793	* 1.4508	* 1.2670	* 1.4857	* 0.8278	*
	* 1.2950	* 1.4691	* 1.3506	* 1.6060	* 1.5183	* 1.3981	* 2.4556	*
13	* 1.6366	* 1.6293	* 1.5210	* 1.6383	* 1.4855	* 1.3835	* 0.6571	*
	* 1.4170	* 1.4251	* 1.5535	* 1.4321	* 1.3982	* 1.4782	* 2.9240	*
14	* 1.8440	* 1.8188	* 1.6913	* 1.0605	* 0.8270	* 0.6570	*	*
	* 1.2636	* 1.2834	* 1.3932	* 2.0922	* 2.4547	* 2.9244	*	*
15	* 0.8943	* 0.8952	* 0.8097	* 0.5455	* F-SUB-Q			
	* 2.3444	* 2.3501	* 2.5931	* 3.8558	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3911	* 1.4949	* 1.8686	* 1.5816	* 1.8574	* 1.6532	* 1.8728	* 0.9012
	* 1.8076	* 1.7524	* 1.3741	* 1.5876	* 1.3507	* 1.4767	* 1.3083	* 2.4470
9	* 1.4949	* 1.8128	* 1.6481	* 1.8745	* 1.6102	* 1.6478	* 1.8482	* 0.9023
	* 1.7524	* 1.4479	* 1.5355	* 1.3504	* 1.5402	* 1.4852	* 1.3298	* 2.4527
10	* 1.8686	* 1.6453	* 1.4364	* 1.5006	* 1.8174	* 1.5441	* 1.7247	* 0.8184
	* 1.3741	* 1.5369	* 1.7796	* 1.6854	* 1.4107	* 1.6248	* 1.4483	* 2.7098
11	* 1.5816	* 1.8735	* 1.4995	* 1.7813	* 1.5056	* 1.7106	* 1.0863	* 0.5629
	* 1.5876	* 1.3509	* 1.6866	* 1.4392	* 1.6531	* 1.4662	* 2.1577	* 4.0610
12	* 1.8574	* 1.6098	* 1.8169	* 1.5045	* 1.4426	* 1.6359	* 0.8688	*
	* 1.3507	* 1.5404	* 1.4111	* 1.6540	* 1.5601	* 1.4300	* 2.5244	*
13	* 1.6532	* 1.6482	* 1.5455	* 1.7105	* 1.6358	* 1.5199	* 0.6999	*
	* 1.4767	* 1.4851	* 1.6240	* 1.4662	* 1.4301	* 1.5169	* 3.0199	*
14	* 1.8728	* 1.8486	* 1.7252	* 1.0864	* 0.8679	* 0.6998	*	*
	* 1.3083	* 1.3295	* 1.4480	* 2.1577	* 2.5236	* 3.0204	*	*
15	* 0.9012	* 0.9029	* 0.8184	* 0.5530	* F-SUB-Q			
	* 2.4470	* 2.4529	* 2.7099	* 4.0521	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4666	* 1.5287	* 1.9029	* 1.5982	* 1.8833	* 1.6681	* 1.9004	* 0.9033
	* 1.8938	* 1.8147	* 1.4487	* 1.6825	* 1.4218	* 1.5541	* 1.3679	* 2.5897
9	* 1.5287	* 1.8604	* 1.6683	* 1.9047	* 1.6245	* 1.6647	* 1.8767	* 0.9061
	* 1.8147	* 1.5086	* 1.6277	* 1.4230	* 1.6314	* 1.5629	* 1.3910	* 2.5932
10	* 1.9029	* 1.6654	* 1.4537	* 1.5199	* 1.8534	* 1.5723	* 1.7574	* 0.8220
	* 1.4487	* 1.6293	* 1.8894	* 1.7878	* 1.4871	* 1.7146	* 1.5180	* 2.8725
11	* 1.5982	* 1.9036	* 1.5189	* 1.8372	* 1.5510	* 1.7758	* 1.1051	* 0.5682
	* 1.6825	* 1.4235	* 1.7891	* 1.4939	* 1.7242	* 1.5194	* 2.2453	* 4.3085
12	* 1.8833	* 1.6241	* 1.8528	* 1.5498	* 1.5796	* 1.7575	* 0.9000	*
	* 1.4218	* 1.6316	* 1.4875	* 1.7251	* 1.6209	* 1.4785	* 2.6411	*
13	* 1.6681	* 1.6652	* 1.5737	* 1.7757	* 1.7574	* 1.6308	* 0.7334	*
	* 1.5541	* 1.5628	* 1.7136	* 1.5194	* 1.4786	* 1.5677	* 3.1564	*
14	* 1.9004	* 1.8771	* 1.7578	* 1.1052	* 0.8990	* 0.7332	*	*
	* 1.3679	* 1.3907	* 1.5177	* 2.2455	* 2.6405	* 3.1570	*	*
15	* 0.9033	* 0.9066	* 0.8219	* 0.5574	* F-SUB-Q			
	* 2.5897	* 2.5934	* 2.8727	* 4.3054	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4809	* 1.5321	* 1.8914	* 1.5901	* 1.8665	* 1.6564	* 1.8848	* 0.9111
	* 2.0018	* 1.9259	* 1.5741	* 1.8230	* 1.5424	* 1.6748	* 1.4749	* 2.7443
9	* 1.5321	* 1.8566	* 1.6604	* 1.8907	* 1.6160	* 1.6546	* 1.8622	* 0.9108
	* 1.9259	* 1.6076	* 1.7654	* 1.5452	* 1.7646	* 1.6833	* 1.5002	* 2.7590
10	* 1.8914	* 1.6575	* 1.4481	* 1.5178	* 1.8446	* 1.5738	* 1.7487	* 0.8337
	* 1.5741	* 1.7669	* 2.0362	* 1.9132	* 1.5902	* 1.8177	* 1.6389	* 3.0352
11	* 1.5901	* 1.8896	* 1.5168	* 1.8419	* 1.5623	* 1.7862	* 1.1294	* 0.5778
	* 1.8230	* 1.5457	* 1.9141	* 1.5836	* 1.8248	* 1.6116	* 2.3289	* 4.4832
12	* 1.8665	* 1.6156	* 1.8440	* 1.5611	* 1.6219	* 1.7934	* 0.9285	*
	* 1.5424	* 1.7647	* 1.5907	* 1.8259	* 1.7280	* 1.5790	* 2.7633	*
13	* 1.6564	* 1.6551	* 1.5753	* 1.7861	* 1.7932	* 1.6713	* 0.7669	*
	* 1.6748	* 1.6832	* 1.8167	* 1.6117	* 1.5791	* 1.6731	* 3.2882	*
14	* 1.8848	* 1.8626	* 1.7491	* 1.1294	* 0.9274	* 0.7667	*	*
	* 1.4749	* 1.4999	* 1.6386	* 2.3292	* 2.7628	* 3.2889	*	*
15	* 0.9111	* 0.9113	* 0.8336	* 0.5686	* F-SUB-Q			
	* 2.7443	* 2.7593	* 3.0356	* 4.4657	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5029	* 1.5491	* 1.9269	* 1.6049	* 1.8981	* 1.6739	* 1.9207	* 0.9042 *
	* 2.1092	* 2.0349	* 1.6483	* 1.9482	* 1.6370	* 1.7812	* 1.5547	* 2.9674 *
9	* 1.5491	* 1.8941	* 1.6778	* 1.9246	* 1.6288	* 1.6736	* 1.8985	* 0.9077 *
	* 2.0349	* 1.6835	* 1.8641	* 1.6413	* 1.8900	* 1.7895	* 1.5816	* 2.9717 *
10	* 1.9269	* 1.6747	* 1.4610	* 1.5325	* 1.8806	* 1.5964	* 1.7850	* 0.8269 *
	* 1.6483	* 1.8661	* 2.1522	* 2.0174	* 1.6597	* 1.9097	* 1.7118	* 3.2884 *
11	* 1.6049	* 1.9234	* 1.5315	* 1.8852	* 1.5869	* 1.8334	* 1.1280	* 0.5741 *
	* 1.9482	* 1.6419	* 2.0184	* 1.6517	* 1.9156	* 1.6754	* 2.4834	* 4.7972 *
12	* 1.8981	* 1.6284	* 1.8800	* 1.5855	* 1.6710	* 1.8558	* 0.9329 *	
	* 1.6370	* 1.8901	* 1.6602	* 1.9168	* 1.8031	* 1.6356	* 2.9347 *	
13	* 1.6739	* 1.6741	* 1.5980	* 1.8333	* 1.8556	* 1.7315	* 0.7696 *	
	* 1.7812	* 1.7893	* 1.9085	* 1.6755	* 1.6358	* 1.7380	* 3.5203 *	
14	* 1.9207	* 1.8988	* 1.7853	* 1.1280	* 0.9317	* 0.7694 *		
	* 1.5547	* 1.5812	* 1.7115	* 2.4839	* 2.9344	* 3.5211 *		
15	* 0.9042	* 0.9083	* 0.8267	* 0.5618	* F-SUB-Q			
	* 2.9674	* 2.9719	* 3.2891	* 4.8051	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5038	* 1.5490	* 1.9313	* 1.6031	* 1.9005	* 1.6728	* 1.9263	* 0.9029 *
	* 2.1334	* 2.0502	* 1.6663	* 1.9766	* 1.6920	* 1.9063	* 1.6684	* 3.1941 *
9	* 1.5490	* 1.8992	* 1.6760	* 1.9281	* 1.6262	* 1.6738	* 1.9043	* 0.9065 *
	* 2.0502	* 1.6973	* 1.8906	* 1.6689	* 1.9437	* 1.9058	* 1.6945	* 3.1985 *
10	* 1.9313	* 1.6727	* 1.4584	* 1.5321	* 1.8859	* 1.5984	* 1.7920	* 0.8268 *
	* 1.6663	* 1.8927	* 2.1814	* 2.0753	* 1.7134	* 2.0017	* 1.8062	* 3.5140 *
11	* 1.6031	* 1.9269	* 1.5310	* 1.8942	* 1.5912	* 1.8457	* 1.1320	* 0.5742 *
	* 1.9766	* 1.6700	* 2.0767	* 1.7136	* 2.0080	* 1.7639	* 2.6193	* 5.1083 *
12	* 1.9005	* 1.6258	* 1.8852	* 1.5897	* 1.6881	* 1.8769	* 0.9385 *	
	* 1.6920	* 1.9441	* 1.7140	* 2.0093	* 1.9122	* 1.7324	* 3.1213 *	
13	* 1.6728	* 1.6743	* 1.6000	* 1.8455	* 1.8766	* 1.7541	* 0.7764 *	
	* 1.9063	* 1.9056	* 2.0004	* 1.7640	* 1.7326	* 1.8380	* 3.7354 *	
14	* 1.9263	* 1.9047	* 1.7922	* 1.1319	* 0.9374	* 0.7763 *		
	* 1.6684	* 1.6941	* 1.8059	* 2.6198	* 3.1210	* 3.7362 *		
15	* 0.9029	* 0.9071	* 0.8266	* 0.5613	* F-SUB-Q			
	* 3.1941	* 3.1987	* 3.5150	* 5.1227	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4888	* 1.5348	* 1.9080	* 1.5863	* 1.8766	* 1.6564	* 1.9058	* 0.9050
	* 2.1189	* 2.0367	* 1.6605	* 1.9648	* 1.6840	* 1.8906	* 1.6613	* 3.1512
9	* 1.5348	* 1.8765	* 1.6573	* 1.9046	* 1.6099	* 1.6588	* 1.8842	* 0.9059
	* 2.0367	* 1.6913	* 1.8824	* 1.6633	* 1.9309	* 1.8903	* 1.6835	* 3.1611
10	* 1.9080	* 1.6541	* 1.4427	* 1.5193	* 1.8642	* 1.5832	* 1.7736	* 0.8317
	* 1.6605	* 1.8847	* 2.1711	* 2.0628	* 1.7082	* 1.9942	* 1.7987	* 3.4366
11	* 1.5863	* 1.9033	* 1.5184	* 1.8743	* 1.5789	* 1.8288	* 1.1398	* 0.5769
	* 1.9648	* 1.6644	* 2.0642	* 1.7097	* 1.9987	* 1.7596	* 2.5677	* 5.0114
12	* 1.8766	* 1.6095	* 1.8634	* 1.5775	* 1.6818	* 1.8655	* 0.9456	*
	* 1.6840	* 1.9313	* 1.7088	* 2.0000	* 1.9275	* 1.7434	* 3.0774	*
13	* 1.6564	* 1.6593	* 1.5848	* 1.8286	* 1.8652	* 1.7465	* 0.7876	*
	* 1.8906	* 1.8901	* 1.9929	* 1.7597	* 1.7436	* 1.8679	* 3.7162	*
14	* 1.9058	* 1.8846	* 1.7738	* 1.1397	* 0.9444	* 0.7874	*	
	* 1.6613	* 1.6832	* 1.7985	* 2.5684	* 3.0773	* 3.7171	*	
15	* 0.9050	* 0.9064	* 0.8314	* 0.5656	F-SUB-Q			
	* 3.1512	* 3.1614	* 3.4377	* 5.0102	M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4932	* 1.5380	* 1.9288	* 1.5910	* 1.8963	* 1.6654	* 1.9322	* 0.8936 *
	* 2.0632	* 1.9777	* 1.5987	* 1.9051	* 1.6226	* 1.8244	* 1.5913	* 3.0805 *
9	* 1.5380	* 1.8965	* 1.6627	* 1.9248	* 1.6128	* 1.6691	* 1.9103	* 0.8981 *
	* 1.9777	* 1.6307	* 1.8248	* 1.6017	* 1.8757	* 1.8283	* 1.6164	* 3.0813 *
10	* 1.9288	* 1.6593	* 1.4446	* 1.5231	* 1.8855	* 1.5903	* 1.7978	* 0.8199 *
	* 1.5987	* 1.8271	* 2.1058	* 2.0064	* 1.6498	* 1.9439	* 1.7321	* 3.3789 *
11	* 1.5910	* 1.9235	* 1.5222	* 1.8960	* 1.5851	* 1.8532	* 1.1274	* 0.5681 *
	* 1.9051	* 1.6028	* 2.0078	* 1.6586	* 1.9552	* 1.7090	* 2.5387	* 4.9028 *
12	* 1.8963	* 1.6124	* 1.8847	* 1.5835	* 1.7010	* 1.8965	* 0.9354 *	
	* 1.6226	* 1.8761	* 1.6504	* 1.9566	* 1.8820	* 1.6929	* 3.0243 *	
13	* 1.6654	* 1.6697	* 1.5920	* 1.8531	* 1.8962	* 1.7769	* 0.7763 *	
	* 1.8244	* 1.8281	* 1.9426	* 1.7092	* 1.6932	* 1.8075	* 3.6470 *	
14	* 1.9322	* 1.9107	* 1.7980	* 1.1273	* 0.9342	* 0.7761 *		
	* 1.5913	* 1.6161	* 1.7319	* 2.5395	* 3.0244	* 3.6480 *		
15	* 0.8936	* 0.8987	* 0.8195	* 0.5540	* F-SUB-Q			
	* 3.0805	* 3.0815	* 3.3803	* 4.9274	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4867	* 1.5317	* 1.9284	* 1.5849	* 1.8952	* 1.6623	* 1.9364	* 0.8867 *
	* 1.8983	* 1.8237	* 1.4764	* 1.7638	* 1.4983	* 1.6932	* 1.4729	* 2.8596 *
9	* 1.5317	* 1.8956	* 1.6558	* 1.9241	* 1.6060	* 1.6667	* 1.9144	* 0.8920 *
	* 1.8237	* 1.5021	* 1.6892	* 1.4802	* 1.7369	* 1.6929	* 1.4934	* 2.8537 *
10	* 1.9284	* 1.6522	* 1.4369	* 1.5175	* 1.8859	* 1.5851	* 1.8010	* 0.8137 *
	* 1.4764	* 1.6913	* 1.9449	* 1.8509	* 1.5200	* 1.7885	* 1.5937	* 3.1230 *
11	* 1.5849	* 1.9227	* 1.5165	* 1.8962	* 1.5803	* 1.8560	* 1.1208	* 0.5625 *
	* 1.7638	* 1.4812	* 1.8523	* 1.5205	* 1.7942	* 1.5613	* 2.3315	* 4.5307 *
12	* 1.8952	* 1.6055	* 1.8851	* 1.5787	* 1.7041	* 1.9038	* 0.9294 *	
	* 1.4983	* 1.7373	* 1.5206	* 1.7955	* 1.7180	* 1.5399	* 2.7814 *	
13	* 1.6623	* 1.6673	* 1.5869	* 1.8559	* 1.9034	* 1.7855	* 0.7719 *	
	* 1.6932	* 1.6927	* 1.7872	* 1.5615	* 1.5402	* 1.6417	* 3.3520 *	
14	* 1.9364	* 1.9148	* 1.8012	* 1.1206	* 0.9281	* 0.7717 *		
	* 1.4729	* 1.4931	* 1.5936	* 2.3323	* 2.7816	* 3.3529 *		
15	* 0.8867	* 0.8926	* 0.8134	* 0.5479	F-SUB-Q			
	* 2.8596	* 2.8539	* 3.1245	* 4.5596	M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4751	* 1.5199	* 1.9158	* 1.5721	* 1.8825	* 1.6520	* 1.9273	* 0.8818 *
	* 1.7632	* 1.6936	* 1.3664	* 1.6323	* 1.3863	* 1.5700	* 1.3631	* 2.6516 *
9	* 1.5199	* 1.8833	* 1.6421	* 1.9115	* 1.5932	* 1.6570	* 1.9053	* 0.8864 *
	* 1.6936	* 1.3924	* 1.5671	* 1.3681	* 1.6081	* 1.5671	* 1.3808	* 2.6462 *
10	* 1.9158	* 1.6385	* 1.4246	* 1.5064	* 1.8746	* 1.5730	* 1.7921	* 0.8100 *
	* 1.3664	* 1.5692	* 1.8070	* 1.7195	* 1.4092	* 1.6605	* 1.4773	* 2.8869 *
11	* 1.5721	* 1.9101	* 1.5054	* 1.8847	* 1.5691	* 1.8465	* 1.1176	* 0.5594 *
	* 1.6323	* 1.3690	* 1.7208	* 1.4076	* 1.6630	* 1.4435	* 2.1546	* 4.2072 *
12	* 1.8826	* 1.5927	* 1.8738	* 1.5675	* 1.6973	* 1.8966	* 0.9257 *	
	* 1.3863	* 1.6084	* 1.4099	* 1.6642	* 1.5855	* 1.4206	* 2.5711 *	
13	* 1.6520	* 1.6576	* 1.5749	* 1.8463	* 1.8963	* 1.7802	* 0.7694 *	
	* 1.5700	* 1.5670	* 1.6592	* 1.4437	* 1.4208	* 1.5130	* 3.0957 *	
14	* 1.9273	* 1.9057	* 1.7923	* 1.1174	* 0.9243	* 0.7692 *		
	* 1.3631	* 1.3806	* 1.4772	* 2.1554	* 2.5714	* 3.0966 *		
15	* 0.8818	* 0.8870	* 0.8096	* 0.5445	F-SUB-Q			
	* 2.6516	* 2.6464	* 2.8883	* 4.2362	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4558	* 1.5002	* 1.8854	* 1.5505	* 1.8524	* 1.6316	* 1.8990	* 0.8798 *
	* 1.7824	* 1.7140	* 1.3861	* 1.6555	* 1.4105	* 1.5945	* 1.3868	* 2.6684 *
9	* 1.5002	* 1.8536	* 1.6184	* 1.8812	* 1.5722	* 1.6367	* 1.8773	* 0.8816 *
	* 1.7140	* 1.4124	* 1.5886	* 1.3891	* 1.6312	* 1.5902	* 1.4040	* 2.6697 *
10	* 1.8854	* 1.6148	* 1.4071	* 1.4877	* 1.8460	* 1.5513	* 1.7657	* 0.8102 *
	* 1.3861	* 1.5907	* 1.8304	* 1.7405	* 1.4303	* 1.6885	* 1.4982	* 2.8909 *
11	* 1.5505	* 1.8798	* 1.4867	* 1.8555	* 1.5495	* 1.8192	* 1.1184	* 0.5584 *
	* 1.6555	* 1.3901	* 1.7419	* 1.4332	* 1.6888	* 1.4682	* 2.1612	* 4.2275 *
12	* 1.8524	* 1.5717	* 1.8452	* 1.5479	* 1.6779	* 1.8701	* 0.9253 *	
	* 1.4105	* 1.6315	* 1.4309	* 1.6901	* 1.6019	* 1.4397	* 2.5778 *	
13	* 1.6316	* 1.6373	* 1.5533	* 1.8190	* 1.8698	* 1.7576	* 0.7725 *	
	* 1.5945	* 1.5900	* 1.6872	* 1.4683	* 1.4400	* 1.5307	* 3.0878 *	
14	* 1.8990	* 1.8776	* 1.7658	* 1.1182	* 0.9239	* 0.7723 *		
	* 1.3868	* 1.4038	* 1.4982	* 2.1620	* 2.5781	* 3.0888 *		
15	* 0.8798	* 0.8822	* 0.8098	* 0.5454	* F-SUB-Q			
	* 2.6684	* 2.6699	* 2.8924	* 4.2424	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4503	* 1.4942	* 1.8953	* 1.5461	* 1.8618	* 1.6316	* 1.9143	* 0.8612 *
	* 1.6667	* 1.6048	* 1.2879	* 1.5530	* 1.3132	* 1.4938	* 1.2884	* 2.5564 *
9	* 1.4942	* 1.8634	* 1.6150	* 1.8911	* 1.5664	* 1.6379	* 1.8923	* 0.8669 *
	* 1.6048	* 1.3096	* 1.4879	* 1.2914	* 1.5320	* 1.4878	* 1.3037	* 2.5451 *
10	* 1.8953	* 1.6113	* 1.3987	* 1.4824	* 1.8570	* 1.5495	* 1.7795	* 0.7915 *
	* 1.2879	* 1.4900	* 1.7190	* 1.6311	* 1.3266	* 1.5757	* 1.3881	* 2.7706 *
11	* 1.5461	* 1.8896	* 1.4814	* 1.8661	* 1.5459	* 1.8321	* 1.0965	* 0.5446 *
	* 1.5530	* 1.2924	* 1.6323	* 1.3274	* 1.5784	* 1.3603	* 2.0555	* 4.0475 *
12	* 1.8618	* 1.5659	* 1.8561	* 1.5442	* 1.6839	* 1.8862	* 0.9056 *	
	* 1.3132	* 1.5323	* 1.3272	* 1.5798	* 1.4840	* 1.3306	* 2.4623 *	
13	* 1.6316	* 1.6386	* 1.5514	* 1.8319	* 1.8858	* 1.7736	* 0.7528 *	
	* 1.4938	* 1.4876	* 1.5744	* 1.3605	* 1.3308	* 1.4139	* 2.9617 *	
14	* 1.9143	* 1.8927	* 1.7797	* 1.0963	* 0.9043	* 0.7526 *		
	* 1.2884	* 1.3035	* 1.3880	* 2.0563	* 2.4627	* 2.9625 *		
15	* 0.8612	* 0.8675	* 0.7911	* 0.5291	* F-SUB-Q			
	* 2.5564	* 2.5452	* 2.7722	* 4.0840	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4267	* 1.4695	* 1.8657	* 1.5205	* 1.8329	* 1.6094	* 1.8885	* 0.8454
	* 1.5944	* 1.5399	* 1.2350	* 1.4924	* 1.2605	* 1.4323	* 1.2343	* 2.4657
9	* 1.4695	* 1.8354	* 1.5890	* 1.8621	* 1.5409	* 1.6158	* 1.8669	* 0.8514
	* 1.5399	* 1.2538	* 1.4284	* 1.2383	* 1.4720	* 1.4259	* 1.2487	* 2.4532
10	* 1.8657	* 1.5852	* 1.3758	* 1.4592	* 1.8305	* 1.5264	* 1.7561	* 0.7773
	* 1.2350	* 1.4306	* 1.6511	* 1.5637	* 1.2693	* 1.5068	* 1.3272	* 2.6687
11	* 1.5205	* 1.8605	* 1.4581	* 1.8390	* 1.5230	* 1.8073	* 1.0801	* 0.5342
	* 1.4924	* 1.2393	* 1.5648	* 1.2669	* 1.5068	* 1.2954	* 1.9658	* 3.8974
12	* 1.8329	* 1.5403	* 1.8295	* 1.5213	* 1.6627	* 1.8611	* 0.8900	*
	* 1.2605	* 1.4723	* 1.2698	* 1.5082	* 1.4136	* 1.2698	* 2.3588	*
13	* 1.6094	* 1.6164	* 1.5284	* 1.8070	* 1.8607	* 1.7522	* 0.7396	*
	* 1.4323	* 1.4257	* 1.5055	* 1.2956	* 1.2700	* 1.3480	* 2.8468	*
14	* 1.8885	* 1.8672	* 1.7562	* 1.0799	* 0.8887	* 0.7394	*	*
	* 1.2343	* 1.2484	* 1.3271	* 1.9666	* 2.3592	* 2.8476	*	*
15	* 0.8454	* 0.8520	* 0.7769	* 0.5187	* F-SUB-Q			
	* 2.4657	* 2.4533	* 2.6703	* 3.9347	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3801	* 1.4188	* 1.7811	* 1.4656	* 1.7503	* 1.5553	* 1.8074	* 0.8290
	* 1.5709	* 1.5216	* 1.2331	* 1.4771	* 1.2590	* 1.4143	* 1.2300	* 2.4032
9	* 1.4188	* 1.7561	* 1.5322	* 1.7800	* 1.4873	* 1.5611	* 1.7867	* 0.8313
	* 1.5216	* 1.2484	* 1.4129	* 1.2348	* 1.4552	* 1.4081	* 1.2440	* 2.4008
10	* 1.7811	* 1.5286	* 1.3326	* 1.4101	* 1.7531	* 1.4744	* 1.6821	* 0.7645
	* 1.2331	* 1.4151	* 1.6285	* 1.5418	* 1.2626	* 1.4853	* 1.3201	* 2.5919
11	* 1.4656	* 1.7785	* 1.4091	* 1.7609	* 1.4728	* 1.7313	* 1.0650	* 0.5255
	* 1.4771	* 1.2359	* 1.5428	* 1.2584	* 1.4822	* 1.2850	* 1.8990	* 3.7830
12	* 1.7503	* 1.4867	* 1.7522	* 1.4712	* 1.6038	* 1.7806	* 0.8748	*
	* 1.2590	* 1.4556	* 1.2632	* 1.4835	* 1.3894	* 1.2577	* 2.2813	*
13	* 1.5553	* 1.5617	* 1.4764	* 1.7310	* 1.7803	* 1.6794	* 0.7308	*
	* 1.4143	* 1.4079	* 1.4839	* 1.2851	* 1.2580	* 1.3348	* 2.7356	*
14	* 1.8074	* 1.7870	* 1.6822	* 1.0648	* 0.8735	* 0.7305	*	*
	* 1.2300	* 1.2438	* 1.3200	* 1.8998	* 2.2817	* 2.7365	*	*
15	* 0.8290	* 0.8319	* 0.7641	* 0.5131	* F-SUB-Q			
	* 2.4032	* 2.4010	* 2.5934	* 3.7984	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3280	* 1.3611	* 1.7066	* 1.4084	* 1.6772	* 1.5000	* 1.7362	* 0.7833
	* 1.5716	* 1.5255	* 1.2379	* 1.4794	* 1.2641	* 1.4113	* 1.2315	* 2.4520
9	* 1.3611	* 1.6864	* 1.4764	* 1.7071	* 1.4286	* 1.5054	* 1.7163	* 0.7889
	* 1.5255	* 1.2501	* 1.4109	* 1.2384	* 1.4582	* 1.4051	* 1.2456	* 2.4387
10	* 1.7066	* 1.4728	* 1.2819	* 1.3548	* 1.6845	* 1.4227	* 1.6173	* 0.7208
	* 1.2379	* 1.4132	* 1.6283	* 1.5432	* 1.2626	* 1.4798	* 1.3203	* 2.6498
11	* 1.4084	* 1.7056	* 1.3538	* 1.6916	* 1.4194	* 1.6650	* 1.0104	* 0.4965
	* 1.4794	* 1.2395	* 1.5442	* 1.2582	* 1.4779	* 1.2828	* 1.9253	* 3.8601
12	* 1.6772	* 1.4281	* 1.6836	* 1.4179	* 1.5459	* 1.7093	* 0.8268	*
	* 1.2641	* 1.4586	* 1.2633	* 1.4793	* 1.3815	* 1.2559	* 2.3195	*
13	* 1.5000	* 1.5060	* 1.4246	* 1.6647	* 1.7090	* 1.6147	* 0.6853	*
	* 1.4113	* 1.4049	* 1.4785	* 1.2829	* 1.2562	* 1.3301	* 2.8015	*
14	* 1.7362	* 1.7166	* 1.6174	* 1.0102	* 0.8255	* 0.6851	*	*
	* 1.2315	* 1.2454	* 1.3202	* 1.9261	* 2.3201	* 2.8024	*	*
15	* 0.7833	* 0.7894	* 0.7204	* 0.4823	* F-SUB-Q			
	* 2.4520	* 2.4388	* 2.6515	* 3.8954	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2157	* 1.2428	* 1.5300	* 1.2877	* 1.5030	* 1.3684	* 1.5538	* 0.7170
	* 1.6660	* 1.6208	* 1.3386	* 1.5694	* 1.3680	* 1.5004	* 1.3342	* 2.6036
9	* 1.2428	* 1.5130	* 1.3531	* 1.5315	* 1.3056	* 1.3735	* 1.5362	* 0.7234
	* 1.6208	* 1.3511	* 1.4929	* 1.3385	* 1.5479	* 1.4937	* 1.3493	* 2.5850
10	* 1.5300	* 1.3500	* 1.1748	* 1.2369	* 1.5109	* 1.3009	* 1.4527	* 0.6593
	* 1.3386	* 1.4952	* 1.7241	* 1.6392	* 1.3642	* 1.5690	* 1.4260	* 2.8160
11	* 1.2877	* 1.5302	* 1.2360	* 1.5175	* 1.2993	* 1.4926	* 0.9258	* 0.4546
	* 1.5694	* 1.3396	* 1.6403	* 1.3590	* 1.5654	* 1.3861	* 2.0394	* 4.1009
12	* 1.5030	* 1.3051	* 1.5101	* 1.2978	* 1.4081	* 1.5299	* 0.7572	*
	* 1.3680	* 1.5483	* 1.3649	* 1.5668	* 1.4678	* 1.3581	* 2.4576	*
13	* 1.3684	* 1.3740	* 1.3026	* 1.4924	* 1.5296	* 1.4466	* 0.6245	*
	* 1.5004	* 1.4936	* 1.5675	* 1.3863	* 1.3584	* 1.4369	* 2.9825	*
14	* 1.5538	* 1.5365	* 1.4529	* 0.9255	* 0.7560	* 0.6243	*	*
	* 1.3342	* 1.3491	* 1.4259	* 2.0403	* 2.4583	* 2.9835	*	*
15	* 0.7170	* 0.7239	* 0.6589	* 0.4413	* F-SUB-Q			
	* 2.6036	* 2.5850	* 2.8180	* 4.1412	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9785	* 1.0044	* 1.2629	* 1.0393	* 1.2403	* 1.0878	* 1.2680	* 0.5887 *
	* 2.0216	* 1.9580	* 1.5825	* 1.8978	* 1.6179	* 1.8424	* 1.5964	* 3.1017 *
9	* 1.0044	* 1.2364	* 1.0991	* 1.2544	* 1.0474	* 1.0969	* 1.2543	* 0.5937 *
	* 1.9580	* 1.6147	* 1.7937	* 1.5954	* 1.8832	* 1.8258	* 1.6137	* 3.0822 *
10	* 1.2629	* 1.0968	* 0.9463	* 0.9951	* 1.2285	* 1.0489	* 1.1667	* 0.5350 *
	* 1.5825	* 1.7961	* 2.0899	* 1.9889	* 1.6380	* 1.8990	* 1.7335	* 3.3971 *
11	* 1.0393	* 1.2535	* 0.9944	* 1.2416	* 1.0443	* 1.2066	* 0.7532	* 0.3699 *
	* 1.8978	* 1.5966	* 1.9901	* 1.6210	* 1.8997	* 1.6741	* 2.4496	* 4.9374 *
12	* 1.2403	* 1.0471	* 1.2280	* 1.0433	* 1.1325	* 1.2518	* 0.6227	*
	* 1.6179	* 1.8837	* 1.6387	* 1.9011	* 1.7801	* 1.6193	* 2.9210	*
13	* 1.0878	* 1.0972	* 1.0500	* 1.2064	* 1.2516	* 1.1305	* 0.5012	*
	* 1.8424	* 1.8256	* 1.8977	* 1.6744	* 1.6196	* 1.7962	* 3.6339	*
14	* 1.2680	* 1.2544	* 1.1667	* 0.7530	* 0.6217	* 0.5011	*	
	* 1.5964	* 1.6135	* 1.7337	* 2.4509	* 2.9215	* 3.6351	*	
15	* 0.5887	* 0.5941	* 0.5346	* 0.3590	F-SUB-Q			
	* 3.1017	* 3.0824	* 3.3997	* 4.9870	M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4015	* 0.4318	* 0.5236	* 0.4456	* 0.5125	* 0.4321	* 0.4724	* 0.2469
	* 4.8171	* 4.4578	* 3.7332	* 4.3307	* 3.8327	* 4.5320	* 4.1905	* 7.2550
9	* 0.4318	* 0.5092	* 0.4491	* 0.5174	* 0.4330	* 0.4337	* 0.4668	* 0.2458
	* 4.4578	* 3.8360	* 4.2892	* 3.7853	* 4.4561	* 4.5121	* 4.2405	* 7.3007
10	* 0.5236	* 0.4484	* 0.4079	* 0.4264	* 0.5064	* 0.4225	* 0.4312	* 0.2243
	* 3.7332	* 4.2925	* 4.7444	* 4.5389	* 3.8876	* 4.6108	* 4.5886	* 7.9487
11	* 0.4456	* 0.5171	* 0.4262	* 0.5025	* 0.4322	* 0.4797	* 0.3176	* 0.1562
	* 4.3307	* 3.7880	* 4.5423	* 3.9191	* 4.4861	* 4.1203	* 5.6895	* 11.4840
12	* 0.5125	* 0.4329	* 0.5062	* 0.4319	* 0.4409	* 0.4673	* 0.2617	*
	* 3.8327	* 4.4572	* 3.8889	* 4.4896	* 4.4666	* 4.2414	* 6.8153	*
13	* 0.4321	* 0.4338	* 0.4228	* 0.4796	* 0.4672	* 0.4144	* 0.2084	*
	* 4.5320	* 4.5121	* 4.6093	* 4.1211	* 4.2422	* 4.7912	* 8.5719	*
14	* 0.4724	* 0.4668	* 0.4312	* 0.3175	* 0.2613	* 0.2083	*	
	* 4.1905	* 4.2400	* 4.5893	* 5.6930	* 6.8145	* 8.5754	*	
15	* 0.2469	* 0.2460	* 0.2241	* 0.1530	F-SUB-Q			
	* 7.2550	* 7.3004	* 7.9550	* 11.4926	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3881	* 0.4937	* 0.6130	* 0.5448	* 0.6217	* 0.5404	* 0.5690	* 0.3263
	* 4.1422	* 4.0231	* 3.3570	* 3.6197	* 3.2987	* 3.6936	* 3.6751	* 5.6513
9	* 0.4937	* 0.5817	* 0.5484	* 0.6176	* 0.5382	* 0.5327	* 0.5600	* 0.3190
	* 4.0231	* 3.5832	* 3.6197	* 3.3227	* 3.6492	* 3.7382	* 3.7295	* 5.8528
10	* 0.6130	* 0.5480	* 0.5013	* 0.5135	* 0.5879	* 0.5024	* 0.5102	* 0.2852
	* 3.3570	* 3.6198	* 4.0396	* 3.8521	* 3.4746	* 3.9021	* 3.9956	* 6.3315
11	* 0.5448	* 0.6175	* 0.5133	* 0.5528	* 0.4755	* 0.5032	* 0.3579	* 0.2005
	* 3.6197	* 3.3233	* 3.8536	* 3.7384	* 4.0563	* 3.9338	* 5.1016	* 8.9639
12	* 0.6217	* 0.5382	* 0.5878	* 0.4753	* 0.3709	* 0.3970	* 0.2716	*
	* 3.2987	* 3.6494	* 3.4752	* 4.0571	* 3.9623	* 3.9724	* 5.9250	*
13	* 0.5404	* 0.5328	* 0.5025	* 0.5032	* 0.3969	* 0.3383	* 0.1992	*
	* 3.6936	* 3.7389	* 3.9023	* 3.9339	* 3.9721	* 4.3523	* 7.3550	*
14	* 0.5690	* 0.5601	* 0.5103	* 0.3580	* 0.2715	* 0.1991	*	*
	* 3.6751	* 3.7291	* 3.9954	* 5.1022	* 5.9134	* 7.3560	*	*
15	* 0.3263	* 0.3194	* 0.2852	* 0.1978	* F-SUB-Q			
	* 5.6513	* 5.8501	* 6.3325	* 8.7981	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8375	* 1.0191	* 1.2708	* 1.1283	* 1.2913	* 1.1802	* 1.3045	* 0.7102
	* 2.0582	* 2.0054	* 1.6645	* 1.8033	* 1.6355	* 1.7379	* 1.6506	* 2.6753
9	* 1.0191	* 1.2090	* 1.1805	* 1.2828	* 1.1490	* 1.1757	* 1.2857	* 0.7019
	* 2.0054	* 1.7589	* 1.7258	* 1.6462	* 1.7627	* 1.7471	* 1.6582	* 2.7144
10	* 1.2708	* 1.1793	* 1.0318	* 1.0631	* 1.2267	* 1.0993	* 1.1791	* 0.6240
	* 1.6645	* 1.7263	* 2.0096	* 1.9087	* 1.7129	* 1.8393	* 1.7788	* 2.9705
11	* 1.1283	* 1.2825	* 1.0626	* 1.1723	* 1.0112	* 1.0888	* 0.7702	* 0.4396
	* 1.8033	* 1.6465	* 1.9095	* 1.7938	* 1.9363	* 1.8392	* 2.4442	* 4.2147
12	* 1.2913	* 1.1489	* 1.2265	* 1.0106	* 0.8131	* 0.9193	* 0.5908	*
	* 1.6355	* 1.7628	* 1.7132	* 1.9368	* 1.8264	* 1.7630	* 2.7764	*
13	* 1.1802	* 1.1758	* 1.0997	* 1.0888	* 0.9192	* 0.8079	* 0.4433	*
	* 1.7379	* 1.7473	* 1.8392	* 1.8393	* 1.7630	* 1.9334	* 3.3753	*
14	* 1.3045	* 1.2858	* 1.1792	* 0.7704	* 0.5904	* 0.4432	*	*
	* 1.6506	* 1.6580	* 1.7787	* 2.4443	* 2.7717	* 3.3757	*	*
15	* 0.7102	* 0.7022	* 0.6240	* 0.4338	* F-SUB-Q			
	* 2.6753	* 2.7151	* 2.9707	* 4.1356	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0077	* 1.2174	* 1.5212	* 1.3489	* 1.5458	* 1.4272	* 1.5638	* 0.8451 *
	* 1.7944	* 1.7126	* 1.4172	* 1.5385	* 1.3929	* 1.4618	* 1.3802	* 2.2551 *
9	* 1.2174	* 1.4472	* 1.3996	* 1.5405	* 1.3831	* 1.4146	* 1.5404	* 0.8408 *
	* 1.7126	* 1.4932	* 1.4815	* 1.3969	* 1.4935	* 1.4712	* 1.3973	* 2.2885 *
10	* 1.5212	* 1.3980	* 1.2265	* 1.2716	* 1.4721	* 1.3118	* 1.4188	* 0.7616 *
	* 1.4172	* 1.4821	* 1.7035	* 1.6253	* 1.4550	* 1.5715	* 1.5040	* 2.4740 *
11	* 1.3489	* 1.5402	* 1.2710	* 1.4003	* 1.2067	* 1.3113	* 0.9361	* 0.5322 *
	* 1.5385	* 1.3971	* 1.6260	* 1.5240	* 1.6444	* 1.5540	* 2.0530	* 3.5530 *
12	* 1.5458	* 1.3831	* 1.4719	* 1.2058	* 0.9785	* 1.1043	* 0.7115	*
	* 1.3929	* 1.4935	* 1.4552	* 1.6449	* 1.5623	* 1.5032	* 2.3475	*
13	* 1.4272	* 1.4149	* 1.3125	* 1.3113	* 1.1042	* 0.9997	* 0.5478	*
	* 1.4618	* 1.4713	* 1.5713	* 1.5541	* 1.5032	* 1.6016	* 2.7864	*
14	* 1.5638	* 1.5407	* 1.4190	* 0.9363	* 0.7110	* 0.5477	*	
	* 1.3802	* 1.3971	* 1.5038	* 2.0530	* 2.3438	* 2.7868	*	
15	* 0.8451	* 0.8412	* 0.7616	* 0.5275	* F-SUB-Q			
	* 2.2551	* 2.2891	* 2.4740	* 3.4703	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0855	* 1.3210	* 1.6991	* 1.4677	* 1.7282	* 1.5621	* 1.7584	* 0.9024 *
	* 1.7002	* 1.6149	* 1.2962	* 1.4447	* 1.2717	* 1.3579	* 1.2463	* 2.1450 *
9	* 1.3210	* 1.6088	* 1.5187	* 1.7191	* 1.5036	* 1.5479	* 1.7319	* 0.9014 *
	* 1.6149	* 1.3719	* 1.3946	* 1.2784	* 1.4030	* 1.3684	* 1.2634	* 2.1705 *
10	* 1.6991	* 1.5168	* 1.3241	* 1.3805	* 1.6419	* 1.4259	* 1.5924	* 0.8111 *
	* 1.2962	* 1.3954	* 1.6100	* 1.5297	* 1.3331	* 1.4759	* 1.3665	* 2.3677 *
11	* 1.4677	* 1.7188	* 1.3798	* 1.5603	* 1.3115	* 1.4691	* 1.0006	* 0.5644 *
	* 1.4447	* 1.2786	* 1.5304	* 1.3958	* 1.5420	* 1.4155	* 1.9630	* 3.4262 *
12	* 1.7282	* 1.5035	* 1.6416	* 1.3104	* 1.0605	* 1.2480	* 0.7617	*
	* 1.2717	* 1.4030	* 1.3333	* 1.5425	* 1.4508	* 1.3627	* 2.2458	*
13	* 1.5621	* 1.5482	* 1.4268	* 1.4691	* 1.2479	* 1.1293	* 0.5872	*
	* 1.3579	* 1.3684	* 1.4755	* 1.4156	* 1.3627	* 1.4572	* 2.6709	*
14	* 1.7584	* 1.7322	* 1.5927	* 1.0008	* 0.7611	* 0.5871	*	
	* 1.2463	* 1.2632	* 1.3663	* 1.9630	* 2.2425	* 2.6713	*	
15	* 0.9024	* 0.9019	* 0.8112	* 0.5579	* F-SUB-Q			
	* 2.1450	* 2.1710	* 2.3677	* 3.3551	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1148	* 1.3531	* 1.7589	* 1.5025	* 1.7882	* 1.6018	* 1.8270	* 0.9278
	* 1.7142	* 1.6184	* 1.2825	* 1.4443	* 1.2567	* 1.3559	* 1.2270	* 2.1369
9	* 1.3531	* 1.6610	* 1.5513	* 1.7782	* 1.5381	* 1.5891	* 1.7995	* 0.9259
	* 1.6184	* 1.3638	* 1.3987	* 1.2643	* 1.4026	* 1.3656	* 1.2448	* 2.1651
10	* 1.7589	* 1.5492	* 1.3486	* 1.4125	* 1.6983	* 1.4606	* 1.6546	* 0.8356
	* 1.2825	* 1.3996	* 1.6225	* 1.5306	* 1.3185	* 1.4726	* 1.3464	* 2.3575
11	* 1.5025	* 1.7779	* 1.4118	* 1.6142	* 1.3443	* 1.5267	* 1.0301	* 0.5785
	* 1.4443	* 1.2645	* 1.5314	* 1.3854	* 1.5454	* 1.3994	* 1.9540	* 3.4218
12	* 1.7882	* 1.5381	* 1.6980	* 1.3431	* 1.0934	* 1.3098	* 0.7883	*
	* 1.2567	* 1.4026	* 1.3188	* 1.5460	* 1.4446	* 1.3437	* 2.2434	*
13	* 1.6018	* 1.5895	* 1.4616	* 1.5268	* 1.3096	* 1.1884	* 0.6120	*
	* 1.3559	* 1.3656	* 1.4721	* 1.3995	* 1.3437	* 1.4383	* 2.6637	*
14	* 1.8270	* 1.7998	* 1.6549	* 1.0303	* 0.7876	* 0.6119	*	*
	* 1.2270	* 1.2446	* 1.3462	* 1.9540	* 2.2402	* 2.6641	*	*
15	* 0.9278	* 0.9263	* 0.8357	* 0.5709	F-SUB-Q			
	* 2.1369	* 2.1656	* 2.3576	* 3.3561	M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1311	* 1.3663	* 1.7732	* 1.5064	* 1.7996	* 1.6063	* 1.8441	* 0.9369
	* 1.7561	* 1.6564	* 1.3115	* 1.4840	* 1.2837	* 1.3840	* 1.2446	* 2.1687
9	* 1.3663	* 1.6742	* 1.5538	* 1.7901	* 1.5409	* 1.5954	* 1.8168	* 0.9336
	* 1.6564	* 1.3972	* 1.4394	* 1.2927	* 1.4402	* 1.3926	* 1.2624	* 2.2001
10	* 1.7732	* 1.5516	* 1.3528	* 1.4179	* 1.7123	* 1.4672	* 1.6724	* 0.8465
	* 1.3115	* 1.4403	* 1.6646	* 1.5739	* 1.3505	* 1.5096	* 1.3687	* 2.3870
11	* 1.5064	* 1.7898	* 1.4171	* 1.6310	* 1.3562	* 1.5512	* 1.0471	* 0.5858
	* 1.4840	* 1.2930	* 1.5747	* 1.4164	* 1.5860	* 1.4301	* 1.9941	* 3.4944
12	* 1.7996	* 1.5409	* 1.7120	* 1.3550	* 1.1145	* 1.3483	* 0.8101	*
	* 1.2837	* 1.4402	* 1.3507	* 1.5867	* 1.4832	* 1.3736	* 2.2870	*
13	* 1.6063	* 1.5958	* 1.4683	* 1.5513	* 1.3481	* 1.2301	* 0.6348	*
	* 1.3840	* 1.3926	* 1.5090	* 1.4303	* 1.3736	* 1.4713	* 2.7185	*
14	* 1.8441	* 1.8171	* 1.6727	* 1.0472	* 0.8094	* 0.6347	*	*
	* 1.2446	* 1.2622	* 1.3685	* 1.9943	* 2.2839	* 2.7190	*	*
15	* 0.9368	* 0.9341	* 0.8465	* 0.5785	F-SUB-Q			
	* 2.1687	* 2.2006	* 2.3871	* 3.4253	M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1544	* 1.3773	* 1.7933	* 1.5109	* 1.8140	* 1.6115	* 1.8645	* 0.9322
	* 1.7954	* 1.7279	* 1.3542	* 1.5425	* 1.3238	* 1.4269	* 1.2716	* 2.2523
9	* 1.3773	* 1.6971	* 1.5595	* 1.8058	* 1.5430	* 1.6026	* 1.8380	* 0.9310
	* 1.7279	* 1.4451	* 1.4973	* 1.3346	* 1.4968	* 1.4359	* 1.2908	* 2.2822
10	* 1.7933	* 1.5572	* 1.3540	* 1.4237	* 1.7329	* 1.4769	* 1.6962	* 0.8442
	* 1.3542	* 1.4984	* 1.7399	* 1.6390	* 1.3961	* 1.5636	* 1.4038	* 2.4848
11	* 1.5109	* 1.8054	* 1.4229	* 1.6588	* 1.3791	* 1.5914	* 1.0527	* 0.5852
	* 1.5425	* 1.3349	* 1.6399	* 1.4421	* 1.6278	* 1.4609	* 2.0869	* 3.6613
12	* 1.8140	* 1.5428	* 1.7326	* 1.3781	* 1.1529	* 1.4172	* 0.8267	*
	* 1.3238	* 1.4967	* 1.3964	* 1.6285	* 1.5212	* 1.4004	* 2.3765	*
13	* 1.6115	* 1.6029	* 1.4780	* 1.5914	* 1.4171	* 1.3024	* 0.6555	*
	* 1.4269	* 1.4359	* 1.5630	* 1.4609	* 1.4005	* 1.5032	* 2.8280	*
14	* 1.8645	* 1.8383	* 1.6965	* 1.0528	* 0.8258	* 0.6554	*	*
	* 1.2716	* 1.2905	* 1.4037	* 2.0872	* 2.3736	* 2.8285	*	*
15	* 0.9322	* 0.9315	* 0.8442	* 0.5757	* F-SUB-Q			
	* 2.2523	* 2.2827	* 2.4850	* 3.6027	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2321	* 1.3969	* 1.8027	* 1.5094	* 1.8150	* 1.6075	* 1.8685	* 0.9282
	* 1.8653	* 1.7979	* 1.4245	* 1.6284	* 1.3906	* 1.4962	* 1.3256	* 2.3636
9	* 1.3969	* 1.7141	* 1.5602	* 1.8088	* 1.5391	* 1.6007	* 1.8435	* 0.9278
	* 1.7979	* 1.5224	* 1.5820	* 1.4036	* 1.5790	* 1.5056	* 1.3462	* 2.3955
10	* 1.8027	* 1.5579	* 1.3549	* 1.4260	* 1.7441	* 1.4811	* 1.7076	* 0.8431
	* 1.4245	* 1.5832	* 1.8397	* 1.7324	* 1.4698	* 1.6451	* 1.4676	* 2.6120
11	* 1.5094	* 1.8084	* 1.4252	* 1.6899	* 1.4097	* 1.6332	* 1.0648	* 0.5871
	* 1.6284	* 1.4039	* 1.7334	* 1.4907	* 1.6852	* 1.5019	* 2.1636	* 3.8651
12	* 1.8150	* 1.5388	* 1.7437	* 1.4087	* 1.2614	* 1.5262	* 0.8549	*
	* 1.3906	* 1.5790	* 1.4701	* 1.6860	* 1.5724	* 1.4418	* 2.4565	*
13	* 1.6075	* 1.6011	* 1.4823	* 1.6332	* 1.5260	* 1.4022	* 0.6881	*
	* 1.4962	* 1.5056	* 1.6444	* 1.5021	* 1.4419	* 1.5517	* 2.9360	*
14	* 1.8685	* 1.8438	* 1.7078	* 1.0649	* 0.8540	* 0.6879	*	*
	* 1.3256	* 1.3460	* 1.4674	* 2.1640	* 2.4537	* 2.9366	*	*
15	* 0.9282	* 0.9283	* 0.8429	* 0.5767	* F-SUB-Q			
	* 2.3636	* 2.3959	* 2.6124	* 3.8084	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3212	* 1.4222	* 1.8184	* 1.5114	* 1.8219	* 1.6069	* 1.8771	* 0.9223
	* 1.9589	* 1.8711	* 1.5080	* 1.7316	* 1.4697	* 1.5803	* 1.3917	* 2.5092
9	* 1.4222	* 1.7442	* 1.5656	* 1.8177	* 1.5386	* 1.6022	* 1.8537	* 0.9236
	* 1.8711	* 1.5837	* 1.6827	* 1.4852	* 1.6777	* 1.5900	* 1.4140	* 2.5406
10	* 1.8184	* 1.5631	* 1.3604	* 1.4318	* 1.7621	* 1.4902	* 1.7252	* 0.8393
	* 1.5080	* 1.6841	* 1.9619	* 1.8443	* 1.5565	* 1.7424	* 1.5440	* 2.7794
11	* 1.5114	* 1.8173	* 1.4309	* 1.7330	* 1.4476	* 1.6864	* 1.0763	* 0.5883
	* 1.7316	* 1.4855	* 1.8454	* 1.5540	* 1.7628	* 1.5607	* 2.2613	* 4.1161
12	* 1.8219	* 1.5383	* 1.7618	* 1.4466	* 1.4375	* 1.6601	* 0.8837	*
	* 1.4697	* 1.6777	* 1.5568	* 1.7636	* 1.6379	* 1.4959	* 2.5794	*
13	* 1.6069	* 1.6026	* 1.4914	* 1.6863	* 1.6599	* 1.5220	* 0.7204	*
	* 1.5803	* 1.5899	* 1.7415	* 1.5609	* 1.4960	* 1.6084	* 3.0827	*
14	* 1.8771	* 1.8539	* 1.7253	* 1.0763	* 0.8826	* 0.7202	*	*
	* 1.3917	* 1.4137	* 1.5438	* 2.2618	* 2.5765	* 3.0833	*	*
15	* 0.9223	* 0.9241	* 0.8391	* 0.5770	* F-SUB-Q			
	* 2.5092	* 2.5411	* 2.7801	* 4.0620	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3647	* 1.4264	* 1.8005	* 1.4963	* 1.7961	* 1.5866	* 1.8511	* 0.9257
	* 2.0710	* 1.9839	* 1.6332	* 1.8761	* 1.5942	* 1.7024	* 1.5010	* 2.6585
9	* 1.4264	* 1.7405	* 1.5516	* 1.7946	* 1.5229	* 1.5847	* 1.8293	* 0.9239
	* 1.9839	* 1.6856	* 1.8209	* 1.6120	* 1.8142	* 1.7124	* 1.5255	* 2.7031
10	* 1.8005	* 1.5492	* 1.3587	* 1.4234	* 1.7477	* 1.4841	* 1.7089	* 0.8479
	* 1.6332	* 1.8224	* 2.0921	* 1.9683	* 1.6581	* 1.8577	* 1.6684	* 2.9357
11	* 1.4963	* 1.7942	* 1.4225	* 1.7384	* 1.4616	* 1.7007	* 1.0987	* 0.5966
	* 1.8761	* 1.6124	* 1.9691	* 1.6491	* 1.8697	* 1.6635	* 2.3444	* 4.2821
12	* 1.7961	* 1.5227	* 1.7474	* 1.4605	* 1.5202	* 1.7239	* 0.9189	*
	* 1.5942	* 1.8142	* 1.6583	* 1.8706	* 1.7459	* 1.5978	* 2.6927	*
13	* 1.5866	* 1.5851	* 1.4854	* 1.7006	* 1.7238	* 1.5856	* 0.7608	*
	* 1.7024	* 1.7123	* 1.8567	* 1.6636	* 1.5979	* 1.7166	* 3.2056	*
14	* 1.8511	* 1.8296	* 1.7090	* 1.0986	* 0.9178	* 0.7606	*	*
	* 1.5010	* 1.5253	* 1.6683	* 2.3450	* 2.6897	* 3.2063	*	*
15	* 0.9257	* 0.9244	* 0.8477	* 0.5876	* F-SUB-Q			
	* 2.6585	* 2.7036	* 2.9365	* 4.2083	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3909	* 1.4412	* 1.8269	* 1.5047	* 1.8173	* 1.5957	* 1.8762	* 0.9152
	* 2.1789	* 2.0938	* 1.7107	* 1.9989	* 1.6922	* 1.8113	* 1.5832	* 2.8731
9	* 1.4412	* 1.7723	* 1.5627	* 1.8180	* 1.5289	* 1.5951	* 1.8553	* 0.9174
	* 2.0938	* 1.7645	* 1.9207	* 1.7105	* 1.9418	* 1.8211	* 1.6091	* 2.9100
10	* 1.8269	* 1.5602	* 1.3587	* 1.4334	* 1.7749	* 1.5034	* 1.7388	* 0.8384
	* 1.7107	* 1.9225	* 2.2250	* 2.0744	* 1.7308	* 1.9510	* 1.7418	* 3.1793
11	* 1.5047	* 1.8172	* 1.4326	* 1.7781	* 1.4862	* 1.7456	* 1.0963	* 0.5919
	* 1.9989	* 1.7109	* 2.0753	* 1.7205	* 1.9611	* 1.7284	* 2.4991	* 4.5786
12	* 1.8173	* 1.5287	* 1.7745	* 1.4850	* 1.5790	* 1.7941	* 0.9242	*
	* 1.6922	* 1.9418	* 1.7309	* 1.9622	* 1.8243	* 1.6579	* 2.8656	*
13	* 1.5957	* 1.5955	* 1.5048	* 1.7455	* 1.7939	* 1.6524	* 0.7678	*
	* 1.8113	* 1.8209	* 1.9498	* 1.7286	* 1.6581	* 1.7849	* 3.4335	*
14	* 1.8762	* 1.8556	* 1.7389	* 1.0962	* 0.9231	* 0.7676	*	*
	* 1.5832	* 1.6089	* 1.7417	* 2.4999	* 2.8626	* 3.4344	*	*
15	* 0.9152	* 0.9179	* 0.8381	* 0.5792	* F-SUB-Q			
	* 2.8731	* 2.9104	* 3.1803	* 4.5296	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3941	* 1.4412	* 1.8285	* 1.5007	* 1.8157	* 1.5907	* 1.8764	* 0.9123
	* 2.1933	* 2.0999	* 1.7190	* 2.0136	* 1.7311	* 1.9124	* 1.6803	* 3.0703
9	* 1.4412	* 1.7764	* 1.5591	* 1.8182	* 1.5239	* 1.5920	* 1.8563	* 0.9147
	* 2.0999	* 1.7708	* 1.9350	* 1.7292	* 1.9788	* 1.9126	* 1.6996	* 3.1015
10	* 1.8285	* 1.5565	* 1.3553	* 1.4315	* 1.7775	* 1.5051	* 1.7429	* 0.8376
	* 1.7190	* 1.9368	* 2.2414	* 2.1166	* 1.7738	* 2.0227	* 1.8126	* 3.3412
11	* 1.5007	* 1.8173	* 1.4306	* 1.7872	* 1.4918	* 1.7584	* 1.1006	* 0.5922
	* 2.0136	* 1.7299	* 2.1178	* 1.7696	* 2.0373	* 1.8025	* 2.6021	* 4.7960
12	* 1.8157	* 1.5236	* 1.7771	* 1.4907	* 1.6012	* 1.8200	* 0.9327	*
	* 1.7311	* 1.9791	* 1.7742	* 2.0386	* 1.9322	* 1.7509	* 3.0154	*
13	* 1.5907	* 1.5924	* 1.5065	* 1.7583	* 1.8198	* 1.6803	* 0.7786	*
	* 1.9124	* 1.9125	* 2.0215	* 1.8027	* 1.7511	* 1.8854	* 3.6343	*
14	* 1.8764	* 1.8566	* 1.7430	* 1.1005	* 0.9314	* 0.7785	*	*
	* 1.6803	* 1.6994	* 1.8126	* 2.6030	* 3.0127	* 3.6352	*	*
15	* 0.9123	* 0.9151	* 0.8373	* 0.5789	* F-SUB-Q			
	* 3.0703	* 3.1020	* 3.3426	* 4.7489	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3826	* 1.4298	* 1.8085	* 1.4854	* 1.7940	* 1.5751	* 1.8558	* 0.9147 *
	* 2.1908	* 2.0948	* 1.7189	* 2.0120	* 1.7309	* 1.9059	* 1.6767	* 3.0156 *
9	* 1.4298	* 1.7582	* 1.5426	* 1.7977	* 1.5090	* 1.5772	* 1.8364	* 0.9143 *
	* 2.0948	* 1.7711	* 1.9345	* 1.7295	* 1.9759	* 1.9072	* 1.6975	* 3.0599 *
10	* 1.8085	* 1.5399	* 1.3521	* 1.4202	* 1.7586	* 1.4919	* 1.7254	* 0.8429 *
	* 1.7189	* 1.9364	* 2.2240	* 2.1137	* 1.7758	* 2.0249	* 1.8134	* 3.2839 *
11	* 1.4854	* 1.7969	* 1.4196	* 1.7715	* 1.4821	* 1.7455	* 1.1100	* 0.5958 *
	* 2.0120	* 1.7303	* 2.1149	* 1.7730	* 2.0385	* 1.8062	* 2.5616	* 4.7234 *
12	* 1.7940	* 1.5088	* 1.7582	* 1.4809	* 1.5995	* 1.8137	* 0.9448 *	
	* 1.7309	* 1.9762	* 1.7762	* 2.0397	* 1.9352	* 1.7546	* 2.9682 *	
13	* 1.5751	* 1.5776	* 1.4933	* 1.7453	* 1.8135	* 1.6806	* 0.7934 *	
	* 1.9059	* 1.9071	* 2.0237	* 1.8063	* 1.7548	* 1.8980	* 3.5771 *	
14	* 1.8558	* 1.8366	* 1.7255	* 1.1098	* 0.9436	* 0.7932 *		
	* 1.6767	* 1.6973	* 1.8134	* 2.5626	* 2.9653	* 3.5781 *		
15	* 0.9147	* 0.9147	* 0.8425	* 0.5846	* F-SUB-Q			
	* 3.0156	* 3.0605	* 3.2854	* 4.6593	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3882	* 1.4338	* 1.8284	* 1.4905	* 1.8121	* 1.5823	* 1.8799	* 0.9035 *
	* 2.1453	* 2.0496	* 1.6694	* 1.9642	* 1.6815	* 1.8540	* 1.6176	* 2.9711 *
9	* 1.4338	* 1.7770	* 1.5484	* 1.8165	* 1.5121	* 1.5858	* 1.8605	* 0.9069 *
	* 2.0496	* 1.7224	* 1.8900	* 1.6803	* 1.9328	* 1.8591	* 1.6418	* 3.0054 *
10	* 1.8284	* 1.5456	* 1.3448	* 1.4244	* 1.7780	* 1.4992	* 1.7491	* 0.8316 *
	* 1.6694	* 1.8919	* 2.1891	* 2.0725	* 1.7316	* 1.9914	* 1.7629	* 3.2559 *
11	* 1.4905	* 1.8156	* 1.4237	* 1.7922	* 1.4899	* 1.7703	* 1.0987	* 0.5876 *
	* 1.9642	* 1.6811	* 2.0738	* 1.7363	* 2.0123	* 1.7713	* 2.5563	* 4.6923 *
12	* 1.8121	* 1.5119	* 1.7775	* 1.4887	* 1.6188	* 1.8451	* 0.9337 *	
	* 1.6815	* 1.9331	* 1.7320	* 2.0136	* 1.9022	* 1.7152	* 2.9776 *	
13	* 1.5823	* 1.5863	* 1.5008	* 1.7700	* 1.8448	* 1.7087	* 0.7825 *	
	* 1.8540	* 1.8590	* 1.9902	* 1.7714	* 1.7154	* 1.8573	* 3.5986 *	
14	* 1.8799	* 1.8607	* 1.7491	* 1.0985	* 0.9325	* 0.7824 *		
	* 1.6176	* 1.6416	* 1.7629	* 2.5574	* 2.9749	* 3.5996 *		
15	* 0.9035	* 0.9074	* 0.8312	* 0.5731	* F-SUB-Q			
	* 2.9711	* 3.0059	* 3.2577	* 4.6562	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3861	* 1.4320	* 1.8329	* 1.4886	* 1.8154	* 1.5817	* 1.8871	* 0.8987 *
	* 1.9894	* 1.9053	* 1.5550	* 1.8307	* 1.5632	* 1.7362	* 1.5138	* 2.7794 *
9	* 1.4320	* 1.7810	* 1.5460	* 1.8203	* 1.5093	* 1.5860	* 1.8677	* 0.9030 *
	* 1.9053	* 1.5999	* 1.7635	* 1.5660	* 1.8016	* 1.7370	* 1.5332	* 2.8050 *
10	* 1.8329	* 1.5432	* 1.3411	* 1.4224	* 1.7820	* 1.4975	* 1.7557	* 0.8268 *
	* 1.5550	* 1.7652	* 2.0363	* 1.9298	* 1.6120	* 1.8535	* 1.6419	* 3.0347 *
11	* 1.4886	* 1.8194	* 1.4218	* 1.7966	* 1.4889	* 1.7784	* 1.0950	* 0.5837 *
	* 1.8307	* 1.5666	* 1.9310	* 1.6097	* 1.8677	* 1.6407	* 2.3756	* 4.3463 *
12	* 1.8154	* 1.5090	* 1.7815	* 1.4877	* 1.6252	* 1.8564	* 0.9306	*
	* 1.5632	* 1.8018	* 1.6124	* 1.8690	* 1.7740	* 1.5944	* 2.7553	*
13	* 1.5817	* 1.5864	* 1.4991	* 1.7780	* 1.8561	* 1.7208	* 0.7802	*
	* 1.7362	* 1.7369	* 1.8523	* 1.6408	* 1.5946	* 1.7205	* 3.3192	*
14	* 1.8871	* 1.8679	* 1.7557	* 1.0947	* 0.9293	* 0.7800	*	
	* 1.5138	* 1.5331	* 1.6420	* 2.3767	* 2.7530	* 3.3202	*	
15	* 0.8987	* 0.9035	* 0.8264	* 0.5686	* F-SUB-Q			
	* 2.7794	* 2.8054	* 3.0364	* 4.3188	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3821	* 1.4282	* 1.8312	* 1.4839	* 1.8127	* 1.5779	* 1.8862	* 0.8982 *
	* 1.8425	* 1.7624	* 1.4315	* 1.6885	* 1.4420	* 1.6067	* 1.3980	* 2.5693 *
9	* 1.4282	* 1.7792	* 1.5407	* 1.8181	* 1.5044	* 1.5828	* 1.8668	* 0.9017 *
	* 1.7624	* 1.4770	* 1.6283	* 1.4406	* 1.6636	* 1.6051	* 1.4147	* 2.5935 *
10	* 1.8312	* 1.5379	* 1.3365	* 1.4185	* 1.7797	* 1.4922	* 1.7545	* 0.8280 *
	* 1.4314	* 1.6300	* 1.8839	* 1.7866	* 1.4895	* 1.7166	* 1.5159	* 2.7912 *
11	* 1.4839	* 1.8172	* 1.4178	* 1.7946	* 1.4846	* 1.7782	* 1.0969	* 0.5834 *
	* 1.6885	* 1.4412	* 1.7877	* 1.4856	* 1.7269	* 1.5129	* 2.1887	* 4.0205 *
12	* 1.8127	* 1.5041	* 1.7792	* 1.4833	* 1.6252	* 1.8578	* 0.9321	*
	* 1.4420	* 1.6638	* 1.4899	* 1.7280	* 1.6330	* 1.4657	* 2.5339	*
13	* 1.5779	* 1.5833	* 1.4938	* 1.7778	* 1.8575	* 1.7228	* 0.7829	*
	* 1.6067	* 1.6050	* 1.7155	* 1.5131	* 1.4659	* 1.5821	* 3.0496	*
14	* 1.8862	* 1.8670	* 1.7545	* 1.0966	* 0.9307	* 0.7827	*	
	* 1.3980	* 1.4146	* 1.5160	* 2.1898	* 2.5320	* 3.0505	*	
15	* 0.8982	* 0.9022	* 0.8276	* 0.5681	* F-SUB-Q			
	* 2.5693	* 2.5940	* 2.7930	* 3.9968	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3735	* 1.4215	* 1.8187	* 1.4756	* 1.7992	* 1.5693	* 1.8727	* 0.9035
	* 1.8529	* 1.7718	* 1.4425	* 1.7029	* 1.4580	* 1.6242	* 1.4150	* 2.5701
9	* 1.4215	* 1.7670	* 1.5305	* 1.8055	* 1.4963	* 1.5743	* 1.8533	* 0.9038
	* 1.7718	* 1.4873	* 1.6418	* 1.4535	* 1.6784	* 1.6211	* 1.4310	* 2.6016
10	* 1.8187	* 1.5276	* 1.3411	* 1.4115	* 1.7670	* 1.4817	* 1.7410	* 0.8346
	* 1.4425	* 1.6435	* 1.8828	* 1.7968	* 1.5007	* 1.7332	* 1.5287	* 2.7794
11	* 1.4756	* 1.8046	* 1.4108	* 1.7816	* 1.4766	* 1.7664	* 1.1060	* 0.5870
	* 1.7029	* 1.4542	* 1.7980	* 1.5016	* 1.7442	* 1.5292	* 2.1804	* 4.0071
12	* 1.7992	* 1.4960	* 1.7665	* 1.4755	* 1.6179	* 1.8458	* 0.9412	*
	* 1.4580	* 1.6786	* 1.5011	* 1.7451	* 1.6421	* 1.4774	* 2.5186	*
13	* 1.5693	* 1.5748	* 1.4834	* 1.7661	* 1.8455	* 1.7144	* 0.7931	*
	* 1.6242	* 1.6210	* 1.7323	* 1.5294	* 1.4776	* 1.5925	* 3.0181	*
14	* 1.8727	* 1.8535	* 1.7409	* 1.1056	* 0.9399	* 0.7929	*	*
	* 1.4150	* 1.4309	* 1.5288	* 2.1815	* 2.5166	* 3.0191	*	*
15	* 0.9035	* 0.9043	* 0.8342	* 0.5737	F-SUB-Q			
	* 2.5701	* 2.6022	* 2.7813	* 3.9689	M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3830	* 1.4299	* 1.8471	* 1.4860	* 1.8265	* 1.5824	* 1.9047	* 0.8928
	* 1.7170	* 1.6467	* 1.3303	* 1.5856	* 1.3474	* 1.5125	* 1.3061	* 2.4443
9	* 1.4299	* 1.7938	* 1.5427	* 1.8330	* 1.5052	* 1.5886	* 1.8850	* 0.8974
	* 1.6467	* 1.3695	* 1.5262	* 1.3417	* 1.5651	* 1.5078	* 1.3202	* 2.4615
10	* 1.8471	* 1.5396	* 1.3353	* 1.4194	* 1.7933	* 1.4931	* 1.7704	* 0.8226
	* 1.3303	* 1.5280	* 1.7684	* 1.6727	* 1.3830	* 1.6076	* 1.4071	* 2.6460
11	* 1.4860	* 1.8321	* 1.4187	* 1.8085	* 1.4863	* 1.7952	* 1.0940	* 0.5781
	* 1.5856	* 1.3423	* 1.6737	* 1.3803	* 1.6172	* 1.4059	* 2.0585	* 3.8067
12	* 1.8265	* 1.5049	* 1.7927	* 1.4851	* 1.6370	* 1.8784	* 0.9275	*
	* 1.3474	* 1.5653	* 1.3833	* 1.6183	* 1.5029	* 1.3486	* 2.3853	*
13	* 1.5824	* 1.5891	* 1.4948	* 1.7948	* 1.8781	* 1.7429	* 0.7780	*
	* 1.5125	* 1.5077	* 1.6064	* 1.4061	* 1.3488	* 1.4524	* 2.8651	*
14	* 1.9047	* 1.8852	* 1.7704	* 1.0936	* 0.9261	* 0.7778	*	*
	* 1.3061	* 1.3201	* 1.4072	* 2.0596	* 2.3835	* 2.8660	*	*
15	* 0.8928	* 0.8980	* 0.8221	* 0.5617	F-SUB-Q			
	* 2.4443	* 2.4618	* 2.6478	* 3.7923	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3799	* 1.4271	* 1.8475	* 1.4830	* 1.8261	* 1.5814	* 1.9062	* 0.8889 *
	* 1.6233	* 1.5612	* 1.2589	* 1.5056	* 1.2768	* 1.4349	* 1.2366	* 2.3294 *
9	* 1.4271	* 1.7946	* 1.5400	* 1.8337	* 1.5021	* 1.5876	* 1.8863	* 0.8938 *
	* 1.5612	* 1.2944	* 1.4481	* 1.2699	* 1.4863	* 1.4297	* 1.2496	* 2.3442 *
10	* 1.8475	* 1.5369	* 1.3319	* 1.4168	* 1.7941	* 1.4905	* 1.7712	* 0.8190 *
	* 1.2589	* 1.4499	* 1.6792	* 1.5859	* 1.3071	* 1.5205	* 1.3301	* 2.5187 *
11	* 1.4830	* 1.8327	* 1.4160	* 1.8093	* 1.4842	* 1.7968	* 1.0922	* 0.5749 *
	* 1.5056	* 1.2705	* 1.5868	* 1.3008	* 1.5241	* 1.3170	* 1.9465	* 3.6220 *
12	* 1.8261	* 1.5018	* 1.7935	* 1.4829	* 1.6380	* 1.8804	* 0.9245 *	
	* 1.2768	* 1.4865	* 1.3074	* 1.5252	* 1.4057	* 1.2623	* 2.2485 *	
13	* 1.5814	* 1.5881	* 1.4923	* 1.7965	* 1.8801	* 1.7450	* 0.7749 *	
	* 1.4349	* 1.4296	* 1.5193	* 1.3173	* 1.2625	* 1.3595	* 2.7023 *	
14	* 1.9062	* 1.8865	* 1.7711	* 1.0919	* 0.9232	* 0.7747 *		
	* 1.2366	* 1.2494	* 1.3302	* 1.9475	* 2.2468	* 2.7031 *		
15	* 0.8889	* 0.8944	* 0.8185	* 0.5583	* F-SUB-Q			
	* 2.3294	* 2.3445	* 2.5205	* 3.6103	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3594	* 1.4049	* 1.8050	* 1.4590	* 1.7839	* 1.5569	* 1.8621	* 0.8881 *
	* 1.5743	* 1.5161	* 1.2316	* 1.4640	* 1.2499	* 1.3941	* 1.2098	* 2.2323 *
9	* 1.4049	* 1.7549	* 1.5146	* 1.7925	* 1.4787	* 1.5623	* 1.8425	* 0.8893 *
	* 1.5161	* 1.2640	* 1.4084	* 1.2416	* 1.4444	* 1.3893	* 1.2223	* 2.2555 *
10	* 1.8050	* 1.5115	* 1.3263	* 1.3958	* 1.7559	* 1.4663	* 1.7294	* 0.8211 *
	* 1.2316	* 1.4101	* 1.6162	* 1.5345	* 1.2726	* 1.4703	* 1.2985	* 2.4037 *
11	* 1.4590	* 1.7915	* 1.3951	* 1.7702	* 1.4624	* 1.7570	* 1.0972	* 0.5757 *
	* 1.4640	* 1.2423	* 1.5353	* 1.2619	* 1.4686	* 1.2771	* 1.8422	* 3.4591 *
12	* 1.7839	* 1.4783	* 1.7553	* 1.4612	* 1.6105	* 1.8369	* 0.9289 *	
	* 1.2499	* 1.4447	* 1.2731	* 1.4695	* 1.3549	* 1.2245	* 2.1259 *	
13	* 1.5569	* 1.5628	* 1.4680	* 1.7566	* 1.8366	* 1.7061	* 0.7809 *	
	* 1.3941	* 1.3892	* 1.4691	* 1.2773	* 1.2247	* 1.3188	* 2.5474 *	
14	* 1.8621	* 1.8427	* 1.7293	* 1.0968	* 0.9275	* 0.7807 *		
	* 1.2098	* 1.2222	* 1.2986	* 1.8432	* 2.1243	* 2.5483 *		
15	* 0.8881	* 0.8897	* 0.8206	* 0.5628	* F-SUB-Q			
	* 2.2323	* 2.2560	* 2.4055	* 3.4255	* M-SUB-Q			

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	* 1.2518	* 1.2868	* 1.6302	* 1.3365	* 1.6104	* 1.4292	* 1.6794	* 0.7966
	* 1.5890	* 1.5373	* 1.2638	* 1.4856	* 1.2847	* 1.4111	* 1.2439	* 2.3252
9	* 1.2868	* 1.5903	* 1.3975	* 1.6216	* 1.3555	* 1.4351	* 1.6623	* 0.8029
	* 1.5373	* 1.2930	* 1.4174	* 1.2721	* 1.4642	* 1.4048	* 1.2561	* 2.3345
10	* 1.6302	* 1.3946	* 1.2093	* 1.2805	* 1.5926	* 1.3531	* 1.5621	* 0.7346
	* 1.2638	* 1.4192	* 1.6464	* 1.5534	* 1.3005	* 1.4791	* 1.3342	* 2.5112
11	* 1.3365	* 1.6206	* 1.2798	* 1.6048	* 1.3476	* 1.5900	* 0.9933	* 0.5178
	* 1.4856	* 1.2728	* 1.5542	* 1.2904	* 1.4790	* 1.3081	* 1.8930	* 3.6047
12	* 1.6104	* 1.3552	* 1.5920	* 1.3463	* 1.4778	* 1.6564	* 0.8343	*
	* 1.2847	* 1.4644	* 1.3009	* 1.4801	* 1.3683	* 1.2578	* 2.2042	*
13	* 1.4292	* 1.4356	* 1.3547	* 1.5896	* 1.6561	* 1.5366	* 0.6939	*
	* 1.4111	* 1.4047	* 1.4780	* 1.3084	* 1.2580	* 1.3558	* 2.6715	*
14	* 1.6794	* 1.6625	* 1.5620	* 0.9930	* 0.8330	* 0.6937	*	*
	* 1.2439	* 1.2559	* 1.3344	* 1.8941	* 2.2026	* 2.6724	*	*
15	* 0.7966	* 0.8033	* 0.7340	* 0.5027	* F-SUB-Q			
	* 2.3252	* 2.3349	* 2.5133	* 3.5939	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0385	* 1.0629	* 1.3263	* 1.1031	* 1.3108	* 1.1675	* 1.3643	* 0.6628
	* 1.8699	* 1.8153	* 1.5137	* 1.7542	* 1.5385	* 1.6849	* 1.4934	* 2.7333
9	* 1.0629	* 1.2935	* 1.1617	* 1.3177	* 1.1132	* 1.1775	* 1.3514	* 0.6695
	* 1.8153	* 1.5498	* 1.6619	* 1.5256	* 1.7386	* 1.6702	* 1.5072	* 2.7392
10	* 1.3263	* 1.1596	* 1.0048	* 1.0573	* 1.2942	* 1.1220	* 1.2667	* 0.6059
	* 1.5137	* 1.6636	* 1.9331	* 1.8353	* 1.5602	* 1.7408	* 1.6061	* 2.9797
11	* 1.1031	* 1.3169	* 1.0567	* 1.3088	* 1.1144	* 1.2873	* 0.8247	* 0.4302
	* 1.7542	* 1.5265	* 1.8362	* 1.5425	* 1.7443	* 1.5750	* 2.2282	* 4.2524
12	* 1.3108	* 1.1129	* 1.2937	* 1.1135	* 1.2203	* 1.3488	* 0.6969	*
	* 1.5385	* 1.7389	* 1.5607	* 1.7455	* 1.6166	* 1.5068	* 2.5802	*
13	* 1.1675	* 1.1779	* 1.1230	* 1.2870	* 1.3486	* 1.2268	* 0.5686	*
	* 1.6849	* 1.6701	* 1.7398	* 1.5753	* 1.5071	* 1.6581	* 3.1916	*
14	* 1.3643	* 1.3515	* 1.2666	* 0.8244	* 0.6959	* 0.5684	*	*
	* 1.4934	* 1.5071	* 1.6064	* 2.2295	* 2.5784	* 3.1928	*	*
15	* 0.6628	* 0.6698	* 0.6054	* 0.4175	* F-SUB-Q			
	* 2.7333	* 2.7398	* 2.9824	* 4.2414	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4500	* 0.4806	* 0.5805	* 0.4970	* 0.5730	* 0.4914	* 0.5402	* 0.2904
	* 4.2300	* 3.9387	* 3.3909	* 3.8169	* 3.4538	* 3.9204	* 3.6975	* 6.1234
9	* 0.4806	* 0.5653	* 0.4997	* 0.5760	* 0.4850	* 0.4937	* 0.5346	* 0.2897
	* 3.9387	* 3.4806	* 3.7841	* 3.4247	* 3.9137	* 3.9020	* 3.7354	* 6.2133
10	* 0.5805	* 0.4990	* 0.4571	* 0.4777	* 0.5659	* 0.4776	* 0.4982	* 0.2658
	* 3.3909	* 3.7865	* 4.1684	* 3.9843	* 3.5015	* 4.0081	* 4.0062	* 6.6692
11	* 0.4970	* 0.5757	* 0.4775	* 0.5616	* 0.4875	* 0.5446	* 0.3660	* 0.1897
	* 3.8169	* 3.4266	* 3.9869	* 3.5273	* 3.9092	* 3.6522	* 4.9310	* 9.4572
12	* 0.5730	* 0.4849	* 0.5657	* 0.4872	* 0.5032	* 0.5348	* 0.3064	*
	* 3.4538	* 3.9143	* 3.5024	* 3.9110	* 3.8408	* 3.7267	* 5.7697	*
13	* 0.4914	* 0.4938	* 0.4779	* 0.5445	* 0.5347	* 0.4790	* 0.2476	*
	* 3.9204	* 3.9021	* 4.0068	* 3.6529	* 3.7273	* 4.1671	* 7.2087	*
14	* 0.5402	* 0.5346	* 0.4981	* 0.3658	* 0.3060	* 0.2475	*	*
	* 3.6975	* 3.7352	* 4.0072	* 4.9345	* 5.7639	* 7.2117	*	*
15	* 0.2904	* 0.2899	* 0.2655	* 0.1858	* F-SUB-Q			
	* 6.1234	* 6.2136	* 6.6755	* 9.3463	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4632	* 0.5991	* 0.7461	* 0.6711	* 0.7656	* 0.6778	* 0.7242	* 0.4348
	* 3.3426	* 3.3574	* 2.9102	* 2.9987	* 2.8332	* 3.0168	* 3.0566	* 4.2352
9	* 0.5991	* 0.7074	* 0.6705	* 0.7578	* 0.6666	* 0.6750	* 0.7141	* 0.4246
	* 3.3574	* 3.1052	* 3.0138	* 2.8624	* 3.0048	* 3.0401	* 3.0949	* 4.4755
10	* 0.7461	* 0.6700	* 0.6188	* 0.6351	* 0.7267	* 0.6337	* 0.6579	* 0.3837
	* 2.9102	* 3.0137	* 3.3292	* 3.1753	* 2.9625	* 3.1494	* 3.2745	* 4.8121
11	* 0.6711	* 0.7577	* 0.6349	* 0.6826	* 0.5886	* 0.6355	* 0.4629	* 0.2812
	* 2.9987	* 2.8628	* 3.1764	* 3.1835	* 3.3009	* 3.2697	* 4.0071	* 6.4882
12	* 0.7656	* 0.6666	* 0.7266	* 0.5883	* 0.4500	* 0.5024	* 0.3584	*
	* 2.8332	* 3.0052	* 2.9630	* 3.3004	* 3.1213	* 3.2677	* 4.4711	*
13	* 0.6778	* 0.6751	* 0.6339	* 0.6354	* 0.5023	* 0.4382	* 0.2689	*
	* 3.0168	* 3.0407	* 3.1497	* 3.2699	* 3.2675	* 3.5459	* 5.5978	*
14	* 0.7242	* 0.7141	* 0.6579	* 0.4629	* 0.3582	* 0.2688	*	*
	* 3.0566	* 3.0947	* 3.2747	* 4.0101	* 4.4689	* 5.5999	*	*
15	* 0.4348	* 0.4248	* 0.3837	* 0.2773	* F-SUB-Q			
	* 4.2352	* 4.4878	* 4.8132	* 6.3704	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8897	* 1.1133	* 1.3873	* 1.2469	* 1.4252	* 1.3364	* 1.4809	* 0.8500
	* 1.8754	* 1.8563	* 1.6057	* 1.6598	* 1.5645	* 1.5785	* 1.5355	* 2.2266
9	* 1.1133	* 1.3154	* 1.2972	* 1.4101	* 1.2779	* 1.3324	* 1.4621	* 0.8420
	* 1.8563	* 1.6990	* 1.5939	* 1.5795	* 1.6126	* 1.5753	* 1.5455	* 2.3091
10	* 1.3873	* 1.2960	* 1.1419	* 1.1817	* 1.3561	* 1.2408	* 1.3540	* 0.7531
	* 1.6057	* 1.5942	* 1.8527	* 1.7461	* 1.6301	* 1.6553	* 1.6340	* 2.5103
11	* 1.2469	* 1.4099	* 1.1812	* 1.2942	* 1.1225	* 1.2251	* 0.8932	* 0.5527
	* 1.6598	* 1.5797	* 1.7467	* 1.6959	* 1.7458	* 1.7071	* 2.1387	* 3.3988
12	* 1.4252	* 1.2778	* 1.3559	* 1.1218	* 0.8814	* 1.0331	* 0.7011	*
	* 1.5645	* 1.6128	* 1.6303	* 1.7458	* 1.6195	* 1.6249	* 2.3156	*
13	* 1.3364	* 1.3325	* 1.2412	* 1.2251	* 1.0329	* 0.9300	* 0.5371	*
	* 1.5785	* 1.5755	* 1.6553	* 1.7072	* 1.6249	* 1.7563	* 2.8468	*
14	* 1.4809	* 1.4622	* 1.3540	* 0.8932	* 0.7007	* 0.5370	*	*
	* 1.5355	* 1.5453	* 1.6340	* 2.1400	* 2.3150	* 2.8478	*	*
15	* 0.8500	* 0.8422	* 0.7530	* 0.5450	* F-SUB-Q			
	* 2.2266	* 2.3160	* 2.5107	* 3.3370	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0246	* 1.2654	* 1.6062	* 1.4157	* 1.6521	* 1.5361	* 1.7229	* 0.9732 *
	* 1.7235	* 1.6613	* 1.4072	* 1.4849	* 1.3697	* 1.3804	* 1.3223	* 1.9488 *
9	* 1.2654	* 1.5155	* 1.4601	* 1.6324	* 1.4595	* 1.5248	* 1.7002	* 0.9679 *
	* 1.6613	* 1.4919	* 1.4347	* 1.3848	* 1.4341	* 1.3877	* 1.3352	* 2.0179 *
10	* 1.6062	* 1.4586	* 1.2854	* 1.3409	* 1.5674	* 1.4110	* 1.5730	* 0.8852 *
	* 1.4072	* 1.4351	* 1.6464	* 1.5601	* 1.4318	* 1.4781	* 1.4260	* 2.1615 *
11	* 1.4157	* 1.6322	* 1.3404	* 1.4900	* 1.2724	* 1.4202	* 1.0438	* 0.6399 *
	* 1.4849	* 1.3849	* 1.5607	* 1.4895	* 1.5552	* 1.4900	* 1.8620	* 2.9848 *
12	* 1.6521	* 1.4595	* 1.5672	* 1.2717	* 1.0151	* 1.2062	* 0.8127	*
	* 1.3697	* 1.4342	* 1.4320	* 1.5555	* 1.4569	* 1.4225	* 2.0255	*
13	* 1.5361	* 1.5250	* 1.4116	* 1.4202	* 1.2061	* 1.0948	* 0.6362	*
	* 1.3804	* 1.3878	* 1.4780	* 1.4901	* 1.4225	* 1.5243	* 2.4427	*
14	* 1.7229	* 1.7004	* 1.5731	* 1.0439	* 0.8121	* 0.6361	*	
	* 1.3223	* 1.3351	* 1.4260	* 1.8632	* 2.0252	* 2.4436	*	
15	* 0.9732	* 0.9682	* 0.8851	* 0.6339	F-SUB-Q			
	* 1.9488	* 2.0240	* 2.1616	* 2.9168	M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0693	* 1.3245	* 1.7171	* 1.4836	* 1.7677	* 1.6210	* 1.8594	* 1.0050 *
	* 1.6877	* 1.6153	* 1.3366	* 1.4383	* 1.2989	* 1.3220	* 1.2361	* 1.9052 *
9	* 1.3245	* 1.6138	* 1.5265	* 1.7455	* 1.5274	* 1.6080	* 1.8346	* 1.0063 *
	* 1.6153	* 1.4225	* 1.3924	* 1.3144	* 1.3908	* 1.3312	* 1.2500	* 1.9614 *
10	* 1.7171	* 1.5248	* 1.3380	* 1.4025	* 1.6732	* 1.4828	* 1.6966	* 0.9130 *
	* 1.3366	* 1.3930	* 1.6024	* 1.5145	* 1.3623	* 1.4271	* 1.3400	* 2.1236 *
11	* 1.4836	* 1.7452	* 1.4019	* 1.5907	* 1.3334	* 1.5229	* 1.0738	* 0.6563 *
	* 1.4383	* 1.3146	* 1.5151	* 1.4162	* 1.5073	* 1.4105	* 1.8363	* 2.9579 *
12	* 1.7677	* 1.5274	* 1.6730	* 1.3326	* 1.0650	* 1.3095	* 0.8396	*
	* 1.2989	* 1.3909	* 1.3625	* 1.5076	* 1.4005	* 1.3412	* 1.9957	*
13	* 1.6210	* 1.6082	* 1.4836	* 1.5228	* 1.3093	* 1.1908	* 0.6584	*
	* 1.3220	* 1.3313	* 1.4268	* 1.4106	* 1.3413	* 1.4351	* 2.4102	*
14	* 1.8594	* 1.8347	* 1.6967	* 1.0739	* 0.8388	* 0.6583	*	
	* 1.2361	* 1.2499	* 1.3400	* 1.8375	* 1.9956	* 2.4111	*	
15	* 1.0050	* 1.0066	* 0.9130	* 0.6487	F-SUB-Q			
	* 1.9052	* 1.9672	* 2.1237	* 2.8975	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0687	* 1.3187	* 1.7203	* 1.4763	* 1.7714	* 1.6166	* 1.8737	* 1.0082
	* 1.7367	* 1.6538	* 1.3570	* 1.4680	* 1.3164	* 1.3478	* 1.2458	* 1.9307
9	* 1.3187	* 1.6142	* 1.5148	* 1.7489	* 1.5191	* 1.6049	* 1.8487	* 1.0061
	* 1.6538	* 1.4493	* 1.4277	* 1.3324	* 1.4202	* 1.3568	* 1.2608	* 1.9956
10	* 1.7203	* 1.5130	* 1.3283	* 1.3950	* 1.6756	* 1.4776	* 1.7092	* 0.9172
	* 1.3570	* 1.4284	* 1.6452	* 1.5467	* 1.3803	* 1.4526	* 1.3511	* 2.1522
11	* 1.4763	* 1.7487	* 1.3944	* 1.5932	* 1.3283	* 1.5302	* 1.0747	* 0.6548
	* 1.4680	* 1.3326	* 1.5473	* 1.4404	* 1.5429	* 1.4302	* 1.8641	* 3.0065
12	* 1.7714	* 1.5191	* 1.6754	* 1.3274	* 1.0658	* 1.3255	* 0.8423	*
	* 1.3164	* 1.4203	* 1.3805	* 1.5433	* 1.4264	* 1.3570	* 2.0344	*
13	* 1.6166	* 1.6051	* 1.4785	* 1.5302	* 1.3254	* 1.2090	* 0.6640	*
	* 1.3478	* 1.3569	* 1.4523	* 1.4303	* 1.3571	* 1.4511	* 2.4531	*
14	* 1.8737	* 1.8488	* 1.7093	* 1.0747	* 0.8416	* 0.6639	*	*
	* 1.2458	* 1.2607	* 1.3511	* 1.8653	* 2.0344	* 2.4541	*	*
15	* 1.0082	* 1.0064	* 0.9171	* 0.6463	* F-SUB-Q			
	* 1.9307	* 2.0016	* 2.1523	* 2.9494	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0563	* 1.2988	* 1.6928	* 1.4477	* 1.7424	* 1.5878	* 1.8497	* 0.9985
	* 1.7981	* 1.7161	* 1.4075	* 1.5270	* 1.3633	* 1.3938	* 1.2823	* 1.9819
9	* 1.2988	* 1.5878	* 1.4837	* 1.7205	* 1.4906	* 1.5793	* 1.8252	* 0.9946
	* 1.7161	* 1.5043	* 1.4872	* 1.3813	* 1.4756	* 1.4001	* 1.2971	* 2.0514
10	* 1.6928	* 1.4819	* 1.3118	* 1.3697	* 1.6490	* 1.4531	* 1.6882	* 0.9100
	* 1.4075	* 1.4880	* 1.6998	* 1.6095	* 1.4337	* 1.5068	* 1.3925	* 2.2048
11	* 1.4477	* 1.7203	* 1.3691	* 1.5690	* 1.3071	* 1.5112	* 1.0699	* 0.6488
	* 1.5270	* 1.3815	* 1.6102	* 1.4927	* 1.6026	* 1.4829	* 1.9206	* 3.1067
12	* 1.7424	* 1.4906	* 1.6488	* 1.3063	* 1.0609	* 1.3172	* 0.8407	*
	* 1.3633	* 1.4757	* 1.4339	* 1.6030	* 1.4855	* 1.4090	* 2.0982	*
13	* 1.5878	* 1.5795	* 1.4540	* 1.5112	* 1.3170	* 1.2058	* 0.6670	*
	* 1.3938	* 1.4002	* 1.5064	* 1.4831	* 1.4091	* 1.5068	* 2.5327	*
14	* 1.8497	* 1.8254	* 1.6882	* 1.0699	* 0.8399	* 0.6669	*	*
	* 1.2823	* 1.2970	* 1.3925	* 1.9220	* 2.0983	* 2.5338	*	*
15	* 0.9985	* 0.9949	* 0.9099	* 0.6411	* F-SUB-Q			
	* 1.9819	* 2.0576	* 2.2050	* 3.0443	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0434	* 1.2813	* 1.6799	* 1.4281	* 1.7265	* 1.5684	* 1.8391	* 0.9785 *
	* 1.8487	* 1.7839	* 1.4652	* 1.5972	* 1.4169	* 1.4467	* 1.3208	* 2.0719 *
9	* 1.2813	* 1.5763	* 1.4639	* 1.7052	* 1.4689	* 1.5616	* 1.8157	* 0.9772 *
	* 1.7839	* 1.5678	* 1.5574	* 1.4378	* 1.5435	* 1.4536	* 1.3370	* 2.1411 *
10	* 1.6799	* 1.4620	* 1.2886	* 1.3517	* 1.6367	* 1.4385	* 1.6823	* 0.8934 *
	* 1.4652	* 1.5583	* 1.7891	* 1.6871	* 1.4945	* 1.5710	* 1.4395	* 2.3102 *
11	* 1.4281	* 1.7050	* 1.3511	* 1.5606	* 1.2964	* 1.5097	* 1.0508	* 0.6368 *
	* 1.5972	* 1.4379	* 1.6878	* 1.5341	* 1.6553	* 1.5270	* 2.0304	* 3.2778 *
12	* 1.7265	* 1.4689	* 1.6365	* 1.2955	* 1.0580	* 1.3273	* 0.8311	*
	* 1.4169	* 1.5436	* 1.4947	* 1.6558	* 1.5329	* 1.4472	* 2.1967	*
13	* 1.5684	* 1.5619	* 1.4394	* 1.5096	* 1.3271	* 1.2222	* 0.6627	*
	* 1.4467	* 1.4536	* 1.5705	* 1.5272	* 1.4473	* 1.5495	* 2.6558	*
14	* 1.8391	* 1.8158	* 1.6823	* 1.0507	* 0.8301	* 0.6625	*	
	* 1.3208	* 1.3369	* 1.4395	* 2.0320	* 2.1970	* 2.6569	*	
15	* 0.9785	* 0.9774	* 0.8932	* 0.6266	* F-SUB-Q			
	* 2.0719	* 2.1476	* 2.3107	* 3.2255	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0452	* 1.2751	* 1.6678	* 1.4118	* 1.7092	* 1.5498	* 1.8236	* 0.9652 *
	* 1.9187	* 1.8562	* 1.5446	* 1.6879	* 1.4913	* 1.5191	* 1.3806	* 2.1778 *
9	* 1.2751	* 1.5686	* 1.4481	* 1.6894	* 1.4503	* 1.5448	* 1.8016	* 0.9648 *
	* 1.8562	* 1.6490	* 1.6478	* 1.5152	* 1.6305	* 1.5264	* 1.3982	* 2.2505 *
10	* 1.6678	* 1.4462	* 1.2752	* 1.3388	* 1.6263	* 1.4270	* 1.6739	* 0.8838 *
	* 1.5446	* 1.6489	* 1.8938	* 1.7855	* 1.5768	* 1.6553	* 1.5087	* 2.4309 *
11	* 1.4118	* 1.6892	* 1.3381	* 1.5570	* 1.2963	* 1.5155	* 1.0472	* 0.6315 *
	* 1.6879	* 1.5154	* 1.7863	* 1.5860	* 1.7140	* 1.5720	* 2.1088	* 3.4664 *
12	* 1.7092	* 1.4503	* 1.6261	* 1.2954	* 1.0743	* 1.3541	* 0.8373	*
	* 1.4913	* 1.6306	* 1.5771	* 1.7145	* 1.5864	* 1.4930	* 2.2724	*
13	* 1.5498	* 1.5451	* 1.4279	* 1.5154	* 1.3539	* 1.2548	* 0.6743	*
	* 1.5191	* 1.5264	* 1.6548	* 1.5722	* 1.4931	* 1.6017	* 2.7580	*
14	* 1.8236	* 1.8017	* 1.6739	* 1.0471	* 0.8364	* 0.6742	*	
	* 1.3806	* 1.3981	* 1.5088	* 2.1104	* 2.2729	* 2.7591	*	
15	* 0.9652	* 0.9650	* 0.8836	* 0.6204	* F-SUB-Q			
	* 2.1778	* 2.2573	* 2.4315	* 3.4157	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0854	* 1.2865	* 1.6712	* 1.4056	* 1.7048	* 1.5400	* 1.8198	* 0.9524 *
	* 2.0074	* 1.9318	* 1.6332	* 1.7908	* 1.5745	* 1.6026	* 1.4489	* 2.3117 *
9	* 1.2865	* 1.5798	* 1.4447	* 1.6871	* 1.4411	* 1.5371	* 1.7994	* 0.9551 *
	* 1.9318	* 1.7081	* 1.7497	* 1.6015	* 1.7297	* 1.6102	* 1.4679	* 2.3834 *
10	* 1.6712	* 1.4427	* 1.2678	* 1.3364	* 1.6319	* 1.4266	* 1.6790	* 0.8740 *
	* 1.6332	* 1.7509	* 2.0190	* 1.8972	* 1.6621	* 1.7508	* 1.5864	* 2.5858 *
11	* 1.4056	* 1.6869	* 1.3358	* 1.5736	* 1.3170	* 1.5463	* 1.0506	* 0.6289 *
	* 1.7908	* 1.6017	* 1.8981	* 1.6495	* 1.7885	* 1.6310	* 2.2034	* 3.6918 *
12	* 1.7048	* 1.4411	* 1.6316	* 1.3160	* 1.1364	* 1.4322	* 0.8552 *	
	* 1.5745	* 1.7298	* 1.6621	* 1.7892	* 1.6481	* 1.5462	* 2.3807 *	
13	* 1.5400	* 1.5374	* 1.4276	* 1.5462	* 1.4320	* 1.3308	* 0.6977 *	
	* 1.6026	* 1.6103	* 1.7503	* 1.6312	* 1.5464	* 1.6567	* 2.8851 *	
14	* 1.8198	* 1.7996	* 1.6789	* 1.0503	* 0.8542	* 0.6975 *		
	* 1.4489	* 1.4679	* 1.5865	* 2.2052	* 2.3814	* 2.8864 *		
15	* 0.9524	* 0.9553	* 0.8736	* 0.6168	* F-SUB-Q			
	* 2.3117	* 2.3905	* 2.5866	* 3.6437	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1908	* 1.2995	* 1.6554	* 1.3911	* 1.6792	* 1.5195	* 1.7910	* 0.9568 *
	* 2.1154	* 2.0359	* 1.7502	* 1.9300	* 1.6955	* 1.7183	* 1.5563	* 2.4321 *
9	* 1.2995	* 1.5768	* 1.4322	* 1.6646	* 1.4250	* 1.5188	* 1.7726	* 0.9544 *
	* 2.0359	* 1.8069	* 1.8743	* 1.7291	* 1.8605	* 1.7265	* 1.5771	* 2.5234 *
10	* 1.6554	* 1.4302	* 1.2766	* 1.3293	* 1.6197	* 1.4176	* 1.6608	* 0.8835 *
	* 1.7502	* 1.8756	* 2.1243	* 2.0031	* 1.7536	* 1.8632	* 1.7071	* 2.7149 *
11	* 1.3911	* 1.6644	* 1.3286	* 1.5868	* 1.3406	* 1.5661	* 1.0804	* 0.6385 *
	* 1.9300	* 1.7293	* 2.0038	* 1.7459	* 1.8889	* 1.7337	* 2.2601	* 3.8190 *
12	* 1.6792	* 1.4250	* 1.6195	* 1.3397	* 1.2761	* 1.5365	* 0.8992 *	
	* 1.6955	* 1.8607	* 1.7537	* 1.8894	* 1.7474	* 1.6432	* 2.4683 *	
13	* 1.5195	* 1.5191	* 1.4185	* 1.5660	* 1.5363	* 1.4182	* 0.7455 *	
	* 1.7183	* 1.7265	* 1.8627	* 1.7339	* 1.6433	* 1.7592	* 2.9849 *	
14	* 1.7910	* 1.7727	* 1.6607	* 1.0801	* 0.8981	* 0.7453 *		
	* 1.5563	* 1.5770	* 1.7073	* 2.2622	* 2.4689	* 2.9864 *		
15	* 0.9568	* 0.9546	* 0.8831	* 0.6294	* F-SUB-Q			
	* 2.4321	* 2.5311	* 2.7159	* 3.7505	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2678	* 1.3272	* 1.6819	* 1.4000	* 1.6969	* 1.5252	* 1.8109	* 0.9440 *
	* 2.2132	* 2.1383	* 1.8263	* 2.0447	* 1.7945	* 1.8217	* 1.6365	* 2.6203 *
9	* 1.3272	* 1.6183	* 1.4452	* 1.6845	* 1.4298	* 1.5267	* 1.7943	* 0.9470 *
	* 2.1383	* 1.8840	* 1.9683	* 1.8220	* 1.9825	* 1.8296	* 1.6584	* 2.7050 *
10	* 1.6819	* 1.4431	* 1.2710	* 1.3405	* 1.6477	* 1.4327	* 1.6895	* 0.8738 *
	* 1.8263	* 1.9698	* 2.2598	* 2.1014	* 1.8241	* 1.9502	* 1.7752	* 2.9274 *
11	* 1.4000	* 1.6843	* 1.3399	* 1.6375	* 1.3796	* 1.6254	* 1.0780	* 0.6350 *
	* 2.0447	* 1.8222	* 2.1021	* 1.8145	* 1.9742	* 1.7937	* 2.4119	* 4.0673 *
12	* 1.6969	* 1.4298	* 1.6475	* 1.3785	* 1.4410	* 1.6619	* 0.9175	*
	* 1.7945	* 1.9826	* 1.8242	* 1.9748	* 1.8222	* 1.7018	* 2.6210	*
13	* 1.5252	* 1.5270	* 1.4337	* 1.6253	* 1.6617	* 1.5330	* 0.7690	*
	* 1.8217	* 1.8296	* 1.9496	* 1.7940	* 1.7020	* 1.8251	* 3.1848	*
14	* 1.8109	* 1.7944	* 1.6893	* 1.0778	* 0.9164	* 0.7689	*	
	* 1.6365	* 1.6583	* 1.7754	* 2.4141	* 2.6219	* 3.1863	*	
15	* 0.9440	* 0.9473	* 0.8733	* 0.6214	* F-SUB-Q			
	* 2.6203	* 2.7131	* 2.9286	* 4.0234	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2975	* 1.3388	* 1.6882	* 1.3995	* 1.6967	* 1.5210	* 1.8102	* 0.9415
	* 2.2452	* 2.1596	* 1.8496	* 2.0724	* 1.8468	* 1.9270	* 1.7413	* 2.7940
9	* 1.3388	* 1.6342	* 1.4465	* 1.6864	* 1.4274	* 1.5244	* 1.7950	* 0.9450
	* 2.1596	* 1.9059	* 1.9955	* 1.8560	* 2.0280	* 1.9241	* 1.7554	* 2.8755
10	* 1.6882	* 1.4444	* 1.2746	* 1.3446	* 1.6560	* 1.4364	* 1.6964	* 0.8751
	* 1.8496	* 1.9970	* 2.2890	* 2.1594	* 1.8908	* 2.0305	* 1.8538	* 3.0625
11	* 1.3995	* 1.6862	* 1.3440	* 1.6619	* 1.4023	* 1.6551	* 1.0896	* 0.6382
	* 2.0724	* 1.8563	* 2.1603	* 1.8815	* 2.0656	* 1.8916	* 2.5177	* 4.2344
12	* 1.6967	* 1.4272	* 1.6558	* 1.4014	* 1.5009	* 1.7233	* 0.9395	
	* 1.8468	* 2.0284	* 1.8910	* 2.0663	* 1.9221	* 1.7932	* 2.7663	
13	* 1.5210	* 1.5248	* 1.4374	* 1.6549	* 1.7231	* 1.5941	* 0.7941	
	* 1.9270	* 1.9242	* 2.0298	* 1.8918	* 1.7934	* 1.9202	* 3.3567	
14	* 1.8102	* 1.7951	* 1.6962	* 1.0893	* 0.9383	* 0.7939	*	
	* 1.7413	* 1.7553	* 1.8541	* 2.5201	* 2.7675	* 3.3583	*	
15	* 0.9415	* 0.9452	* 0.8746	* 0.6240	* F-SUB-Q			
	* 2.7940	* 2.8843	* 3.0640	* 4.1924	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2986	* 1.3358	* 1.6747	* 1.3883	* 1.6789	* 1.5073	* 1.7910	* 0.9460 *
	* 2.2091	* 2.1216	* 1.8219	* 2.0387	* 1.8196	* 1.8947	* 1.7151	* 2.7065 *
9	* 1.3358	* 1.6258	* 1.4355	* 1.6703	* 1.4165	* 1.5120	* 1.7770	* 0.9459 *
	* 2.1216	* 1.8774	* 1.9650	* 1.8287	* 1.9938	* 1.8917	* 1.7292	* 2.7994 *
10	* 1.6747	* 1.4333	* 1.2823	* 1.3399	* 1.6463	* 1.4293	* 1.6832	* 0.8820 *
	* 1.8219	* 1.9665	* 2.2242	* 2.1231	* 1.8641	* 1.9975	* 1.8276	* 2.9666 *
11	* 1.3883	* 1.6701	* 1.3394	* 1.6586	* 1.4055	* 1.6566	* 1.1099	* 0.6453 *
	* 2.0387	* 1.8289	* 2.1240	* 1.8564	* 2.0344	* 1.8673	* 2.4303	* 4.1055 *
12	* 1.6789	* 1.4163	* 1.6462	* 1.4046	* 1.5197	* 1.7377	* 0.9629 *	
	* 1.8196	* 1.9942	* 1.8644	* 2.0350	* 1.9240	* 1.7912	* 2.6770 *	
13	* 1.5073	* 1.5123	* 1.4303	* 1.6563	* 1.7376	* 1.6153	* 0.8193 *	
	* 1.8947	* 1.8917	* 1.9969	* 1.8675	* 1.7914	* 1.9294	* 3.2744 *	
14	* 1.7910	* 1.7771	* 1.6829	* 1.1094	* 0.9617	* 0.8191 *		
	* 1.7151	* 1.7291	* 1.8279	* 2.4328	* 2.6781	* 3.2761 *		
15	* 0.9460	* 0.9461	* 0.8815	* 0.6342	* F-SUB-Q			
	* 2.7065	* 2.8081	* 2.9682	* 4.0432	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3078	* 1.3411	* 1.6917	* 1.3928	* 1.6934	* 1.5119	* 1.8101	* 0.9330 *
	* 2.1507	* 2.0652	* 1.7585	* 1.9784	* 1.7544	* 1.8267	* 1.6421	* 2.6439 *
9	* 1.3411	* 1.6436	* 1.4408	* 1.6853	* 1.4186	* 1.5181	* 1.7968	* 0.9381 *
	* 2.0652	* 1.8153	* 1.9087	* 1.7650	* 1.9377	* 1.8298	* 1.6610	* 2.7251 *
10	* 1.6917	* 1.4386	* 1.2695	* 1.3458	* 1.6663	* 1.4365	* 1.7055	* 0.8702 *
	* 1.7585	* 1.9103	* 2.1902	* 2.0682	* 1.8041	* 1.9422	* 1.7613	* 2.9274 *
11	* 1.3928	* 1.6851	* 1.3454	* 1.6805	* 1.4159	* 1.6861	* 1.0961	* 0.6376 *
	* 1.9784	* 1.7652	* 2.0691	* 1.8022	* 1.9873	* 1.8097	* 2.4176	* 4.0640 *
12	* 1.6934	* 1.4185	* 1.6662	* 1.4150	* 1.5452	* 1.7751	* 0.9548 *	
	* 1.7544	* 1.9380	* 1.8043	* 1.9881	* 1.8714	* 1.7325	* 2.6618 *	
13	* 1.5119	* 1.5185	* 1.4375	* 1.6858	* 1.7749	* 1.6508	* 0.8141 *	
	* 1.8267	* 1.8298	* 1.9416	* 1.8099	* 1.7327	* 1.8665	* 3.2598 *	
14	* 1.8101	* 1.7969	* 1.7052	* 1.0957	* 0.9535	* 0.8139 *		
	* 1.6421	* 1.6610	* 1.7617	* 2.4201	* 2.6631	* 3.2615 *		
15	* 0.9330	* 0.9382	* 0.8696	* 0.6220	* F-SUB-Q			
	* 2.6439	* 2.7335	* 2.9291	* 4.0326	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3071	* 1.3395	* 1.6943	* 1.3902	* 1.6944	* 1.5092	* 1.8135	* 0.9264 *
	* 2.0418	* 1.9674	* 1.6794	* 1.8828	* 1.6673	* 1.7490	* 1.5702	* 2.5332 *
9	* 1.3395	* 1.6465	* 1.4378	* 1.6867	* 1.4151	* 1.5166	* 1.8008	* 0.9341 *
	* 1.9674	* 1.7295	* 1.8239	* 1.6800	* 1.8445	* 1.7481	* 1.5859	* 2.6006 *
10	* 1.6943	* 1.4355	* 1.2660	* 1.3448	* 1.6704	* 1.4359	* 1.7113	* 0.8649 *
	* 1.6794	* 1.8254	* 2.0865	* 1.9767	* 1.7252	* 1.8635	* 1.6875	* 2.7898 *
11	* 1.3902	* 1.6865	* 1.3443	* 1.6853	* 1.4167	* 1.6958	* 1.0935	* 0.6346 *
	* 1.8828	* 1.6802	* 1.9775	* 1.7185	* 1.8994	* 1.7298	* 2.3095	* 3.8591 *
12	* 1.6944	* 1.4149	* 1.6703	* 1.4157	* 1.5543	* 1.7889	* 0.9536	*
	* 1.6673	* 1.8446	* 1.7254	* 1.9001	* 1.7992	* 1.6618	* 2.5403	*
13	* 1.5092	* 1.5169	* 1.4369	* 1.6954	* 1.7887	* 1.6663	* 0.8142	*
	* 1.7490	* 1.7481	* 1.8629	* 1.7300	* 1.6620	* 1.7877	* 3.1085	*
14	* 1.8135	* 1.8009	* 1.7110	* 1.0931	* 0.9522	* 0.8139	*	
	* 1.5702	* 1.5859	* 1.6879	* 2.3123	* 2.5418	* 3.1102	*	
15	* 0.9264	* 0.9342	* 0.8643	* 0.6182	* F-SUB-Q			
	* 2.5332	* 2.6087	* 2.7916	* 3.8349	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3029	* 1.3353	* 1.6906	* 1.3846	* 1.6897	* 1.5037	* 1.8099	* 0.9274 *
	* 1.8952	* 1.8222	* 1.5477	* 1.7426	* 1.5443	* 1.6250	* 1.4578	* 2.3441 *
9	* 1.3353	* 1.6432	* 1.4317	* 1.6823	* 1.4094	* 1.5118	* 1.7975	* 0.9327 *
	* 1.8222	* 1.6000	* 1.6853	* 1.5537	* 1.7094	* 1.6218	* 1.4703	* 2.4109 *
10	* 1.6906	* 1.4294	* 1.2651	* 1.3408	* 1.6674	* 1.4321	* 1.7090	* 0.8681 *
	* 1.5477	* 1.6867	* 1.9259	* 1.8275	* 1.5956	* 1.7228	* 1.5567	* 2.5672 *
11	* 1.3846	* 1.6821	* 1.3403	* 1.6828	* 1.4134	* 1.6959	* 1.0964	* 0.6351 *
	* 1.7426	* 1.5538	* 1.8284	* 1.5902	* 1.7597	* 1.5993	* 2.1318	* 3.5673 *
12	* 1.6897	* 1.4093	* 1.6673	* 1.4124	* 1.5550	* 1.7908	* 0.9572	*
	* 1.5443	* 1.7097	* 1.5958	* 1.7603	* 1.6595	* 1.5318	* 2.3378	*
13	* 1.5037	* 1.5122	* 1.4331	* 1.6956	* 1.7906	* 1.6694	* 0.8187	*
	* 1.6250	* 1.6218	* 1.7222	* 1.5995	* 1.5320	* 1.6457	* 2.8537	*
14	* 1.8099	* 1.7975	* 1.7086	* 1.0959	* 0.9558	* 0.8185	*	
	* 1.4578	* 1.4703	* 1.5571	* 2.1342	* 2.3392	* 2.8552	*	
15	* 0.9274	* 0.9329	* 0.8674	* 0.6185	* F-SUB-Q			
	* 2.3441	* 2.4184	* 2.5690	* 3.5461	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2955	* 1.3297	* 1.6793	* 1.3768	* 1.6777	* 1.4959	* 1.7971	* 0.9349
	* 1.9089	* 1.8312	* 1.5628	* 1.7609	* 1.5644	* 1.6456	* 1.4786	* 2.3444
9	* 1.3297	* 1.6324	* 1.4228	* 1.6706	* 1.4026	* 1.5042	* 1.7849	* 0.9363
	* 1.8312	* 1.6112	* 1.7018	* 1.5720	* 1.7272	* 1.6407	* 1.4902	* 2.4199
10	* 1.6793	* 1.4205	* 1.2739	* 1.3353	* 1.6565	* 1.4257	* 1.6969	* 0.8762
	* 1.5628	* 1.7032	* 1.9193	* 1.8402	* 1.6085	* 1.7350	* 1.5730	* 2.5583
11	* 1.3768	* 1.6704	* 1.3348	* 1.6719	* 1.4075	* 1.6862	* 1.1115	* 0.6409
	* 1.7609	* 1.5721	* 1.8410	* 1.6061	* 1.7748	* 1.6166	* 2.1108	* 3.5412
12	* 1.6777	* 1.4025	* 1.6565	* 1.4065	* 1.5503	* 1.7810	* 0.9704	*
	* 1.5644	* 1.7275	* 1.6087	* 1.7755	* 1.6687	* 1.5449	* 2.3175	*
13	* 1.4959	* 1.5046	* 1.4267	* 1.6858	* 1.7808	* 1.6633	* 0.8315	*
	* 1.6456	* 1.6407	* 1.7345	* 1.6167	* 1.5451	* 1.6580	* 2.8215	*
14	* 1.7971	* 1.7850	* 1.6966	* 1.1109	* 0.9691	* 0.8313	*	
	* 1.4786	* 1.4902	* 1.5734	* 2.1133	* 2.3188	* 2.8231	*	
15	* 0.9349	* 0.9364	* 0.8755	* 0.6270	F-SUB-Q			
	* 2.3444	* 2.4276	* 2.5602	* 3.5040	M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3064	* 1.3384	* 1.7050	* 1.3877	* 1.7027	* 1.5087	* 1.8276	* 0.9250
	* 1.7634	* 1.7034	* 1.4443	* 1.6412	* 1.4487	* 1.5350	* 1.3675	* 2.2306
9	* 1.3384	* 1.6566	* 1.4345	* 1.6952	* 1.4115	* 1.5183	* 1.8155	* 0.9320
	* 1.7034	* 1.4866	* 1.5845	* 1.4550	* 1.6128	* 1.5283	* 1.3773	* 2.2876
10	* 1.7050	* 1.4322	* 1.2626	* 1.3439	* 1.6808	* 1.4375	* 1.7272	* 0.8646
	* 1.4443	* 1.5859	* 1.8132	* 1.7140	* 1.4854	* 1.6134	* 1.4495	* 2.4366
11	* 1.3877	* 1.6951	* 1.3434	* 1.6970	* 1.4177	* 1.7146	* 1.0969	* 0.6331
	* 1.6412	* 1.4552	* 1.7148	* 1.4770	* 1.6448	* 1.4848	* 1.9984	* 3.3592
12	* 1.7027	* 1.4114	* 1.6808	* 1.4166	* 1.5688	* 1.8137	* 0.9569	
	* 1.4487	* 1.6131	* 1.4856	* 1.6455	* 1.5337	* 1.4158	* 2.1987	
13	* 1.5087	* 1.5187	* 1.4386	* 1.7142	* 1.8135	* 1.6923	* 0.8185	
	* 1.5350	* 1.5283	* 1.6128	* 1.4850	* 1.4159	* 1.5171	* 2.6802	
14	* 1.8276	* 1.8156	* 1.7268	* 1.0964	* 0.9555	* 0.8183		
	* 1.3675	* 1.3773	* 1.4498	* 2.0007	* 2.2001	* 2.6816		
15	* 0.9249	* 0.9322	* 0.8639	* 0.6152	* F-SUB-Q			
	* 2.2306	* 2.2947	* 2.4384	* 3.3467	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3109	* 1.3434	* 1.7150	* 1.3928	* 1.7124	* 1.5160	* 1.8397	* 0.9280
	* 1.6597	* 1.6086	* 1.3618	* 1.5524	* 1.3674	* 1.4509	* 1.2895	* 2.1129
9	* 1.3434	* 1.6661	* 1.4400	* 1.7048	* 1.4167	* 1.5258	* 1.8275	* 0.9351
	* 1.6086	* 1.4002	* 1.4979	* 1.3728	* 1.5258	* 1.4438	* 1.2983	* 2.1660
10	* 1.7150	* 1.4376	* 1.2666	* 1.3488	* 1.6906	* 1.4444	* 1.7386	* 0.8676
	* 1.3618	* 1.4993	* 1.7152	* 1.6171	* 1.3988	* 1.5215	* 1.3642	* 2.3049
11	* 1.3928	* 1.7046	* 1.3483	* 1.7069	* 1.4235	* 1.7259	* 1.1023	* 0.6347
	* 1.5524	* 1.3730	* 1.6177	* 1.3837	* 1.5405	* 1.3799	* 1.8783	* 3.1744
12	* 1.7124	* 1.4165	* 1.6905	* 1.4225	* 1.5787	* 1.8267	* 0.9610	*
	* 1.3674	* 1.5260	* 1.3991	* 1.5411	* 1.4175	* 1.3095	* 2.0490	*
13	* 1.5160	* 1.5262	* 1.4455	* 1.7255	* 1.8265	* 1.7045	* 0.8216	*
	* 1.4509	* 1.4438	* 1.5209	* 1.3801	* 1.3097	* 1.4033	* 2.4936	*
14	* 1.8397	* 1.8276	* 1.7382	* 1.1018	* 0.9596	* 0.8214	*	*
	* 1.2895	* 1.2983	* 1.3646	* 1.8805	* 2.0503	* 2.4950	*	*
15	* 0.9280	* 0.9353	* 0.8669	* 0.6164	* F-SUB-Q			
	* 2.1129	* 2.1727	* 2.3067	* 3.1645	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3057	* 1.3401	* 1.7010	* 1.3875	* 1.6984	* 1.5126	* 1.8239	* 0.9423
	* 1.5758	* 1.5271	* 1.3005	* 1.4798	* 1.3093	* 1.3831	* 1.2359	* 1.9842
9	* 1.3401	* 1.6533	* 1.4353	* 1.6912	* 1.4137	* 1.5217	* 1.8117	* 0.9438
	* 1.5271	* 1.3347	* 1.4250	* 1.3124	* 1.4523	* 1.3760	* 1.2436	* 2.0459
10	* 1.7010	* 1.4328	* 1.2861	* 1.3459	* 1.6783	* 1.4419	* 1.7222	* 0.8841
	* 1.3005	* 1.4264	* 1.6053	* 1.5322	* 1.3307	* 1.4442	* 1.3045	* 2.1536
11	* 1.3875	* 1.6911	* 1.3454	* 1.6940	* 1.4214	* 1.7120	* 1.1278	* 0.6454
	* 1.4798	* 1.3129	* 1.5327	* 1.3163	* 1.4569	* 1.3119	* 1.7351	* 2.9715
12	* 1.6984	* 1.4136	* 1.6782	* 1.4203	* 1.5750	* 1.8110	* 0.9820	*
	* 1.3093	* 1.4526	* 1.3310	* 1.4575	* 1.3388	* 1.2448	* 1.8944	*
13	* 1.5126	* 1.5220	* 1.4430	* 1.7116	* 1.8107	* 1.6922	* 0.8400	*
	* 1.3831	* 1.3760	* 1.4437	* 1.3121	* 1.2450	* 1.3330	* 2.3039	*
14	* 1.8239	* 1.8117	* 1.7218	* 1.1272	* 0.9806	* 0.8398	*	*
	* 1.2359	* 1.2436	* 1.3049	* 1.7372	* 1.8956	* 2.3053	*	*
15	* 0.9423	* 0.9439	* 0.8833	* 0.6317	* F-SUB-Q			
	* 1.9842	* 2.0523	* 2.1553	* 2.9389	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3105	* 1.3398	* 1.7077	* 1.3893	* 1.7049	* 1.5174	* 1.8322	* 0.9253
	* 1.5004	* 1.4592	* 1.2368	* 1.4118	* 1.2452	* 1.3166	* 1.1740	* 1.9322
9	* 1.3398	* 1.6607	* 1.4414	* 1.6980	* 1.4149	* 1.5261	* 1.8202	* 0.9321
	* 1.4592	* 1.2685	* 1.3552	* 1.2478	* 1.3863	* 1.3101	* 1.1813	* 1.9806
10	* 1.7077	* 1.4389	* 1.2687	* 1.3465	* 1.6870	* 1.4456	* 1.7306	* 0.8672
	* 1.2368	* 1.3566	* 1.5552	* 1.4629	* 1.2637	* 1.3757	* 1.2391	* 2.0996
11	* 1.3893	* 1.6978	* 1.3460	* 1.7027	* 1.4245	* 1.7202	* 1.1081	* 0.6340
	* 1.4118	* 1.2482	* 1.4634	* 1.2496	* 1.3877	* 1.2449	* 1.6872	* 2.8956
12	* 1.7049	* 1.4148	* 1.6869	* 1.4234	* 1.5804	* 1.8201	* 0.9634	*
	* 1.2452	* 1.3866	* 1.2637	* 1.3883	* 1.2719	* 1.1806	* 1.8447	*
13	* 1.5174	* 1.5264	* 1.4467	* 1.7198	* 1.8199	* 1.6947	* 0.8208	*
	* 1.3166	* 1.3101	* 1.3752	* 1.2452	* 1.1807	* 1.2677	* 2.2528	*
14	* 1.8322	* 1.8202	* 1.7302	* 1.1075	* 0.9619	* 0.8205	*	*
	* 1.1740	* 1.1813	* 1.2394	* 1.6892	* 1.8460	* 2.2541	*	*
15	* 0.9253	* 0.9323	* 0.8664	* 0.6163	* F-SUB-Q			
	* 1.9322	* 1.9866	* 2.1014	* 2.8842	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2674	* 1.2891	* 1.6269	* 1.3368	* 1.6242	* 1.4592	* 1.7418	* 0.8838
	* 1.4971	* 1.4628	* 1.2510	* 1.4154	* 1.2597	* 1.3202	* 1.1899	* 1.9543
9	* 1.2891	* 1.5844	* 1.3933	* 1.6174	* 1.3626	* 1.4690	* 1.7308	* 0.8940
	* 1.4628	* 1.2816	* 1.3524	* 1.2619	* 1.3885	* 1.3124	* 1.1969	* 1.9950
10	* 1.6269	* 1.3909	* 1.2232	* 1.2968	* 1.6115	* 1.3937	* 1.6463	* 0.8293
	* 1.2510	* 1.3536	* 1.5541	* 1.4651	* 1.2747	* 1.3761	* 1.2554	* 2.1219
11	* 1.3368	* 1.6171	* 1.2963	* 1.6258	* 1.3752	* 1.6393	* 1.0667	* 0.6092
	* 1.4154	* 1.2624	* 1.4656	* 1.2610	* 1.3857	* 1.2582	* 1.6916	* 2.9163
12	* 1.6242	* 1.3624	* 1.6114	* 1.3741	* 1.5194	* 1.7310	* 0.9241	*
	* 1.2597	* 1.3887	* 1.2748	* 1.3864	* 1.2751	* 1.1953	* 1.8571	*
13	* 1.4592	* 1.4693	* 1.3948	* 1.6389	* 1.7307	* 1.6073	* 0.7832	*
	* 1.3202	* 1.3124	* 1.3756	* 1.2584	* 1.1955	* 1.2876	* 2.2805	*
14	* 1.7418	* 1.7309	* 1.6459	* 1.0661	* 0.9227	* 0.7829	*	*
	* 1.1899	* 1.1969	* 1.2558	* 1.6937	* 1.8585	* 2.2818	*	*
15	* 0.8838	* 0.8943	* 0.8285	* 0.5918	* F-SUB-Q			
	* 1.9543	* 2.0010	* 2.1238	* 2.9067	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 445 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1052	* 1.1150	* 1.3692	* 1.1565	* 1.3668	* 1.2529	* 1.4620	* 0.7619
	* 1.6692	* 1.6438	* 1.4434	* 1.5892	* 1.4537	* 1.4932	* 1.3760	* 2.2073
9	* 1.1150	* 1.3398	* 1.2145	* 1.3646	* 1.1735	* 1.2663	* 1.4534	* 0.7715
	* 1.6438	* 1.4720	* 1.5070	* 1.4508	* 1.5669	* 1.4789	* 1.3837	* 2.2515
10	* 1.3692	* 1.2127	* 1.0678	* 1.1239	* 1.3633	* 1.2076	* 1.3861	* 0.7061
	* 1.4434	* 1.5082	* 1.7308	* 1.6427	* 1.4634	* 1.5392	* 1.4488	* 2.4282
11	* 1.1565	* 1.3644	* 1.1235	* 1.3760	* 1.1962	* 1.3821	* 0.9207	* 0.5256
	* 1.5892	* 1.4513	* 1.6433	* 1.4474	* 1.5477	* 1.4497	* 1.9062	* 3.2998
12	* 1.3668	* 1.1734	* 1.3632	* 1.1954	* 1.3183	* 1.4558	* 0.7993	*
	* 1.4537	* 1.5672	* 1.4635	* 1.5484	* 1.4276	* 1.3800	* 2.0905	*
13	* 1.2529	* 1.2666	* 1.2087	* 1.3818	* 1.4555	* 1.3512	* 0.6662	*
	* 1.4932	* 1.4789	* 1.5384	* 1.4500	* 1.3802	* 1.4878	* 2.6124	*
14	* 1.4620	* 1.4534	* 1.3856	* 0.9202	* 0.7981	* 0.6660	*	
	* 1.3760	* 1.3838	* 1.4493	* 1.9086	* 2.0919	* 2.6139	*	
15	* 0.7619	* 0.7717	* 0.7054	* 0.5101	* F-SUB-Q			
	* 2.2073	* 2.2583	* 2.4306	* 3.2914	* M-SUB-Q			

AT 75% POWER, 445 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5232	* 0.5507	* 0.6575	* 0.5687	* 0.6559	* 0.5787	* 0.6390	* 0.3619 *
	* 3.4424	* 3.2495	* 2.9341	* 3.1545	* 2.9574	* 3.1513	* 3.0679	* 4.5463 *
9	* 0.5507	* 0.6434	* 0.5716	* 0.6553	* 0.5603	* 0.5829	* 0.6346	* 0.3621 *
	* 3.2495	* 2.9930	* 3.1240	* 2.9487	* 3.2029	* 3.1317	* 3.0887	* 4.6944 *
10	* 0.6575	* 0.5709	* 0.5308	* 0.5554	* 0.6536	* 0.5634	* 0.6016	* 0.3360 *
	* 2.9341	* 3.1254	* 3.4014	* 3.2461	* 2.9747	* 3.2189	* 3.2566	* 4.9942 *
11	* 0.5687	* 0.6552	* 0.5552	* 0.6490	* 0.5720	* 0.6424	* 0.4453	* 0.2505 *
	* 3.1545	* 2.9498	* 3.2473	* 2.9943	* 3.1580	* 3.0396	* 3.8521	* 6.7875 *
12	* 0.6559	* 0.5603	* 0.6536	* 0.5717	* 0.5988	* 0.6366	* 0.3815	*
	* 2.9574	* 3.2035	* 2.9751	* 3.1590	* 3.0621	* 3.0759	* 4.2849	*
13	* 0.5787	* 0.5830	* 0.5637	* 0.6423	* 0.6365	* 0.5791	* 0.3151	*
	* 3.1513	* 3.1320	* 3.2181	* 3.0403	* 3.0765	* 3.3886	* 5.4074	*
14	* 0.6390	* 0.6346	* 0.6013	* 0.4450	* 0.3810	* 0.3150	*	
	* 3.0679	* 3.0888	* 3.2580	* 3.8573	* 4.2869	* 5.4109	*	
15	* 0.3619	* 0.3623	* 0.3357	* 0.2456	* F-SUB-Q			
	* 4.5463	* 4.7074	* 4.9995	* 6.7038	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3767	* 0.4993	* 0.6171	* 0.5484	* 0.6403	* 0.5554	* 0.5750	* 0.3074
	* 5.0803	* 4.7784	* 3.8468	* 4.3120	* 3.6953	* 4.2989	* 4.2059	* 7.1434
9	* 0.4993	* 0.5843	* 0.5554	* 0.6278	* 0.5478	* 0.5441	* 0.5643	* 0.3021
	* 4.7784	* 4.1087	* 4.2851	* 3.7722	* 4.3194	* 4.3849	* 4.2817	* 7.2871
10	* 0.6171	* 0.5550	* 0.4997	* 0.5250	* 0.6018	* 0.5142	* 0.5005	* 0.2657
	* 3.8468	* 4.2879	* 4.8466	* 4.5138	* 3.9195	* 4.5885	* 4.7189	* 8.0820
11	* 0.5484	* 0.6275	* 0.5248	* 0.5604	* 0.4924	* 0.4974	* 0.3530	* 0.1739
	* 4.3120	* 3.7736	* 4.5159	* 4.1533	* 4.7086	* 4.4550	* 6.1593	* 12.2569
12	* 0.6403	* 0.5477	* 0.6016	* 0.4921	* 0.3726	* 0.3741	* 0.2475	*
	* 3.6953	* 4.3200	* 3.9204	* 4.7107	* 4.6778	* 4.5875	* 7.3182	*
13	* 0.5554	* 0.5442	* 0.5144	* 0.4974	* 0.3741	* 0.2981	* 0.1695	*
	* 4.2989	* 4.3846	* 4.5866	* 4.4550	* 4.5871	* 5.1483	* 9.3315	*
14	* 0.5750	* 0.5644	* 0.5007	* 0.3531	* 0.2474	* 0.1695	*	*
	* 4.2059	* 4.2807	* 4.7176	* 6.1581	* 7.3139	* 9.3324	*	*
15	* 0.3074	* 0.3025	* 0.2657	* 0.1715	* F-SUB-Q			
	* 7.1434	* 7.2799	* 8.0810	* 12.2326	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9028	* 1.1362	* 1.4091	* 1.2275	* 1.4750	* 1.3514	* 1.4969	* 0.7323
	* 2.2523	* 2.1786	* 1.7469	* 2.0038	* 1.6690	* 1.8339	* 1.6757	* 3.1145
9	* 1.1362	* 1.3687	* 1.3140	* 1.4442	* 1.2821	* 1.3502	* 1.4739	* 0.7223
	* 2.1786	* 1.8109	* 1.8786	* 1.7003	* 1.9179	* 1.8367	* 1.6858	* 3.1344
10	* 1.4091	* 1.3129	* 1.1463	* 1.2059	* 1.4120	* 1.2583	* 1.3292	* 0.6376
	* 1.7469	* 1.8802	* 2.1812	* 2.0378	* 1.7335	* 1.9486	* 1.8439	* 3.4855
11	* 1.2275	* 1.4437	* 1.2053	* 1.3378	* 1.1605	* 1.2278	* 0.8483	* 0.4189
	* 2.0038	* 1.7009	* 2.0387	* 1.7839	* 2.0579	* 1.8642	* 2.6649	* 5.2854
12	* 1.4750	* 1.2819	* 1.4117	* 1.1598	* 0.8952	* 0.9794	* 0.5900	*
	* 1.6690	* 1.9182	* 1.7335	* 2.0589	* 1.9423	* 1.8114	* 3.1803	*
13	* 1.3514	* 1.3504	* 1.2590	* 1.2279	* 0.9793	* 0.8144	* 0.4163	*
	* 1.8339	* 1.8363	* 1.9475	* 1.8641	* 1.8112	* 2.0270	* 3.9407	*
14	* 1.4969	* 1.4743	* 1.3296	* 0.8487	* 0.5897	* 0.4163	*	*
	* 1.6757	* 1.6854	* 1.8433	* 2.6642	* 3.1794	* 3.9411	*	*
15	* 0.7323	* 0.7229	* 0.6378	* 0.4134	* F-SUB-Q			
	* 3.1145	* 3.1330	* 3.4848	* 5.2696	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0708	* 1.2741	* 1.3495	* 1.3813	* 1.4491	* 1.6203	* 1.6271	* 0.8378
	* 1.9629	* 2.0019	* 1.8789	* 1.8310	* 1.7480	* 1.5693	* 1.5624	* 2.7563
9	* 1.2741	* 1.3978	* 1.4882	* 1.4261	* 1.5113	* 1.6242	* 1.6204	* 0.8371
	* 2.0019	* 1.8215	* 1.7088	* 1.7722	* 1.6761	* 1.5633	* 1.5655	* 2.7573
10	* 1.3495	* 1.4852	* 1.3699	* 1.3834	* 1.4686	* 1.5155	* 1.5446	* 0.7582
	* 1.8789	* 1.7123	* 1.8586	* 1.8272	* 1.7177	* 1.6664	* 1.6305	* 3.0075
11	* 1.3813	* 1.4254	* 1.3827	* 1.3500	* 1.3546	* 1.3613	* 1.0153	* 0.5084
	* 1.8310	* 1.7729	* 1.8281	* 1.8040	* 1.7831	* 1.7264	* 2.2944	* 4.4848
12	* 1.4491	* 1.5113	* 1.4687	* 1.3543	* 1.0719	* 1.0910	* 0.6840	*
	* 1.7480	* 1.6762	* 1.7176	* 1.7836	* 1.6806	* 1.7109	* 2.8360	*
13	* 1.6203	* 1.6246	* 1.5166	* 1.3614	* 1.0910	* 1.0150	* 0.5119	*
	* 1.5693	* 1.5629	* 1.6653	* 1.7264	* 1.7105	* 1.7204	* 3.3134	*
14	* 1.6271	* 1.6207	* 1.5453	* 1.0157	* 0.6835	* 0.5118	*	*
	* 1.5624	* 1.5652	* 1.6298	* 2.2936	* 2.8356	* 3.3138	*	*
15	* 0.8378	* 0.8377	* 0.7584	* 0.5040	* F-SUB-Q			
	* 2.7563	* 2.7561	* 3.0066	* 4.4512	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1423	* 1.3270	* 1.4319	* 1.4465	* 1.5801	* 1.7749	* 1.7979	* 0.8731
	* 1.8943	* 1.9851	* 1.7469	* 1.8124	* 1.6604	* 1.4768	* 1.4566	* 2.7244
9	* 1.3270	* 1.5131	* 1.5901	* 1.5249	* 1.6282	* 1.7829	* 1.7932	* 0.8792
	* 1.9851	* 1.7432	* 1.6558	* 1.7003	* 1.6076	* 1.4694	* 1.4590	* 2.7085
10	* 1.4319	* 1.5864	* 1.4697	* 1.4652	* 1.6157	* 1.6565	* 1.7239	* 0.7983
	* 1.7469	* 1.6597	* 1.7916	* 1.7867	* 1.6171	* 1.5759	* 1.5101	* 2.9528
11	* 1.4465	* 1.5241	* 1.4643	* 1.4653	* 1.4623	* 1.5101	* 1.0819	* 0.5384
	* 1.8124	* 1.7009	* 1.7878	* 1.7150	* 1.6975	* 1.6175	* 2.2335	* 4.3886
12	* 1.5801	* 1.6282	* 1.6159	* 1.4619	* 1.1630	* 1.2107	* 0.7219	*
	* 1.6604	* 1.6076	* 1.6169	* 1.6981	* 1.5883	* 1.6073	* 2.8031	*
13	* 1.7749	* 1.7834	* 1.6580	* 1.5103	* 1.2107	* 1.1534	* 0.5492	*
	* 1.4768	* 1.4690	* 1.5745	* 1.6175	* 1.6070	* 1.5832	* 3.2270	*
14	* 1.7979	* 1.7936	* 1.7247	* 1.0824	* 0.7213	* 0.5491	*	*
	* 1.4566	* 1.4587	* 1.5094	* 2.2326	* 2.8031	* 3.2274	*	*
15	* 0.8731	* 0.8799	* 0.7986	* 0.5326	* F-SUB-Q			
	* 2.7244	* 2.7071	* 2.9518	* 4.3655	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1644	* 1.3502	* 1.4624	* 1.4660	* 1.6339	* 1.8360	* 1.8760	* 0.8946 *
	* 1.9554	* 2.0518	* 1.8840	* 1.8690	* 1.6767	* 1.4899	* 1.4566	* 2.7764 *
9	* 1.3502	* 1.5505	* 1.6171	* 1.5694	* 1.6712	* 1.8450	* 1.8720	* 0.9032 *
	* 2.0518	* 1.7850	* 1.7068	* 1.7453	* 1.6337	* 1.4823	* 1.4588	* 2.7548 *
10	* 1.4624	* 1.6128	* 1.4924	* 1.4991	* 1.6763	* 1.7165	* 1.8068	* 0.8235 *
	* 1.8840	* 1.7113	* 1.8505	* 1.8256	* 1.6257	* 1.5850	* 1.5029	* 2.9936 *
11	* 1.4660	* 1.5686	* 1.4981	* 1.5176	* 1.5205	* 1.5817	* 1.1219	* 0.5543 *
	* 1.8690	* 1.7462	* 1.8268	* 1.7309	* 1.7223	* 1.6213	* 2.2458	* 4.4444 *
12	* 1.6339	* 1.6712	* 1.6766	* 1.5200	* 1.2042	* 1.2761	* 0.7490	*
	* 1.6767	* 1.6337	* 1.6255	* 1.7229	* 1.5981	* 1.6105	* 2.8520	*
13	* 1.8360	* 1.8456	* 1.7182	* 1.5820	* 1.2760	* 1.2297	* 0.5755	*
	* 1.4899	* 1.4819	* 1.5834	* 1.6213	* 1.6102	* 1.5732	* 3.2653	*
14	* 1.8760	* 1.8726	* 1.8077	* 1.1225	* 0.7483	* 0.5754	*	*
	* 1.4566	* 1.4584	* 1.5022	* 2.2450	* 2.8523	* 3.2658	*	*
15	* 0.8946	* 0.9040	* 0.8238	* 0.5474	* F-SUB-Q			
	* 2.7764	* 2.7533	* 2.9926	* 4.4290	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1771	* 1.3622	* 1.4724	* 1.4719	* 1.6551	* 1.8632	* 1.9123	* 0.9094 *
	* 2.0513	* 2.1526	* 1.9730	* 1.9609	* 1.7368	* 1.5372	* 1.4966	* 2.8654 *
9	* 1.3622	* 1.5618	* 1.6236	* 1.5877	* 1.6903	* 1.8740	* 1.9091	* 0.9179 *
	* 2.1526	* 1.8694	* 1.7904	* 1.8183	* 1.7015	* 1.5282	* 1.4983	* 2.8416 *
10	* 1.4724	* 1.6191	* 1.4972	* 1.5199	* 1.7036	* 1.7464	* 1.8484	* 0.8413 *
	* 1.9730	* 1.7954	* 1.9434	* 1.9028	* 1.6862	* 1.6387	* 1.5434	* 3.0725 *
11	* 1.4719	* 1.5868	* 1.5190	* 1.5442	* 1.5583	* 1.6231	* 1.1517	* 0.5661 *
	* 1.9609	* 1.8194	* 1.9040	* 1.7996	* 1.7954	* 1.6770	* 2.3158	* 4.5950 *
12	* 1.6551	* 1.6902	* 1.7038	* 1.5577	* 1.2344	* 1.3214	* 0.7733	*
	* 1.7368	* 1.7015	* 1.6859	* 1.7965	* 1.6614	* 1.6735	* 2.9657	*
13	* 1.8632	* 1.8746	* 1.7482	* 1.6234	* 1.3213	* 1.2868	* 0.6005	*
	* 1.5372	* 1.5276	* 1.6370	* 1.6771	* 1.6732	* 1.6267	* 3.3885	*
14	* 1.9123	* 1.9097	* 1.8494	* 1.1521	* 0.7725	* 0.6004	*	*
	* 1.4966	* 1.4978	* 1.5427	* 2.3151	* 2.9663	* 3.3891	*	*
15	* 0.9094	* 0.9187	* 0.8415	* 0.5589	* F-SUB-Q			
	* 2.8654	* 2.8399	* 3.0717	* 4.5794	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1975	* 1.3735	* 1.4946	* 1.4858	* 1.6853	* 1.8960	* 1.9560	* 0.9139 *
	* 2.1481	* 2.2521	* 2.0860	* 2.0809	* 1.8200	* 1.6067	* 1.5556	* 3.0270 *
9	* 1.3735	* 1.5877	* 1.6418	* 1.6143	* 1.7157	* 1.9089	* 1.9536	* 0.9248 *
	* 2.2521	* 1.9778	* 1.9011	* 1.9184	* 1.7961	* 1.5970	* 1.5581	* 2.9996 *
10	* 1.4946	* 1.6370	* 1.5127	* 1.5378	* 1.7421	* 1.7836	* 1.8975	* 0.8476 *
	* 2.0860	* 1.9067	* 2.0668	* 2.0214	* 1.7688	* 1.7178	* 1.6078	* 3.2541 *
11	* 1.4858	* 1.6132	* 1.5366	* 1.5842	* 1.5952	* 1.6786	* 1.1706	* 0.5713 *
	* 2.0809	* 1.9196	* 2.0229	* 1.8721	* 1.8690	* 1.7375	* 2.4549	* 4.8888 *
12	* 1.6852	* 1.7156	* 1.7423	* 1.5946	* 1.2757	* 1.3853	* 0.7936 *	
	* 1.8200	* 1.7959	* 1.7685	* 1.8702	* 1.7332	* 1.7401	* 3.1397 *	
13	* 1.8960	* 1.9097	* 1.7856	* 1.6788	* 1.3851	* 1.3669	* 0.6239 *	
	* 1.6067	* 1.5964	* 1.7160	* 1.7375	* 1.7399	* 1.6915	* 3.5970 *	
14	* 1.9560	* 1.9541	* 1.8984	* 1.1710	* 0.7927	* 0.6237 *		
	* 1.5556	* 1.5576	* 1.6070	* 2.4543	* 3.1407	* 3.5977 *		
15	* 0.9139	* 0.9256	* 0.8478	* 0.5621	* F-SUB-Q			
	* 3.0270	* 2.9978	* 3.2534	* 4.8894	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2369	* 1.3906	* 1.5076	* 1.4924	* 1.7004	* 1.9137	* 1.9798	* 0.9176 *
	* 2.3011	* 2.4167	* 2.2599	* 2.2571	* 1.9569	* 1.7219	* 1.6617	* 3.2568 *
9	* 1.3906	* 1.6072	* 1.6540	* 1.6300	* 1.7328	* 1.9299	* 1.9788	* 0.9295 *
	* 2.4167	* 2.1444	* 2.0646	* 2.0739	* 1.9391	* 1.7111	* 1.6649	* 3.2275 *
10	* 1.5076	* 1.6489	* 1.5240	* 1.5561	* 1.7694	* 1.8102	* 1.9306	* 0.8544 *
	* 2.2599	* 2.0711	* 2.2471	* 2.1903	* 1.9037	* 1.8453	* 1.7199	* 3.5026 *
11	* 1.4924	* 1.6289	* 1.5548	* 1.6246	* 1.6378	* 1.7327	* 1.1946	* 0.5783 *
	* 2.2570	* 2.0753	* 2.1921	* 1.9815	* 1.9797	* 1.8319	* 2.6087	* 5.2791 *
12	* 1.7004	* 1.7327	* 1.7701	* 1.6372	* 1.3391	* 1.4694	* 0.8244 *	
	* 1.9569	* 1.9389	* 1.9033	* 1.9811	* 1.8375	* 1.8366	* 3.3289 *	
13	* 1.9137	* 1.9307	* 1.8122	* 1.7329	* 1.4692	* 1.4693	* 0.6589 *	
	* 1.7219	* 1.7103	* 1.8432	* 1.8320	* 1.8364	* 1.7912	* 3.8405 *	
14	* 1.9798	* 1.9794	* 1.9315	* 1.1949	* 0.8234	* 0.6587 *		
	* 1.6617	* 1.6644	* 1.7190	* 2.6082	* 3.3302	* 3.8413 *		
15	* 0.9176	* 0.9304	* 0.8545	* 0.5681	* F-SUB-Q			
	* 3.2568	* 3.2255	* 3.5021	* 5.2874	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3434	* 1.4174	* 1.5271	* 1.5021	* 1.7196	* 1.9324	* 2.0056	* 0.9182
	* 2.5189	* 2.6341	* 2.4778	* 2.4741	* 2.1268	* 1.8718	* 1.8001	* 3.5519
9	* 1.4174	* 1.6371	* 1.6727	* 1.6554	* 1.7536	* 1.9521	* 2.0062	* 0.9322
	* 2.6341	* 2.3424	* 2.2716	* 2.2673	* 2.1199	* 1.8599	* 1.8041	* 3.5179
10	* 1.5271	* 1.6674	* 1.5413	* 1.5799	* 1.8058	* 1.8404	* 1.9677	* 0.8586
	* 2.4778	* 2.2789	* 2.4757	* 2.3755	* 2.0741	* 2.0106	* 1.8655	* 3.8222
11	* 1.5021	* 1.6542	* 1.5788	* 1.6809	* 1.6901	* 1.8042	* 1.2195	* 0.5847
	* 2.4741	* 2.2689	* 2.3770	* 2.1371	* 2.1392	* 1.9700	* 2.8114	* 5.7682
12	* 1.7196	* 1.7535	* 1.8064	* 1.6893	* 1.4784	* 1.6177	* 0.8632	*
	* 2.1268	* 2.1196	* 2.0736	* 2.1408	* 1.9794	* 1.9737	* 3.6084	*
13	* 1.9324	* 1.9529	* 1.8425	* 1.8044	* 1.6177	* 1.6209	* 0.7027	*
	* 1.8718	* 1.8591	* 2.0082	* 1.9702	* 1.9735	* 1.9151	* 4.1522	*
14	* 2.0056	* 2.0068	* 1.9686	* 1.2197	* 0.8621	* 0.7026	*	*
	* 1.8001	* 1.8036	* 1.8647	* 2.8111	* 3.6101	* 4.1531	*	*
15	* 0.9182	* 0.9331	* 0.8586	* 0.5736	* F-SUB-Q			
	* 3.5519	* 3.5158	* 3.8220	* 5.7856	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4588	* 1.4393	* 1.5112	* 1.4871	* 1.6978	* 1.9147	* 1.9837	* 0.9233
	* 2.7921	* 2.9207	* 2.7377	* 2.7122	* 2.3300	* 2.0454	* 1.9709	* 3.8217
9	* 1.4393	* 1.6302	* 1.6625	* 1.6429	* 1.7468	* 1.9377	* 1.9864	* 0.9347
	* 2.9207	* 2.6186	* 2.5125	* 2.4905	* 2.3144	* 2.0298	* 1.9735	* 3.7877
10	* 1.5112	* 1.6571	* 1.5342	* 1.5919	* 1.8000	* 1.8374	* 1.9598	* 0.8690
	* 2.7377	* 2.5206	* 2.7350	* 2.6222	* 2.2724	* 2.1908	* 2.0339	* 4.0767
11	* 1.4871	* 1.6416	* 1.5908	* 1.7064	* 1.7381	* 1.8378	* 1.2529	* 0.5960
	* 2.7122	* 2.4923	* 2.6241	* 2.3794	* 2.3589	* 2.1876	* 3.0445	* 6.1291
12	* 1.6978	* 1.7467	* 1.8007	* 1.7373	* 1.6840	* 1.7501	* 0.9105	*
	* 2.3300	* 2.3142	* 2.2719	* 2.3600	* 2.2077	* 2.2063	* 3.9478	*
13	* 1.9147	* 1.9385	* 1.8395	* 1.8378	* 1.7502	* 1.7454	* 0.7560	*
	* 2.0454	* 2.0289	* 2.1883	* 2.1877	* 2.2062	* 2.1359	* 4.5285	*
14	* 1.9837	* 1.9870	* 1.9607	* 1.2531	* 0.9093	* 0.7558	*	*
	* 1.9710	* 1.9729	* 2.0330	* 3.0443	* 3.9499	* 4.5296	*	*
15	* 0.9233	* 0.9355	* 0.8689	* 0.5859	* F-SUB-Q			
	* 3.8217	* 3.7856	* 4.0769	* 6.1343	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5377	* 1.4743	* 1.5355	* 1.4975	* 1.7225	* 1.9360	* 2.0161	* 0.9137
	* 3.0891	* 3.2379	* 2.9126	* 2.9071	* 2.4717	* 2.1684	* 2.0763	* 4.1112
9	* 1.4743	* 1.6638	* 1.6825	* 1.6750	* 1.7666	* 1.9621	* 2.0202	* 0.9293
	* 3.2379	* 2.7930	* 2.6868	* 2.6573	* 2.4808	* 2.1541	* 2.0817	* 4.0708
10	* 1.5355	* 1.6768	* 1.5516	* 1.6230	* 1.8445	* 1.8683	* 2.0017	* 0.8621
	* 2.9126	* 2.6958	* 2.9290	* 2.8349	* 2.4196	* 2.3385	* 2.1561	* 4.4182
11	* 1.4975	* 1.6737	* 1.6218	* 1.7763	* 1.7744	* 1.9193	* 1.2612	* 0.5941
	* 2.9071	* 2.6593	* 2.8374	* 2.6062	* 2.6052	* 2.3873	* 3.3786	* 6.6719
12	* 1.7225	* 1.7665	* 1.8449	* 1.7735	* 1.8315	* 1.8715	* 0.9316	*
	* 2.4717	* 2.4806	* 2.4191	* 2.6073	* 2.4221	* 2.4055	* 4.4014	*
13	* 1.9360	* 1.9629	* 1.8705	* 1.9191	* 1.8715	* 1.8803	* 0.7827	*
	* 2.1684	* 2.1531	* 2.3357	* 2.3876	* 2.4054	* 2.3357	* 5.0918	*
14	* 2.0161	* 2.0208	* 2.0026	* 1.2614	* 0.9303	* 0.7825	*	*
	* 2.0763	* 2.0811	* 2.1551	* 3.3785	* 4.4040	* 5.0931	*	*
15	* 0.9137	* 0.9302	* 0.8620	* 0.5815	* F-SUB-Q			
	* 4.1112	* 4.0683	* 4.4186	* 6.7077	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5509	* 1.4807	* 1.5305	* 1.4871	* 1.7156	* 1.9281	* 2.0117	* 0.9072
	* 3.1236	* 3.2634	* 3.1118	* 3.1220	* 2.6759	* 2.3449	* 2.2400	* 4.4436
9	* 1.4807	* 1.6620	* 1.6754	* 1.6737	* 1.7614	* 1.9569	* 2.0170	* 0.9233
	* 3.2634	* 2.9070	* 2.8827	* 2.8570	* 2.6949	* 2.3287	* 2.2463	* 4.3994
10	* 1.5305	* 1.6697	* 1.5451	* 1.6272	* 1.8538	* 1.8690	* 2.0059	* 0.8590
	* 3.1118	* 2.8926	* 3.1269	* 2.9658	* 2.6065	* 2.5329	* 2.3271	* 4.7705
11	* 1.4871	* 1.6723	* 1.6259	* 1.7996	* 1.7914	* 1.9484	* 1.2691	* 0.5943
	* 3.1220	* 2.8594	* 2.9682	* 2.6801	* 2.6956	* 2.4773	* 3.5395	* 7.2186
12	* 1.7156	* 1.7613	* 1.8543	* 1.7899	* 1.8882	* 1.9172	* 0.9464	*
	* 2.6759	* 2.6946	* 2.6059	* 2.6979	* 2.5639	* 2.5194	* 4.6383	*
13	* 1.9281	* 1.9578	* 1.8713	* 1.9481	* 1.9172	* 1.9415	* 0.8023	*
	* 2.3449	* 2.3277	* 2.5298	* 2.4777	* 2.5194	* 2.4871	* 5.4369	*
14	* 2.0117	* 2.0175	* 2.0067	* 1.2692	* 0.9451	* 0.8021	*	*
	* 2.2400	* 2.2457	* 2.3261	* 3.5397	* 4.6413	* 5.4385	*	*
15	* 0.9072	* 0.9242	* 0.8588	* 0.5809	* F-SUB-Q			
	* 4.4436	* 4.3967	* 4.7712	* 7.2664	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5279	* 1.4563	* 1.4985	* 1.4566	* 1.6790	* 1.8937	* 1.9735	* 0.9013
	* 3.1637	* 3.3066	* 3.0300	* 3.0340	* 2.6100	* 2.3052	* 2.2114	* 4.3683
9	* 1.4563	* 1.6273	* 1.6430	* 1.6400	* 1.7322	* 1.9241	* 1.9797	* 0.9150
	* 3.3066	* 2.8997	* 2.7984	* 2.7783	* 2.6223	* 2.2912	* 2.2199	* 4.3399
10	* 1.4985	* 1.6371	* 1.5160	* 1.6093	* 1.8273	* 1.8413	* 1.9743	* 0.8570
	* 3.0300	* 2.8082	* 3.0474	* 2.9510	* 2.5636	* 2.5031	* 2.3171	* 4.7027
11	* 1.4566	* 1.6386	* 1.6083	* 1.7802	* 1.7850	* 1.9305	* 1.2730	* 0.5944
	* 3.0340	* 2.7806	* 2.9536	* 2.7124	* 2.7047	* 2.5042	* 3.5182	* 7.1968
12	* 1.6790	* 1.7321	* 1.8270	* 1.7840	* 1.8902	* 1.9086	* 0.9553	*
	* 2.6100	* 2.6223	* 2.5631	* 2.7061	* 2.5868	* 2.5474	* 4.6170	*
13	* 1.8937	* 1.9250	* 1.8436	* 1.9302	* 1.9086	* 1.9432	* 0.8159	*
	* 2.3052	* 2.2902	* 2.5001	* 2.5046	* 2.5474	* 2.5140	* 5.4036	*
14	* 1.9735	* 1.9803	* 1.9750	* 1.2731	* 0.9539	* 0.8156	*	*
	* 2.2114	* 2.2193	* 2.3162	* 3.5185	* 4.6203	* 5.4053	*	*
15	* 0.9013	* 0.9158	* 0.8568	* 0.5823	* F-SUB-Q			
	* 4.3683	* 4.3373	* 4.7037	* 7.2279	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5188	* 1.4454	* 1.4962	* 1.4439	* 1.6789	* 1.8895	* 1.9792	* 0.8805
	* 3.0167	* 3.1463	* 2.9002	* 2.9242	* 2.4944	* 2.2066	* 2.1062	* 4.2634
9	* 1.4454	* 1.6248	* 1.6321	* 1.6412	* 1.7215	* 1.9214	* 1.9856	* 0.8977
	* 3.1463	* 2.7712	* 2.6903	* 2.6632	* 2.5225	* 2.1922	* 2.1146	* 4.2271
10	* 1.4962	* 1.6261	* 1.5041	* 1.5973	* 1.8369	* 1.8394	* 1.9823	* 0.8379
	* 2.9002	* 2.7001	* 2.9323	* 2.8579	* 2.4467	* 2.3967	* 2.2072	* 4.5994
11	* 1.4439	* 1.6398	* 1.5960	* 1.7862	* 1.7752	* 1.9435	* 1.2515	* 0.5813
	* 2.9242	* 2.6655	* 2.8609	* 2.6028	* 2.6284	* 2.4043	* 3.4268	* 7.0433
12	* 1.6789	* 1.7213	* 1.8365	* 1.7735	* 1.9077	* 1.9268	* 0.9393	*
	* 2.4944	* 2.5224	* 2.4462	* 2.6310	* 2.4952	* 2.4412	* 4.4857	*
13	* 1.8895	* 1.9223	* 1.8417	* 1.9431	* 1.9268	* 1.9732	* 0.8042	*
	* 2.2066	* 2.1912	* 2.3937	* 2.4048	* 2.4413	* 2.3972	* 5.2338	*
14	* 1.9792	* 1.9862	* 1.9830	* 1.2515	* 0.9379	* 0.8039	*	*
	* 2.1062	* 2.1140	* 2.2064	* 3.4274	* 4.4893	* 5.2355	*	*
15	* 0.8805	* 0.8985	* 0.8377	* 0.5667	* F-SUB-Q			
	* 4.2634	* 4.2244	* 4.6005	* 7.1080	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4905	* 1.4172	* 1.4708	* 1.4159	* 1.6539	* 1.8624	* 1.9558	* 0.8615
	* 2.7593	* 2.8815	* 2.6811	* 2.7251	* 2.3401	* 2.0832	* 1.9822	* 4.0125
9	* 1.4172	* 1.5977	* 1.6016	* 1.6169	* 1.6922	* 1.8952	* 1.9624	* 0.8793
	* 2.8815	* 2.5563	* 2.4969	* 2.4762	* 2.3690	* 2.0675	* 1.9890	* 3.9724
10	* 1.4708	* 1.5954	* 1.4753	* 1.5713	* 1.8163	* 1.8141	* 1.9608	* 0.8209
	* 2.6811	* 2.5062	* 2.7211	* 2.6275	* 2.2878	* 2.2514	* 2.0679	* 4.3128
11	* 1.4159	* 1.6154	* 1.5700	* 1.7660	* 1.7517	* 1.9246	* 1.2301	* 0.5693
	* 2.7251	* 2.4785	* 2.6297	* 2.3670	* 2.3927	* 2.1823	* 3.1385	* 6.5626
12	* 1.6539	* 1.6920	* 1.8159	* 1.7499	* 1.8943	* 1.9113	* 0.9237	*
	* 2.3401	* 2.3689	* 2.2874	* 2.3951	* 2.2677	* 2.2175	* 4.1108	*
13	* 1.8624	* 1.8961	* 1.8166	* 1.9242	* 1.9113	* 1.9660	* 0.7927	*
	* 2.0832	* 2.0666	* 2.2485	* 2.1828	* 2.2176	* 2.1745	* 4.8000	*
14	* 1.9558	* 1.9630	* 1.9615	* 1.2301	* 0.9222	* 0.7925	*	*
	* 1.9822	* 1.9885	* 2.0671	* 3.1391	* 4.1143	* 4.8016	*	*
15	* 0.8615	* 0.8802	* 0.8206	* 0.5542	* F-SUB-Q			
	* 4.0125	* 3.9700	* 4.3143	* 6.6319	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4530	* 1.3806	* 1.4339	* 1.3797	* 1.6159	* 1.8216	* 1.9151	* 0.8433
	* 2.5420	* 2.6544	* 2.4347	* 2.4792	* 2.1268	* 1.8920	* 1.7987	* 3.6517
9	* 1.3806	* 1.5583	* 1.5614	* 1.5791	* 1.6524	* 1.8548	* 1.9219	* 0.8604
	* 2.6544	* 2.3161	* 2.2652	* 2.2473	* 2.1506	* 1.8757	* 1.8040	* 3.6134
10	* 1.4339	* 1.5553	* 1.4385	* 1.5351	* 1.7785	* 1.7750	* 1.9214	* 0.8049
	* 2.4347	* 2.2739	* 2.4678	* 2.4113	* 2.0722	* 2.0390	* 1.8707	* 3.9106
11	* 1.3797	* 1.5776	* 1.5337	* 1.7294	* 1.7141	* 1.8870	* 1.2087	* 0.5583
	* 2.4792	* 2.2492	* 2.4140	* 2.1824	* 2.2049	* 2.0102	* 2.8767	* 5.9385
12	* 1.6159	* 1.6523	* 1.7781	* 1.7123	* 1.8616	* 1.8761	* 0.9072	*
	* 2.1268	* 2.1505	* 2.0719	* 2.2064	* 2.0899	* 2.0479	* 3.7951	*
13	* 1.8216	* 1.8558	* 1.7776	* 1.8866	* 1.8759	* 1.9343	* 0.7801	*
	* 1.8920	* 1.8748	* 2.0362	* 2.0106	* 2.0480	* 2.0015	* 4.4265	*
14	* 1.9151	* 1.9224	* 1.9222	* 1.2086	* 0.9057	* 0.7799	*	*
	* 1.7987	* 1.8035	* 1.8700	* 2.8774	* 3.7985	* 4.4280	*	*
15	* 0.8433	* 0.8612	* 0.8046	* 0.5431	* F-SUB-Q			
	* 3.6517	* 3.6112	* 3.9121	* 6.0054	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4050	* 1.3347	* 1.3831	* 1.3343	* 1.5612	* 1.7653	* 1.8538	* 0.8270 *
	* 2.5414	* 2.6547	* 2.4343	* 2.4771	* 2.1305	* 1.8900	* 1.7991	* 3.6191 *
9	* 1.3347	* 1.5039	* 1.5096	* 1.5249	* 1.6010	* 1.7984	* 1.8607	* 0.8411 *
	* 2.6547	* 2.3086	* 2.2569	* 2.2440	* 2.1416	* 1.8713	* 1.8031	* 3.5853 *
10	* 1.3831	* 1.5036	* 1.3920	* 1.4933	* 1.7210	* 1.7208	* 1.8616	* 0.7909 *
	* 2.4343	* 2.2656	* 2.4571	* 2.3943	* 2.0676	* 2.0291	* 1.8637	* 3.8552 *
11	* 1.3343	* 1.5234	* 1.4922	* 1.6728	* 1.6689	* 1.8288	* 1.1886	* 0.5484 *
	* 2.4771	* 2.2464	* 2.3967	* 2.1849	* 2.1870	* 2.0112	* 2.8374	* 5.8394 *
12	* 1.5612	* 1.6008	* 1.7206	* 1.6679	* 1.8099	* 1.8193	* 0.8929 *	
	* 2.1305	* 2.1424	* 2.0675	* 2.1885	* 2.0898	* 2.0502	* 3.7469 *	
13	* 1.7653	* 1.7994	* 1.7231	* 1.8284	* 1.8191	* 1.8787	* 0.7698 *	
	* 1.8900	* 1.8704	* 2.0265	* 2.0117	* 2.0503	* 2.0070	* 4.3754 *	
14	* 1.8538	* 1.8613	* 1.8623	* 1.1885	* 0.8914	* 0.7695 *		
	* 1.7991	* 1.8026	* 1.8631	* 2.8381	* 3.7505	* 4.3771 *		
15	* 0.8270	* 0.8419	* 0.7905	* 0.5351	* F-SUB-Q			
	* 3.6191	* 3.5832	* 3.8569	* 5.8874	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3799	* 1.3096	* 1.3674	* 1.3088	* 1.5443	* 1.7404	* 1.8376	* 0.7964 *
	* 2.3262	* 2.4277	* 2.2189	* 2.2796	* 1.9483	* 1.7348	* 1.6430	* 3.4053 *
9	* 1.3096	* 1.4865	* 1.4835	* 1.5085	* 1.5708	* 1.7738	* 1.8440	* 0.8137 *
	* 2.4277	* 2.0960	* 2.0652	* 2.0445	* 1.9672	* 1.7155	* 1.6460	* 3.3608 *
10	* 1.3674	* 1.4774	* 1.3657	* 1.4595	* 1.7039	* 1.6946	* 1.8439	* 0.7610 *
	* 2.2189	* 2.0736	* 2.2510	* 2.1974	* 1.8814	* 1.8559	* 1.6961	* 3.6257 *
11	* 1.3088	* 1.5070	* 1.4581	* 1.6558	* 1.6346	* 1.8100	* 1.1474	* 0.5271 *
	* 2.2796	* 2.0464	* 2.2000	* 1.9961	* 2.0180	* 1.8345	* 2.6306	* 5.4742 *
12	* 1.5443	* 1.5707	* 1.7035	* 1.6328	* 1.7882	* 1.8015	* 0.8594 *	
	* 1.9483	* 1.9675	* 1.8811	* 2.0195	* 1.8992	* 1.8672	* 3.5262 *	
13	* 1.7404	* 1.7747	* 1.6972	* 1.8096	* 1.8013	* 1.8656	* 0.7399 *	
	* 1.7348	* 1.7146	* 1.8533	* 1.8349	* 1.8674	* 1.8216	* 4.1113 *	
14	* 1.8376	* 1.8446	* 1.8446	* 1.1472	* 0.8579	* 0.7396 *		
	* 1.6430	* 1.6456	* 1.6955	* 2.6312	* 3.5296	* 4.1128 *		
15	* 0.7964	* 0.8145	* 0.7607	* 0.5118	* F-SUB-Q			
	* 3.4053	* 3.3589	* 3.6273	* 5.5471	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3409	* 1.2720	* 1.3294	* 1.2702	* 1.5005	* 1.6913	* 1.7865	* 0.7710
	* 2.1458	* 2.2534	* 2.0772	* 2.1440	* 1.8342	* 1.6341	* 1.5474	* 3.2301
9	* 1.2720	* 1.4459	* 1.4418	* 1.4654	* 1.5241	* 1.7240	* 1.7927	* 0.7879
	* 2.2534	* 1.9502	* 1.9302	* 1.9147	* 1.8461	* 1.6139	* 1.5490	* 3.1838
10	* 1.3294	* 1.4357	* 1.3257	* 1.4159	* 1.6552	* 1.6459	* 1.7920	* 0.7369
	* 2.0772	* 1.9381	* 2.1029	* 2.0554	* 1.7589	* 1.7386	* 1.5895	* 3.4267
11	* 1.2702	* 1.4640	* 1.4145	* 1.6084	* 1.5863	* 1.7583	* 1.1133	* 0.5103
	* 2.1440	* 1.9164	* 2.0578	* 1.8531	* 1.8792	* 1.7012	* 2.4648	* 5.1455
12	* 1.5005	* 1.5239	* 1.6548	* 1.5846	* 1.7388	* 1.7502	* 0.8324	*
	* 1.8342	* 1.8464	* 1.7583	* 1.8812	* 1.7631	* 1.7322	* 3.2806	*
13	* 1.6913	* 1.7250	* 1.6484	* 1.7579	* 1.7501	* 1.8134	* 0.7163	*
	* 1.6341	* 1.6130	* 1.7360	* 1.7016	* 1.7323	* 1.6969	* 3.8491	*
14	* 1.7865	* 1.7932	* 1.7927	* 1.1131	* 0.8310	* 0.7161	*	*
	* 1.5474	* 1.5486	* 1.5890	* 2.4654	* 3.2839	* 3.8506	*	*
15	* 0.7710	* 0.7887	* 0.7365	* 0.4952	F-SUB-Q			
	* 3.2301	* 3.1820	* 3.4284	* 5.2171	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2869	* 1.2210	* 1.2667	* 1.2183	* 1.4260	* 1.6146	* 1.6948	* 0.7503
	* 2.0643	* 2.1447	* 2.0062	* 2.0654	* 1.7872	* 1.5860	* 1.5115	* 3.0887
9	* 1.2210	* 1.3787	* 1.3834	* 1.3922	* 1.4592	* 1.6457	* 1.7008	* 0.7632
	* 2.1447	* 1.8696	* 1.8485	* 1.8540	* 1.7763	* 1.5647	* 1.5118	* 3.0528
10	* 1.2667	* 1.3776	* 1.2721	* 1.3599	* 1.5701	* 1.5714	* 1.6992	* 0.7176
	* 2.0062	* 1.8560	* 2.0108	* 1.9551	* 1.7011	* 1.6761	* 1.5445	* 3.2600
11	* 1.2183	* 1.3908	* 1.3589	* 1.5268	* 1.5224	* 1.6683	* 1.0851	* 0.4978
	* 2.0654	* 1.8560	* 1.9570	* 1.7974	* 1.7890	* 1.6533	* 2.3055	* 4.8569
12	* 1.4260	* 1.4590	* 1.5697	* 1.5214	* 1.6577	* 1.6602	* 0.8119	*
	* 1.7872	* 1.7766	* 1.7004	* 1.7903	* 1.6904	* 1.6757	* 3.0987	*
13	* 1.6146	* 1.6465	* 1.5736	* 1.6679	* 1.6601	* 1.7149	* 0.6986	*
	* 1.5860	* 1.5639	* 1.6738	* 1.6537	* 1.6758	* 1.6391	* 3.6171	*
14	* 1.6948	* 1.7013	* 1.6999	* 1.0849	* 0.8105	* 0.6983	*	*
	* 1.5115	* 1.5114	* 1.5440	* 2.3062	* 3.1015	* 3.6186	*	*
15	* 0.7503	* 0.7640	* 0.7173	* 0.4852	F-SUB-Q			
	* 3.0887	* 3.0509	* 3.2618	* 4.9024	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2537	* 1.1898	* 1.2368	* 1.1908	* 1.3828	* 1.5623	* 1.6355	* 0.7141 *
	* 1.9334	* 2.0251	* 1.9112	* 1.9758	* 1.7276	* 1.5372	* 1.4693	* 3.0499 *
9	* 1.1898	* 1.3439	* 1.3507	* 1.3527	* 1.4127	* 1.5908	* 1.6404	* 0.7291 *
	* 2.0251	* 1.7758	* 1.7618	* 1.7771	* 1.7111	* 1.5163	* 1.4694	* 3.0045 *
10	* 1.2368	* 1.3451	* 1.2398	* 1.3126	* 1.5167	* 1.5171	* 1.6336	* 0.6802 *
	* 1.9112	* 1.7690	* 1.9186	* 1.8721	* 1.6361	* 1.6178	* 1.4993	* 3.2267 *
11	* 1.1908	* 1.3513	* 1.3114	* 1.4781	* 1.4653	* 1.6069	* 1.0310	* 0.4718 *
	* 1.9758	* 1.7789	* 1.8739	* 1.7104	* 1.7235	* 1.5784	* 2.2521	* 4.7808 *
12	* 1.3828	* 1.4126	* 1.5163	* 1.4637	* 1.6006	* 1.5993	* 0.7697 *	
	* 1.7276	* 1.7113	* 1.6355	* 1.7254	* 1.6380	* 1.6199	* 3.0339 *	
13	* 1.5623	* 1.5917	* 1.5193	* 1.6065	* 1.5991	* 1.6444	* 0.6580 *	
	* 1.5372	* 1.5156	* 1.6156	* 1.5788	* 1.6200	* 1.5982	* 3.5999 *	
14	* 1.6355	* 1.6408	* 1.6341	* 1.0308	* 0.7683	* 0.6577 *		
	* 1.4693	* 1.4690	* 1.4988	* 2.2527	* 3.0370	* 3.6013 *		
15	* 0.7141	* 0.7298	* 0.6798	* 0.4579	* F-SUB-Q			
	* 3.0499	* 3.0026	* 3.2286	* 4.8463	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1719	* 1.1261	* 1.1817	* 1.1491	* 1.2871	* 1.4501	* 1.5104	* 0.6797 *
	* 1.9416	* 1.9978	* 1.7639	* 1.9378	* 1.6994	* 1.5741	* 1.5122	* 3.0532 *
9	* 1.1261	* 1.2583	* 1.2752	* 1.2702	* 1.3232	* 1.4738	* 1.5129	* 0.6919 *
	* 1.9978	* 1.7649	* 1.7635	* 1.7245	* 1.7292	* 1.5545	* 1.5135	* 3.0172 *
10	* 1.1817	* 1.2701	* 1.1628	* 1.2392	* 1.4053	* 1.4003	* 1.4942	* 0.6391 *
	* 1.7639	* 1.7702	* 1.9336	* 1.8647	* 1.6704	* 1.6587	* 1.5523	* 3.2681 *
11	* 1.1491	* 1.2689	* 1.2380	* 1.3753	* 1.3696	* 1.4836	* 0.9637	* 0.4395 *
	* 1.9378	* 1.7263	* 1.8665	* 1.6834	* 1.7317	* 1.6043	* 2.2744	* 4.8670 *
12	* 1.2871	* 1.3230	* 1.4050	* 1.3681	* 1.4897	* 1.4808	* 0.7276 *	
	* 1.6994	* 1.7295	* 1.6699	* 1.7336	* 1.6364	* 1.6302	* 3.0086 *	
13	* 1.4501	* 1.4745	* 1.4021	* 1.4832	* 1.4806	* 1.4965	* 0.6119 *	
	* 1.5741	* 1.5538	* 1.6566	* 1.6047	* 1.6303	* 1.6388	* 3.6215 *	
14	* 1.5104	* 1.5133	* 1.4946	* 0.9635	* 0.7263	* 0.6117 *		
	* 1.5122	* 1.5132	* 1.5519	* 2.2752	* 3.0115	* 3.6229 *		
15	* 0.6797	* 0.6925	* 0.6387	* 0.4262	* F-SUB-Q			
	* 3.0532	* 3.0156	* 3.2702	* 4.9376	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9612	* 0.9839	* 1.2105	* 1.0109	* 1.2750	* 1.1859	* 1.3638	* 0.5925 *
	* 2.2528	* 2.1799	* 1.7639	* 2.1290	* 1.6994	* 1.8510	* 1.6095	* 3.3821 *
9	* 0.9839	* 1.2150	* 1.0803	* 1.2541	* 1.0879	* 1.2034	* 1.3535	* 0.5996 *
	* 2.1799	* 1.7649	* 1.9847	* 1.7245	* 2.0075	* 1.8290	* 1.6262	* 3.3606 *
10	* 1.2105	* 1.0784	* 0.9545	* 1.0660	* 1.3318	* 1.1564	* 1.2648	* 0.5428 *
	* 1.7639	* 1.9871	* 2.2599	* 2.0889	* 1.6729	* 1.9447	* 1.7616	* 3.7108 *
11	* 1.0109	* 1.2528	* 1.0652	* 1.3375	* 1.1408	* 1.3184	* 0.8149	* 0.3657 *
	* 2.1290	* 1.7263	* 2.0905	* 1.6834	* 1.9795	* 1.7244	* 2.5756	* 5.6307 *
12	* 1.2750	* 1.0877	* 1.3315	* 1.1400	* 1.2370	* 1.3470	* 0.6389	*
	* 1.6994	* 2.0091	* 1.6733	* 1.9809	* 1.8779	* 1.7173	* 3.2827	*
13	* 1.1859	* 1.2039	* 1.1579	* 1.3182	* 1.3467	* 1.2094	* 0.5069	*
	* 1.8509	* 1.8283	* 1.9423	* 1.7247	* 1.7176	* 1.9291	* 4.1778	*
14	* 1.3638	* 1.3539	* 1.2649	* 0.8147	* 0.6378	* 0.5067	*	
	* 1.6095	* 1.6258	* 1.7615	* 2.5766	* 3.2854	* 4.1795	*	
15	* 0.5925	* 0.6001	* 0.5425	* 0.3549	F-SUB-Q			
	* 3.3821	* 3.3590	* 3.7133	* 5.7090	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3810	* 0.4134	* 0.4957	* 0.4319	* 0.5139	* 0.4533	* 0.4851	* 0.2466 *
	* 5.4523	* 5.0010	* 4.1569	* 4.8073	* 4.0582	* 4.6694	* 4.3663	* 7.8724 *
9	* 0.4134	* 0.4857	* 0.4342	* 0.5050	* 0.4389	* 0.4568	* 0.4801	* 0.2458 *
	* 5.0010	* 4.2531	* 4.7712	* 4.1148	* 4.7996	* 4.6479	* 4.4230	* 7.9384 *
10	* 0.4957	* 0.4334	* 0.3996	* 0.4436	* 0.5262	* 0.4474	* 0.4422	* 0.2241 *
	* 4.1569	* 4.7801	* 5.2261	* 4.8326	* 4.0556	* 4.8168	* 4.8581	* 8.7001 *
11	* 0.4319	* 0.5044	* 0.4433	* 0.5207	* 0.4566	* 0.4987	* 0.3329	* 0.1516 *
	* 4.8073	* 4.1192	* 4.8358	* 4.1289	* 4.7598	* 4.3837	* 6.0740	*13.1483 *
12	* 0.5139	* 0.4386	* 0.5260	* 0.4562	* 0.4635	* 0.4811	* 0.2653	*
	* 4.0582	* 4.8030	* 4.0570	* 4.7635	* 4.8087	* 4.6309	* 7.6416	*
13	* 0.4533	* 0.4569	* 0.4477	* 0.4986	* 0.4810	* 0.4223	* 0.2067	*
	* 4.6694	* 4.6465	* 4.8135	* 4.3846	* 4.6319	* 5.3180	* 9.8855	*
14	* 0.4851	* 0.4802	* 0.4422	* 0.3328	* 0.2650	* 0.2066	*	
	* 4.3663	* 4.4221	* 4.8582	* 6.0768	* 7.6451	* 9.8899	*	
15	* 0.2466	* 0.2460	* 0.2239	* 0.1485	* F-SUB-Q			
	* 7.8724	* 7.9345	* 8.7059	*13.2061	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3386	* 0.4448	* 0.5539	* 0.4881	* 0.5670	* 0.4879	* 0.5053	* 0.2706 *
	* 5.6025	* 5.3665	* 4.2896	* 4.8482	* 4.1749	* 4.8951	* 4.7841	* 8.1022 *
9	* 0.4448	* 0.5233	* 0.4942	* 0.5597	* 0.4850	* 0.4775	* 0.4957	* 0.2659 *
	* 5.3665	* 4.5869	* 4.8218	* 4.2354	* 4.8810	* 4.9923	* 4.8735	* 8.2671 *
10	* 0.5539	* 0.4937	* 0.4448	* 0.4620	* 0.5315	* 0.4505	* 0.4410	* 0.2336 *
	* 4.2896	* 4.8250	* 5.4483	* 5.1408	* 4.4439	* 5.2413	* 5.3608	* 9.1771 *
11	* 0.4881	* 0.5595	* 0.4617	* 0.4953	* 0.4314	* 0.4373	* 0.3083	* 0.1531 *
	* 4.8482	* 4.2369	* 5.1431	* 4.6521	* 5.2761	* 4.9868	* 7.0387	*13.9092 *
12	* 0.5670	* 0.4849	* 0.5314	* 0.4311	* 0.3269	* 0.3297	* 0.2177	*
	* 4.1749	* 4.8817	* 4.4450	* 5.2786	* 5.2439	* 5.1319	* 8.1719	*
13	* 0.4879	* 0.4775	* 0.4507	* 0.4373	* 0.3297	* 0.2642	* 0.1499	*
	* 4.8951	* 4.9920	* 5.2391	* 4.9867	* 5.1311	* 5.7321	*10.3877	*
14	* 0.5053	* 0.4958	* 0.4412	* 0.3084	* 0.2176	* 0.1499	*	
	* 4.7841	* 4.8723	* 5.3595	* 7.0375	* 8.1672	*10.3887	*	
15	* 0.2706	* 0.2663	* 0.2336	* 0.1510	* F-SUB-Q			
	* 8.1022	* 8.2592	* 9.1759	*13.8956	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8249	* 1.0339	* 1.2967	* 1.1229	* 1.3277	* 1.2087	* 1.3384	* 0.6581 *
	* 2.4509	* 2.3922	* 1.8977	* 2.1892	* 1.8516	* 2.0445	* 1.8696	* 3.4522 *
9	* 1.0339	* 1.2494	* 1.1925	* 1.3168	* 1.1628	* 1.2028	* 1.3164	* 0.6482 *
	* 2.3922	* 1.9816	* 2.0692	* 1.8641	* 2.1131	* 2.0583	* 1.8840	* 3.4783 *
10	* 1.2967	* 1.1915	* 1.0390	* 1.0806	* 1.2718	* 1.1220	* 1.1852	* 0.5712 *
	* 1.8977	* 2.0708	* 2.4025	* 2.2735	* 1.9238	* 2.1843	* 2.0667	* 3.8784 *
11	* 1.1229	* 1.3164	* 1.0801	* 1.2053	* 1.0351	* 1.0970	* 0.7529	* 0.3754 *
	* 2.1892	* 1.8647	* 2.2745	* 1.9665	* 2.2645	* 2.0571	* 2.9862	* 5.8851 *
12	* 1.3277	* 1.1627	* 1.2715	* 1.0345	* 0.8008	* 0.8781	* 0.5293	*
	* 1.8516	* 2.1133	* 1.9243	* 2.2659	* 2.1454	* 1.9954	* 3.4853	*
13	* 1.2087	* 1.2030	* 1.1226	* 1.0971	* 0.8780	* 0.7318	* 0.3745	*
	* 2.0445	* 2.0580	* 2.1831	* 2.0571	* 1.9953	* 2.2280	* 4.3183	*
14	* 1.3384	* 1.3168	* 1.1855	* 0.7532	* 0.5291	* 0.3744	*	
	* 1.8696	* 1.8835	* 2.0661	* 2.9855	* 3.4843	* 4.3187	*	
15	* 0.6581	* 0.6487	* 0.5714	* 0.3705	* F-SUB-Q			
	* 3.4522	* 3.4771	* 3.8776	* 5.8725	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0137	* 1.2253	* 1.3471	* 1.3314	* 1.4110	* 1.4920	* 1.5208	* 0.7802
	* 2.0832	* 2.0797	* 1.8807	* 1.9007	* 1.7916	* 1.7008	* 1.6689	* 2.9478
9	* 1.2253	* 1.3646	* 1.4104	* 1.4164	* 1.4024	* 1.4891	* 1.5047	* 0.7777
	* 2.0797	* 1.8634	* 1.8013	* 1.7833	* 1.8040	* 1.7023	* 1.6839	* 2.9565
10	* 1.3471	* 1.4075	* 1.2786	* 1.3006	* 1.3962	* 1.3870	* 1.4317	* 0.7010
	* 1.8807	* 1.8050	* 1.9886	* 1.9425	* 1.8022	* 1.8186	* 1.7577	* 3.2422
11	* 1.3314	* 1.4159	* 1.2999	* 1.3193	* 1.2460	* 1.2849	* 0.9290	* 0.4667
	* 1.9007	* 1.7840	* 1.9434	* 1.8405	* 1.9044	* 1.8102	* 2.4939	* 4.8723
12	* 1.4110	* 1.4023	* 1.3962	* 1.2457	* 0.9913	* 1.0271	* 0.6373	*
	* 1.7916	* 1.8040	* 1.8022	* 1.9054	* 1.8042	* 1.8071	* 2.9972	*
13	* 1.4920	* 1.4894	* 1.3880	* 1.2851	* 1.0271	* 0.9394	* 0.4735	*
	* 1.7008	* 1.7019	* 1.8173	* 1.8103	* 1.8068	* 1.8394	* 3.5393	*
14	* 1.5208	* 1.5050	* 1.4323	* 0.9294	* 0.6369	* 0.4734	*	*
	* 1.6689	* 1.6835	* 1.7570	* 2.4932	* 2.9968	* 3.5397	*	*
15	* 0.7802	* 0.7784	* 0.7012	* 0.4627	* F-SUB-Q			
	* 2.9478	* 2.9553	* 3.2413	* 4.8409	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1204	* 1.3273	* 1.4878	* 1.4493	* 1.5782	* 1.6730	* 1.7293	* 0.8382
	* 1.9643	* 1.9938	* 1.7664	* 1.8095	* 1.6572	* 1.5634	* 1.5120	* 2.8261
9	* 1.3273	* 1.5301	* 1.5537	* 1.5783	* 1.5463	* 1.6709	* 1.7109	* 0.8409
	* 1.9938	* 1.7225	* 1.6922	* 1.6581	* 1.6910	* 1.5646	* 1.5269	* 2.8204
10	* 1.4878	* 1.5500	* 1.4090	* 1.4254	* 1.5837	* 1.5491	* 1.6383	* 0.7577
	* 1.7664	* 1.6961	* 1.8662	* 1.8344	* 1.6453	* 1.6840	* 1.5868	* 3.0997
11	* 1.4493	* 1.5777	* 1.4245	* 1.4879	* 1.3840	* 1.4691	* 1.0146	* 0.5052
	* 1.8095	* 1.6588	* 1.8356	* 1.6909	* 1.7720	* 1.6476	* 2.3700	* 4.6616
12	* 1.5782	* 1.5463	* 1.5838	* 1.3834	* 1.1091	* 1.1773	* 0.6927	*
	* 1.6572	* 1.6911	* 1.6452	* 1.7730	* 1.6644	* 1.6501	* 2.8811	*
13	* 1.6730	* 1.6713	* 1.5503	* 1.4693	* 1.1773	* 1.0963	* 0.5206	*
	* 1.5634	* 1.5642	* 1.6826	* 1.6476	* 1.6499	* 1.6555	* 3.3704	*
14	* 1.7293	* 1.7113	* 1.6390	* 1.0151	* 0.6921	* 0.5205	*	*
	* 1.5120	* 1.5265	* 1.5861	* 2.3692	* 2.8811	* 3.3708	*	*
15	* 0.8382	* 0.8417	* 0.7580	* 0.4998	* F-SUB-Q			
	* 2.8261	* 2.8192	* 3.0986	* 4.6420	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1739	* 1.3879	* 1.5667	* 1.5082	* 1.6706	* 1.7618	* 1.8399	* 0.8770
	* 1.9865	* 2.0016	* 1.7594	* 1.8214	* 1.6374	* 1.5486	* 1.4819	* 2.8186
9	* 1.3879	* 1.6135	* 1.6184	* 1.6669	* 1.6186	* 1.7601	* 1.8202	* 0.8814
	* 2.0016	* 1.7132	* 1.7022	* 1.6450	* 1.6897	* 1.5494	* 1.4971	* 2.8097
10	* 1.5667	* 1.6143	* 1.4643	* 1.4926	* 1.6849	* 1.6268	* 1.7478	* 0.7967
	* 1.7594	* 1.7066	* 1.8823	* 1.8359	* 1.6195	* 1.6752	* 1.5540	* 3.0817
11	* 1.5082	* 1.6662	* 1.4916	* 1.5808	* 1.4660	* 1.5703	* 1.0711	* 0.5296
	* 1.8214	* 1.6457	* 1.8371	* 1.6688	* 1.7659	* 1.6202	* 2.3530	* 4.6595
12	* 1.6706	* 1.6185	* 1.6850	* 1.4654	* 1.1742	* 1.2689	* 0.7334	*
	* 1.6374	* 1.6898	* 1.6194	* 1.7670	* 1.6451	* 1.6218	* 2.8749	*
13	* 1.7618	* 1.7606	* 1.6282	* 1.5705	* 1.2688	* 1.1906	* 0.5556	*
	* 1.5486	* 1.5489	* 1.6735	* 1.6202	* 1.6216	* 1.6175	* 3.3514	*
14	* 1.8399	* 1.8207	* 1.7486	* 1.0716	* 0.7328	* 0.5555	*	*
	* 1.4819	* 1.4967	* 1.5533	* 2.3522	* 2.8752	* 3.3518	*	*
15	* 0.8770	* 0.8822	* 0.7969	* 0.5229	* F-SUB-Q			
	* 2.8186	* 2.8082	* 3.0807	* 4.6479	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2081	* 1.4287	* 1.6115	* 1.5431	* 1.7216	* 1.8123	* 1.9027	* 0.9053
	* 2.0522	* 2.0691	* 1.8190	* 1.8903	* 1.6838	* 1.5913	* 1.5144	* 2.8892
9	* 1.4287	* 1.6586	* 1.6543	* 1.7170	* 1.6616	* 1.8126	* 1.8826	* 0.9092
	* 2.0691	* 1.7731	* 1.7704	* 1.6964	* 1.7467	* 1.5909	* 1.5303	* 2.8819
10	* 1.6115	* 1.6499	* 1.4948	* 1.5400	* 1.7439	* 1.6747	* 1.8118	* 0.8255
	* 1.8190	* 1.7752	* 1.9613	* 1.8941	* 1.6620	* 1.7236	* 1.5877	* 3.1505
11	* 1.5431	* 1.7162	* 1.5390	* 1.6363	* 1.5230	* 1.6340	* 1.1140	* 0.5482
	* 1.8903	* 1.6973	* 1.8953	* 1.7085	* 1.8151	* 1.6556	* 2.4048	* 4.7815
12	* 1.7216	* 1.6615	* 1.7440	* 1.5224	* 1.2201	* 1.3322	* 0.7676	*
	* 1.6838	* 1.7468	* 1.6619	* 1.8163	* 1.6876	* 1.6614	* 2.9493	*
13	* 1.8123	* 1.8133	* 1.6764	* 1.6342	* 1.3320	* 1.2595	* 0.5866	*
	* 1.5913	* 1.5903	* 1.7217	* 1.6557	* 1.6612	* 1.6512	* 3.4307	*
14	* 1.9027	* 1.8831	* 1.8127	* 1.1144	* 0.7669	* 0.5865	*	*
	* 1.5144	* 1.5299	* 1.5869	* 2.4043	* 2.9499	* 3.4312	*	*
15	* 0.9053	* 0.9100	* 0.8257	* 0.5412	* F-SUB-Q			
	* 2.8892	* 2.8803	* 3.1496	* 4.7700	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2409	* 1.4570	* 1.6588	* 1.5783	* 1.7725	* 1.8620	* 1.9665	* 0.9199 *
	* 2.1232	* 2.1692	* 1.9084	* 1.9916	* 1.7576	* 1.6601	* 1.5699	* 3.0450 *
9	* 1.4570	* 1.7089	* 1.6931	* 1.7698	* 1.7037	* 1.8645	* 1.9461	* 0.9260 *
	* 2.1692	* 1.8610	* 1.8679	* 1.7753	* 1.8351	* 1.6588	* 1.5870	* 3.0338 *
10	* 1.6588	* 1.6883	* 1.5278	* 1.5745	* 1.8057	* 1.7246	* 1.8780	* 0.8404 *
	* 1.9084	* 1.8732	* 2.0735	* 1.9992	* 1.7320	* 1.8006	* 1.6467	* 3.3235 *
11	* 1.5783	* 1.7684	* 1.5733	* 1.6965	* 1.5716	* 1.7046	* 1.1421	* 0.5586 *
	* 1.9916	* 1.7762	* 2.0007	* 1.7571	* 1.8742	* 1.7000	* 2.4872	* 5.0594 *
12	* 1.7725	* 1.7036	* 1.8058	* 1.5708	* 1.2685	* 1.4056	* 0.7938	*
	* 1.7576	* 1.8352	* 1.7318	* 1.8756	* 1.7479	* 1.7138	* 3.0952	*
13	* 1.8620	* 1.8652	* 1.7265	* 1.7048	* 1.4053	* 1.3427	* 0.6122	*
	* 1.6601	* 1.6581	* 1.7986	* 1.7001	* 1.7137	* 1.7046	* 3.6154	*
14	* 1.9665	* 1.9467	* 1.8789	* 1.1425	* 0.7929	* 0.6121	*	
	* 1.5699	* 1.5866	* 1.6459	* 2.4867	* 3.0961	* 3.6160	*	
15	* 0.9199	* 0.9269	* 0.8406	* 0.5496	* F-SUB-Q			
	* 3.0450	* 3.0322	* 3.3228	* 5.0644	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2782	* 1.4849	* 1.6897	* 1.6009	* 1.8024	* 1.8923	* 2.0053	* 0.9312 *
	* 2.2609	* 2.3136	* 2.0570	* 2.1499	* 1.8850	* 1.7762	* 1.6731	* 3.2678 *
9	* 1.4849	* 1.7459	* 1.7191	* 1.8045	* 1.7325	* 1.8975	* 1.9857	* 0.9383 *
	* 2.3136	* 1.9891	* 2.0195	* 1.9095	* 1.9754	* 1.7740	* 1.6918	* 3.2552 *
10	* 1.6897	* 1.7140	* 1.5509	* 1.6048	* 1.8501	* 1.7602	* 1.9234	* 0.8535 *
	* 2.0570	* 2.0255	* 2.2453	* 2.1511	* 1.8499	* 1.9294	* 1.7558	* 3.5656 *
11	* 1.6009	* 1.8029	* 1.6035	* 1.7446	* 1.6197	* 1.7664	* 1.1717	* 0.5691 *
	* 2.1499	* 1.9106	* 2.1525	* 1.8472	* 1.9743	* 1.7812	* 2.6273	* 5.4263 *
12	* 1.8024	* 1.7324	* 1.8502	* 1.6189	* 1.3240	* 1.4840	* 0.8267	*
	* 1.8850	* 1.9756	* 1.8500	* 1.9758	* 1.8428	* 1.7981	* 3.2631	*
13	* 1.8923	* 1.8983	* 1.7622	* 1.7666	* 1.4837	* 1.4361	* 0.6464	*
	* 1.7762	* 1.7733	* 1.9271	* 1.7813	* 1.7980	* 1.7953	* 3.8383	*
14	* 2.0053	* 1.9862	* 1.9243	* 1.1721	* 0.8257	* 0.6463	*	
	* 1.6731	* 1.6913	* 1.7550	* 2.6269	* 3.2642	* 3.8390	*	
15	* 0.9312	* 0.9391	* 0.8536	* 0.5591	* F-SUB-Q			
	* 3.2678	* 3.2534	* 3.5650	* 5.4396	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3638	* 1.5169	* 1.7228	* 1.6223	* 1.8312	* 1.9194	* 2.0415	* 0.9372
	* 2.4582	* 2.4794	* 2.2269	* 2.3233	* 2.0235	* 1.9085	* 1.7909	* 3.5176
9	* 1.5169	* 1.7908	* 1.7468	* 1.8401	* 1.7612	* 1.9276	* 2.0231	* 0.9462
	* 2.4794	* 2.1302	* 2.1935	* 2.0571	* 2.1353	* 1.9061	* 1.8118	* 3.5021
10	* 1.7228	* 1.7415	* 1.5759	* 1.6360	* 1.8982	* 1.7960	* 1.9693	* 0.8621
	* 2.2269	* 2.2001	* 2.4432	* 2.2989	* 1.9681	* 2.0798	* 1.8830	* 3.8415
11	* 1.6223	* 1.8385	* 1.6346	* 1.8074	* 1.6756	* 1.8430	* 1.2005	* 0.5780
	* 2.3233	* 2.0583	* 2.3004	* 1.9856	* 2.1271	* 1.9083	* 2.8155	* 5.8237
12	* 1.8312	* 1.7610	* 1.8983	* 1.6747	* 1.4358	* 1.6102	* 0.8667	*
	* 2.0235	* 2.1354	* 1.9682	* 2.1288	* 1.9780	* 1.9250	* 3.5228	*
13	* 1.9194	* 1.9284	* 1.7981	* 1.8431	* 1.6100	* 1.5740	* 0.6892	*
	* 1.9085	* 1.9053	* 2.0774	* 1.9085	* 1.9249	* 1.9124	* 4.1335	*
14	* 2.0415	* 2.0236	* 1.9702	* 1.2008	* 0.8656	* 0.6890	*	*
	* 1.7909	* 1.8113	* 1.8821	* 2.8152	* 3.5243	* 4.1343	*	*
15	* 0.9372	* 0.9470	* 0.8621	* 0.5671	* F-SUB-Q			
	* 3.5176	* 3.5004	* 3.8412	* 5.8462	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4700	* 1.5484	* 1.7156	* 1.6151	* 1.8154	* 1.9082	* 2.0260	* 0.9464
	* 2.7182	* 2.7547	* 2.4426	* 2.5304	* 2.2041	* 2.0763	* 1.9528	* 3.7667
9	* 1.5484	* 1.7957	* 1.7427	* 1.8312	* 1.7606	* 1.9196	* 2.0103	* 0.9526
	* 2.7547	* 2.3797	* 2.4028	* 2.2471	* 2.3185	* 2.0710	* 1.9731	* 3.7539
10	* 1.7156	* 1.7373	* 1.5748	* 1.6418	* 1.9015	* 1.7994	* 1.9677	* 0.8758
	* 2.4426	* 2.4101	* 2.6792	* 2.5296	* 2.1795	* 2.2547	* 2.0437	* 4.0786
11	* 1.6151	* 1.8295	* 1.6403	* 1.8426	* 1.7283	* 1.8846	* 1.2385	* 0.5916
	* 2.5304	* 2.2484	* 2.5315	* 2.1983	* 2.3447	* 2.1093	* 3.0424	* 6.2072
12	* 1.8154	* 1.7604	* 1.9015	* 1.7274	* 1.5903	* 1.7512	* 0.9195	*
	* 2.2041	* 2.3187	* 2.1797	* 2.3466	* 2.2020	* 2.1470	* 3.8337	*
13	* 1.9082	* 1.9204	* 1.8015	* 1.8846	* 1.7510	* 1.7065	* 0.7457	*
	* 2.0763	* 2.0701	* 2.2520	* 2.1096	* 2.1469	* 2.1290	* 4.4965	*
14	* 2.0260	* 2.0109	* 1.9686	* 1.2387	* 0.9183	* 0.7455	*	*
	* 1.9528	* 1.9725	* 2.0428	* 3.0423	* 3.8353	* 4.4976	*	*
15	* 0.9464	* 0.9534	* 0.8758	* 0.5817	* F-SUB-Q			
	* 3.7667	* 3.7520	* 4.0787	* 6.2168	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5790	* 1.5759	* 1.7493	* 1.6314	* 1.8421	* 1.9315	* 2.0624	* 0.9386
	* 2.9902	* 3.0409	* 2.6023	* 2.7105	* 2.3381	* 2.1958	* 2.0501	* 4.0370
9	* 1.5759	* 1.8414	* 1.7662	* 1.8655	* 1.7836	* 1.9460	* 2.0479	* 0.9493
	* 3.0409	* 2.5698	* 2.5706	* 2.3917	* 2.4824	* 2.1922	* 2.0748	* 4.0174
10	* 1.7493	* 1.7606	* 1.5954	* 1.6773	* 1.9510	* 1.8317	* 2.0146	* 0.8710
	* 2.6023	* 2.5788	* 2.8695	* 2.7331	* 2.3227	* 2.4018	* 2.1587	* 4.4014
11	* 1.6314	* 1.8637	* 1.6761	* 1.9155	* 1.7805	* 1.9749	* 1.2507	* 0.5913
	* 2.7105	* 2.3931	* 2.7356	* 2.4102	* 2.5823	* 2.3037	* 3.4044	* 6.7298
12	* 1.8421	* 1.7834	* 1.9508	* 1.7788	* 1.8098	* 1.9030	* 0.9467	*
	* 2.3381	* 2.4824	* 2.3226	* 2.5845	* 2.4093	* 2.3350	* 4.2755	*
13	* 1.9315	* 1.9468	* 1.8339	* 1.9746	* 1.9030	* 1.8623	* 0.7780	*
	* 2.1958	* 2.1913	* 2.3989	* 2.3039	* 2.3349	* 2.3205	* 5.0398	*
14	* 2.0624	* 2.0484	* 2.0154	* 1.2508	* 0.9454	* 0.7778	*	*
	* 2.0501	* 2.0742	* 2.1578	* 3.4044	* 4.2778	* 5.0410	*	*
15	* 0.9386	* 0.9501	* 0.8709	* 0.5788	* F-SUB-Q			
	* 4.0370	* 4.0155	* 4.4017	* 6.7713	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6026	* 1.5813	* 1.7466	* 1.6228	* 1.8346	* 1.9243	* 2.0591	* 0.9330
	* 3.0187	* 3.0534	* 2.7086	* 2.8439	* 2.4837	* 2.3689	* 2.2058	* 4.3486
9	* 1.5813	* 1.8444	* 1.7604	* 1.8630	* 1.7801	* 1.9415	* 2.0462	* 0.9444
	* 3.0534	* 2.6201	* 2.6912	* 2.5106	* 2.6479	* 2.3644	* 2.2327	* 4.3267
10	* 1.7466	* 1.7546	* 1.5906	* 1.6849	* 1.9686	* 1.8354	* 2.0212	* 0.8692
	* 2.7086	* 2.6999	* 2.9978	* 2.8740	* 2.4619	* 2.5948	* 2.3229	* 4.7348
11	* 1.6228	* 1.8611	* 1.6836	* 1.9454	* 1.8050	* 2.0137	* 1.2616	* 0.5927
	* 2.8439	* 2.5123	* 2.8762	* 2.4846	* 2.6819	* 2.4032	* 3.5630	* 7.2543
12	* 1.8346	* 1.7799	* 1.9684	* 1.8032	* 1.8832	* 1.9646	* 0.9670	*
	* 2.4837	* 2.6480	* 2.4621	* 2.6846	* 2.5600	* 2.4599	* 4.5357	*
13	* 1.9243	* 1.9423	* 1.8376	* 2.0134	* 1.9646	* 1.9388	* 0.8028	*
	* 2.3689	* 2.3634	* 2.5916	* 2.4036	* 2.4600	* 2.4854	* 5.4216	*
14	* 2.0591	* 2.0467	* 2.0220	* 1.2617	* 0.9657	* 0.8026	*	*
	* 2.2058	* 2.2321	* 2.3220	* 3.5632	* 4.5385	* 5.4230	*	*
15	* 0.9330	* 0.9452	* 0.8691	* 0.5794	* F-SUB-Q			
	* 4.3486	* 4.3246	* 4.7354	* 7.3089	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5820	* 1.5558	* 1.7084	* 1.5895	* 1.7941	* 1.8890	* 2.0189	* 0.9274 *
	* 3.0605	* 3.0834	* 2.6534	* 2.7803	* 2.4293	* 2.3083	* 2.1583	* 4.2451 *
9	* 1.5558	* 1.8065	* 1.7264	* 1.8242	* 1.7506	* 1.9082	* 2.0081	* 0.9362 *
	* 3.0834	* 2.6119	* 2.6293	* 2.4587	* 2.5836	* 2.3066	* 2.1880	* 4.2406 *
10	* 1.7084	* 1.7206	* 1.5610	* 1.6637	* 1.9415	* 1.8130	* 1.9893	* 0.8673 *
	* 2.6534	* 2.6380	* 2.9270	* 2.8001	* 2.4276	* 2.5437	* 2.2966	* 4.6415 *
11	* 1.5895	* 1.8223	* 1.6624	* 1.9263	* 1.7903	* 1.9986	* 1.2674	* 0.5935 *
	* 2.7803	* 2.4604	* 2.8026	* 2.5192	* 2.7125	* 2.4330	* 3.5454	* 7.1947 *
12	* 1.7941	* 1.7503	* 1.9412	* 1.7890	* 1.8928	* 1.9626	* 0.9796 *	
	* 2.4293	* 2.5838	* 2.4276	* 2.7141	* 2.5928	* 2.4893	* 4.5168 *	
13	* 1.8890	* 1.9090	* 1.8151	* 1.9982	* 1.9626	* 1.9481	* 0.8198 *	
	* 2.3083	* 2.3057	* 2.5406	* 2.4334	* 2.4895	* 2.5170	* 5.3921 *	
14	* 2.0189	* 2.0086	* 1.9900	* 1.2674	* 0.9783	* 0.8196 *		
	* 2.1583	* 2.1874	* 2.2957	* 3.5457	* 4.5195	* 5.3937 *		
15	* 0.9274	* 0.9370	* 0.8671	* 0.5815	* F-SUB-Q			
	* 4.2451	* 4.2386	* 4.6423	* 7.2316	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5698	* 1.5391	* 1.6989	* 1.5723	* 1.7864	* 1.8801	* 2.0205	* 0.9046 *
	* 2.9155	* 2.9454	* 2.5597	* 2.6969	* 2.3423	* 2.2261	* 2.0698	* 4.1611 *
9	* 1.5391	* 1.7990	* 1.7108	* 1.8177	* 1.7362	* 1.9008	* 2.0101	* 0.9173 *
	* 2.9454	* 2.5148	* 2.5470	* 2.3719	* 2.5058	* 2.2235	* 2.0987	* 4.1478 *
10	* 1.6989	* 1.7048	* 1.5452	* 1.6530	* 1.9459	* 1.8078	* 1.9949	* 0.8471 *
	* 2.5597	* 2.5557	* 2.8373	* 2.7349	* 2.3357	* 2.4550	* 2.2021	* 4.5597 *
11	* 1.5723	* 1.8157	* 1.6516	* 1.9326	* 1.7888	* 2.0119	* 1.2447	* 0.5796 *
	* 2.6969	* 2.3736	* 2.7378	* 2.4022	* 2.5987	* 2.3185	* 3.4241	* 7.0760 *
12	* 1.7864	* 1.7360	* 1.9456	* 1.7871	* 1.9108	* 1.9816	* 0.9632 *	
	* 2.3423	* 2.5059	* 2.3357	* 2.6015	* 2.4847	* 2.3719	* 4.3663 *	
13	* 1.8801	* 1.9017	* 1.8101	* 2.0115	* 1.9815	* 1.9795	* 0.8086 *	
	* 2.2261	* 2.2225	* 2.4519	* 2.3190	* 2.3720	* 2.3837	* 5.1946 *	
14	* 2.0205	* 2.0106	* 1.9956	* 1.2447	* 0.9617	* 0.8083 *		
	* 2.0698	* 2.0982	* 2.2013	* 3.4247	* 4.3696	* 5.1962 *		
15	* 0.9046	* 0.9181	* 0.8468	* 0.5652	* F-SUB-Q			
	* 4.1611	* 4.1457	* 4.5607	* 7.1463	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5348	* 1.5032	* 1.6618	* 1.5355	* 1.7510	* 1.8462	* 1.9898	* 0.8827
	* 2.7064	* 2.7393	* 2.3694	* 2.5106	* 2.1830	* 2.0815	* 1.9294	* 3.8874
9	* 1.5032	* 1.7612	* 1.6724	* 1.7817	* 1.7008	* 1.8680	* 1.9801	* 0.8961
	* 2.7393	* 2.3207	* 2.3634	* 2.2023	* 2.3376	* 2.0768	* 1.9552	* 3.8687
10	* 1.6618	* 1.6663	* 1.5098	* 1.6210	* 1.9160	* 1.7766	* 1.9674	* 0.8276
	* 2.3694	* 2.3717	* 2.6298	* 2.5373	* 2.1658	* 2.2846	* 2.0431	* 4.2437
11	* 1.5355	* 1.7797	* 1.6196	* 1.9032	* 1.7601	* 1.9877	* 1.2203	* 0.5661
	* 2.5106	* 2.2039	* 2.5401	* 2.2143	* 2.3996	* 2.1311	* 3.1785	* 6.5503
12	* 1.7510	* 1.7005	* 1.9158	* 1.7583	* 1.8935	* 1.9620	* 0.9454	*
	* 2.1830	* 2.3386	* 2.1658	* 2.4020	* 2.2851	* 2.1793	* 4.0474	*
13	* 1.8462	* 1.8689	* 1.7789	* 1.9873	* 1.9618	* 1.9687	* 0.7959	*
	* 2.0815	* 2.0759	* 2.2818	* 2.1316	* 2.1795	* 2.1877	* 4.8195	*
14	* 1.9898	* 1.9806	* 1.9681	* 1.2202	* 0.9439	* 0.7956	*	*
	* 1.9294	* 1.9547	* 2.0424	* 3.1791	* 4.0508	* 4.8210	*	*
15	* 0.8827	* 0.8969	* 0.8273	* 0.5513	* F-SUB-Q			
	* 3.8875	* 3.8668	* 4.2450	* 6.6243	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4877	* 1.4557	* 1.6092	* 1.4869	* 1.6997	* 1.7962	* 1.9381	* 0.8599
	* 2.5274	* 2.5557	* 2.1916	* 2.3253	* 2.0200	* 1.9228	* 1.7806	* 3.5961
9	* 1.4557	* 1.7063	* 1.6209	* 1.7286	* 1.6521	* 1.8187	* 1.9293	* 0.8725
	* 2.5557	* 2.1416	* 2.1836	* 2.0369	* 2.1575	* 1.9164	* 1.8031	* 3.5772
10	* 1.6092	* 1.6149	* 1.4632	* 1.5753	* 1.8650	* 1.7287	* 1.9185	* 0.8077
	* 2.1916	* 2.1915	* 2.4295	* 2.3407	* 1.9946	* 2.1049	* 1.8800	* 3.9121
11	* 1.4869	* 1.7265	* 1.5739	* 1.8527	* 1.7141	* 1.9397	* 1.1938	* 0.5527
	* 2.3253	* 2.0384	* 2.3433	* 2.0700	* 2.2429	* 1.9899	* 2.9528	* 6.0275
12	* 1.6997	* 1.6518	* 1.8648	* 1.7123	* 1.8528	* 1.9174	* 0.9247	*
	* 2.0200	* 2.1578	* 1.9946	* 2.2454	* 2.1355	* 2.0407	* 3.7878	*
13	* 1.7962	* 1.8196	* 1.7309	* 1.9393	* 1.9173	* 1.9293	* 0.7802	*
	* 1.9228	* 1.9156	* 2.1023	* 1.9904	* 2.0409	* 2.0420	* 4.5055	*
14	* 1.9381	* 1.9299	* 1.9192	* 1.1937	* 0.9232	* 0.7800	*	*
	* 1.7806	* 1.8027	* 1.8794	* 2.9535	* 3.7910	* 4.5070	*	*
15	* 0.8599	* 0.8733	* 0.8074	* 0.5378	* F-SUB-Q			
	* 3.5961	* 3.5754	* 3.9135	* 6.0996	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4270	* 1.3965	* 1.5387	* 1.4256	* 1.6287	* 1.7281	* 1.8622	* 0.8373
	* 2.5687	* 2.5805	* 2.2339	* 2.3678	* 2.0612	* 1.9550	* 1.8131	* 3.6257
9	* 1.3965	* 1.6319	* 1.5545	* 1.6552	* 1.5887	* 1.7508	* 1.8546	* 0.8470
	* 2.5805	* 2.1773	* 2.2184	* 2.0758	* 2.1888	* 1.9462	* 1.8343	* 3.6114
10	* 1.5387	* 1.5487	* 1.4038	* 1.5187	* 1.7902	* 1.6631	* 1.8453	* 0.7879
	* 2.2339	* 2.2265	* 2.4663	* 2.3636	* 2.0245	* 2.1325	* 1.9070	* 3.9254
11	* 1.4256	* 1.6532	* 1.5176	* 1.7783	* 1.6504	* 1.8661	* 1.1662	* 0.5394
	* 2.3678	* 2.0782	* 2.3660	* 2.1087	* 2.2710	* 2.0232	* 2.9557	* 6.0318
12	* 1.6287	* 1.5884	* 1.7899	* 1.6486	* 1.7894	* 1.8471	* 0.9043	*
	* 2.0612	* 2.1892	* 2.0245	* 2.2726	* 2.1678	* 2.0743	* 3.7973	*
13	* 1.7281	* 1.7516	* 1.6653	* 1.8656	* 1.8469	* 1.8617	* 0.7651	*
	* 1.9550	* 1.9454	* 2.1297	* 2.0237	* 2.0745	* 2.0785	* 4.5193	*
14	* 1.8622	* 1.8551	* 1.8460	* 1.1661	* 0.9029	* 0.7649	*	*
	* 1.8131	* 1.8338	* 1.9064	* 2.9565	* 3.8004	* 4.5209	*	*
15	* 0.8373	* 0.8478	* 0.7876	* 0.5264	* F-SUB-Q			
	* 3.6257	* 3.6096	* 3.9270	* 6.0858	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3845	* 1.3520	* 1.4989	* 1.3815	* 1.5895	* 1.6855	* 1.8266	* 0.7983
	* 2.3925	* 2.4089	* 2.0844	* 2.2260	* 1.9280	* 1.8308	* 1.6888	* 3.4763
9	* 1.3520	* 1.5918	* 1.5093	* 1.6147	* 1.5419	* 1.7085	* 1.8190	* 0.8113
	* 2.4089	* 2.0219	* 2.0759	* 1.9353	* 2.0519	* 1.8202	* 1.7076	* 3.4497
10	* 1.4989	* 1.5033	* 1.3610	* 1.4701	* 1.7512	* 1.6188	* 1.8101	* 0.7510
	* 2.0844	* 2.0838	* 2.3095	* 2.2208	* 1.8798	* 1.9900	* 1.7695	* 3.7619
11	* 1.3815	* 1.6128	* 1.4687	* 1.7379	* 1.6061	* 1.8290	* 1.1147	* 0.5133
	* 2.2260	* 1.9376	* 2.2234	* 1.9549	* 2.1193	* 1.8754	* 2.7862	* 5.7671
12	* 1.5895	* 1.5416	* 1.7509	* 1.6043	* 1.7505	* 1.8108	* 0.8617	*
	* 1.9280	* 2.0523	* 1.8798	* 2.1218	* 2.0056	* 1.9221	* 3.6351	*
13	* 1.6855	* 1.7093	* 1.6211	* 1.8285	* 1.8106	* 1.8313	* 0.7285	*
	* 1.8308	* 1.8194	* 1.9874	* 1.8758	* 1.9223	* 1.9200	* 4.3221	*
14	* 1.8266	* 1.8195	* 1.8107	* 1.1145	* 0.8602	* 0.7282	*	*
	* 1.6888	* 1.7071	* 1.7689	* 2.7869	* 3.6385	* 4.3236	*	*
15	* 0.7983	* 0.8121	* 0.7507	* 0.4985	* F-SUB-Q			
	* 3.4763	* 3.4479	* 3.7634	* 5.8480	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3246	* 1.2920	* 1.4318	* 1.3197	* 1.5200	* 1.6161	* 1.7519	* 0.7626 *
	* 2.2589	* 2.3038	* 2.0009	* 2.1438	* 1.8588	* 1.7616	* 1.6251	* 3.3671 *
9	* 1.2920	* 1.5221	* 1.4441	* 1.5432	* 1.4752	* 1.6385	* 1.7450	* 0.7753 *
	* 2.3038	* 1.9280	* 1.9887	* 1.8590	* 1.9693	* 1.7493	* 1.6413	* 3.3371 *
10	* 1.4318	* 1.4383	* 1.3019	* 1.4056	* 1.6756	* 1.5506	* 1.7363	* 0.7178 *
	* 2.0009	* 1.9965	* 2.2111	* 2.1269	* 1.7975	* 1.9048	* 1.6941	* 3.6306 *
11	* 1.3197	* 1.5413	* 1.4043	* 1.6623	* 1.5376	* 1.7528	* 1.0678	* 0.4906 *
	* 2.1438	* 1.8612	* 2.1295	* 1.8570	* 2.0149	* 1.7747	* 2.6577	* 5.5367 *
12	* 1.5200	* 1.4749	* 1.6753	* 1.5359	* 1.6800	* 1.7361	* 0.8239	*
	* 1.8588	* 1.9697	* 1.7976	* 2.0170	* 1.8987	* 1.8180	* 3.4476	*
13	* 1.6161	* 1.6394	* 1.5528	* 1.7523	* 1.7359	* 1.7578	* 0.6965	*
	* 1.7616	* 1.7485	* 1.9022	* 1.7752	* 1.8183	* 1.8235	* 4.1250	*
14	* 1.7519	* 1.7455	* 1.7370	* 1.0677	* 0.8224	* 0.6963	*	
	* 1.6251	* 1.6409	* 1.6936	* 2.6584	* 3.4509	* 4.1265	*	
15	* 0.7626	* 0.7761	* 0.7175	* 0.4762	* F-SUB-Q			
	* 3.3671	* 3.3353	* 3.6322	* 5.6177	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2466	* 1.2154	* 1.3349	* 1.2402	* 1.4170	* 1.5170	* 1.6328	* 0.7292 *
	* 2.2288	* 2.2265	* 1.9868	* 2.1174	* 1.8586	* 1.7506	* 1.6270	* 3.2982 *
9	* 1.2154	* 1.4198	* 1.3580	* 1.4375	* 1.3868	* 1.5380	* 1.6274	* 0.7380 *
	* 2.2265	* 1.8981	* 1.9582	* 1.8512	* 1.9431	* 1.7366	* 1.6407	* 3.2777 *
10	* 1.3349	* 1.3526	* 1.2258	* 1.3247	* 1.5593	* 1.4563	* 1.6185	* 0.6872 *
	* 1.9868	* 1.9658	* 2.1721	* 2.0922	* 1.7831	* 1.8795	* 1.6864	* 3.5369 *
11	* 1.2402	* 1.4357	* 1.3237	* 1.5480	* 1.4434	* 1.6326	* 1.0239	* 0.4708 *
	* 2.1174	* 1.8535	* 2.0947	* 1.8431	* 1.9691	* 1.7658	* 2.5428	* 5.3485 *
12	* 1.4170	* 1.3866	* 1.5590	* 1.4422	* 1.5745	* 1.6181	* 0.7894	*
	* 1.8586	* 1.9435	* 1.7831	* 1.9706	* 1.8613	* 1.7990	* 3.3306	*
13	* 1.5170	* 1.5387	* 1.4583	* 1.6322	* 1.6179	* 1.6354	* 0.6684	*
	* 1.7506	* 1.7358	* 1.8769	* 1.7663	* 1.7993	* 1.7999	* 3.9585	*
14	* 1.6328	* 1.6278	* 1.6191	* 1.0237	* 0.7881	* 0.6682	*	
	* 1.6270	* 1.6403	* 1.6859	* 2.5435	* 3.3334	* 3.9600	*	
15	* 0.7292	* 0.7386	* 0.6869	* 0.4591	* F-SUB-Q			
	* 3.2982	* 3.2760	* 3.5386	* 5.4019	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1833	* 1.1510	* 1.2628	* 1.1772	* 1.3359	* 1.4349	* 1.5392	* 0.6774 *
	* 2.1475	* 2.1861	* 1.9654	* 2.0931	* 1.8581	* 1.7452	* 1.6281	* 3.3540 *
9	* 1.1510	* 1.3422	* 1.2901	* 1.3557	* 1.3102	* 1.4536	* 1.5338	* 0.6884 *
	* 2.1861	* 1.8652	* 1.9299	* 1.8411	* 1.9289	* 1.7307	* 1.6407	* 3.3204 *
10	* 1.2628	* 1.2850	* 1.1637	* 1.2451	* 1.4654	* 1.3758	* 1.5223	* 0.6369 *
	* 1.9654	* 1.9374	* 2.1399	* 2.0695	* 1.7703	* 1.8643	* 1.6826	* 3.5989 *
11	* 1.1772	* 1.3540	* 1.2439	* 1.4561	* 1.3624	* 1.5355	* 0.9514	* 0.4366 *
	* 2.0931	* 1.8434	* 2.0715	* 1.8137	* 1.9419	* 1.7348	* 2.5514	* 5.4077 *
12	* 1.3359	* 1.3099	* 1.4651	* 1.3608	* 1.4849	* 1.5214	* 0.7311	*
	* 1.8581	* 1.9293	* 1.7704	* 1.9444	* 1.8539	* 1.7915	* 3.3565	*
13	* 1.4348	* 1.4544	* 1.3778	* 1.5350	* 1.5213	* 1.5343	* 0.6157	*
	* 1.7452	* 1.7299	* 1.8617	* 1.7352	* 1.7917	* 1.8011	* 4.0429	*
14	* 1.5392	* 1.5342	* 1.5228	* 0.9513	* 0.7299	* 0.6155	*	
	* 1.6281	* 1.6403	* 1.6821	* 2.5522	* 3.3597	* 4.0444	*	
15	* 0.6774	* 0.6891	* 0.6365	* 0.4239	* F-SUB-Q			
	* 3.3540	* 3.3184	* 3.6008	* 5.4858	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0747	* 1.0569	* 1.1580	* 1.0890	* 1.2108	* 1.2943	* 1.3758	* 0.6226 *
	* 2.2279	* 2.2408	* 2.0296	* 2.1517	* 1.9549	* 1.8470	* 1.7392	* 3.4902 *
9	* 1.0569	* 1.2129	* 1.1797	* 1.2280	* 1.1894	* 1.3099	* 1.3704	* 0.6319 *
	* 2.2408	* 1.9472	* 2.0039	* 1.9311	* 2.0196	* 1.8323	* 1.7522	* 3.4602 *
10	* 1.1580	* 1.1752	* 1.0591	* 1.1342	* 1.3110	* 1.2425	* 1.3519	* 0.5804 *
	* 2.0296	* 2.0114	* 2.2317	* 2.1447	* 1.8733	* 1.9681	* 1.8021	* 3.7725 *
11	* 1.0890	* 1.2265	* 1.1331	* 1.3085	* 1.2342	* 1.3694	* 0.8635	* 0.3962 *
	* 2.1517	* 1.9334	* 2.1466	* 1.9003	* 2.0207	* 1.8319	* 2.6647	* 5.6699 *
12	* 1.2108	* 1.1892	* 1.3108	* 1.2329	* 1.3398	* 1.3606	* 0.6681	*
	* 1.9549	* 2.0200	* 1.8734	* 2.0231	* 1.9213	* 1.8731	* 3.4529	*
13	* 1.2943	* 1.3105	* 1.2441	* 1.3690	* 1.3605	* 1.3576	* 0.5565	*
	* 1.8469	* 1.8315	* 1.9657	* 1.8324	* 1.8734	* 1.9108	* 4.2068	*
14	* 1.3758	* 1.3707	* 1.3523	* 0.8633	* 0.6670	* 0.5563	*	
	* 1.7392	* 1.7518	* 1.8017	* 2.6656	* 3.4561	* 4.2084	*	
15	* 0.6226	* 0.6325	* 0.5800	* 0.3844	* F-SUB-Q			
	* 3.4902	* 3.4585	* 3.7748	* 5.7558	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8569	* 0.8803	* 1.0989	* 0.9058	* 1.1227	* 1.0249	* 1.1883	* 0.5215 *
	* 2.6650	* 2.5724	* 2.0520	* 2.4923	* 2.0320	* 2.2510	* 1.9434	* 4.0329 *
9	* 0.8803	* 1.0906	* 0.9650	* 1.1179	* 0.9556	* 1.0373	* 1.1778	* 0.5269 *
	* 2.5724	* 2.0766	* 2.3453	* 2.0342	* 2.4074	* 2.2311	* 1.9668	* 4.0147 *
10	* 1.0989	* 0.9631	* 0.8447	* 0.9282	* 1.1639	* 0.9966	* 1.0976	* 0.4758 *
	* 2.0520	* 2.3482	* 2.6920	* 2.5274	* 2.0221	* 2.3761	* 2.1396	* 4.4474 *
11	* 0.9058	* 1.1168	* 0.9275	* 1.1712	* 0.9898	* 1.1489	* 0.7057	* 0.3210 *
	* 2.4923	* 2.0356	* 2.5299	* 2.0239	* 2.4127	* 2.0913	* 3.1298	* 6.7492 *
12	* 1.1227	* 0.9549	* 1.1636	* 0.9888	* 1.0752	* 1.1798	* 0.5620 *	
	* 2.0320	* 2.4092	* 2.0228	* 2.4153	* 2.2861	* 2.0759	* 3.9390 *	
13	* 1.0249	* 1.0377	* 0.9978	* 1.1487	* 1.1795	* 1.0607	* 0.4469 *	
	* 2.2510	* 2.2302	* 2.3734	* 2.0916	* 2.0763	* 2.3314	* 5.0121 *	
14	* 1.1883	* 1.1780	* 1.0976	* 0.7055	* 0.5611	* 0.4467 *		
	* 1.9434	* 1.9664	* 2.1395	* 3.1311	* 3.9422	* 5.0140 *		
15	* 0.5215	* 0.5273	* 0.4755	* 0.3115	* F-SUB-Q			
	* 4.0329	* 4.0130	* 4.4503	* 6.8490	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3342	* 0.3621	* 0.4384	* 0.3769	* 0.4444	* 0.3856	* 0.4159	* 0.2122 *
	* 6.5629	* 6.0361	* 4.9698	* 5.7972	* 4.9472	* 5.7801	* 5.3635	* 9.6097 *
9	* 0.3621	* 0.4279	* 0.3805	* 0.4414	* 0.3778	* 0.3880	* 0.4113	* 0.2114 *
	* 6.0361	* 5.1046	* 5.7503	* 4.9677	* 5.8564	* 5.7636	* 5.4389	* 9.6995 *
10	* 0.4384	* 0.3799	* 0.3473	* 0.3789	* 0.4520	* 0.3811	* 0.3786	* 0.1926 *
	* 4.9698	* 5.7607	* 6.3338	* 5.9467	* 4.9912	* 5.9911	* 5.9838	*10.6460 *
11	* 0.3769	* 0.4410	* 0.3787	* 0.4482	* 0.3897	* 0.4278	* 0.2837	* 0.1307 *
	* 5.7972	* 4.9725	* 5.9526	* 5.0803	* 5.8910	* 5.4092	* 7.5128	*16.0524 *
12	* 0.4444	* 0.3776	* 0.4519	* 0.3894	* 0.3964	* 0.4141	* 0.2284 *	
	* 4.9472	* 5.8590	* 4.9932	* 5.8975	* 5.9666	* 5.6969	* 9.3777 *	
13	* 0.3856	* 0.3881	* 0.3814	* 0.4277	* 0.4140	* 0.3641	* 0.1789 *	
	* 5.7801	* 5.7619	* 5.9867	* 5.4103	* 5.6981	* 6.5377	*12.0871 *	
14	* 0.4159	* 0.4114	* 0.3786	* 0.2836	* 0.2281	* 0.1788 *		
	* 5.3635	* 5.4379	* 5.9840	* 7.5165	* 9.3819	*12.0923 *		
15	* 0.2122	* 0.2116	* 0.1925	* 0.1281	* F-SUB-Q			
	* 9.6097	* 9.6951	*10.6531	*16.1386	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3263	* 0.4262	* 0.5360	* 0.4700	* 0.5440	* 0.4658	* 0.4853	* 0.2602
	* 5.7762	* 5.6151	* 4.4515	* 5.0631	* 4.3771	* 5.1550	* 5.0064	* 8.4435
9	* 0.4262	* 0.5058	* 0.4760	* 0.5389	* 0.4649	* 0.4560	* 0.4759	* 0.2555
	* 5.6151	* 4.7665	* 5.0377	* 4.4185	* 5.1186	* 5.2528	* 5.1012	* 8.6223
10	* 0.5360	* 0.4755	* 0.4278	* 0.4419	* 0.5092	* 0.4283	* 0.4234	* 0.2242
	* 4.4515	* 5.0422	* 5.6801	* 5.4018	* 4.6573	* 5.5322	* 5.6089	* 9.5816
11	* 0.4700	* 0.5387	* 0.4417	* 0.4738	* 0.4078	* 0.4177	* 0.2924	* 0.1476
	* 5.0631	* 4.4199	* 5.4050	* 4.8655	* 5.5256	* 5.1906	* 7.3557	* 14.4284
12	* 0.5440	* 0.4649	* 0.5091	* 0.4076	* 0.3091	* 0.3143	* 0.2073	*
	* 4.3771	* 5.1193	* 4.6585	* 5.5283	* 5.4711	* 5.3207	* 8.4743	*
13	* 0.4658	* 0.4560	* 0.4284	* 0.4177	* 0.3143	* 0.2529	* 0.1433	*
	* 5.1550	* 5.2525	* 5.5300	* 5.1906	* 5.3200	* 5.9260	* 10.7180	*
14	* 0.4853	* 0.4760	* 0.4236	* 0.2925	* 0.2072	* 0.1433	*	*
	* 5.0064	* 5.1001	* 5.6076	* 7.3549	* 8.4696	* 10.7190	*	*
15	* 0.2602	* 0.2558	* 0.2242	* 0.1455	* F-SUB-Q			
	* 8.4436	* 8.6155	* 9.5807	* 14.4120	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.7909	* 0.9926	* 1.2563	* 1.0899	* 1.2752	* 1.1544	* 1.2779	* 0.6343
	* 2.5367	* 2.4952	* 1.9656	* 2.2649	* 1.9339	* 2.1504	* 1.9674	* 3.5886
9	* 0.9926	* 1.2016	* 1.1532	* 1.2693	* 1.1185	* 1.1454	* 1.2557	* 0.6243
	* 2.4952	* 2.0636	* 2.1498	* 1.9426	* 2.2068	* 2.1712	* 1.9841	* 3.6182
10	* 1.2563	* 1.1518	* 0.9985	* 1.0297	* 1.2128	* 1.0655	* 1.1284	* 0.5490
	* 1.9656	* 2.1526	* 2.5061	* 2.3937	* 2.0239	* 2.3069	* 2.1777	* 4.0415
11	* 1.0899	* 1.2689	* 1.0290	* 1.1472	* 0.9777	* 1.0385	* 0.7129	* 0.3618
	* 2.2649	* 1.9432	* 2.3951	* 2.0652	* 2.3684	* 2.1582	* 3.1208	* 6.1010
12	* 1.2752	* 1.1183	* 1.2125	* 0.9771	* 0.7548	* 0.8303	* 0.5049	*
	* 1.9339	* 2.2071	* 2.0244	* 2.3699	* 2.2395	* 2.0816	* 3.6069	*
13	* 1.1544	* 1.1456	* 1.0661	* 1.0385	* 0.8302	* 0.6947	* 0.3577	*
	* 2.1505	* 2.1708	* 2.3056	* 2.1582	* 2.0815	* 2.3174	* 4.4557	*
14	* 1.2779	* 1.2560	* 1.1287	* 0.7132	* 0.5046	* 0.3577	*	*
	* 1.9674	* 1.9836	* 2.1771	* 3.1202	* 3.6059	* 4.4562	*	*
15	* 0.6343	* 0.6247	* 0.5491	* 0.3571	* F-SUB-Q			
	* 3.5886	* 3.6176	* 4.0408	* 6.0869	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9835	* 1.2135	* 1.3906	* 1.3284	* 1.4214	* 1.4417	* 1.4874	* 0.7656 *
	* 2.1344	* 2.0998	* 1.8255	* 1.9109	* 1.7854	* 1.7664	* 1.7134	* 3.0078 *
9	* 1.2135	* 1.3852	* 1.3967	* 1.4457	* 1.3768	* 1.4333	* 1.4611	* 0.7618 *
	* 2.0998	* 1.8370	* 1.8220	* 1.7528	* 1.8423	* 1.7741	* 1.7396	* 3.0209 *
10	* 1.3906	* 1.3948	* 1.2425	* 1.2682	* 1.3978	* 1.3278	* 1.3866	* 0.6838 *
	* 1.8255	* 1.8245	* 2.0494	* 1.9959	* 1.8047	* 1.9018	* 1.8192	* 3.3252 *
11	* 1.3284	* 1.4452	* 1.2676	* 1.3196	* 1.2028	* 1.2504	* 0.8910	* 0.4538 *
	* 1.9109	* 1.7535	* 1.9972	* 1.8412	* 1.9654	* 1.8466	* 2.5712	* 5.0014 *
12	* 1.4214	* 1.3765	* 1.3974	* 1.2020	* 0.9428	* 0.9993	* 0.6193	*
	* 1.7854	* 1.8427	* 1.8052	* 1.9665	* 1.8612	* 1.8478	* 3.0413	*
13	* 1.4417	* 1.4336	* 1.3287	* 1.2505	* 0.9992	* 0.8994	* 0.4569	*
	* 1.7664	* 1.7738	* 1.9006	* 1.8466	* 1.8475	* 1.8897	* 3.6122	*
14	* 1.4874	* 1.4614	* 1.3871	* 0.8914	* 0.6188	* 0.4569	*	
	* 1.7134	* 1.7392	* 1.8186	* 2.5706	* 3.0409	* 3.6126	*	
15	* 0.7656	* 0.7624	* 0.6840	* 0.4498	F-SUB-Q			
	* 3.0078	* 3.0204	* 3.3243	* 4.9689	M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1060	* 1.3381	* 1.5819	* 1.4736	* 1.6244	* 1.6282	* 1.7078	* 0.8331 *
	* 1.9932	* 1.9735	* 1.6604	* 1.7813	* 1.6121	* 1.6093	* 1.5346	* 2.8419 *
9	* 1.3381	* 1.5822	* 1.5516	* 1.6463	* 1.5318	* 1.6190	* 1.6764	* 0.8332 *
	* 1.9735	* 1.6638	* 1.6955	* 1.5911	* 1.7113	* 1.6170	* 1.5601	* 2.8439 *
10	* 1.5819	* 1.5491	* 1.3830	* 1.4131	* 1.6039	* 1.4924	* 1.5986	* 0.7458 *
	* 1.6604	* 1.6983	* 1.9010	* 1.8503	* 1.6259	* 1.7474	* 1.6272	* 3.1446 *
11	* 1.4736	* 1.6457	* 1.4121	* 1.5118	* 1.3404	* 1.4433	* 0.9802	* 0.4943 *
	* 1.7813	* 1.5917	* 1.8516	* 1.6661	* 1.8139	* 1.6626	* 2.4263	* 4.7458 *
12	* 1.6244	* 1.5314	* 1.6034	* 1.3392	* 1.0679	* 1.1620	* 0.6803	*
	* 1.6121	* 1.7117	* 1.6263	* 1.8150	* 1.7024	* 1.6693	* 2.8894	*
13	* 1.6282	* 1.6194	* 1.4936	* 1.4435	* 1.1619	* 1.0575	* 0.5063	*
	* 1.6093	* 1.6166	* 1.7460	* 1.6627	* 1.6690	* 1.6897	* 3.4123	*
14	* 1.7078	* 1.6768	* 1.5993	* 0.9806	* 0.6798	* 0.5062	*	
	* 1.5346	* 1.5598	* 1.6265	* 2.4257	* 2.8894	* 3.4127	*	
15	* 0.8331	* 0.8339	* 0.7460	* 0.4889	F-SUB-Q			
	* 2.8419	* 2.8432	* 3.1437	* 4.7258	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1753	* 1.4124	* 1.6862	* 1.5484	* 1.7330	* 1.7192	* 1.8227	* 0.8760
	* 2.0004	* 1.9550	* 1.6248	* 1.7664	* 1.5730	* 1.5861	* 1.4955	* 2.8132
9	* 1.4124	* 1.6822	* 1.6270	* 1.7541	* 1.6114	* 1.7092	* 1.7895	* 0.8769
	* 1.9550	* 1.6354	* 1.6864	* 1.5546	* 1.6928	* 1.5937	* 1.5195	* 2.8143
10	* 1.6862	* 1.6242	* 1.4464	* 1.4869	* 1.7126	* 1.5701	* 1.7084	* 0.7870
	* 1.6248	* 1.6894	* 1.8986	* 1.8318	* 1.5842	* 1.7269	* 1.5846	* 3.1067
11	* 1.5484	* 1.7533	* 1.4858	* 1.6141	* 1.4191	* 1.5468	* 1.0367	* 0.5195
	* 1.7664	* 1.5553	* 1.8332	* 1.6351	* 1.8004	* 1.6284	* 2.3974	* 4.6995
12	* 1.7330	* 1.6110	* 1.7121	* 1.4185	* 1.1410	* 1.2597	* 0.7230	*
	* 1.5730	* 1.6932	* 1.5847	* 1.8015	* 1.6763	* 1.6336	* 2.8669	*
13	* 1.7192	* 1.7097	* 1.5715	* 1.5470	* 1.2596	* 1.1516	* 0.5416	*
	* 1.5861	* 1.5932	* 1.7254	* 1.6285	* 1.6335	* 1.6464	* 3.3788	*
14	* 1.8227	* 1.7901	* 1.7092	* 1.0371	* 0.7224	* 0.5415	*	*
	* 1.4955	* 1.5191	* 1.5839	* 2.3967	* 2.8671	* 3.3792	*	*
15	* 0.8760	* 0.8776	* 0.7872	* 0.5129	* F-SUB-Q			
	* 2.8132	* 2.8134	* 3.1058	* 4.6880	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2152	* 1.4599	* 1.7434	* 1.5902	* 1.7908	* 1.7676	* 1.8850	* 0.9054
	* 2.0560	* 1.9918	* 1.6524	* 1.8079	* 1.5947	* 1.6125	* 1.5116	* 2.8501
9	* 1.4599	* 1.7352	* 1.6678	* 1.8129	* 1.6555	* 1.7588	* 1.8552	* 0.9052
	* 1.9918	* 1.6677	* 1.7292	* 1.5801	* 1.7302	* 1.6189	* 1.5325	* 2.8531
10	* 1.7434	* 1.6648	* 1.4799	* 1.5314	* 1.7724	* 1.6126	* 1.7688	* 0.8155
	* 1.6524	* 1.7324	* 1.9493	* 1.8716	* 1.6095	* 1.7654	* 1.6022	* 3.1366
11	* 1.5902	* 1.8121	* 1.5304	* 1.6712	* 1.4711	* 1.6066	* 1.0764	* 0.5374
	* 1.8079	* 1.5808	* 1.8727	* 1.6704	* 1.8484	* 1.6628	* 2.4310	* 4.7743
12	* 1.7908	* 1.6550	* 1.7718	* 1.4704	* 1.1852	* 1.3201	* 0.7553	*
	* 1.5947	* 1.7307	* 1.6100	* 1.8496	* 1.7176	* 1.6697	* 2.9339	*
13	* 1.7676	* 1.7594	* 1.6141	* 1.6068	* 1.3199	* 1.2129	* 0.5700	*
	* 1.6125	* 1.6183	* 1.7637	* 1.6629	* 1.6697	* 1.6795	* 3.4508	*
14	* 1.8850	* 1.8558	* 1.7696	* 1.0767	* 0.7545	* 0.5698	*	*
	* 1.5116	* 1.5320	* 1.6015	* 2.4305	* 2.9344	* 3.4513	*	*
15	* 0.9054	* 0.9060	* 0.8157	* 0.5306	* F-SUB-Q			
	* 2.8501	* 2.8522	* 3.1358	* 4.7622	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2436	* 1.4879	* 1.7985	* 1.6271	* 1.8453	* 1.8119	* 1.9466	* 0.9195
	* 2.1198	* 2.0924	* 1.7126	* 1.8880	* 1.6475	* 1.6687	* 1.5492	* 2.9728
9	* 1.4879	* 1.7876	* 1.7058	* 1.8690	* 1.6933	* 1.8042	* 1.9183	* 0.9212
	* 2.0924	* 1.7324	* 1.8073	* 1.6367	* 1.8049	* 1.6753	* 1.5719	* 2.9725
10	* 1.7985	* 1.7025	* 1.5108	* 1.5643	* 1.8305	* 1.6523	* 1.8279	* 0.8289
	* 1.7126	* 1.8108	* 2.0421	* 1.9576	* 1.6663	* 1.8326	* 1.6497	* 3.2796
11	* 1.6271	* 1.8680	* 1.5629	* 1.7275	* 1.5104	* 1.6667	* 1.0984	* 0.5458
	* 1.8880	* 1.6375	* 1.9594	* 1.7170	* 1.9094	* 1.7091	* 2.5336	* 5.0175
12	* 1.8453	* 1.6928	* 1.8298	* 1.5097	* 1.2215	* 1.3806	* 0.7755	*
	* 1.6475	* 1.8054	* 1.6669	* 1.9109	* 1.7812	* 1.7202	* 3.0795	*
13	* 1.8119	* 1.8048	* 1.6539	* 1.6669	* 1.3804	* 1.2777	* 0.5886	*
	* 1.6687	* 1.6747	* 1.8307	* 1.7093	* 1.7202	* 1.7357	* 3.6401	*
14	* 1.9466	* 1.9189	* 1.8287	* 1.0988	* 0.7746	* 0.5885	*	
	* 1.5492	* 1.5714	* 1.6490	* 2.5332	* 3.0803	* 3.6406	*	
15	* 0.9195	* 0.9220	* 0.8290	* 0.5371	F-SUB-Q			
	* 2.9728	* 2.9717	* 3.2790	* 5.0217	M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2691	* 1.5108	* 1.8315	* 1.6487	* 1.8752	* 1.8363	* 1.9832	* 0.9295 *
	* 2.2558	* 2.2464	* 1.8313	* 2.0263	* 1.7551	* 1.7762	* 1.6391	* 3.1681 *
9	* 1.5108	* 1.8207	* 1.7282	* 1.9014	* 1.7147	* 1.8303	* 1.9551	* 0.9319 *
	* 2.2464	* 1.8556	* 1.9419	* 1.7483	* 1.9347	* 1.7831	* 1.6638	* 3.1682 *
10	* 1.8315	* 1.7247	* 1.5295	* 1.5874	* 1.8675	* 1.6776	* 1.8649	* 0.8398 *
	* 1.8313	* 1.9458	* 2.1981	* 2.1010	* 1.7784	* 1.9556	* 1.7503	* 3.4979 *
11	* 1.6487	* 1.9004	* 1.5859	* 1.7662	* 1.5436	* 1.7118	* 1.1199	* 0.5538 *
	* 2.0263	* 1.7492	* 2.1030	* 1.8061	* 2.0151	* 1.7929	* 2.6783	* 5.3699 *
12	* 1.8752	* 1.7141	* 1.8668	* 1.5428	* 1.2563	* 1.4342	* 0.7983	*
	* 1.7551	* 1.9353	* 1.7782	* 2.0166	* 1.8820	* 1.8080	* 3.2512	*
13	* 1.8363	* 1.8310	* 1.6794	* 1.7120	* 1.4339	* 1.3391	* 0.6116	*
	* 1.7762	* 1.7824	* 1.9535	* 1.7930	* 1.8080	* 1.8320	* 3.8706	*
14	* 1.9832	* 1.9557	* 1.8657	* 1.1201	* 0.7974	* 0.6115	*	
	* 1.6391	* 1.6633	* 1.7495	* 2.6781	* 3.2523	* 3.8713	*	
15	* 0.9295	* 0.9327	* 0.8399	* 0.5441	* F-SUB-Q			
	* 3.1681	* 3.1673	* 3.4975	* 5.3820	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3044	* 1.5343	* 1.8658	* 1.6687	* 1.9043	* 1.8581	* 2.0171	* 0.9343
	* 2.4449	* 2.4046	* 1.9920	* 2.2101	* 1.8984	* 1.9248	* 1.7658	* 3.4414
9	* 1.5343	* 1.8598	* 1.7512	* 1.9337	* 1.7340	* 1.8541	* 1.9900	* 0.9383
	* 2.4046	* 2.0109	* 2.1225	* 1.8964	* 2.1066	* 1.9320	* 1.7930	* 3.4391
10	* 1.8658	* 1.7475	* 1.5500	* 1.6118	* 1.9074	* 1.7049	* 1.9028	* 0.8463
	* 1.9920	* 2.1269	* 2.4054	* 2.2928	* 1.9279	* 2.1234	* 1.8896	* 3.8013
11	* 1.6687	* 1.9326	* 1.6103	* 1.8125	* 1.5826	* 1.7676	* 1.1403	* 0.5604
	* 2.2101	* 1.8975	* 2.2950	* 1.9429	* 2.1742	* 1.9234	* 2.8734	* 5.8423
12	* 1.9043	* 1.7335	* 1.9067	* 1.5812	* 1.3051	* 1.5081	* 0.8256	*
	* 1.8984	* 2.1073	* 1.9280	* 2.1760	* 2.0230	* 1.9333	* 3.5133	*
13	* 1.8581	* 1.8548	* 1.7067	* 1.7677	* 1.5078	* 1.4260	* 0.6407	*
	* 1.9248	* 1.9312	* 2.1211	* 1.9236	* 1.9334	* 1.9549	* 4.1730	*
14	* 2.0171	* 1.9906	* 1.9036	* 1.1405	* 0.8246	* 0.6405	*	*
	* 1.7658	* 1.7924	* 1.8889	* 2.8732	* 3.5147	* 4.1738	*	*
15	* 0.9343	* 0.9391	* 0.8464	* 0.5499	* F-SUB-Q			
	* 3.4414	* 3.4382	* 3.8011	* 5.8637	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3806	* 1.5627	* 1.8564	* 1.6615	* 1.8860	* 1.8453	* 2.0006	* 0.9428
	* 2.7053	* 2.6697	* 2.1887	* 2.4115	* 2.0753	* 2.1021	* 1.9347	* 3.6997
9	* 1.5627	* 1.8613	* 1.7453	* 1.9194	* 1.7258	* 1.8442	* 1.9756	* 0.9440
	* 2.6697	* 2.2389	* 2.3274	* 2.0765	* 2.2957	* 2.1071	* 1.9615	* 3.7021
10	* 1.8564	* 1.7416	* 1.5478	* 1.6192	* 1.9056	* 1.7052	* 1.8974	* 0.8588
	* 2.1887	* 2.3320	* 2.6395	* 2.4859	* 2.1102	* 2.3104	* 2.0597	* 4.0522
11	* 1.6615	* 1.9183	* 1.6180	* 1.8280	* 1.6202	* 1.7961	* 1.1730	* 0.5726
	* 2.4115	* 2.0776	* 2.4877	* 2.1512	* 2.3962	* 2.1274	* 3.1068	* 6.1955
12	* 1.8860	* 1.7252	* 1.9048	* 1.6193	* 1.3978	* 1.5879	* 0.8697	*
	* 2.0753	* 2.2965	* 2.1101	* 2.3983	* 2.2544	* 2.1583	* 3.8273	*
13	* 1.8453	* 1.8450	* 1.7070	* 1.7962	* 1.5875	* 1.5218	* 0.6880	*
	* 2.1021	* 2.1063	* 2.3079	* 2.1276	* 2.1584	* 2.1787	* 4.5410	*
14	* 2.0006	* 1.9762	* 1.8981	* 1.1731	* 0.8686	* 0.6879	*	*
	* 1.9347	* 1.9609	* 2.0589	* 3.1068	* 3.8288	* 4.5420	*	*
15	* 0.9428	* 0.9448	* 0.8588	* 0.5632	* F-SUB-Q			
	* 3.6997	* 3.7013	* 4.0523	* 6.2030	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4925	* 1.5876	* 1.8979	* 1.6813	* 1.9181	* 1.8670	* 2.0387	* 0.9360
	* 2.9823	* 2.9365	* 2.3426	* 2.5982	* 2.2103	* 2.2342	* 2.0369	* 3.9797
9	* 1.5876	* 1.9163	* 1.7710	* 1.9563	* 1.7493	* 1.8685	* 2.0152	* 0.9415
	* 2.9365	* 2.3974	* 2.5079	* 2.2205	* 2.4737	* 2.2417	* 2.0684	* 3.9751
10	* 1.8979	* 1.7670	* 1.5705	* 1.6412	* 1.9562	* 1.7369	* 1.9435	* 0.8548
	* 2.3426	* 2.5134	* 2.8457	* 2.7018	* 2.2578	* 2.4733	* 2.1833	* 4.3881
11	* 1.6813	* 1.9551	* 1.6398	* 1.9089	* 1.6818	* 1.8827	* 1.1866	* 0.5730
	* 2.5982	* 2.2218	* 2.7045	* 2.3608	* 2.6455	* 2.3265	* 3.4584	* 6.7495
12	* 1.9181	* 1.7482	* 1.9553	* 1.6803	* 1.5874	* 1.7553	* 0.9021	*
	* 2.2103	* 2.4745	* 2.2577	* 2.6477	* 2.4693	* 2.3470	* 4.2699	*
13	* 1.8670	* 1.8692	* 1.7388	* 1.8827	* 1.7550	* 1.6917	* 0.7245	*
	* 2.2342	* 2.2408	* 2.4705	* 2.3268	* 2.3472	* 2.3768	* 5.0949	*
14	* 2.0387	* 2.0157	* 1.9443	* 1.1867	* 0.9009	* 0.7243	*	*
	* 2.0369	* 2.0678	* 2.1825	* 3.4586	* 4.2721	* 5.0960	*	*
15	* 0.9360	* 0.9423	* 0.8547	* 0.5610	* F-SUB-Q			
	* 3.9797	* 3.9741	* 4.3885	* 6.7895	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5746	* 1.6080	* 1.9035	* 1.6792	* 1.9155	* 1.8628	* 2.0396	* 0.9327
	* 3.0010	* 2.9618	* 2.4519	* 2.7366	* 2.3726	* 2.4250	* 2.2033	* 4.3089
9	* 1.6080	* 1.9335	* 1.7718	* 1.9578	* 1.7515	* 1.8672	* 2.0180	* 0.9388
	* 2.9618	* 2.4737	* 2.6352	* 2.3488	* 2.6347	* 2.4324	* 2.2372	* 4.3034
10	* 1.9035	* 1.7677	* 1.5727	* 1.6483	* 1.9711	* 1.7493	* 1.9550	* 0.8553
	* 2.4519	* 2.6411	* 2.9896	* 2.8775	* 2.4306	* 2.6875	* 2.3620	* 4.7446
11	* 1.6792	* 1.9566	* 1.6467	* 1.9498	* 1.7208	* 1.9381	* 1.2038	* 0.5768
	* 2.7366	* 2.3502	* 2.8806	* 2.4439	* 2.7671	* 2.4492	* 3.6779	* 7.3059
12	* 1.9155	* 1.7504	* 1.9701	* 1.7192	* 1.7541	* 1.8678	* 0.9341	*
	* 2.3726	* 2.6357	* 2.4318	* 2.7699	* 2.6535	* 2.5096	* 4.5738	*
13	* 1.8628	* 1.8679	* 1.7514	* 1.9378	* 1.8677	* 1.8088	* 0.7608	*
	* 2.4250	* 2.4314	* 2.6844	* 2.4496	* 2.5098	* 2.5738	* 5.5344	*
14	* 2.0396	* 2.0186	* 1.9557	* 1.2039	* 0.9328	* 0.7606	*	*
	* 2.2033	* 2.2366	* 2.3613	* 3.6782	* 4.5764	* 5.5357	*	*
15	* 0.9327	* 0.9396	* 0.8552	* 0.5638	* F-SUB-Q			
	* 4.3089	* 4.3022	* 4.7453	* 7.3601	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5800	* 1.6031	* 1.8722	* 1.6544	* 1.8797	* 1.8347	* 2.0066	* 0.9302
	* 3.0337	* 2.9454	* 2.3978	* 2.6692	* 2.3185	* 2.3770	* 2.1760	* 4.2335
9	* 1.6031	* 1.9092	* 1.7463	* 1.9242	* 1.7308	* 1.8415	* 1.9869	* 0.9340
	* 2.9454	* 2.4433	* 2.5705	* 2.2960	* 2.5681	* 2.3884	* 2.2140	* 4.2478
10	* 1.8722	* 1.7422	* 1.5534	* 1.6393	* 1.9548	* 1.7415	* 1.9325	* 0.8570
	* 2.3978	* 2.5761	* 2.9134	* 2.7872	* 2.3739	* 2.6542	* 2.3548	* 4.6875
11	* 1.6544	* 1.9230	* 1.6381	* 1.9429	* 1.7236	* 1.9451	* 1.2181	* 0.5808
	* 2.6692	* 2.2974	* 2.7896	* 2.4741	* 2.7934	* 2.4770	* 3.6557	* 7.3061
12	* 1.8797	* 1.7296	* 1.9546	* 1.7219	* 1.7990	* 1.8984	* 0.9580	
	* 2.3185	* 2.5691	* 2.3751	* 2.7962	* 2.6820	* 2.5388	* 4.5523	
13	* 1.8347	* 1.8422	* 1.7436	* 1.9448	* 1.8982	* 1.8511	* 0.7896	
	* 2.3770	* 2.3874	* 2.6512	* 2.4774	* 2.5390	* 2.6030	* 5.4974	
14	* 2.0066	* 1.9875	* 1.9332	* 1.2181	* 0.9567	* 0.7894		
	* 2.1760	* 2.2134	* 2.3540	* 3.6562	* 4.5549	* 5.4990		
15	* 0.9302	* 0.9348	* 0.8568	* 0.5692	F-SUB-Q			
	* 4.2335	* 4.2468	* 4.6882	* 7.3416	M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5833	* 1.5937	* 1.8760	* 1.6462	* 1.8820	* 1.8319	* 2.0169	* 0.9113
	* 2.9006	* 2.8600	* 2.3075	* 2.5851	* 2.2306	* 2.2917	* 2.0835	* 4.1445
9	* 1.5937	* 1.9166	* 1.7399	* 1.9280	* 1.7249	* 1.8407	* 1.9982	* 0.9191
	* 2.8600	* 2.3479	* 2.4895	* 2.2097	* 2.4894	* 2.3016	* 2.1200	* 4.1485
10	* 1.8760	* 1.7353	* 1.5469	* 1.6395	* 1.9736	* 1.7463	* 1.9474	* 0.8409
	* 2.3075	* 2.4952	* 2.8215	* 2.7156	* 2.2811	* 2.5606	* 2.2558	* 4.5977
11	* 1.6462	* 1.9267	* 1.6382	* 1.9629	* 1.7332	* 1.9753	* 1.2043	* 0.5705
	* 2.5851	* 2.2112	* 2.7188	* 2.3564	* 2.6782	* 2.3605	* 3.5306	* 7.1769
12	* 1.8820	* 1.7237	* 1.9733	* 1.7313	* 1.8380	* 1.9433	* 0.9521	*
	* 2.2306	* 2.4904	* 2.2824	* 2.6810	* 2.5700	* 2.4148	* 4.3974	*
13	* 1.8319	* 1.8415	* 1.7485	* 1.9749	* 1.9431	* 1.9038	* 0.7879	*
	* 2.2917	* 2.3007	* 2.5575	* 2.3609	* 2.4151	* 2.4645	* 5.2960	*
14	* 2.0169	* 1.9988	* 1.9480	* 1.2042	* 0.9507	* 0.7877	*	
	* 2.0835	* 2.1194	* 2.2551	* 3.5313	* 4.4005	* 5.2975	*	
15	* 0.9113	* 0.9199	* 0.8406	* 0.5564	* F-SUB-Q			
	* 4.1445	* 4.1473	* 4.5988	* 7.2461	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5601	* 1.5682	* 1.8479	* 1.6181	* 1.8547	* 1.8066	* 1.9955	* 0.8935
	* 2.6824	* 2.6486	* 2.1419	* 2.4070	* 2.0792	* 2.1395	* 1.9392	* 3.8650
9	* 1.5682	* 1.8903	* 1.7116	* 1.9010	* 1.6987	* 1.8168	* 1.9778	* 0.9022
	* 2.6486	* 2.1723	* 2.3160	* 2.0545	* 2.3212	* 2.1462	* 1.9711	* 3.8623
10	* 1.8479	* 1.7057	* 1.5211	* 1.6185	* 1.9567	* 1.7266	* 1.9307	* 0.8259
	* 2.1419	* 2.3216	* 2.6192	* 2.5222	* 2.1144	* 2.3784	* 2.0889	* 4.2701
11	* 1.6181	* 1.8995	* 1.6172	* 1.9479	* 1.7165	* 1.9663	* 1.1883	* 0.5605
	* 2.4069	* 2.0559	* 2.5251	* 2.1674	* 2.4673	* 2.1638	* 3.2688	* 6.6292
12	* 1.8547	* 1.6975	* 1.9564	* 1.7146	* 1.8374	* 1.9432	* 0.9425	*
	* 2.0792	* 2.3222	* 2.1155	* 2.4699	* 2.3582	* 2.2126	* 4.0648	*
13	* 1.8066	* 1.8176	* 1.7289	* 1.9659	* 1.9430	* 1.9106	* 0.7827	*
	* 2.1395	* 2.1453	* 2.3756	* 2.1643	* 2.2130	* 2.2568	* 4.9013	*
14	* 1.9955	* 1.9784	* 1.9313	* 1.1883	* 0.9410	* 0.7825	*	*
	* 1.9392	* 1.9706	* 2.0883	* 3.2695	* 4.0679	* 4.9028	*	*
15	* 0.8935	* 0.9030	* 0.8256	* 0.5459	F-SUB-Q			
	* 3.8650	* 3.8612	* 4.2715	* 6.7023	M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5228	* 1.5287	* 1.7999	* 1.5765	* 1.8090	* 1.7661	* 1.9529	* 0.8747
	* 2.4944	* 2.4480	* 1.9756	* 2.2213	* 1.9194	* 1.9726	* 1.7858	* 3.5672
9	* 1.5287	* 1.8434	* 1.6693	* 1.8553	* 1.6587	* 1.7775	* 1.9361	* 0.8829
	* 2.4480	* 1.9985	* 2.1362	* 1.8941	* 2.1419	* 1.9768	* 1.8144	* 3.5634
10	* 1.7999	* 1.6635	* 1.4835	* 1.5830	* 1.9168	* 1.6905	* 1.8928	* 0.8101
	* 1.9756	* 2.1412	* 2.4132	* 2.3219	* 1.9427	* 2.1870	* 1.9187	* 3.9286
11	* 1.5765	* 1.8533	* 1.5817	* 1.9093	* 1.6822	* 1.9317	* 1.1697	* 0.5503
	* 2.2213	* 1.8954	* 2.3248	* 2.0163	* 2.2976	* 2.0142	* 3.0284	* 6.0880
12	* 1.8090	* 1.6575	* 1.9165	* 1.6804	* 1.8109	* 1.9134	* 0.9283	*
	* 1.9194	* 2.1429	* 1.9438	* 2.3002	* 2.1987	* 2.0654	* 3.7930	*
13	* 1.7661	* 1.7783	* 1.6928	* 1.9313	* 1.9131	* 1.8863	* 0.7732	*
	* 1.9726	* 1.9759	* 2.1843	* 2.0146	* 2.0657	* 2.1017	* 4.5703	*
14	* 1.9529	* 1.9367	* 1.8934	* 1.1695	* 0.9269	* 0.7730	*	*
	* 1.7858	* 1.8139	* 1.9182	* 3.0292	* 3.7961	* 4.5717	*	*
15	* 0.8747	* 0.8836	* 0.8098	* 0.5357	F-SUB-Q			
	* 3.5672	* 3.5623	* 3.9299	* 6.1590	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4695	* 1.4791	* 1.7285	* 1.5200	* 1.7401	* 1.7076	* 1.8843	* 0.8556
	* 2.5291	* 2.4543	* 2.0112	* 2.2550	* 1.9565	* 2.0021	* 1.8161	* 3.5888
9	* 1.4791	* 1.7726	* 1.6102	* 1.7856	* 1.6032	* 1.7197	* 1.8684	* 0.8611
	* 2.4543	* 2.0282	* 2.1661	* 1.9271	* 2.1733	* 2.0040	* 1.8441	* 3.5910
10	* 1.7285	* 1.6045	* 1.4317	* 1.5323	* 1.8503	* 1.6368	* 1.8296	* 0.7941
	* 2.0112	* 2.1721	* 2.4447	* 2.3378	* 1.9693	* 2.2119	* 1.9439	* 3.9357
11	* 1.5200	* 1.7836	* 1.5310	* 1.8433	* 1.6296	* 1.8696	* 1.1492	* 0.5399
	* 2.2550	* 1.9285	* 2.3401	* 2.0496	* 2.3274	* 2.0440	* 3.0248	* 6.0828
12	* 1.7401	* 1.6019	* 1.8500	* 1.6278	* 1.7600	* 1.8529	* 0.9128	*
	* 1.9565	* 2.1743	* 1.9704	* 2.3300	* 2.2272	* 2.0997	* 3.7988	*
13	* 1.7076	* 1.7205	* 1.6391	* 1.8691	* 1.8526	* 1.8316	* 0.7633	*
	* 2.0021	* 2.0032	* 2.2092	* 2.0445	* 2.0999	* 2.1353	* 4.5742	*
14	* 1.8843	* 1.8690	* 1.8301	* 1.1491	* 0.9114	* 0.7630	*	*
	* 1.8161	* 1.8436	* 1.9434	* 3.0256	* 3.8016	* 4.5757	*	*
15	* 0.8556	* 0.8619	* 0.7938	* 0.5271	* F-SUB-Q			
	* 3.5888	* 3.5900	* 3.9371	* 6.1352	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4309	* 1.4337	* 1.6910	* 1.4784	* 1.7051	* 1.6706	* 1.8545	* 0.8188
	* 2.3533	* 2.3117	* 1.8750	* 2.1175	* 1.8280	* 1.8752	* 1.6911	* 3.4400
9	* 1.4337	* 1.7365	* 1.5690	* 1.7500	* 1.5610	* 1.6835	* 1.8391	* 0.8279
	* 2.3117	* 1.8827	* 2.0273	* 1.7974	* 2.0429	* 1.8746	* 1.7160	* 3.4284
10	* 1.6910	* 1.5632	* 1.3929	* 1.4923	* 1.8186	* 1.5983	* 1.8021	* 0.7600
	* 1.8750	* 2.0346	* 2.2904	* 2.2006	* 1.8277	* 2.0645	* 1.8035	* 3.7691
11	* 1.4784	* 1.7480	* 1.4910	* 1.8107	* 1.5923	* 1.8413	* 1.1032	* 0.5159
	* 2.1175	* 1.7987	* 2.2032	* 1.8905	* 2.1642	* 1.8916	* 2.8501	* 5.8151
12	* 1.7051	* 1.5597	* 1.8183	* 1.5905	* 1.7294	* 1.8271	* 0.8745	*
	* 1.8280	* 2.0438	* 1.8287	* 2.1668	* 2.0604	* 1.9410	* 3.6303	*
13	* 1.6706	* 1.6843	* 1.6006	* 1.8409	* 1.8267	* 1.8103	* 0.7301	*
	* 1.8752	* 1.8738	* 2.0619	* 1.8920	* 1.9413	* 1.9718	* 4.3739	*
14	* 1.8545	* 1.8397	* 1.8027	* 1.1030	* 0.8731	* 0.7298	*	*
	* 1.6911	* 1.7156	* 1.8030	* 2.8509	* 3.6334	* 4.3753	*	*
15	* 0.8188	* 0.8287	* 0.7597	* 0.5011	* F-SUB-Q			
	* 3.4400	* 3.4273	* 3.7707	* 5.8950	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3714	* 1.3724	* 1.6161	* 1.4145	* 1.6326	* 1.6057	* 1.7811	* 0.7840 *
	* 2.2282	* 2.2133	* 1.8052	* 2.0410	* 1.7657	* 1.8062	* 1.6303	* 3.3350 *
9	* 1.3724	* 1.6631	* 1.5040	* 1.6758	* 1.4961	* 1.6186	* 1.7666	* 0.7930 *
	* 2.2133	* 1.7999	* 1.9463	* 1.7322	* 1.9701	* 1.8034	* 1.6529	* 3.3195 *
10	* 1.6161	* 1.4983	* 1.3350	* 1.4308	* 1.7451	* 1.5348	* 1.7336	* 0.7283 *
	* 1.8052	* 1.9535	* 2.1977	* 2.1111	* 1.7511	* 1.9781	* 1.7290	* 3.6410 *
11	* 1.4145	* 1.6738	* 1.4296	* 1.7372	* 1.5291	* 1.7706	* 1.0601	* 0.4944 *
	* 2.0410	* 1.7335	* 2.1136	* 1.8040	* 2.0598	* 1.7913	* 2.7185	* 5.5891 *
12	* 1.6326	* 1.4948	* 1.7448	* 1.5274	* 1.6653	* 1.7559	* 0.8387 *	
	* 1.7657	* 1.9710	* 1.7521	* 2.0623	* 1.9515	* 1.8398	* 3.4453 *	
13	* 1.6057	* 1.6194	* 1.5370	* 1.7702	* 1.7556	* 1.7440	* 0.7004 *	
	* 1.8062	* 1.8026	* 1.9755	* 1.7918	* 1.8400	* 1.8731	* 4.1764 *	
14	* 1.7811	* 1.7671	* 1.7342	* 1.0600	* 0.8373	* 0.7002 *		
	* 1.6303	* 1.6524	* 1.7286	* 2.7193	* 3.4484	* 4.1778 *		
15	* 0.7840	* 0.7938	* 0.7280	* 0.4799	* F-SUB-Q			
	* 3.3350	* 3.3183	* 3.6427	* 5.6693	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2891	* 1.2927	* 1.4980	* 1.3260	* 1.5173	* 1.5087	* 1.6572	* 0.7492
	* 2.2091	* 2.1409	* 1.8093	* 2.0288	* 1.7761	* 1.7992	* 1.6402	* 3.2772
9	* 1.2927	* 1.5474	* 1.4125	* 1.5576	* 1.4052	* 1.5212	* 1.6440	* 0.7548
	* 2.1409	* 1.7847	* 1.9265	* 1.7383	* 1.9533	* 1.7943	* 1.6613	* 3.2710
10	* 1.4980	* 1.4073	* 1.2558	* 1.3450	* 1.6237	* 1.4428	* 1.6173	* 0.6974
	* 1.8093	* 1.9335	* 2.1696	* 2.0817	* 1.7457	* 1.9567	* 1.7261	* 3.5584
11	* 1.3260	* 1.5558	* 1.3440	* 1.6174	* 1.4371	* 1.6510	* 1.0177	* 0.4747
	* 2.0288	* 1.7396	* 2.0838	* 1.7890	* 2.0283	* 1.7867	* 2.6077	* 5.4158
12	* 1.5173	* 1.4041	* 1.6234	* 1.4357	* 1.5628	* 1.6331	* 0.8037	
	* 1.7761	* 1.9549	* 1.7468	* 2.0299	* 1.9179	* 1.8244	* 3.3396	
13	* 1.5087	* 1.5219	* 1.4449	* 1.6506	* 1.6328	* 1.6254	* 0.6732	
	* 1.7992	* 1.7935	* 1.9542	* 1.7872	* 1.8247	* 1.8528	* 4.0166	
14	* 1.6572	* 1.6444	* 1.6178	* 1.0175	* 0.8025	* 0.6730		
	* 1.6402	* 1.6609	* 1.7256	* 2.6086	* 3.3423	* 4.0180		
15	* 0.7492	* 0.7554	* 0.6971	* 0.4631	* F-SUB-Q			
	* 3.2772	* 3.2700	* 3.5600	* 5.4674	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2154	* 1.2107	* 1.4013	* 1.2468	* 1.4193	* 1.4216	* 1.5542	* 0.6925
	* 2.1485	* 2.1370	* 1.8163	* 2.0315	* 1.7948	* 1.8062	* 1.6547	* 3.3613
9	* 1.2107	* 1.4512	* 1.3319	* 1.4581	* 1.3193	* 1.4330	* 1.5391	* 0.7005
	* 2.1370	* 1.7736	* 1.9197	* 1.7496	* 1.9571	* 1.8000	* 1.6777	* 3.3404
10	* 1.4013	* 1.3269	* 1.1841	* 1.2614	* 1.5196	* 1.3562	* 1.5171	* 0.6435
	* 1.8163	* 1.9268	* 2.1598	* 2.0841	* 1.7482	* 1.9539	* 1.7325	* 3.6477
11	* 1.2468	* 1.4563	* 1.2603	* 1.5148	* 1.3514	* 1.5481	* 0.9427	* 0.4387
	* 2.0315	* 1.7509	* 2.0863	* 1.7761	* 2.0043	* 1.7663	* 2.6332	* 5.5126
12	* 1.4193	* 1.3182	* 1.5193	* 1.3499	* 1.4691	* 1.5293	* 0.7420	*
	* 1.7948	* 1.9587	* 1.7493	* 2.0068	* 1.9227	* 1.8293	* 3.3885	*
13	* 1.4216	* 1.4337	* 1.3581	* 1.5477	* 1.5291	* 1.5218	* 0.6179	*
	* 1.8062	* 1.7992	* 1.9514	* 1.7668	* 1.8295	* 1.8640	* 4.1294	*
14	* 1.5542	* 1.5396	* 1.5175	* 0.9426	* 0.7407	* 0.6177	*	*
	* 1.6547	* 1.6773	* 1.7320	* 2.6341	* 3.3916	* 4.1308	*	*
15	* 0.6925	* 0.7011	* 0.6432	* 0.4260	* F-SUB-Q			
	* 3.3613	* 3.3394	* 3.6497	* 5.5902	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0918	* 1.0925	* 1.2504	* 1.1297	* 1.2587	* 1.2711	* 1.3732	* 0.6271
	* 2.2595	* 2.2335	* 1.9375	* 2.1377	* 1.9329	* 1.9337	* 1.7930	* 3.5572
9	* 1.0925	* 1.2866	* 1.2002	* 1.2938	* 1.1865	* 1.2815	* 1.3585	* 0.6348
	* 2.2335	* 1.8925	* 2.0259	* 1.8742	* 2.0733	* 1.9255	* 1.8195	* 3.5355
10	* 1.2504	* 1.1958	* 1.0657	* 1.1328	* 1.3397	* 1.2161	* 1.3354	* 0.5800
	* 1.9375	* 2.0313	* 2.2838	* 2.2027	* 1.8794	* 2.0833	* 1.8772	* 3.8758
11	* 1.1297	* 1.2927	* 1.1318	* 1.3400	* 1.2120	* 1.3653	* 0.8481	* 0.3949
	* 2.1377	* 1.8766	* 2.2051	* 1.9028	* 2.1154	* 1.8921	* 2.7827	* 5.8412
12	* 1.2587	* 1.1855	* 1.3395	* 1.2107	* 1.3123	* 1.3514	* 0.6695	*
	* 1.9329	* 2.0750	* 1.8806	* 2.1179	* 2.0193	* 1.9418	* 3.5405	*
13	* 1.2711	* 1.2820	* 1.2177	* 1.3650	* 1.3512	* 1.3356	* 0.5536	*
	* 1.9337	* 1.9247	* 2.0807	* 1.8926	* 1.9420	* 2.0009	* 4.3499	*
14	* 1.3732	* 1.3589	* 1.3357	* 0.8479	* 0.6684	* 0.5534	*	*
	* 1.7930	* 1.8191	* 1.8768	* 2.7837	* 3.5436	* 4.3515	*	*
15	* 0.6271	* 0.6353	* 0.5797	* 0.3832	* F-SUB-Q			
	* 3.5572	* 3.5345	* 3.8781	* 5.9274	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8611	* 0.8830	* 1.1114	* 0.9128	* 1.1065	* 0.9934	* 1.1565	* 0.5145 *
	* 2.7364	* 2.6487	* 2.0958	* 2.5534	* 2.1150	* 2.3925	* 2.0584	* 4.2034 *
9	* 0.8830	* 1.0955	* 0.9704	* 1.1135	* 0.9394	* 1.0030	* 1.1447	* 0.5190 *
	* 2.6487	* 2.1342	* 2.4099	* 2.0971	* 2.5102	* 2.3776	* 2.0860	* 4.1901 *
10	* 1.1114	* 0.9680	* 0.8406	* 0.9017	* 1.1278	* 0.9631	* 1.0634	* 0.4675 *
	* 2.0958	* 2.4156	* 2.7907	* 2.6584	* 2.1349	* 2.5351	* 2.2764	* 4.6554 *
11	* 0.9128	* 1.1125	* 0.9010	* 1.1377	* 0.9579	* 1.1100	* 0.6825	* 0.3167 *
	* 2.5534	* 2.0991	* 2.6612	* 2.1409	* 2.5709	* 2.2325	* 3.3249	* 7.0354 *
12	* 1.1065	* 0.9387	* 1.1275	* 0.9569	* 1.0382	* 1.1457	* 0.5506 *	
	* 2.1150	* 2.5113	* 2.1361	* 2.5736	* 2.4425	* 2.2061	* 4.1380 *	
13	* 0.9934	* 1.0034	* 0.9641	* 1.1098	* 1.1454	* 1.0304	* 0.4388 *	
	* 2.3925	* 2.3767	* 2.5323	* 2.2329	* 2.2066	* 2.4765	* 5.2590 *	
14	* 1.1565	* 1.1449	* 1.0635	* 0.6823	* 0.5497	* 0.4387 *		
	* 2.0584	* 2.0856	* 2.2763	* 3.3263	* 4.1412	* 5.2609 *		
15	* 0.5145	* 0.5194	* 0.4672	* 0.3074	* F-SUB-Q			
	* 4.2034	* 4.1891	* 4.6584	* 7.1382	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3364	* 0.3639	* 0.4419	* 0.3768	* 0.4393	* 0.3746	* 0.4064	* 0.2083 *
	* 6.7367	* 6.2043	* 5.0992	* 5.9881	* 5.1663	* 6.1386	* 5.6648	*10.0775 *
9	* 0.3639	* 0.4305	* 0.3805	* 0.4400	* 0.3714	* 0.3764	* 0.4016	* 0.2074 *
	* 6.2043	* 5.2456	* 5.9378	* 5.1469	* 6.1269	* 6.1276	* 5.7492	*10.1781 *
10	* 0.4419	* 0.3799	* 0.3458	* 0.3699	* 0.4409	* 0.3690	* 0.3694	* 0.1888 *
	* 5.0992	* 5.9476	* 6.5638	* 6.2554	* 5.2769	* 6.3793	* 6.3313	*11.1831 *
11	* 0.3768	* 0.4396	* 0.3696	* 0.4376	* 0.3777	* 0.4163	* 0.2748	* 0.1288 *
	* 5.9881	* 5.1515	* 6.2613	* 5.3712	* 6.2619	* 5.7428	* 7.9785	*16.7716 *
12	* 0.4393	* 0.3712	* 0.4407	* 0.3774	* 0.3840	* 0.4036	* 0.2229 *	
	* 5.1663	* 6.1294	* 5.2792	* 6.2686	* 6.3654	* 6.0387	* 9.8968 *	
13	* 0.3746	* 0.3765	* 0.3693	* 0.4162	* 0.4035	* 0.3556	* 0.1754 *	
	* 6.1386	* 6.1260	* 6.3746	* 5.7440	* 6.0399	* 6.9159	*12.7153 *	
14	* 0.4064	* 0.4016	* 0.3694	* 0.2747	* 0.2226	* 0.1753 *		
	* 5.6648	* 5.7482	* 6.3317	* 7.9827	* 9.9011	*12.7206 *		
15	* 0.2083	* 0.2075	* 0.1887	* 0.1262	* F-SUB-Q			
	*10.0775	*10.1743	*11.1905	*16.8595	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3419	* 0.4412	* 0.5587	* 0.4964	* 0.5717	* 0.4747	* 0.4185	* 0.2188
	* 5.5091	* 5.3324	* 4.2802	* 4.7832	* 4.2107	* 4.8920	* 4.7225	* 7.7841
9	* 0.4412	* 0.5101	* 0.4882	* 0.5647	* 0.4892	* 0.4680	* 0.4651	* 0.2485
	* 5.3324	* 4.5879	* 4.7718	* 4.2459	* 4.8282	* 4.9703	* 4.8087	* 7.9660
10	* 0.5587	* 0.4878	* 0.3878	* 0.4523	* 0.5338	* 0.4522	* 0.4480	* 0.2339
	* 4.2802	* 4.7721	* 5.3677	* 5.1178	* 4.4754	* 5.2264	* 5.2674	* 8.8477
11	* 0.4964	* 0.5646	* 0.4521	* 0.4814	* 0.4240	* 0.4513	* 0.3145	* 0.1641
	* 4.7832	* 4.2470	* 5.1203	* 4.7288	* 5.2755	* 4.9855	* 6.9394	* 13.0298
12	* 0.5717	* 0.4891	* 0.5337	* 0.4238	* 0.3262	* 0.3460	* 0.2299	*
	* 4.2107	* 4.8285	* 4.4765	* 5.2767	* 5.1819	* 5.0489	* 7.9608	*
13	* 0.4747	* 0.4680	* 0.4523	* 0.4513	* 0.3459	* 0.2854	* 0.1624	*
	* 4.8920	* 4.9711	* 5.2264	* 4.9856	* 5.0484	* 5.5722	* 9.9474	*
14	* 0.4185	* 0.4652	* 0.4481	* 0.3145	* 0.2298	* 0.1624	*	*
	* 4.7225	* 4.8078	* 5.2665	* 6.9392	* 7.9522	* 9.9484	*	*
15	* 0.2188	* 0.2486	* 0.2339	* 0.1618	* F-SUB-Q			
	* 7.7841	* 7.9614	* 8.8476	* 12.9524	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8039	* 1.0014	* 1.2808	* 1.1228	* 1.3097	* 1.1535	* 1.0983	* 0.5718
	* 2.5132	* 2.4521	* 1.9484	* 2.1993	* 1.9172	* 2.1116	* 1.9429	* 3.4125
9	* 1.0014	* 1.1808	* 1.1619	* 1.2969	* 1.1501	* 1.1358	* 1.2008	* 0.6093
	* 2.4521	* 2.0615	* 2.0948	* 1.9287	* 2.1443	* 2.1242	* 1.9609	* 3.4463
10	* 1.2808	* 1.1605	* 0.9116	* 1.0376	* 1.2336	* 1.0904	* 1.1506	* 0.5655
	* 1.9484	* 2.0957	* 2.4630	* 2.3392	* 2.0188	* 2.2594	* 2.1433	* 3.8478
11	* 1.1228	* 1.2966	* 1.0371	* 1.1393	* 0.9921	* 1.0775	* 0.7414	* 0.3914
	* 2.1993	* 1.9292	* 2.3404	* 2.0782	* 2.3309	* 2.1473	* 3.0622	* 5.6888
12	* 1.3097	* 1.1500	* 1.2334	* 0.9915	* 0.7743	* 0.8754	* 0.5423	*
	* 1.9172	* 2.1443	* 2.0193	* 2.3318	* 2.1932	* 2.0613	* 3.4816	*
13	* 1.1535	* 1.1359	* 1.0909	* 1.0776	* 0.8754	* 0.7452	* 0.3912	*
	* 2.1116	* 2.1243	* 2.2591	* 2.1474	* 2.0612	* 2.2772	* 4.2598	*
14	* 1.0983	* 1.2011	* 1.1509	* 0.7416	* 0.5420	* 0.3911	*	*
	* 1.9429	* 1.9605	* 2.1429	* 3.0618	* 3.4788	* 4.2602	*	*
15	* 0.5718	* 0.6098	* 0.5656	* 0.3863	* F-SUB-Q			
	* 3.4125	* 3.4466	* 3.8474	* 5.6510	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9981	* 1.2487	* 1.5372	* 1.3918	* 1.5668	* 1.4550	* 1.5019	* 0.7743
	* 2.1341	* 2.0396	* 1.6836	* 1.8383	* 1.6574	* 1.7342	* 1.6397	* 2.8475
9	* 1.2487	* 1.4561	* 1.4412	* 1.5696	* 1.4332	* 1.4368	* 1.5065	* 0.7825
	* 2.0396	* 1.7553	* 1.7619	* 1.6502	* 1.7800	* 1.7470	* 1.6641	* 2.8642
10	* 1.5372	* 1.4393	* 1.2188	* 1.3003	* 1.4969	* 1.3537	* 1.4324	* 0.7196
	* 1.6836	* 1.7629	* 2.0312	* 1.9456	* 1.7210	* 1.8796	* 1.7837	* 3.1575
11	* 1.3918	* 1.5692	* 1.2995	* 1.3887	* 1.2266	* 1.3115	* 0.9271	* 0.4901
	* 1.8383	* 1.6507	* 1.9467	* 1.7797	* 1.9380	* 1.8217	* 2.5240	* 4.6935
12	* 1.5668	* 1.4330	* 1.4965	* 1.2258	* 0.9586	* 1.0624	* 0.6662	*
	* 1.6574	* 1.7802	* 1.7215	* 1.9387	* 1.8329	* 1.7768	* 2.9118	*
13	* 1.4550	* 1.4370	* 1.3546	* 1.3116	* 1.0623	* 0.9464	* 0.4939	*
	* 1.7342	* 1.7470	* 1.8792	* 1.8218	* 1.7767	* 1.8574	* 3.4612	*
14	* 1.5019	* 1.5068	* 1.4328	* 0.9274	* 0.6658	* 0.4938	*	*
	* 1.6397	* 1.6637	* 1.7832	* 2.5236	* 2.9098	* 3.4616	*	*
15	* 0.7743	* 0.7830	* 0.7198	* 0.4857	F-SUB-Q			
	* 2.8475	* 2.8644	* 3.1570	* 4.6426	M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1061	* 1.3840	* 1.7689	* 1.5556	* 1.8017	* 1.6524	* 1.8034	* 0.8806
	* 2.0062	* 1.9166	* 1.5224	* 1.7104	* 1.4966	* 1.5949	* 1.4650	* 2.6914
9	* 1.3840	* 1.6843	* 1.6148	* 1.8047	* 1.6006	* 1.6398	* 1.7783	* 0.8818
	* 1.9166	* 1.5903	* 1.6423	* 1.4913	* 1.6555	* 1.6074	* 1.4891	* 2.7016
10	* 1.7689	* 1.6124	* 1.3936	* 1.4558	* 1.7202	* 1.5099	* 1.6510	* 0.7923
	* 1.5224	* 1.6435	* 1.8978	* 1.8126	* 1.5542	* 1.7465	* 1.6082	* 2.9995
11	* 1.5556	* 1.8042	* 1.4549	* 1.6074	* 1.3662	* 1.5025	* 1.0124	* 0.5318
	* 1.7104	* 1.4917	* 1.8137	* 1.6116	* 1.8018	* 1.6451	* 2.3920	* 4.4855
12	* 1.8017	* 1.6003	* 1.7197	* 1.3650	* 1.0619	* 1.2117	* 0.7240	*
	* 1.4966	* 1.6557	* 1.5546	* 1.8025	* 1.6891	* 1.5972	* 2.7700	*
13	* 1.6524	* 1.6403	* 1.5110	* 1.5027	* 1.2115	* 1.0856	* 0.5365	*
	* 1.5949	* 1.6073	* 1.7459	* 1.6452	* 1.5972	* 1.6734	* 3.2905	*
14	* 1.8034	* 1.7788	* 1.6516	* 1.0128	* 0.7234	* 0.5364	*	*
	* 1.4650	* 1.4887	* 1.6077	* 2.3916	* 2.7684	* 3.2908	*	*
15	* 0.8806	* 0.8824	* 0.7924	* 0.5259	F-SUB-Q			
	* 2.6914	* 2.7016	* 2.9989	* 4.4470	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1548	* 1.4507	* 1.8746	* 1.6251	* 1.9085	* 1.7418	* 1.9379	* 0.9345 *
	* 2.0267	* 1.9123	* 1.4995	* 1.7078	* 1.4720	* 1.5906	* 1.4365	* 2.6844 *
9	* 1.4507	* 1.7801	* 1.6849	* 1.9098	* 1.6709	* 1.7258	* 1.9046	* 0.9324 *
	* 1.9123	* 1.5765	* 1.6455	* 1.4688	* 1.6523	* 1.6026	* 1.4612	* 2.6944 *
10	* 1.8746	* 1.6822	* 1.4543	* 1.5202	* 1.8161	* 1.5710	* 1.7487	* 0.8341 *
	* 1.4995	* 1.6469	* 1.9119	* 1.8113	* 1.5318	* 1.7461	* 1.5863	* 2.9895 *
11	* 1.6251	* 1.9092	* 1.5192	* 1.7002	* 1.4218	* 1.5838	* 1.0562	* 0.5536 *
	* 1.7078	* 1.4693	* 1.8124	* 1.5971	* 1.8081	* 1.6243	* 2.3791	* 4.4843 *
12	* 1.9085	* 1.6706	* 1.8156	* 1.4204	* 1.1060	* 1.2794	* 0.7547	*
	* 1.4720	* 1.6525	* 1.5322	* 1.8089	* 1.6821	* 1.5708	* 2.7715	*
13	* 1.7418	* 1.7262	* 1.5722	* 1.5840	* 1.2793	* 1.1470	* 0.5601	*
	* 1.5906	* 1.6025	* 1.7453	* 1.6244	* 1.5708	* 1.6504	* 3.2887	*
14	* 1.9379	* 1.9051	* 1.7493	* 1.0566	* 0.7540	* 0.5600	*	
	* 1.4365	* 1.4608	* 1.5858	* 2.3788	* 2.7702	* 3.2891	*	
15	* 0.9345	* 0.9330	* 0.8342	* 0.5465	* F-SUB-Q			
	* 2.6844	* 2.6944	* 2.9890	* 4.4530	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1758	* 1.4811	* 1.9133	* 1.6480	* 1.9478	* 1.7721	* 1.9905	* 0.9601
	* 2.0986	* 1.9626	* 1.5342	* 1.7547	* 1.5002	* 1.6378	* 1.4671	* 2.7470
9	* 1.4811	* 1.8124	* 1.7058	* 1.9469	* 1.6937	* 1.7556	* 1.9544	* 0.9554
	* 1.9626	* 1.6256	* 1.7019	* 1.5000	* 1.6948	* 1.6488	* 1.4920	* 2.7608
10	* 1.9133	* 1.7030	* 1.4708	* 1.5405	* 1.8487	* 1.5886	* 1.7847	* 0.8559
	* 1.5342	* 1.7033	* 1.9843	* 1.8629	* 1.5606	* 1.7893	* 1.6244	* 3.0498
11	* 1.6480	* 1.9462	* 1.5394	* 1.7312	* 1.4443	* 1.6127	* 1.0779	* 0.5647
	* 1.7547	* 1.5005	* 1.8641	* 1.6491	* 1.8761	* 1.6771	* 2.4026	* 4.5469
12	* 1.9478	* 1.6933	* 1.8482	* 1.4430	* 1.1232	* 1.3078	* 0.7705	
	* 1.5002	* 1.6951	* 1.5610	* 1.8770	* 1.7445	* 1.6195	* 2.8663	
13	* 1.7721	* 1.7561	* 1.5900	* 1.6129	* 1.3076	* 1.1740	* 0.5749	
	* 1.6378	* 1.6487	* 1.7884	* 1.6773	* 1.6196	* 1.7053	* 3.3901	
14	* 1.9905	* 1.9549	* 1.7854	* 1.0782	* 0.7698	* 0.5748		
	* 1.4671	* 1.4916	* 1.6239	* 2.4024	* 2.8650	* 3.3906		
15	* 0.9601	* 0.9560	* 0.8560	* 0.5576	* F-SUB-Q			
	* 2.7470	* 2.7609	* 3.0494	* 4.5144	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1881	* 1.4846	* 1.9410	* 1.6585	* 1.9748	* 1.7890	* 2.0283	* 0.9627 *
	* 2.1810	* 2.0405	* 1.5736	* 1.8144	* 1.5382	* 1.6870	* 1.5020	* 2.8629 *
9	* 1.4846	* 1.8366	* 1.7159	* 1.9731	* 1.7031	* 1.7726	* 1.9906	* 0.9596 *
	* 2.0405	* 1.6680	* 1.7562	* 1.5392	* 1.7530	* 1.6946	* 1.5241	* 2.8651 *
10	* 1.9410	* 1.7130	* 1.4767	* 1.5482	* 1.8726	* 1.6002	* 1.8120	* 0.8568 *
	* 1.5736	* 1.7579	* 2.0531	* 1.9267	* 1.6056	* 1.8485	* 1.6541	* 3.1560 *
11	* 1.6585	* 1.9724	* 1.5470	* 1.7542	* 1.4486	* 1.6373	* 1.0780	* 0.5636 *
	* 1.8144	* 1.5397	* 1.9281	* 1.7121	* 1.9620	* 1.7416	* 2.5120	* 4.7429 *
12	* 1.9748	* 1.7027	* 1.8721	* 1.4471	* 1.1351	* 1.3356	* 0.7730	*
	* 1.5382	* 1.7533	* 1.6061	* 1.9631	* 1.8268	* 1.6847	* 3.0327	*
13	* 1.7890	* 1.7731	* 1.6017	* 1.6374	* 1.3354	* 1.2039	* 0.5771	*
	* 1.6870	* 1.6944	* 1.8475	* 1.7416	* 1.6848	* 1.7804	* 3.6081	*
14	* 2.0283	* 1.9911	* 1.8126	* 1.0782	* 0.7722	* 0.5770	*	*
	* 1.5020	* 1.5237	* 1.6536	* 2.5119	* 3.0316	* 3.6086	*	*
15	* 0.9627	* 0.9602	* 0.8569	* 0.5545	* F-SUB-Q			
	* 2.8629	* 2.8653	* 3.1559	* 4.7259	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2000	* 1.4806	* 1.9414	* 1.6511	* 1.9734	* 1.7835	* 2.0337	* 0.9593 *
	* 2.3382	* 2.1786	* 1.6703	* 1.9337	* 1.6299	* 1.7745	* 1.5665	* 2.9991 *
9	* 1.4806	* 1.8363	* 1.7074	* 1.9716	* 1.6940	* 1.7680	* 1.9956	* 0.9564 *
	* 2.1786	* 1.7725	* 1.8722	* 1.6333	* 1.8673	* 1.7850	* 1.5932	* 3.0067 *
10	* 1.9414	* 1.7044	* 1.4676	* 1.5405	* 1.8713	* 1.5944	* 1.8139	* 0.8540 *
	* 1.6703	* 1.8742	* 2.1884	* 2.0558	* 1.7068	* 1.9618	* 1.7424	* 3.3286 *
11	* 1.6511	* 1.9708	* 1.5393	* 1.7541	* 1.4453	* 1.6416	* 1.0750	* 0.5609 *
	* 1.9337	* 1.6339	* 2.0573	* 1.8210	* 2.0916	* 1.8460	* 2.6804	* 5.0479 *
12	* 1.9734	* 1.6936	* 1.8707	* 1.4436	* 1.1471	* 1.3547	* 0.7741	*
	* 1.6299	* 1.8674	* 1.7073	* 2.0927	* 1.9501	* 1.7887	* 3.2313	*
13	* 1.7835	* 1.7685	* 1.5959	* 1.6418	* 1.3545	* 1.2230	* 0.5804	*
	* 1.7745	* 1.7848	* 1.9606	* 1.8460	* 1.7889	* 1.8989	* 3.8708	*
14	* 2.0337	* 1.9961	* 1.8144	* 1.0752	* 0.7733	* 0.5803	*	*
	* 1.5665	* 1.5928	* 1.7419	* 2.6804	* 3.2303	* 3.8714	*	*
15	* 0.9593	* 0.9571	* 0.8540	* 0.5511	* F-SUB-Q			
	* 2.9991	* 3.0069	* 3.3286	* 5.0367	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2036	* 1.4713	* 1.9417	* 1.6418	* 1.9718	* 1.7759	* 2.0366	* 0.9505 *
	* 2.5524	* 2.3814	* 1.8097	* 2.1050	* 1.7616	* 1.9103	* 1.6738	* 3.2351 *
9	* 1.4713	* 1.8367	* 1.6981	* 1.9700	* 1.6831	* 1.7612	* 1.9986	* 0.9488 *
	* 2.3814	* 1.9229	* 2.0386	* 1.7681	* 2.0302	* 1.9226	* 1.7044	* 3.2421 *
10	* 1.9417	* 1.6950	* 1.4586	* 1.5314	* 1.8709	* 1.5877	* 1.8154	* 0.8459 *
	* 1.8097	* 2.0408	* 2.3851	* 2.2406	* 1.8498	* 2.1239	* 1.8719	* 3.6051 *
11	* 1.6418	* 1.9693	* 1.5301	* 1.7555	* 1.4410	* 1.6480	* 1.0679	* 0.5560 *
	* 2.1050	* 1.7688	* 2.2423	* 1.9727	* 2.2743	* 1.9941	* 2.9121	* 5.4847 *
12	* 1.9718	* 1.6827	* 1.8702	* 1.4392	* 1.1522	* 1.3734	* 0.7725	*
	* 1.7616	* 2.0302	* 1.8504	* 2.2755	* 2.1126	* 1.9275	* 3.5173	*
13	* 1.7759	* 1.7618	* 1.5893	* 1.6481	* 1.3731	* 1.2418	* 0.5817	*
	* 1.9103	* 1.9224	* 2.1226	* 1.9942	* 1.9276	* 2.0437	* 4.2054	*
14	* 2.0366	* 1.9991	* 1.8158	* 1.0680	* 0.7716	* 0.5815	*	
	* 1.6738	* 1.7039	* 1.8714	* 2.9123	* 3.5165	* 4.2061	*	
15	* 0.9505	* 0.9494	* 0.8459	* 0.5454	* F-SUB-Q			
	* 3.2351	* 3.2422	* 3.6053	* 5.4807	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1966	* 1.4648	* 1.9004	* 1.6106	* 1.9277	* 1.7411	* 1.9940	* 0.9479 *
	* 2.8319	* 2.6049	* 2.0043	* 2.3197	* 1.9444	* 2.1097	* 1.8551	* 3.5157 *
9	* 1.4648	* 1.7984	* 1.6648	* 1.9265	* 1.6515	* 1.7286	* 1.9570	* 0.9427 *
	* 2.6049	* 2.1377	* 2.2526	* 1.9534	* 2.2319	* 2.1191	* 1.8858	* 3.5311 *
10	* 1.9004	* 1.6617	* 1.4370	* 1.5074	* 1.8313	* 1.5589	* 1.7791	* 0.8473 *
	* 2.0043	* 2.2547	* 2.6180	* 2.4614	* 2.0426	* 2.3343	* 2.0623	* 3.8806 *
11	* 1.6106	* 1.9258	* 1.5064	* 1.7205	* 1.4254	* 1.6195	* 1.0715	* 0.5572 *
	* 2.3197	* 1.9541	* 2.4628	* 2.1942	* 2.5277	* 2.2221	* 3.1439	* 5.8832 *
12	* 1.9277	* 1.6510	* 1.8307	* 1.4239	* 1.1460	* 1.3592	* 0.7779	*
	* 1.9444	* 2.2319	* 2.0433	* 2.5293	* 2.3655	* 2.1619	* 3.8636	*
13	* 1.7411	* 1.7292	* 1.5604	* 1.6195	* 1.3589	* 1.2334	* 0.5921	*
	* 2.1097	* 2.1189	* 2.3328	* 2.2222	* 2.1621	* 2.2893	* 4.5879	*
14	* 1.9940	* 1.9575	* 1.7795	* 1.0716	* 0.7769	* 0.5920	*	
	* 1.8551	* 1.8854	* 2.0618	* 3.1443	* 3.8628	* 4.5888	*	
15	* 0.9479	* 0.9434	* 0.8473	* 0.5484	* F-SUB-Q			
	* 3.5157	* 3.5314	* 3.8810	* 5.8600	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1928	* 1.4505	* 1.9165	* 1.6097	* 1.9410	* 1.7422	* 2.0119	* 0.9325 *
	* 3.1231	* 2.9075	* 2.1924	* 2.5567	* 2.1207	* 2.2880	* 1.9901	* 3.8551 *
9	* 1.4505	* 1.8145	* 1.6655	* 1.9407	* 1.6482	* 1.7310	* 1.9753	* 0.9313 *
	* 2.9075	* 2.3394	* 2.4819	* 2.1346	* 2.4569	* 2.3004	* 2.0267	* 3.8624 *
10	* 1.9165	* 1.6623	* 1.4300	* 1.5035	* 1.8475	* 1.5619	* 1.7973	* 0.8330 *
	* 2.1924	* 2.4848	* 2.9073	* 2.7224	* 2.2352	* 2.5527	* 2.2288	* 4.2876 *
11	* 1.6097	* 1.9400	* 1.5022	* 1.7383	* 1.4231	* 1.6429	* 1.0594	* 0.5489 *
	* 2.5567	* 2.1354	* 2.7246	* 2.4048	* 2.8008	* 2.4384	* 3.5098	* 6.5431 *
12	* 1.9410	* 1.6478	* 1.8469	* 1.4219	* 1.1481	* 1.3901	* 0.7741	*
	* 2.1207	* 2.4570	* 2.2359	* 2.8025	* 2.6133	* 2.3697	* 4.3255	*
13	* 1.7422	* 1.7315	* 1.5634	* 1.6429	* 1.3898	* 1.2673	* 0.5896	*
	* 2.2880	* 2.3001	* 2.5511	* 2.4385	* 2.3699	* 2.5191	* 5.1969	*
14	* 2.0119	* 1.9757	* 1.7977	* 1.0594	* 0.7731	* 0.5895	*	
	* 1.9901	* 2.0262	* 2.2284	* 3.5104	* 4.3249	* 5.1980	*	
15	* 0.9325	* 0.9319	* 0.8329	* 0.5371	* F-SUB-Q			
	* 3.8551	* 3.8624	* 4.2884	* 6.5535	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1978	* 1.4487	* 1.9128	* 1.6008	* 1.9326	* 1.7308	* 2.0045	* 0.9263 *
	* 3.1357	* 3.0000	* 2.3570	* 2.7586	* 2.3202	* 2.5445	* 2.2062	* 4.2750 *
9	* 1.4487	* 1.8136	* 1.6572	* 1.9341	* 1.6375	* 1.7215	* 1.9690	* 0.9254 *
	* 3.0000	* 2.4719	* 2.6772	* 2.3232	* 2.6935	* 2.5575	* 2.2465	* 4.2829 *
10	* 1.9128	* 1.6539	* 1.4230	* 1.4974	* 1.8458	* 1.5563	* 1.7954	* 0.8296 *
	* 2.3570	* 2.6804	* 3.1331	* 2.9818	* 2.4750	* 2.8430	* 2.4706	* 4.7488 *
11	* 1.6008	* 1.9333	* 1.4961	* 1.7415	* 1.4277	* 1.6544	* 1.0624	* 0.5484 *
	* 2.7586	* 2.3241	* 2.9843	* 2.4910	* 2.9236	* 2.5601	* 3.8364	* 7.2472 *
12	* 1.9326	* 1.6371	* 1.8451	* 1.4264	* 1.1593	* 1.4166	* 0.7839	*
	* 2.3202	* 2.6939	* 2.4759	* 2.9256	* 2.8062	* 2.5320	* 4.6186	*
13	* 1.7308	* 1.7221	* 1.5579	* 1.6544	* 1.4162	* 1.3002	* 0.6026	*
	* 2.5445	* 2.5571	* 2.8412	* 2.5602	* 2.5323	* 2.7213	* 5.6220	*
14	* 2.0045	* 1.9695	* 1.7957	* 1.0624	* 0.7829	* 0.6024	*	
	* 2.2062	* 2.2460	* 2.4701	* 3.8371	* 4.6182	* 5.6233	*	
15	* 0.9263	* 0.9261	* 0.8294	* 0.5361	* F-SUB-Q			
	* 4.2750	* 4.2830	* 4.7499	* 7.2672	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2176	* 1.4592	* 1.8913	* 1.5835	* 1.9038	* 1.7085	* 1.9749	* 0.9258 *
	* 3.1644	* 2.9738	* 2.2935	* 2.6800	* 2.2595	* 2.5071	* 2.1971	* 4.2127 *
9	* 1.4592	* 1.7997	* 1.6404	* 1.9077	* 1.6190	* 1.7010	* 1.9414	* 0.9225 *
	* 2.9738	* 2.4390	* 2.6019	* 2.2622	* 2.6165	* 2.5259	* 2.2427	* 4.2460 *
10	* 1.8913	* 1.6371	* 1.4181	* 1.4876	* 1.8282	* 1.5432	* 1.7762	* 0.8339 *
	* 2.2935	* 2.6047	* 3.0286	* 2.8944	* 2.4104	* 2.8234	* 2.4856	* 4.7096 *
11	* 1.5835	* 1.9069	* 1.4866	* 1.7356	* 1.4395	* 1.6600	* 1.0781	* 0.5536 *
	* 2.6800	* 2.2632	* 2.8962	* 2.5287	* 2.9608	* 2.5995	* 3.8257	* 7.2911 *
12	* 1.9038	* 1.6185	* 1.8275	* 1.4386	* 1.1970	* 1.4535	* 0.8083	*
	* 2.2595	* 2.6168	* 2.4113	* 2.9629	* 2.8452	* 2.5720	* 4.6170	*
13	* 1.7085	* 1.7016	* 1.5448	* 1.6600	* 1.4532	* 1.3462	* 0.6327	*
	* 2.5071	* 2.5256	* 2.8216	* 2.5997	* 2.5724	* 2.7634	* 5.5954	*
14	* 1.9749	* 1.9418	* 1.7765	* 1.0780	* 0.8072	* 0.6325	*	
	* 2.1971	* 2.2422	* 2.4852	* 3.8265	* 4.6167	* 5.5969	*	
15	* 0.9258	* 0.9231	* 0.8337	* 0.5428	* F-SUB-Q			
	* 4.2127	* 4.2463	* 4.7108	* 7.2889	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2924	* 1.4729	* 1.9232	* 1.5941	* 1.9258	* 1.7165	* 1.9999	* 0.9140 *
	* 3.0581	* 2.8942	* 2.1948	* 2.5856	* 2.1647	* 2.4126	* 2.0967	* 4.1230 *
9	* 1.4729	* 1.8401	* 1.6554	* 1.9330	* 1.6258	* 1.7119	* 1.9678	* 0.9150 *
	* 2.8942	* 2.3329	* 2.5095	* 2.1670	* 2.5279	* 2.4292	* 2.1403	* 4.1398 *
10	* 1.9232	* 1.6519	* 1.4236	* 1.4995	* 1.8626	* 1.5602	* 1.8071	* 0.8245 *
	* 2.1948	* 2.5128	* 2.9389	* 2.7964	* 2.3079	* 2.7208	* 2.3737	* 4.6189 *
11	* 1.5941	* 1.9321	* 1.4981	* 1.7929	* 1.4786	* 1.7252	* 1.0830	* 0.5507 *
	* 2.5856	* 2.1679	* 2.7990	* 2.4338	* 2.8654	* 2.4973	* 3.7285	* 7.1563 *
12	* 1.9258	* 1.6254	* 1.8619	* 1.4772	* 1.3069	* 1.5799	* 0.8316	*
	* 2.1647	* 2.5284	* 2.3088	* 2.8675	* 2.7374	* 2.4578	* 4.4704	*
13	* 1.7165	* 1.7126	* 1.5618	* 1.7252	* 1.5795	* 1.4702	* 0.6586	*
	* 2.4126	* 2.4288	* 2.7189	* 2.4976	* 2.4582	* 2.6273	* 5.4044	*
14	* 1.9999	* 1.9682	* 1.8074	* 1.0829	* 0.8304	* 0.6584	*	
	* 2.0967	* 2.1399	* 2.3733	* 3.7296	* 4.4705	* 5.4058	*	
15	* 0.9140	* 0.9157	* 0.8243	* 0.5371	* F-SUB-Q			
	* 4.1230	* 4.1399	* 4.6203	* 7.1915	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3935	* 1.5023	* 1.9387	* 1.5972	* 1.9304	* 1.7147	* 2.0050	* 0.9082
	* 2.7623	* 2.6476	* 2.0526	* 2.4246	* 2.0322	* 2.2711	* 1.9691	* 3.8617
9	* 1.5023	* 1.8705	* 1.6621	* 1.9426	* 1.6261	* 1.7129	* 1.9747	* 0.9107
	* 2.6476	* 2.1714	* 2.3505	* 2.0313	* 2.3734	* 2.2824	* 2.0070	* 3.8690
10	* 1.9387	* 1.6584	* 1.4303	* 1.5075	* 1.8820	* 1.5699	* 1.8232	* 0.8225
	* 2.0526	* 2.3536	* 2.7412	* 2.6117	* 2.1530	* 2.5411	* 2.2111	* 4.3001
11	* 1.5972	* 1.9411	* 1.5060	* 1.8401	* 1.5221	* 1.7844	* 1.0973	* 0.5524
	* 2.4246	* 2.0321	* 2.6140	* 2.1894	* 2.5867	* 2.2443	* 3.3824	* 6.6008
12	* 1.9304	* 1.6256	* 1.8812	* 1.5206	* 1.5021	* 1.7286	* 0.8645	*
	* 2.0322	* 2.3739	* 2.1538	* 2.5887	* 2.4671	* 2.2098	* 4.0551	*
13	* 1.7147	* 1.7135	* 1.5716	* 1.7842	* 1.7282	* 1.6060	* 0.6959	*
	* 2.2711	* 2.2821	* 2.5395	* 2.2446	* 2.2102	* 2.3632	* 4.9093	*
14	* 2.0050	* 1.9752	* 1.8235	* 1.0971	* 0.8632	* 0.6957	*	*
	* 1.9692	* 2.0066	* 2.2108	* 3.3835	* 4.0554	* 4.9107	*	*
15	* 0.9082	* 0.9114	* 0.8222	* 0.5380	F-SUB-Q			
	* 3.8617	* 3.8691	* 4.3018	* 6.6427	M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4525	* 1.5198	* 1.9419	* 1.5944	* 1.9245	* 1.7069	* 1.9977	* 0.9051
	* 2.5084	* 2.3978	* 1.8408	* 2.1799	* 1.8267	* 2.0457	* 1.7713	* 3.4780
9	* 1.5198	* 1.8904	* 1.6620	* 1.9419	* 1.6213	* 1.7074	* 1.9693	* 0.9076
	* 2.3978	* 1.9459	* 2.1124	* 1.8238	* 2.1355	* 2.0541	* 1.8046	* 3.4865
10	* 1.9419	* 1.6583	* 1.4323	* 1.5115	* 1.8896	* 1.5737	* 1.8273	* 0.8231
	* 1.8408	* 2.1153	* 2.4626	* 2.3449	* 1.9297	* 2.2842	* 1.9851	* 3.8649
11	* 1.5944	* 1.9404	* 1.5102	* 1.8707	* 1.5521	* 1.8253	* 1.1136	* 0.5563
	* 2.1799	* 1.8246	* 2.3470	* 1.9925	* 2.3591	* 2.0457	* 3.0706	* 5.9238
12	* 1.9245	* 1.6208	* 1.8889	* 1.5506	* 1.6261	* 1.8304	* 0.8943	*
	* 1.8267	* 2.1360	* 1.9305	* 2.3610	* 2.2542	* 2.0193	* 3.7047	*
13	* 1.7069	* 1.7081	* 1.5756	* 1.8252	* 1.8300	* 1.7013	* 0.7292	*
	* 2.0457	* 2.0539	* 2.2827	* 2.0459	* 2.0197	* 2.1569	* 4.4849	*
14	* 1.9977	* 1.9698	* 1.8275	* 1.1134	* 0.8930	* 0.7290	*	*
	* 1.7713	* 1.8043	* 1.9849	* 3.0716	* 3.7051	* 4.4861	*	*
15	* 0.9051	* 0.9083	* 0.8228	* 0.5416	F-SUB-Q			
	* 3.4780	* 3.4866	* 3.8665	* 5.9644	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4665	* 1.5188	* 1.9224	* 1.5801	* 1.8992	* 1.6878	* 1.9696	* 0.9046 *
	* 2.4726	* 2.3521	* 1.8210	* 2.1543	* 1.8116	* 2.0260	* 1.7583	* 3.4127 *
9	* 1.5188	* 1.8804	* 1.6481	* 1.9202	* 1.6065	* 1.6899	* 1.9431	* 0.9048 *
	* 2.3521	* 1.9220	* 2.0867	* 1.8063	* 2.1110	* 2.0331	* 1.7907	* 3.4303 *
10	* 1.9224	* 1.6444	* 1.4275	* 1.5045	* 1.8748	* 1.5707	* 1.8103	* 0.8270 *
	* 1.8210	* 2.0893	* 2.4174	* 2.3121	* 1.9072	* 2.2559	* 1.9655	* 3.7762 *
11	* 1.5801	* 1.9187	* 1.5032	* 1.8706	* 1.5593	* 1.8312	* 1.1290	* 0.5610 *
	* 2.1542	* 1.8071	* 2.3143	* 1.9797	* 2.3384	* 2.0333	* 3.0041	* 5.7822 *
12	* 1.8992	* 1.6060	* 1.8741	* 1.5577	* 1.6658	* 1.8622	* 0.9170	*
	* 1.8116	* 2.1115	* 1.9080	* 2.3403	* 2.2378	* 2.0100	* 3.6332	*
13	* 1.6878	* 1.6905	* 1.5727	* 1.8310	* 1.8618	* 1.7391	* 0.7569	*
	* 2.0260	* 2.0328	* 2.2545	* 2.0335	* 2.0104	* 2.1474	* 4.3909	*
14	* 1.9696	* 1.9436	* 1.8105	* 1.1288	* 0.9157	* 0.7567	*	
	* 1.7583	* 1.7903	* 1.9653	* 3.0053	* 3.6337	* 4.3923	*	
15	* 0.9046	* 0.9054	* 0.8267	* 0.5480	F-SUB-Q			
	* 3.4127	* 3.4305	* 3.7779	* 5.8024	M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4714	* 1.5204	* 1.9385	* 1.5796	* 1.9114	* 1.6879	* 1.9848	* 0.8860 *
	* 2.2599	* 2.1490	* 1.6514	* 1.9730	* 1.6483	* 1.8572	* 1.5988	* 3.1987 *
9	* 1.5204	* 1.9002	* 1.6501	* 1.9351	* 1.6039	* 1.6922	* 1.9592	* 0.8906 *
	* 2.1490	* 1.7389	* 1.9079	* 1.6411	* 1.9369	* 1.8610	* 1.6271	* 3.1991 *
10	* 1.9385	* 1.6462	* 1.4231	* 1.5068	* 1.8937	* 1.5797	* 1.8300	* 0.8100 *
	* 1.6514	* 1.9108	* 2.2253	* 2.1160	* 1.7273	* 2.0609	* 1.7819	* 3.5386 *
11	* 1.5796	* 1.9335	* 1.5057	* 1.8974	* 1.5705	* 1.8628	* 1.1155	* 0.5507 *
	* 1.9730	* 1.6419	* 2.1181	* 1.7850	* 2.1302	* 1.8382	* 2.7728	* 5.4044 *
12	* 1.9114	* 1.6033	* 1.8929	* 1.5687	* 1.7018	* 1.9089	* 0.9109	*
	* 1.6483	* 1.9374	* 1.7281	* 2.1320	* 2.0304	* 1.8195	* 3.3998	*
13	* 1.6879	* 1.6929	* 1.5818	* 1.8626	* 1.9085	* 1.7882	* 0.7522	*
	* 1.8572	* 1.8607	* 2.0594	* 1.8384	* 1.8198	* 1.9441	* 4.1197	*
14	* 1.9848	* 1.9596	* 1.8303	* 1.1153	* 0.9096	* 0.7520	*	
	* 1.5988	* 1.6268	* 1.7818	* 2.7738	* 3.4004	* 4.1209	*	
15	* 0.8860	* 0.8913	* 0.8096	* 0.5350	F-SUB-Q			
	* 3.1987	* 3.1990	* 3.5403	* 5.4529	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4520	* 1.4980	* 1.9093	* 1.5541	* 1.8809	* 1.6626	* 1.9547	* 0.8692 *
	* 2.0966	* 2.0088	* 1.5476	* 1.8550	* 1.5509	* 1.7485	* 1.5048	* 3.0292 *
9	* 1.4980	* 1.8743	* 1.6248	* 1.9059	* 1.5781	* 1.6677	* 1.9302	* 0.8743 *
	* 2.0088	* 1.6214	* 1.7898	* 1.5401	* 1.8228	* 1.7503	* 1.5304	* 3.0267 *
10	* 1.9093	* 1.6208	* 1.4021	* 1.4874	* 1.8697	* 1.5608	* 1.8069	* 0.7960 *
	* 1.5476	* 1.7926	* 2.0862	* 1.9838	* 1.6148	* 1.9310	* 1.6702	* 3.3414 *
11	* 1.5541	* 1.9043	* 1.4863	* 1.8766	* 1.5537	* 1.8457	* 1.1028	* 0.5421 *
	* 1.8550	* 1.5413	* 1.9858	* 1.6647	* 1.9851	* 1.7082	* 2.5906	* 5.0812 *
12	* 1.8809	* 1.5775	* 1.8688	* 1.5520	* 1.6941	* 1.8976	* 0.9020 *	
	* 1.5509	* 1.8232	* 1.6155	* 1.9869	* 1.8826	* 1.6872	* 3.1578 *	
13	* 1.6626	* 1.6684	* 1.5628	* 1.8454	* 1.8972	* 1.7825	* 0.7465 *	
	* 1.7485	* 1.7500	* 1.9295	* 1.7084	* 1.6876	* 1.8068	* 3.8487 *	
14	* 1.9547	* 1.9307	* 1.8071	* 1.1026	* 0.9007	* 0.7463 *		
	* 1.5048	* 1.5301	* 1.6700	* 2.5916	* 3.1584	* 3.8499 *		
15	* 0.8692	* 0.8749	* 0.7956	* 0.5263	* F-SUB-Q			
	* 3.0292	* 3.0267	* 3.3432	* 5.1296	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4052	* 1.4474	* 1.8200	* 1.4960	* 1.7927	* 1.6026	* 1.8650	* 0.8506 *
	* 2.0232	* 1.9096	* 1.5132	* 1.8017	* 1.5238	* 1.7019	* 1.4790	* 2.9105 *
9	* 1.4474	* 1.7915	* 1.5648	* 1.8190	* 1.5210	* 1.6074	* 1.8422	* 0.8522 *
	* 1.9096	* 1.5678	* 1.7340	* 1.5073	* 1.7707	* 1.7027	* 1.5030	* 2.9186 *
10	* 1.8200	* 1.5610	* 1.3586	* 1.4374	* 1.7904	* 1.5076	* 1.7280	* 0.7821 *
	* 1.5132	* 1.7367	* 2.0075	* 1.9174	* 1.5723	* 1.8673	* 1.6322	* 3.1922 *
11	* 1.4960	* 1.8174	* 1.4364	* 1.7974	* 1.5036	* 1.7691	* 1.0880	* 0.5337 *
	* 1.8017	* 1.5085	* 1.9191	* 1.6115	* 1.9130	* 1.6669	* 2.4319	* 4.8247 *
12	* 1.7927	* 1.5204	* 1.7898	* 1.5019	* 1.6382	* 1.8193	* 0.8892 *	
	* 1.5238	* 1.7712	* 1.5730	* 1.9147	* 1.8138	* 1.6418	* 3.0015 *	
13	* 1.6026	* 1.6080	* 1.5097	* 1.7689	* 1.8190	* 1.7136	* 0.7408 *	
	* 1.7019	* 1.7024	* 1.8659	* 1.6671	* 1.6421	* 1.7511	* 3.6242 *	
14	* 1.8650	* 1.8426	* 1.7282	* 1.0877	* 0.8878	* 0.7406 *		
	* 1.4790	* 1.5027	* 1.6319	* 2.4329	* 3.0020	* 3.6254 *		
15	* 0.8506	* 0.8528	* 0.7817	* 0.5210	* F-SUB-Q			
	* 2.9105	* 2.9187	* 3.1939	* 4.8439	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3477	* 1.3824	* 1.7379	* 1.4328	* 1.7116	* 1.5391	* 1.7837	* 0.8009 *
	* 1.9515	* 1.8763	* 1.4926	* 1.7772	* 1.5108	* 1.6806	* 1.4662	* 2.9388 *
9	* 1.3824	* 1.7149	* 1.5028	* 1.7385	* 1.4560	* 1.5439	* 1.7621	* 0.8060 *
	* 1.8763	* 1.5332	* 1.7020	* 1.4890	* 1.7503	* 1.6801	* 1.4890	* 2.9326 *
10	* 1.7379	* 1.4991	* 1.3019	* 1.3776	* 1.7158	* 1.4510	* 1.6558	* 0.7352 *
	* 1.4926	* 1.7048	* 1.9753	* 1.8875	* 1.5452	* 1.8314	* 1.6082	* 3.2224 *
11	* 1.4328	* 1.7370	* 1.3766	* 1.7224	* 1.4458	* 1.6976	* 1.0300	* 0.5034 *
	* 1.7772	* 1.4903	* 1.8894	* 1.5724	* 1.8559	* 1.6177	* 2.4149	* 4.8327 *
12	* 1.7116	* 1.4555	* 1.7149	* 1.4442	* 1.5769	* 1.7438	* 0.8398	*
	* 1.5108	* 1.7508	* 1.5459	* 1.8576	* 1.7885	* 1.6222	* 2.9921	*
13	* 1.5391	* 1.5445	* 1.4529	* 1.6973	* 1.7435	* 1.6459	* 0.6948	*
	* 1.6806	* 1.6798	* 1.8300	* 1.6179	* 1.6225	* 1.7299	* 3.6751	*
14	* 1.7837	* 1.7625	* 1.6559	* 1.0298	* 0.8385	* 0.6946	*	
	* 1.4662	* 1.4887	* 1.6080	* 2.4159	* 2.9928	* 3.6763	*	
15	* 0.8009	* 0.8066	* 0.7348	* 0.4890	* F-SUB-Q			
	* 2.9388	* 2.9325	* 3.2243	* 4.8766	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2285	* 1.2567	* 1.5504	* 1.3039	* 1.5261	* 1.3962	* 1.5875	* 0.7297
	* 2.0308	* 1.9521	* 1.5954	* 1.8669	* 1.6224	* 1.7766	* 1.5803	* 3.1008
9	* 1.2567	* 1.5314	* 1.3708	* 1.5522	* 1.3244	* 1.4008	* 1.5687	* 0.7358
	* 1.9521	* 1.6250	* 1.7806	* 1.5937	* 1.8422	* 1.7750	* 1.6037	* 3.0897
10	* 1.5504	* 1.3676	* 1.1880	* 1.2524	* 1.5322	* 1.3211	* 1.4803	* 0.6697
	* 1.5954	* 1.7834	* 2.0662	* 1.9810	* 1.6501	* 1.9243	* 1.7206	* 3.3986
11	* 1.3039	* 1.5508	* 1.2515	* 1.5385	* 1.3181	* 1.5154	* 0.9400	* 0.4593
	* 1.8669	* 1.5951	* 1.9830	* 1.6751	* 1.9373	* 1.7217	* 2.5258	* 5.0708
12	* 1.5261	* 1.3239	* 1.5313	* 1.3167	* 1.4308	* 1.5547	* 0.7667	
	* 1.6224	* 1.8427	* 1.6509	* 1.9390	* 1.8564	* 1.7136	* 3.1080	
13	* 1.3962	* 1.4013	* 1.3229	* 1.5152	* 1.5544	* 1.4693	* 0.6316	
	* 1.7766	* 1.7748	* 1.9228	* 1.7219	* 1.7140	* 1.8326	* 3.8313	
14	* 1.5875	* 1.5690	* 1.4805	* 0.9397	* 0.7655	* 0.6314	*	
	* 1.5803	* 1.6035	* 1.7204	* 2.5270	* 3.1088	* 3.8326	*	
15	* 0.7297	* 0.7364	* 0.6693	* 0.4459	* F-SUB-Q			
	* 3.1008	* 3.0896	* 3.4009	* 5.1203	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9827	* 1.0091	* 1.2709	* 1.0455	* 1.2506	* 1.1022	* 1.2862	* 0.5954 *
	* 2.4285	* 2.3356	* 1.8770	* 2.2490	* 1.9142	* 2.1797	* 1.8896	* 3.6886 *
9	* 1.0091	* 1.2432	* 1.1061	* 1.2628	* 1.0556	* 1.1110	* 1.2717	* 0.6001 *
	* 2.3356	* 1.9248	* 2.1295	* 1.8924	* 2.2348	* 2.1670	* 1.9161	* 3.6783 *
10	* 1.2709	* 1.1038	* 0.9509	* 1.0015	* 1.2380	* 1.0584	* 1.1806	* 0.5401 *
	* 1.8770	* 2.1323	* 2.4918	* 2.3884	* 1.9695	* 2.3149	* 2.0889	* 4.0894 *
11	* 1.0455	* 1.2619	* 1.0008	* 1.2509	* 1.0528	* 1.2174	* 0.7602	* 0.3718 *
	* 2.2490	* 1.8937	* 2.3907	* 1.9808	* 2.3370	* 2.0692	* 3.0105	* 6.0690 *
12	* 1.2506	* 1.0552	* 1.2375	* 1.0518	* 1.1437	* 1.2642	* 0.6270	*
	* 1.9142	* 2.2354	* 1.9703	* 2.3387	* 2.2310	* 2.0262	* 3.6658	*
13	* 1.1022	* 1.1114	* 1.0596	* 1.2172	* 1.2640	* 1.1425	* 0.5043	*
	* 2.1797	* 2.1668	* 2.3133	* 2.0695	* 2.0265	* 2.2611	* 4.6192	*
14	* 1.2862	* 1.2719	* 1.1805	* 0.7600	* 0.6261	* 0.5041	*	
	* 1.8896	* 1.9158	* 2.0890	* 3.0120	* 3.6664	* 4.6208	*	
15	* 0.5954	* 0.6005	* 0.5397	* 0.3608	* F-SUB-Q			
	* 3.6886	* 3.6785	* 4.0923	* 6.1294	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3987	* 0.4290	* 0.5208	* 0.4432	* 0.5110	* 0.4324	* 0.4730	* 0.2469 *
	* 5.7692	* 5.3158	* 4.4371	* 5.1438	* 4.5473	* 5.3839	* 4.9799	* 8.6497 *
9	* 0.4290	* 0.5062	* 0.4466	* 0.5149	* 0.4314	* 0.4339	* 0.4673	* 0.2458 *
	* 5.3158	* 4.5736	* 5.1028	* 4.4999	* 5.3028	* 5.3762	* 5.0539	* 8.7328 *
10	* 0.5208	* 0.4459	* 0.4054	* 0.4245	* 0.5046	* 0.4214	* 0.4310	* 0.2240 *
	* 4.4371	* 5.1068	* 5.6642	* 5.4504	* 4.6946	* 5.6129	* 5.5426	* 9.5839 *
11	* 0.4432	* 0.5146	* 0.4242	* 0.5004	* 0.4308	* 0.4784	* 0.3170	* 0.1555 *
	* 5.1438	* 4.5031	* 5.4553	* 4.7900	* 5.4967	* 5.0890	* 6.9909	* 14.1049 *
12	* 0.5110	* 0.4313	* 0.5044	* 0.4305	* 0.4398	* 0.4661	* 0.2607	*
	* 4.5473	* 5.3041	* 4.6966	* 5.5009	* 5.6075	* 5.3159	* 8.5580	*
13	* 0.4324	* 0.4340	* 0.4217	* 0.4783	* 0.4660	* 0.4137	* 0.2075	*
	* 5.3839	* 5.3761	* 5.6111	* 5.0899	* 5.3169	* 6.0372	* 10.8826	*
14	* 0.4730	* 0.4673	* 0.4309	* 0.3169	* 0.2604	* 0.2074	*	
	* 4.9799	* 5.0533	* 5.5433	* 6.9949	* 8.5569	* 10.8870	*	
15	* 0.2469	* 0.2460	* 0.2239	* 0.1523	* F-SUB-Q			
	* 8.6497	* 8.7322	* 9.5910	* 14.1142	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3616	* 0.4658	* 0.5903	* 0.5328	* 0.6132	* 0.5015	* 0.4241	* 0.2192
	* 4.9367	* 4.7953	* 3.9428	* 4.2685	* 3.8478	* 4.3156	* 4.2098	* 6.6426
9	* 0.4658	* 0.5333	* 0.5122	* 0.6027	* 0.5264	* 0.4992	* 0.4946	* 0.2671
	* 4.7953	* 4.2328	* 4.2785	* 3.8908	* 4.2945	* 4.3750	* 4.2798	* 6.8837
10	* 0.5903	* 0.5119	* 0.3954	* 0.4826	* 0.5770	* 0.4956	* 0.4927	* 0.2560
	* 3.9428	* 4.2790	* 4.7922	* 4.5643	* 4.0756	* 4.5903	* 4.6547	* 7.5418
11	* 0.5328	* 0.6026	* 0.4824	* 0.5195	* 0.4668	* 0.5101	* 0.3565	* 0.1931
	* 4.2685	* 3.8917	* 4.5663	* 4.3387	* 4.7170	* 4.4823	* 5.8637	* 10.7888
12	* 0.6132	* 0.5263	* 0.5769	* 0.4666	* 0.3609	* 0.4037	* 0.2733	*
	* 3.8478	* 4.2948	* 4.0765	* 4.7181	* 4.5372	* 4.5251	* 6.9242	*
13	* 0.5015	* 0.4992	* 0.4958	* 0.5101	* 0.4037	* 0.3455	* 0.2004	*
	* 4.3156	* 4.3757	* 4.5903	* 4.4826	* 4.5247	* 4.9542	* 8.5928	*
14	* 0.4241	* 0.4947	* 0.4928	* 0.3565	* 0.2732	* 0.2004	*	*
	* 4.2098	* 4.2792	* 4.6543	* 5.8646	* 6.9107	* 8.5939	*	*
15	* 0.2192	* 0.2672	* 0.2559	* 0.1904	* F-SUB-Q			
	* 6.6426	* 6.8800	* 7.5428	* 10.5923	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8044	* 1.0034	* 1.2787	* 1.1468	* 1.3284	* 1.1434	* 0.9975	* 0.5119
	* 2.3934	* 2.3257	* 1.9002	* 2.0715	* 1.8560	* 1.9723	* 1.8362	* 3.0697
9	* 1.0034	* 1.1598	* 1.1498	* 1.3064	* 1.1725	* 1.1374	* 1.1918	* 0.6127
	* 2.3257	* 2.0204	* 1.9820	* 1.8735	* 2.0157	* 1.9718	* 1.8567	* 3.1355
10	* 1.2787	* 1.1486	* 0.8428	* 1.0429	* 1.2548	* 1.1291	* 1.1870	* 0.5855
	* 1.9002	* 1.9827	* 2.3330	* 2.2016	* 1.9537	* 2.1038	* 2.0144	* 3.4557
11	* 1.1468	* 1.3062	* 1.0425	* 1.1526	* 1.0364	* 1.1443	* 0.7946	* 0.4370
	* 2.0715	* 1.8739	* 2.2026	* 2.0210	* 2.1912	* 2.0580	* 2.7759	* 5.0116
12	* 1.3284	* 1.1725	* 1.2546	* 1.0359	* 0.8119	* 0.9612	* 0.6114	*
	* 1.8560	* 2.0158	* 1.9541	* 2.1917	* 2.0315	* 1.9590	* 3.1806	*
13	* 1.1434	* 1.1375	* 1.1297	* 1.1443	* 0.9611	* 0.8483	* 0.4569	*
	* 1.9723	* 1.9719	* 2.1036	* 2.0581	* 1.9589	* 2.1519	* 3.8702	*
14	* 0.9975	* 1.1920	* 1.1872	* 0.7947	* 0.6110	* 0.4568	*	*
	* 1.8362	* 1.8564	* 2.0142	* 2.7761	* 3.1753	* 3.8707	*	*
15	* 0.5119	* 0.6129	* 0.5855	* 0.4311	* F-SUB-Q			
	* 3.0697	* 3.1361	* 3.4558	* 4.9176	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9843	* 1.2266	* 1.5673	* 1.3991	* 1.6234	* 1.4162	* 1.2943	* 0.6726 *
	* 2.0875	* 1.9764	* 1.6161	* 1.7644	* 1.5789	* 1.6450	* 1.5410	* 2.5968 *
9	* 1.2266	* 1.4273	* 1.4029	* 1.6043	* 1.4424	* 1.3945	* 1.4787	* 0.7738 *
	* 1.9764	* 1.7135	* 1.6989	* 1.5878	* 1.7047	* 1.6578	* 1.5636	* 2.6393 *
10	* 1.5673	* 1.4013	* 1.0816	* 1.2908	* 1.5364	* 1.3728	* 1.4635	* 0.7399 *
	* 1.6161	* 1.6998	* 1.9744	* 1.8707	* 1.6579	* 1.7949	* 1.7011	* 2.8731 *
11	* 1.3991	* 1.6040	* 1.2904	* 1.4114	* 1.2600	* 1.3939	* 0.9803	* 0.5388 *
	* 1.7644	* 1.5882	* 1.8716	* 1.7187	* 1.8608	* 1.7409	* 2.3324	* 4.2166 *
12	* 1.6234	* 1.4423	* 1.5362	* 1.2593	* 0.9860	* 1.1587	* 0.7417	*
	* 1.5789	* 1.7048	* 1.6583	* 1.8613	* 1.7390	* 1.6729	* 2.6900	*
13	* 1.4162	* 1.3946	* 1.3736	* 1.3940	* 1.1586	* 1.0513	* 0.5664	*
	* 1.6450	* 1.6578	* 1.7946	* 1.7409	* 1.6729	* 1.7844	* 3.1957	*
14	* 1.2943	* 1.4790	* 1.4638	* 0.9805	* 0.7411	* 0.5663	*	
	* 1.5410	* 1.5633	* 1.7009	* 2.3325	* 2.6858	* 3.1961	*	
15	* 0.6726	* 0.7741	* 0.7400	* 0.5340	* F-SUB-Q			
	* 2.5968	* 2.6398	* 2.8729	* 4.1186	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0784	* 1.3586	* 1.7883	* 1.5484	* 1.8469	* 1.5970	* 1.6086	* 0.8229 *
	* 1.9992	* 1.8865	* 1.4915	* 1.6717	* 1.4546	* 1.5419	* 1.4038	* 2.4885 *
9	* 1.3586	* 1.6329	* 1.5697	* 1.8259	* 1.5959	* 1.5704	* 1.7319	* 0.8667 *
	* 1.8865	* 1.5884	* 1.6135	* 1.4662	* 1.6158	* 1.5560	* 1.4262	* 2.5233 *
10	* 1.7883	* 1.5676	* 1.2750	* 1.4288	* 1.7429	* 1.5136	* 1.6798	* 0.8178 *
	* 1.4915	* 1.6146	* 1.8827	* 1.7763	* 1.5325	* 1.6940	* 1.5585	* 2.7711 *
11	* 1.5484	* 1.8255	* 1.4281	* 1.6087	* 1.3822	* 1.5699	* 1.0574	* 0.5799 *
	* 1.6717	* 1.4665	* 1.7773	* 1.5912	* 1.7640	* 1.6022	* 2.2440	* 4.0960 *
12	* 1.8469	* 1.5959	* 1.7426	* 1.3813	* 1.0751	* 1.3064	* 0.7936	*
	* 1.4546	* 1.6158	* 1.5328	* 1.7647	* 1.6317	* 1.5323	* 2.5985	*
13	* 1.5970	* 1.5707	* 1.5147	* 1.5699	* 1.3063	* 1.1787	* 0.6033	*
	* 1.5419	* 1.5560	* 1.6934	* 1.6023	* 1.5323	* 1.6401	* 3.0917	*
14	* 1.6086	* 1.7323	* 1.6801	* 1.0577	* 0.7929	* 0.6032	*	
	* 1.4038	* 1.4259	* 1.5582	* 2.2440	* 2.5947	* 3.0921	*	
15	* 0.8229	* 0.8675	* 0.8178	* 0.5733	* F-SUB-Q			
	* 2.4885	* 2.5237	* 2.7710	* 4.0110	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1194	* 1.4135	* 1.8823	* 1.6065	* 1.9377	* 1.6855	* 1.9059	* 0.9379 *
	* 2.0519	* 1.9220	* 1.5007	* 1.6990	* 1.4615	* 1.5644	* 1.4043	* 2.5164 *
9	* 1.4135	* 1.7395	* 1.6436	* 1.9181	* 1.6559	* 1.6859	* 1.9012	* 0.9467 *
	* 1.9220	* 1.6060	* 1.6457	* 1.4743	* 1.6422	* 1.5778	* 1.4277	* 2.5538 *
10	* 1.8823	* 1.6412	* 1.3933	* 1.4948	* 1.8247	* 1.5661	* 1.7775	* 0.8702 *
	* 1.5007	* 1.6469	* 1.9291	* 1.8069	* 1.5414	* 1.7188	* 1.5613	* 2.8009 *
11	* 1.6065	* 1.9176	* 1.4940	* 1.6941	* 1.4219	* 1.6304	* 1.0935	* 0.6010 *
	* 1.6990	* 1.4746	* 1.8079	* 1.6082	* 1.7997	* 1.6121	* 2.2642	* 4.1529 *
12	* 1.9377	* 1.6558	* 1.8243	* 1.4209	* 1.1069	* 1.3562	* 0.8149	*
	* 1.4615	* 1.6422	* 1.5417	* 1.8004	* 1.6532	* 1.5376	* 2.6385	*
13	* 1.6855	* 1.6862	* 1.5673	* 1.6305	* 1.3561	* 1.2192	* 0.6191	*
	* 1.5644	* 1.5778	* 1.7181	* 1.6122	* 1.5376	* 1.6468	* 3.1326	*
14	* 1.9059	* 1.9015	* 1.7779	* 1.0937	* 0.8142	* 0.6190	*	*
	* 1.4043	* 1.4274	* 1.5610	* 2.2643	* 2.6347	* 3.1331	*	*
15	* 0.9379	* 0.9472	* 0.8703	* 0.5931	* F-SUB-Q			
	* 2.5164	* 2.5542	* 2.8008	* 4.0732	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1344	* 1.4429	* 1.9125	* 1.6233	* 1.9653	* 1.7458	* 2.0088	* 0.9942 *
	* 2.1493	* 1.9941	* 1.5583	* 1.7684	* 1.5133	* 1.6325	* 1.4564	* 2.6079 *
9	* 1.4429	* 1.7774	* 1.6656	* 1.9462	* 1.6719	* 1.7346	* 1.9814	* 0.9920 *
	* 1.9941	* 1.6816	* 1.7238	* 1.5276	* 1.7079	* 1.6445	* 1.4803	* 2.6502 *
10	* 1.9125	* 1.6631	* 1.4353	* 1.5147	* 1.8467	* 1.5846	* 1.8159	* 0.8995 *
	* 1.5583	* 1.7249	* 2.0160	* 1.8824	* 1.5932	* 1.7879	* 1.6195	* 2.8935 *
11	* 1.6233	* 1.9457	* 1.5138	* 1.7265	* 1.4278	* 1.6410	* 1.1082	* 0.6110 *
	* 1.7684	* 1.5280	* 1.8835	* 1.6837	* 1.8907	* 1.6874	* 2.3424	* 4.2606 *
12	* 1.9653	* 1.6719	* 1.8463	* 1.4270	* 1.1123	* 1.3635	* 0.8225	*
	* 1.5133	* 1.7079	* 1.5935	* 1.8916	* 1.7383	* 1.6100	* 2.7521	*
13	* 1.7458	* 1.7350	* 1.5859	* 1.6411	* 1.3633	* 1.2228	* 0.6243	*
	* 1.6325	* 1.6444	* 1.7871	* 1.6876	* 1.6100	* 1.7247	* 3.2690	*
14	* 2.0088	* 1.9818	* 1.8162	* 1.1083	* 0.8217	* 0.6242	*	*
	* 1.4564	* 1.4800	* 1.6192	* 2.3426	* 2.7484	* 3.2696	*	*
15	* 0.9942	* 0.9926	* 0.8995	* 0.6034	* F-SUB-Q			
	* 2.6079	* 2.6506	* 2.8935	* 4.1765	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1322	* 1.4384	* 1.9297	* 1.6265	* 1.9816	* 1.7703	* 2.0601	* 1.0070
	* 2.2572	* 2.0993	* 1.6190	* 1.8502	* 1.5714	* 1.7008	* 1.5103	* 2.7495
9	* 1.4384	* 1.7950	* 1.6700	* 1.9617	* 1.6736	* 1.7559	* 2.0256	* 1.0039
	* 2.0993	* 1.7432	* 1.7999	* 1.5876	* 1.7868	* 1.7095	* 1.5312	* 2.7820
10	* 1.9297	* 1.6674	* 1.4363	* 1.5164	* 1.8580	* 1.5911	* 1.8426	* 0.9032
	* 1.6190	* 1.8013	* 2.1070	* 1.9695	* 1.6604	* 1.8614	* 1.6652	* 3.0234
11	* 1.6265	* 1.9613	* 1.5154	* 1.7402	* 1.4209	* 1.6482	* 1.1004	* 0.6075
	* 1.8502	* 1.5879	* 1.9707	* 1.7698	* 1.9977	* 1.7759	* 2.4803	* 4.4898
12	* 1.9816	* 1.6736	* 1.8576	* 1.4198	* 1.1050	* 1.3697	* 0.8130	*
	* 1.5714	* 1.7867	* 1.6608	* 1.9987	* 1.8364	* 1.6907	* 2.9415	*
13	* 1.7703	* 1.7564	* 1.5925	* 1.6483	* 1.3695	* 1.2275	* 0.6164	*
	* 1.7008	* 1.7094	* 1.8605	* 1.7761	* 1.6908	* 1.8152	* 3.4997	*
14	* 2.0601	* 2.0260	* 1.8429	* 1.1005	* 0.8121	* 0.6163	*	*
	* 1.5103	* 1.5309	* 1.6649	* 2.4806	* 2.9379	* 3.5003	*	*
15	* 1.0070	* 1.0044	* 0.9031	* 0.5977	* F-SUB-Q			
	* 2.7495	* 2.7824	* 3.0237	* 4.4180	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1244	* 1.4263	* 1.9191	* 1.6115	* 1.9700	* 1.7642	* 2.0652	* 1.0058
	* 2.4311	* 2.2588	* 1.7284	* 1.9723	* 1.6704	* 1.8008	* 1.5866	* 2.8973
9	* 1.4263	* 1.7849	* 1.6541	* 1.9492	* 1.6574	* 1.7498	* 2.0287	* 1.0019
	* 2.2588	* 1.8679	* 1.9340	* 1.6900	* 1.9061	* 1.8121	* 1.6124	* 2.9375
10	* 1.9191	* 1.6515	* 1.4233	* 1.5012	* 1.8443	* 1.5790	* 1.8398	* 0.8992
	* 1.7284	* 1.9354	* 2.2622	* 2.1121	* 1.7622	* 1.9853	* 1.7663	* 3.2105
11	* 1.6115	* 1.9487	* 1.5003	* 1.7284	* 1.4053	* 1.6371	* 1.0903	* 0.6022
	* 1.9723	* 1.6904	* 2.1134	* 1.8905	* 2.1420	* 1.8914	* 2.6381	* 4.7516
12	* 1.9700	* 1.6573	* 1.8439	* 1.4044	* 1.0937	* 1.3640	* 0.8044	*
	* 1.6704	* 1.9061	* 1.7625	* 2.1430	* 1.9698	* 1.8056	* 3.1488	*
13	* 1.7642	* 1.7503	* 1.5803	* 1.6372	* 1.3638	* 1.2229	* 0.6104	*
	* 1.8008	* 1.8120	* 1.9844	* 1.8916	* 1.8058	* 1.9446	* 3.7669	*
14	* 2.0652	* 2.0290	* 1.8401	* 1.0904	* 0.8035	* 0.6102	*	*
	* 1.5866	* 1.6121	* 1.7660	* 2.6386	* 3.1451	* 3.7677	*	*
15	* 1.0058	* 1.0025	* 0.8991	* 0.5916	* F-SUB-Q			
	* 2.8973	* 2.9379	* 3.2110	* 4.6822	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1214	* 1.4094	* 1.9073	* 1.5939	* 1.9572	* 1.7514	* 2.0613	* 0.9948 *
	* 2.6656	* 2.4303	* 1.8468	* 2.1181	* 1.7829	* 1.9453	* 1.7043	* 3.1386 *
9	* 1.4094	* 1.7746	* 1.6363	* 1.9357	* 1.6385	* 1.7374	* 2.0242	* 0.9919 *
	* 2.4303	* 2.0018	* 2.0720	* 1.8056	* 2.0448	* 1.9501	* 1.7337	* 3.1812 *
10	* 1.9073	* 1.6336	* 1.4017	* 1.4837	* 1.8310	* 1.5645	* 1.8341	* 0.8874 *
	* 1.8468	* 2.0735	* 2.4415	* 2.2628	* 1.8893	* 2.1178	* 1.8747	* 3.4595 *
11	* 1.5939	* 1.9352	* 1.4828	* 1.7171	* 1.3916	* 1.6291	* 1.0762	* 0.5940 *
	* 2.1181	* 1.8060	* 2.2642	* 2.0241	* 2.3354	* 2.0489	* 2.8574	* 5.1116 *
12	* 1.9572	* 1.6384	* 1.8306	* 1.3905	* 1.0893	* 1.3672	* 0.7944 *	
	* 1.7829	* 2.0447	* 1.8897	* 2.3366	* 2.1403	* 1.9531	* 3.4408 *	
13	* 1.7514	* 1.7379	* 1.5659	* 1.6292	* 1.3670	* 1.2263	* 0.6032 *	
	* 1.9453	* 1.9500	* 2.1167	* 2.0492	* 1.9532	* 2.1001	* 4.1137 *	
14	* 2.0613	* 2.0246	* 1.8343	* 1.0762	* 0.7934	* 0.6031 *		
	* 1.7043	* 1.7334	* 1.8745	* 2.8580	* 3.4369	* 4.1145 *		
15	* 0.9948	* 0.9924	* 0.8873	* 0.5826	* F-SUB-Q			
	* 3.1386	* 3.1816	* 3.4604	* 5.0445	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1222	* 1.3993	* 1.8581	* 1.5559	* 1.9048	* 1.7126	* 2.0113	* 0.9898 *
	* 2.9533	* 2.6637	* 2.0556	* 2.3500	* 1.9799	* 2.1129	* 1.8568	* 3.3537 *
9	* 1.3993	* 1.7304	* 1.5972	* 1.8843	* 1.6003	* 1.6994	* 1.9750	* 0.9829 *
	* 2.6637	* 2.2245	* 2.2971	* 2.0080	* 2.2630	* 2.1238	* 1.8856	* 3.4064 *
10	* 1.8581	* 1.5948	* 1.3877	* 1.4516	* 1.7831	* 1.5333	* 1.7889	* 0.8863 *
	* 2.0556	* 2.2989	* 2.6617	* 2.5074	* 2.1062	* 2.3352	* 2.0634	* 3.6947 *
11	* 1.5559	* 1.8838	* 1.4509	* 1.6739	* 1.3729	* 1.5914	* 1.0741	* 0.5925 *
	* 2.3500	* 2.0085	* 2.5085	* 2.2571	* 2.6057	* 2.2981	* 3.1149	* 5.5338 *
12	* 1.9048	* 1.6002	* 1.7827	* 1.3721	* 1.0879	* 1.3490	* 0.7965 *	
	* 1.9799	* 2.2630	* 2.1067	* 2.6068	* 2.3946	* 2.1897	* 3.7663 *	
13	* 1.7126	* 1.6999	* 1.5345	* 1.5914	* 1.3488	* 1.2101	* 0.6097 *	
	* 2.1129	* 2.1237	* 2.3344	* 2.2984	* 2.1899	* 2.3517	* 4.4790 *	
14	* 2.0113	* 1.9754	* 1.7891	* 1.0740	* 0.7956	* 0.6095 *		
	* 1.8568	* 1.8853	* 2.0632	* 3.1157	* 3.7620	* 4.4800 *		
15	* 0.9898	* 0.9835	* 0.8862	* 0.5836	* F-SUB-Q			
	* 3.3537	* 3.4068	* 3.6957	* 5.4383	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1143	* 1.3750	* 1.8597	* 1.5450	* 1.9046	* 1.7035	* 2.0171	* 0.9694
	* 3.1748	* 3.0078	* 2.2746	* 2.6151	* 2.1828	* 2.3152	* 2.0132	* 3.7115
9	* 1.3750	* 1.7326	* 1.5863	* 1.8840	* 1.5869	* 1.6915	* 1.9810	* 0.9665
	* 3.0078	* 2.4622	* 2.5591	* 2.2197	* 2.5174	* 2.3297	* 2.0483	* 3.7610
10	* 1.8597	* 1.5835	* 1.3627	* 1.4387	* 1.7836	* 1.5212	* 1.7959	* 0.8668
	* 2.2746	* 2.5613	* 2.9972	* 2.8005	* 2.3306	* 2.5824	* 2.2541	* 4.1220
11	* 1.5450	* 1.8836	* 1.4377	* 1.6765	* 1.3577	* 1.5984	* 1.0533	* 0.5798
	* 2.6151	* 2.2202	* 2.8023	* 2.5031	* 2.8828	* 2.5239	* 3.5071	* 6.2122
12	* 1.9046	* 1.5868	* 1.7832	* 1.3566	* 1.0862	* 1.3660	* 0.7826	*
	* 2.1828	* 2.5174	* 2.3310	* 2.8843	* 2.6569	* 2.4115	* 4.2427	*
13	* 1.7035	* 1.6920	* 1.5226	* 1.5984	* 1.3657	* 1.2292	* 0.5993	*
	* 2.3152	* 2.3295	* 2.5810	* 2.5242	* 2.4118	* 2.5958	* 5.0935	*
14	* 2.0171	* 1.9813	* 1.7961	* 1.0532	* 0.7816	* 0.5991	*	
	* 2.0132	* 2.0479	* 2.2539	* 3.5082	* 4.2383	* 5.0946	*	
15	* 0.9694	* 0.9671	* 0.8666	* 0.5673	* F-SUB-Q			
	* 3.7115	* 3.7613	* 4.1233	* 6.1457	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1066	* 1.3627	* 1.8436	* 1.5271	* 1.8855	* 1.6837	* 1.9993	* 0.9589
	* 3.2217	* 3.0674	* 2.4164	* 2.7937	* 2.3585	* 2.5795	* 2.2591	* 4.1640
9	* 1.3627	* 1.7184	* 1.5679	* 1.8659	* 1.5673	* 1.6731	* 1.9640	* 0.9561
	* 3.0674	* 2.5733	* 2.7250	* 2.3850	* 2.7208	* 2.6002	* 2.2998	* 4.2228
10	* 1.8436	* 1.5653	* 1.3490	* 1.4226	* 1.7679	* 1.5057	* 1.7826	* 0.8590
	* 2.4164	* 2.7273	* 3.1934	* 3.0254	* 2.5485	* 2.9012	* 2.5301	* 4.6204
11	* 1.5271	* 1.8654	* 1.4216	* 1.6640	* 1.3469	* 1.5907	* 1.0466	* 0.5752
	* 2.7937	* 2.3856	* 3.0274	* 2.5632	* 2.9569	* 2.6043	* 3.7933	* 6.9697
12	* 1.8855	* 1.5672	* 1.7675	* 1.3457	* 1.0847	* 1.3678	* 0.7813	*
	* 2.3585	* 2.7208	* 2.5491	* 2.9587	* 2.7917	* 2.5222	* 4.4262	*
13	* 1.6837	* 1.6736	* 1.5071	* 1.5907	* 1.3675	* 1.2358	* 0.6015	*
	* 2.5795	* 2.6001	* 2.8997	* 2.6044	* 2.5225	* 2.7406	* 5.3715	*
14	* 1.9993	* 1.9643	* 1.7827	* 1.0465	* 0.7802	* 0.6013	*	
	* 2.2591	* 2.2994	* 2.5299	* 3.7944	* 4.4221	* 5.3729	*	
15	* 0.9589	* 0.9567	* 0.8587	* 0.5623	* F-SUB-Q			
	* 4.1640	* 4.2232	* 4.6222	* 6.9011	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1050	* 1.3610	* 1.8126	* 1.5025	* 1.8502	* 1.6555	* 1.9624	* 0.9554
	* 3.2899	* 3.0552	* 2.3656	* 2.7322	* 2.3103	* 2.5145	* 2.2041	* 4.0080
9	* 1.3610	* 1.6917	* 1.5434	* 1.8324	* 1.5419	* 1.6460	* 1.9286	* 0.9498
	* 3.0552	* 2.5515	* 2.6647	* 2.3363	* 2.6598	* 2.5354	* 2.2477	* 4.0865
10	* 1.8126	* 1.5409	* 1.3432	* 1.4036	* 1.7390	* 1.4897	* 1.7534	* 0.8596
	* 2.3656	* 2.6670	* 3.0895	* 2.9568	* 2.4978	* 2.8188	* 2.4955	* 4.4742
11	* 1.5025	* 1.8319	* 1.4028	* 1.6403	* 1.3431	* 1.5729	* 1.0515	* 0.5767
	* 2.7322	* 2.3369	* 2.9589	* 2.6298	* 3.0289	* 2.6735	* 3.8233	* 6.8427
12	* 1.8502	* 1.5419	* 1.7386	* 1.3423	* 1.0916	* 1.3640	* 0.7919	*
	* 2.3103	* 2.6598	* 2.4984	* 3.0308	* 2.8631	* 2.5916	* 4.4614	*
13	* 1.6555	* 1.6465	* 1.4909	* 1.5729	* 1.3637	* 1.2386	* 0.6158	*
	* 2.5145	* 2.5352	* 2.8178	* 2.6736	* 2.5919	* 2.8103	* 5.4010	*
14	* 1.9624	* 1.9289	* 1.7535	* 1.0513	* 0.7908	* 0.6156	*	*
	* 2.2041	* 2.2474	* 2.4953	* 3.8246	* 4.4570	* 5.4025	*	*
15	* 0.9554	* 0.9503	* 0.8593	* 0.5659	* F-SUB-Q			
	* 4.0080	* 4.0871	* 4.4760	* 6.7494	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1106	* 1.3538	* 1.8315	* 1.5056	* 1.8634	* 1.6563	* 1.9792	* 0.9404
	* 3.2092	* 3.0005	* 2.2827	* 2.6566	* 2.2318	* 2.4395	* 2.1206	* 3.9504
9	* 1.3538	* 1.7125	* 1.5478	* 1.8474	* 1.5413	* 1.6492	* 1.9464	* 0.9392
	* 3.0006	* 2.4616	* 2.5918	* 2.2571	* 2.5898	* 2.4583	* 2.1625	* 4.0120
10	* 1.8315	* 1.5450	* 1.3318	* 1.4063	* 1.7578	* 1.4913	* 1.7751	* 0.8467
	* 2.2827	* 2.5942	* 3.0404	* 2.8794	* 2.4129	* 2.7530	* 2.4016	* 4.4183
11	* 1.5056	* 1.8469	* 1.4052	* 1.6644	* 1.3492	* 1.6052	* 1.0453	* 0.5702
	* 2.6566	* 2.2576	* 2.8814	* 2.5776	* 2.9922	* 2.6289	* 3.7789	* 6.7623
12	* 1.8634	* 1.5412	* 1.7574	* 1.3480	* 1.1128	* 1.4122	* 0.7943	*
	* 2.2318	* 2.5898	* 2.4135	* 2.9942	* 2.8270	* 2.5443	* 4.4314	*
13	* 1.6563	* 1.6497	* 1.4927	* 1.6052	* 1.4118	* 1.2931	* 0.6217	*
	* 2.4395	* 2.4581	* 2.7514	* 2.6291	* 2.5446	* 2.7500	* 5.3411	*
14	* 1.9792	* 1.9467	* 1.7752	* 1.0451	* 0.7932	* 0.6215	*	*
	* 2.1206	* 2.1622	* 2.4015	* 3.7804	* 4.4274	* 5.3426	*	*
15	* 0.9404	* 0.9398	* 0.8464	* 0.5562	* F-SUB-Q			
	* 3.9504	* 4.0124	* 4.4203	* 6.7099	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1432	* 1.3705	* 1.8440	* 1.5077	* 1.8674	* 1.6533	* 1.9828	* 0.9346
	* 2.8827	* 2.7551	* 2.1625	* 2.5228	* 2.1218	* 2.3306	* 2.0223	* 3.7696
9	* 1.3705	* 1.7316	* 1.5524	* 1.8541	* 1.5400	* 1.6485	* 1.9517	* 0.9349
	* 2.7551	* 2.3037	* 2.4599	* 2.1432	* 2.4658	* 2.3463	* 2.0610	* 3.8229
10	* 1.8440	* 1.5495	* 1.3323	* 1.4115	* 1.7718	* 1.4974	* 1.7872	* 0.8435
	* 2.1625	* 2.4626	* 2.8859	* 2.7336	* 2.2902	* 2.6217	* 2.2820	* 4.2083
11	* 1.5077	* 1.8537	* 1.4104	* 1.6917	* 1.3752	* 1.6429	* 1.0549	* 0.5713
	* 2.5228	* 2.1437	* 2.7356	* 2.3045	* 2.6763	* 2.3418	* 3.4203	* 6.3604
12	* 1.8674	* 1.5399	* 1.7714	* 1.3739	* 1.1686	* 1.4885	* 0.8168	*
	* 2.1218	* 2.4658	* 2.2907	* 2.6778	* 2.5193	* 2.2612	* 3.9704	*
13	* 1.6533	* 1.6490	* 1.4989	* 1.6428	* 1.4881	* 1.3726	* 0.6477	*
	* 2.3306	* 2.3461	* 2.6203	* 2.3420	* 2.2615	* 2.4456	* 4.7951	*
14	* 1.9828	* 1.9520	* 1.7872	* 1.0547	* 0.8156	* 0.6475	*	*
	* 2.0223	* 2.0607	* 2.2820	* 3.4218	* 3.9671	* 4.7965	*	*
15	* 0.9346	* 0.9355	* 0.8431	* 0.5565	* F-SUB-Q			
	* 3.7696	* 3.8233	* 4.2104	* 6.3201	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2466	* 1.3993	* 1.8576	* 1.5120	* 1.8701	* 1.6506	* 1.9822	* 0.9351
	* 2.5813	* 2.4607	* 1.9224	* 2.2484	* 1.8948	* 2.0880	* 1.8109	* 3.3542
9	* 1.3993	* 1.7569	* 1.5601	* 1.8603	* 1.5413	* 1.6482	* 1.9530	* 0.9352
	* 2.4607	* 2.0541	* 2.1889	* 1.9100	* 2.2007	* 2.0978	* 1.8423	* 3.4007
10	* 1.8576	* 1.5571	* 1.3454	* 1.4209	* 1.7880	* 1.5063	* 1.7969	* 0.8486
	* 1.9224	* 2.1912	* 2.5497	* 2.4238	* 2.0289	* 2.3260	* 2.0250	* 3.7155
11	* 1.5120	* 1.8598	* 1.4198	* 1.7339	* 1.4154	* 1.6917	* 1.0767	* 0.5781
	* 2.2484	* 1.9105	* 2.4255	* 2.0675	* 2.4092	* 2.1052	* 3.0621	* 5.6067
12	* 1.8701	* 1.5411	* 1.7875	* 1.4141	* 1.3058	* 1.6185	* 0.8552	*
	* 1.8948	* 2.2007	* 2.0294	* 2.4109	* 2.2697	* 2.0363	* 3.5726	*
13	* 1.6506	* 1.6488	* 1.5078	* 1.6917	* 1.6181	* 1.4886	* 0.6900	*
	* 2.0880	* 2.0976	* 2.3247	* 2.1055	* 2.0366	* 2.2008	* 4.3085	*
14	* 1.9822	* 1.9533	* 1.7969	* 1.0764	* 0.8539	* 0.6898	*	*
	* 1.8109	* 1.8421	* 2.0251	* 3.0636	* 3.5700	* 4.3098	*	*
15	* 0.9351	* 0.9358	* 0.8481	* 0.5629	* F-SUB-Q			
	* 3.3542	* 3.4011	* 3.7176	* 5.5735	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3444	* 1.4294	* 1.8621	* 1.5141	* 1.8635	* 1.6444	* 1.9700	* 0.9424 *
	* 2.5060	* 2.3932	* 1.8634	* 2.1799	* 1.8420	* 2.0311	* 1.7643	* 3.2284 *
9	* 1.4294	* 1.7817	* 1.5643	* 1.8576	* 1.5415	* 1.6440	* 1.9429	* 0.9400 *
	* 2.3932	* 1.9934	* 2.1207	* 1.8542	* 2.1354	* 2.0391	* 1.7942	* 3.2826 *
10	* 1.8621	* 1.5612	* 1.3647	* 1.4289	* 1.7959	* 1.5118	* 1.7959	* 0.8602 *
	* 1.8634	* 2.1228	* 2.4443	* 2.3448	* 1.9661	* 2.2443	* 1.9683	* 3.5618 *
11	* 1.5141	* 1.8572	* 1.4278	* 1.7683	* 1.4545	* 1.7354	* 1.1073	* 0.5897 *
	* 2.1799	* 1.8547	* 2.3465	* 2.0195	* 2.3501	* 2.0579	* 2.9477	* 5.3673 *
12	* 1.8635	* 1.5412	* 1.7955	* 1.4532	* 1.5018	* 1.7432	* 0.9029	*
	* 1.8420	* 2.1354	* 1.9666	* 2.3518	* 2.2194	* 1.9952	* 3.4371	*
13	* 1.6444	* 1.6445	* 1.5133	* 1.7353	* 1.7429	* 1.6013	* 0.7413	*
	* 2.0311	* 2.0389	* 2.2434	* 2.0581	* 1.9955	* 2.1551	* 4.1461	*
14	* 1.9700	* 1.9431	* 1.7959	* 1.1070	* 0.9016	* 0.7411	*	
	* 1.7643	* 1.7940	* 1.9684	* 2.9492	* 3.4343	* 4.1474	*	
15	* 0.9424	* 0.9406	* 0.8597	* 0.5763	* F-SUB-Q			
	* 3.2284	* 3.2831	* 3.5640	* 5.3161	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3958	* 1.4595	* 1.9055	* 1.5336	* 1.8983	* 1.6606	* 2.0055	* 0.9329 *
	* 2.2499	* 2.1321	* 1.6569	* 1.9579	* 1.6439	* 1.8290	* 1.5753	* 2.9690 *
9	* 1.4595	* 1.8363	* 1.5890	* 1.8951	* 1.5581	* 1.6630	* 1.9798	* 0.9356 *
	* 2.1321	* 1.7675	* 1.9020	* 1.6528	* 1.9232	* 1.8336	* 1.6007	* 3.0030 *
10	* 1.9055	* 1.5858	* 1.3676	* 1.4503	* 1.8403	* 1.5363	* 1.8380	* 0.8519 *
	* 1.6569	* 1.9043	* 2.2243	* 2.1054	* 1.7476	* 2.0217	* 1.7505	* 3.2768 *
11	* 1.5336	* 1.8946	* 1.4494	* 1.8330	* 1.4990	* 1.8073	* 1.1132	* 0.5876 *
	* 1.9579	* 1.6532	* 2.1069	* 1.7917	* 2.1074	* 1.8313	* 2.6773	* 4.9194 *
12	* 1.8983	* 1.5578	* 1.8398	* 1.4975	* 1.6147	* 1.8637	* 0.9202	*
	* 1.6439	* 1.9231	* 1.7480	* 2.1090	* 1.9816	* 1.7761	* 3.1706	*
13	* 1.6606	* 1.6636	* 1.5379	* 1.8071	* 1.8634	* 1.7152	* 0.7599	*
	* 1.8290	* 1.8335	* 2.0205	* 1.8315	* 1.7763	* 1.9225	* 3.8339	*
14	* 2.0055	* 1.9801	* 1.8380	* 1.1128	* 0.9188	* 0.7597	*	
	* 1.5753	* 1.6006	* 1.7506	* 2.6787	* 3.1682	* 3.8350	*	
15	* 0.9329	* 0.9362	* 0.8514	* 0.5709	* F-SUB-Q			
	* 2.9690	* 3.0033	* 3.2789	* 4.9007	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4150	* 1.4700	* 1.9149	* 1.5364	* 1.9018	* 1.6604	* 2.0070	* 0.9296
	* 2.0454	* 1.9545	* 1.5162	* 1.8001	* 1.5113	* 1.6867	* 1.4504	* 2.7509
9	* 1.4700	* 1.8525	* 1.5941	* 1.9026	* 1.5598	* 1.6641	* 1.9826	* 0.9331
	* 1.9545	* 1.6103	* 1.7451	* 1.5166	* 1.7705	* 1.6892	* 1.4728	* 2.7795
10	* 1.9149	* 1.5908	* 1.3729	* 1.4572	* 1.8527	* 1.5428	* 1.8459	* 0.8510
	* 1.5162	* 1.7473	* 2.0412	* 1.9309	* 1.5969	* 1.8540	* 1.6050	* 3.0278
11	* 1.5364	* 1.9015	* 1.4562	* 1.8574	* 1.5195	* 1.8356	* 1.1234	* 0.5893
	* 1.8001	* 1.5170	* 1.9323	* 1.6354	* 1.9254	* 1.6670	* 2.4532	* 4.5254
12	* 1.9018	* 1.5595	* 1.8522	* 1.5183	* 1.6615	* 1.9124	* 0.9367	*
	* 1.5113	* 1.7708	* 1.5973	* 1.9269	* 1.8004	* 1.6124	* 2.8841	*
13	* 1.6604	* 1.6646	* 1.5444	* 1.8354	* 1.9121	* 1.7655	* 0.7778	*
	* 1.6867	* 1.6890	* 1.8528	* 1.6672	* 1.6127	* 1.7502	* 3.5065	*
14	* 2.0070	* 1.9828	* 1.8459	* 1.1230	* 0.9353	* 0.7776	*	*
	* 1.4504	* 1.4727	* 1.6051	* 2.4545	* 2.8820	* 3.5076	*	*
15	* 0.9296	* 0.9337	* 0.8505	* 0.5723	* F-SUB-Q			
	* 2.7509	* 2.7798	* 3.0298	* 4.5107	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4037	* 1.4534	* 1.8737	* 1.5137	* 1.8580	* 1.6332	* 1.9577	* 0.9284
	* 1.9299	* 1.8148	* 1.4402	* 1.7034	* 1.4431	* 1.6021	* 1.3880	* 2.5781
9	* 1.4534	* 1.8174	* 1.5711	* 1.8620	* 1.5372	* 1.6370	* 1.9346	* 0.9284
	* 1.8148	* 1.5114	* 1.6483	* 1.4447	* 1.6768	* 1.6037	* 1.4084	* 2.6144
10	* 1.8737	* 1.5678	* 1.3726	* 1.4417	* 1.8179	* 1.5222	* 1.8048	* 0.8544
	* 1.4402	* 1.6501	* 1.8994	* 1.8194	* 1.5121	* 1.7494	* 1.5296	* 2.8201
11	* 1.5137	* 1.8609	* 1.4409	* 1.8284	* 1.5088	* 1.8106	* 1.1349	* 0.5930
	* 1.7034	* 1.4454	* 1.8208	* 1.5418	* 1.8114	* 1.5838	* 2.2480	* 4.1954
12	* 1.8580	* 1.5368	* 1.8175	* 1.5076	* 1.6553	* 1.8904	* 0.9518	*
	* 1.4431	* 1.6770	* 1.5125	* 1.8128	* 1.6944	* 1.5296	* 2.6693	*
13	* 1.6332	* 1.6376	* 1.5238	* 1.8102	* 1.8901	* 1.7528	* 0.7957	*
	* 1.6021	* 1.6035	* 1.7486	* 1.5840	* 1.5299	* 1.6532	* 3.2236	*
14	* 1.9577	* 1.9348	* 1.8048	* 1.1345	* 0.9504	* 0.7954	*	*
	* 1.3880	* 1.4082	* 1.5298	* 2.2492	* 2.6673	* 3.2248	*	*
15	* 0.9284	* 0.9289	* 0.8538	* 0.5796	* F-SUB-Q			
	* 2.5781	* 2.6148	* 2.8220	* 4.1545	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3792	* 1.4241	* 1.8379	* 1.4828	* 1.8211	* 1.6025	* 1.9175	* 0.8923
	* 1.8163	* 1.7363	* 1.3797	* 1.6393	* 1.3897	* 1.5436	* 1.3388	* 2.5416
9	* 1.4241	* 1.7863	* 1.5452	* 1.8270	* 1.5062	* 1.6070	* 1.8955	* 0.8970
	* 1.7363	* 1.4376	* 1.5768	* 1.3864	* 1.6153	* 1.5436	* 1.3575	* 2.5628
10	* 1.8379	* 1.5419	* 1.3327	* 1.4158	* 1.7882	* 1.4977	* 1.7725	* 0.8205
	* 1.3797	* 1.5789	* 1.8408	* 1.7458	* 1.4448	* 1.6746	* 1.4686	* 2.7786
11	* 1.4828	* 1.8259	* 1.4150	* 1.8008	* 1.4868	* 1.7859	* 1.0997	* 0.5717
	* 1.6393	* 1.3872	* 1.7472	* 1.4634	* 1.7152	* 1.4967	* 2.1801	* 4.1055
12	* 1.8211	* 1.5058	* 1.7876	* 1.4855	* 1.6372	* 1.8647	* 0.9199	*
	* 1.3897	* 1.6156	* 1.4452	* 1.7167	* 1.6294	* 1.4673	* 2.5985	*
13	* 1.6025	* 1.6076	* 1.4993	* 1.7855	* 1.8644	* 1.7267	* 0.7652	*
	* 1.5436	* 1.5434	* 1.6735	* 1.4969	* 1.4675	* 1.5963	* 3.1968	*
14	* 1.9175	* 1.8958	* 1.7725	* 1.0993	* 0.9186	* 0.7650	*	*
	* 1.3388	* 1.3574	* 1.4687	* 2.1812	* 2.5966	* 3.1980	*	*
15	* 0.8923	* 0.8975	* 0.8200	* 0.5555	* F-SUB-Q			
	* 2.5416	* 2.5632	* 2.7807	* 4.0900	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2893	* 1.3264	* 1.6837	* 1.3800	* 1.6672	* 1.4886	* 1.7514	* 0.8279
	* 1.8422	* 1.7602	* 1.4332	* 1.6809	* 1.4498	* 1.5900	* 1.4015	* 2.6283
9	* 1.3264	* 1.6406	* 1.4434	* 1.6754	* 1.4021	* 1.4938	* 1.7323	* 0.8337
	* 1.7602	* 1.4789	* 1.6086	* 1.4411	* 1.6578	* 1.5883	* 1.4198	* 2.6458
10	* 1.6837	* 1.4405	* 1.2464	* 1.3203	* 1.6443	* 1.3990	* 1.6225	* 0.7613
	* 1.4332	* 1.6107	* 1.8765	* 1.7852	* 1.4964	* 1.7143	* 1.5320	* 2.8716
11	* 1.3800	* 1.6744	* 1.3196	* 1.6557	* 1.3907	* 1.6412	* 1.0269	* 0.5331
	* 1.6809	* 1.4419	* 1.7866	* 1.5132	* 1.7438	* 1.5465	* 2.2244	* 4.2112
12	* 1.6672	* 1.4018	* 1.6441	* 1.3894	* 1.5252	* 1.7101	* 0.8587	*
	* 1.4498	* 1.6581	* 1.4968	* 1.7452	* 1.6451	* 1.5083	* 2.6431	*
13	* 1.4886	* 1.4943	* 1.4006	* 1.6409	* 1.7098	* 1.5844	* 0.7124	*
	* 1.5900	* 1.5881	* 1.7134	* 1.5467	* 1.5086	* 1.6415	* 3.2486	*
14	* 1.7514	* 1.7325	* 1.6224	* 1.0265	* 0.8574	* 0.7122	*	*
	* 1.4015	* 1.4197	* 1.5321	* 2.2257	* 2.6413	* 3.2498	*	*
15	* 0.8279	* 0.8342	* 0.7608	* 0.5176	* F-SUB-Q			
	* 2.6283	* 2.6463	* 2.8739	* 4.1983	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0641	* 1.0896	* 1.3617	* 1.1324	* 1.3488	* 1.2080	* 1.4134	* 0.6850 *
	* 2.1304	* 2.0554	* 1.7055	* 1.9740	* 1.7288	* 1.8923	* 1.6775	* 3.0751 *
9	* 1.0896	* 1.3269	* 1.1928	* 1.3534	* 1.1447	* 1.2178	* 1.3993	* 0.6913 *
	* 2.0554	* 1.7543	* 1.8740	* 1.7189	* 1.9590	* 1.8814	* 1.6980	* 3.0922 *
10	* 1.3617	* 1.1907	* 1.0301	* 1.0847	* 1.3291	* 1.1542	* 1.3081	* 0.6247 *
	* 1.7055	* 1.8760	* 2.1875	* 2.0931	* 1.7824	* 2.0117	* 1.8340	* 3.3902 *
11	* 1.1324	* 1.3526	* 1.0841	* 1.3434	* 1.1444	* 1.3223	* 0.8485	* 0.4411 *
	* 1.9740	* 1.7199	* 2.0947	* 1.7882	* 2.0366	* 1.8460	* 2.5913	* 4.9259 *
12	* 1.3488	* 1.1444	* 1.3286	* 1.1435	* 1.2540	* 1.3863	* 0.7145	*
	* 1.7288	* 1.9594	* 1.7829	* 2.0380	* 1.9217	* 1.7881	* 3.0634	*
13	* 1.2080	* 1.2182	* 1.1553	* 1.3220	* 1.3861	* 1.2608	* 0.5819	*
	* 1.8923	* 1.8813	* 2.0106	* 1.8463	* 1.7884	* 1.9792	* 3.8318	*
14	* 1.4134	* 1.3994	* 1.3079	* 0.8481	* 0.7134	* 0.5817	*	
	* 1.6775	* 1.6978	* 1.8342	* 2.5929	* 3.0612	* 3.8332	*	
15	* 0.6850	* 0.6917	* 0.6242	* 0.4281	* F-SUB-Q			
	* 3.0751	* 3.0927	* 3.3931	* 4.9130	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4562	* 0.4875	* 0.5895	* 0.5048	* 0.5833	* 0.5024	* 0.5528	* 0.2970 *
	* 4.7831	* 4.4382	* 3.8109	* 4.2853	* 3.8743	* 4.3986	* 4.1489	* 6.8868 *
9	* 0.4875	* 0.5737	* 0.5074	* 0.5854	* 0.4933	* 0.5045	* 0.5469	* 0.2961 *
	* 4.4382	* 3.9219	* 4.2554	* 3.8491	* 4.4014	* 4.3902	* 4.2026	* 7.0095 *
10	* 0.5895	* 0.5067	* 0.4637	* 0.4851	* 0.5753	* 0.4860	* 0.5085	* 0.2712 *
	* 3.8109	* 4.2582	* 4.7013	* 4.5235	* 3.9910	* 4.6097	* 4.5626	* 7.5804 *
11	* 0.5048	* 0.5850	* 0.4848	* 0.5703	* 0.4954	* 0.5539	* 0.3726	* 0.1928 *
	* 4.2853	* 3.8513	* 4.5268	* 4.0691	* 4.5363	* 4.2525	* 5.7063	* 10.9426 *
12	* 0.5833	* 0.4932	* 0.5752	* 0.4950	* 0.5113	* 0.5436	* 0.3112	*
	* 3.8743	* 4.4021	* 3.9922	* 4.5385	* 4.5509	* 4.4083	* 6.8249	*
13	* 0.5024	* 0.5046	* 0.4863	* 0.5538	* 0.5435	* 0.4870	* 0.2511	*
	* 4.3986	* 4.3903	* 4.6081	* 4.2533	* 4.4091	* 4.9539	* 8.6089	*
14	* 0.5528	* 0.5469	* 0.5084	* 0.3725	* 0.3108	* 0.2510	*	
	* 4.1489	* 4.2024	* 4.5636	* 5.7103	* 6.8181	* 8.6126	*	
15	* 0.2970	* 0.2963	* 0.2710	* 0.1889	* F-SUB-Q			
	* 6.8868	* 7.0097	* 7.5873	* 10.8134	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4210	* 0.5435	* 0.6881	* 0.6300	* 0.7244	* 0.5954	* 0.4997	* 0.2685
	* 4.0451	* 4.0410	* 3.4488	* 3.5527	* 3.3291	* 3.5272	* 3.5037	* 4.9820
9	* 0.5435	* 0.6193	* 0.5969	* 0.7100	* 0.6263	* 0.6021	* 0.6022	* 0.3404
	* 4.0410	* 3.6959	* 3.5944	* 3.3774	* 3.5544	* 3.5417	* 3.5532	* 5.2725
10	* 0.6881	* 0.5965	* 0.4563	* 0.5764	* 0.6956	* 0.6065	* 0.6138	* 0.3279
	* 3.4488	* 3.5947	* 3.9794	* 3.7900	* 3.4108	* 3.6343	* 3.8234	* 5.7439
11	* 0.6300	* 0.7099	* 0.5762	* 0.6280	* 0.5780	* 0.6417	* 0.4557	* 0.2649
	* 3.5527	* 3.3780	* 3.7915	* 3.7239	* 3.7224	* 3.6085	* 4.4790	* 7.5968
12	* 0.7244	* 0.6263	* 0.6956	* 0.5777	* 0.4431	* 0.5270	* 0.3679	*
	* 3.3291	* 3.5548	* 3.4110	* 3.7230	* 3.6108	* 3.7623	* 5.1063	*
13	* 0.5954	* 0.6022	* 0.6067	* 0.6416	* 0.5269	* 0.4710	* 0.2826	*
	* 3.5272	* 3.5422	* 3.6346	* 3.6090	* 3.7622	* 4.0779	* 6.6192	*
14	* 0.4997	* 0.6022	* 0.6137	* 0.4557	* 0.3677	* 0.2826	*	*
	* 3.5037	* 3.5529	* 3.8236	* 4.4827	* 5.1049	* 6.6217	*	*
15	* 0.2685	* 0.3403	* 0.3278	* 0.2611	* F-SUB-Q			
	* 4.9820	* 5.2866	* 5.7451	* 7.4617	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8368	* 1.0515	* 1.3341	* 1.2190	* 1.4050	* 1.2117	* 1.0371	* 0.5524
	* 2.2022	* 2.1645	* 1.8415	* 1.9092	* 1.7795	* 1.7775	* 1.7034	* 2.5446
9	* 1.0515	* 1.2017	* 1.2016	* 1.3764	* 1.2505	* 1.2221	* 1.2840	* 0.6968
	* 2.1645	* 1.9624	* 1.8392	* 1.8036	* 1.8488	* 1.7759	* 1.7255	* 2.6543
10	* 1.3341	* 1.2006	* 0.8709	* 1.1167	* 1.3523	* 1.2355	* 1.3115	* 0.6722
	* 1.8415	* 1.8398	* 2.1504	* 2.0194	* 1.8544	* 1.8761	* 1.8454	* 2.9106
11	* 1.2190	* 1.3763	* 1.1164	* 1.2421	* 1.1489	* 1.2839	* 0.9106	* 0.5371
	* 1.9092	* 1.8039	* 2.0202	* 1.9231	* 1.9772	* 1.9015	* 2.3692	* 3.9626
12	* 1.4050	* 1.2505	* 1.3523	* 1.1484	* 0.9031	* 1.1171	* 0.7413	*
	* 1.7795	* 1.8490	* 1.8545	* 1.9776	* 1.8112	* 1.8145	* 2.6658	*
13	* 1.2117	* 1.2224	* 1.2360	* 1.2838	* 1.1169	* 1.0278	* 0.5791	*
	* 1.7775	* 1.7761	* 1.8760	* 1.9018	* 1.8145	* 1.9653	* 3.2837	*
14	* 1.0371	* 1.2841	* 1.3115	* 0.9106	* 0.7408	* 0.5790	*	*
	* 1.7034	* 1.7253	* 1.8454	* 2.3709	* 2.6652	* 3.2849	*	*
15	* 0.5524	* 0.6968	* 0.6717	* 0.5295	* F-SUB-Q			
	* 2.5446	* 2.6619	* 2.9109	* 3.8919	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9714	* 1.2167	* 1.5747	* 1.4106	* 1.6587	* 1.4094	* 1.2565	* 0.6697
	* 2.0210	* 1.9278	* 1.6107	* 1.7034	* 1.5548	* 1.5506	* 1.4708	* 2.2329
9	* 1.2167	* 1.4135	* 1.3855	* 1.6243	* 1.4555	* 1.4048	* 1.5244	* 0.8372
	* 1.9278	* 1.7196	* 1.6515	* 1.5773	* 1.6392	* 1.5609	* 1.4882	* 2.3159
10	* 1.5747	* 1.3847	* 1.0466	* 1.3024	* 1.5882	* 1.4198	* 1.5500	* 0.8049
	* 1.6107	* 1.6522	* 1.9096	* 1.7991	* 1.6330	* 1.6781	* 1.6055	* 2.4982
11	* 1.4106	* 1.6241	* 1.3021	* 1.4547	* 1.3234	* 1.5039	* 1.0788	* 0.6319
	* 1.7034	* 1.5775	* 1.7999	* 1.6878	* 1.7672	* 1.6745	* 2.0699	* 3.4929
12	* 1.6587	* 1.4555	* 1.5882	* 1.3226	* 1.0541	* 1.3063	* 0.8657	*
	* 1.5548	* 1.6394	* 1.6332	* 1.7672	* 1.6280	* 1.5875	* 2.3272	*
13	* 1.4094	* 1.4052	* 1.4206	* 1.5038	* 1.3060	* 1.2095	* 0.6883	*
	* 1.5506	* 1.5610	* 1.6778	* 1.6746	* 1.5875	* 1.7035	* 2.8123	*
14	* 1.2565	* 1.5245	* 1.5500	* 1.0788	* 0.8650	* 0.6881	*	*
	* 1.4708	* 1.4881	* 1.6055	* 2.0714	* 2.3268	* 2.8134	*	*
15	* 0.6697	* 0.8374	* 0.8047	* 0.6259	F-SUB-Q			
	* 2.2329	* 2.3227	* 2.4983	* 3.4144	M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0217	* 1.2961	* 1.7154	* 1.5036	* 1.8054	* 1.5141	* 1.3989	* 0.7270
	* 1.9988	* 1.8962	* 1.5448	* 1.6659	* 1.4882	* 1.4990	* 1.3877	* 2.2002
9	* 1.2961	* 1.5385	* 1.4749	* 1.7679	* 1.5494	* 1.5052	* 1.6880	* 0.8919
	* 1.8962	* 1.6553	* 1.6188	* 1.5118	* 1.6050	* 1.5117	* 1.4062	* 2.2698
10	* 1.7154	* 1.4734	* 1.1155	* 1.3780	* 1.7178	* 1.5063	* 1.7016	* 0.8530
	* 1.5448	* 1.6196	* 1.8813	* 1.7629	* 1.5687	* 1.6350	* 1.5223	* 2.4742
11	* 1.5036	* 1.7677	* 1.3776	* 1.5776	* 1.3968	* 1.6226	* 1.1208	* 0.6578
	* 1.6659	* 1.5120	* 1.7636	* 1.6212	* 1.7310	* 1.6012	* 2.0654	* 3.4901
12	* 1.8054	* 1.5494	* 1.7179	* 1.3959	* 1.1072	* 1.4143	* 0.8954	*
	* 1.4882	* 1.6052	* 1.5690	* 1.7314	* 1.5809	* 1.5116	* 2.3140	*
13	* 1.5141	* 1.5056	* 1.5072	* 1.6225	* 1.4141	* 1.3057	* 0.7094	*
	* 1.4990	* 1.5117	* 1.6346	* 1.6013	* 1.5117	* 1.6193	* 2.7989	*
14	* 1.3989	* 1.6881	* 1.7016	* 1.1208	* 0.8945	* 0.7093	*	*
	* 1.3877	* 1.4060	* 1.5223	* 2.0669	* 2.3139	* 2.8000	*	*
15	* 0.7270	* 0.8921	* 0.8528	* 0.6501	F-SUB-Q			
	* 2.2002	* 2.2764	* 2.4743	* 3.4144	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0389	* 1.3206	* 1.7602	* 1.5276	* 1.8471	* 1.5592	* 1.5267	* 0.8083
	* 2.0934	* 1.9756	* 1.5962	* 1.7301	* 1.5341	* 1.5543	* 1.4225	* 2.2648
9	* 1.3206	* 1.5847	* 1.5095	* 1.8111	* 1.5737	* 1.5521	* 1.7699	* 0.9325
	* 1.9756	* 1.7169	* 1.6892	* 1.5594	* 1.6676	* 1.5655	* 1.4425	* 2.3453
10	* 1.7602	* 1.5078	* 1.1862	* 1.4058	* 1.7483	* 1.5296	* 1.7564	* 0.8907
	* 1.5962	* 1.6901	* 1.9590	* 1.8318	* 1.6177	* 1.6933	* 1.5620	* 2.5487
11	* 1.5276	* 1.8109	* 1.4054	* 1.6140	* 1.4031	* 1.6405	* 1.1344	* 0.6681
	* 1.7301	* 1.5597	* 1.8326	* 1.6787	* 1.8033	* 1.6523	* 2.1361	* 3.6120
12	* 1.8471	* 1.5737	* 1.7484	* 1.4022	* 1.1131	* 1.4261	* 0.8980	*
	* 1.5341	* 1.6677	* 1.6180	* 1.8038	* 1.6387	* 1.5565	* 2.3976	*
13	* 1.5592	* 1.5526	* 1.5305	* 1.6404	* 1.4258	* 1.3124	* 0.7102	*
	* 1.5543	* 1.5655	* 1.6929	* 1.6524	* 1.5566	* 1.6658	* 2.8942	*
14	* 1.5267	* 1.7700	* 1.7564	* 1.1344	* 0.8971	* 0.7100	*	*
	* 1.4225	* 1.4424	* 1.5619	* 2.1377	* 2.3976	* 2.8953	*	*
15	* 0.8083	* 0.9328	* 0.8905	* 0.6592	* F-SUB-Q			
	* 2.2648	* 2.3522	* 2.5488	* 3.5442	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0485	* 1.3362	* 1.7788	* 1.5323	* 1.8588	* 1.5973	* 1.7204	* 0.9313
	* 2.2155	* 2.0803	* 1.6821	* 1.8220	* 1.6124	* 1.6428	* 1.4982	* 2.3765
9	* 1.3362	* 1.6122	* 1.5349	* 1.8261	* 1.5805	* 1.6060	* 1.8378	* 0.9688
	* 2.0803	* 1.8233	* 1.7929	* 1.6391	* 1.7558	* 1.6527	* 1.5185	* 2.4645
10	* 1.7788	* 1.5331	* 1.2946	* 1.4261	* 1.7542	* 1.5410	* 1.7848	* 0.9251
	* 1.6821	* 1.7938	* 2.0697	* 1.9314	* 1.6948	* 1.7807	* 1.6429	* 2.6658
11	* 1.5323	* 1.8258	* 1.4256	* 1.6289	* 1.3958	* 1.6286	* 1.1421	* 0.6744
	* 1.8220	* 1.6394	* 1.9323	* 1.7813	* 1.9170	* 1.7547	* 2.2430	* 3.7732
12	* 1.8588	* 1.5805	* 1.7539	* 1.3951	* 1.1030	* 1.4076	* 0.8933	*
	* 1.6124	* 1.7560	* 1.6950	* 1.9175	* 1.7478	* 1.6559	* 2.5302	*
13	* 1.5973	* 1.6063	* 1.5420	* 1.6286	* 1.4073	* 1.2905	* 0.7047	*
	* 1.6428	* 1.6528	* 1.7802	* 1.7549	* 1.6560	* 1.7712	* 3.0559	*
14	* 1.7204	* 1.8379	* 1.7848	* 1.1420	* 0.8924	* 0.7045	*	*
	* 1.4982	* 1.5183	* 1.6429	* 2.2448	* 2.5303	* 3.0571	*	*
15	* 0.9313	* 0.9692	* 0.9249	* 0.6663	* F-SUB-Q			
	* 2.3765	* 2.4718	* 2.6661	* 3.6976	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0492	* 1.3431	* 1.8027	* 1.5396	* 1.8776	* 1.6688	* 1.9514	* 1.0104
	* 2.3401	* 2.2055	* 1.7640	* 1.9216	* 1.6881	* 1.7276	* 1.5697	* 2.5282
9	* 1.3431	* 1.6586	* 1.5573	* 1.8464	* 1.5881	* 1.6706	* 1.9422	* 1.0168
	* 2.2055	* 1.9060	* 1.8861	* 1.7196	* 1.8512	* 1.7328	* 1.5860	* 2.6081
10	* 1.8027	* 1.5553	* 1.3529	* 1.4408	* 1.7681	* 1.5553	* 1.8238	* 0.9434
	* 1.7640	* 1.8873	* 2.1798	* 2.0367	* 1.7837	* 1.8691	* 1.7048	* 2.8064
11	* 1.5396	* 1.8462	* 1.4401	* 1.6531	* 1.3836	* 1.6263	* 1.1287	* 0.6713
	* 1.9216	* 1.7198	* 2.0376	* 1.8866	* 2.0374	* 1.8598	* 2.4100	* 4.0116
12	* 1.8776	* 1.5881	* 1.7678	* 1.3826	* 1.0853	* 1.3982	* 0.8738	*
	* 1.6881	* 1.8513	* 1.7839	* 2.0380	* 1.8574	* 1.7509	* 2.7243	*
13	* 1.6688	* 1.6709	* 1.5563	* 1.6262	* 1.3979	* 1.2774	* 0.6852	*
	* 1.7276	* 1.7329	* 1.8686	* 1.8600	* 1.7510	* 1.8757	* 3.2969	*
14	* 1.9514	* 1.9424	* 1.8238	* 1.1286	* 0.8728	* 0.6850	*	*
	* 1.5697	* 1.5859	* 1.7049	* 2.4120	* 2.7247	* 3.2982	*	*
15	* 1.0104	* 1.0171	* 0.9431	* 0.6605	* F-SUB-Q			
	* 2.5282	* 2.6159	* 2.8070	* 3.9476	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0470	* 1.3438	* 1.8070	* 1.5363	* 1.8810	* 1.7033	* 2.0121	* 1.0424
	* 2.5169	* 2.3793	* 1.8951	* 2.0664	* 1.8088	* 1.8326	* 1.6544	* 2.6703
9	* 1.3438	* 1.6715	* 1.5604	* 1.8483	* 1.5850	* 1.6979	* 1.9889	* 1.0427
	* 2.3793	* 2.0477	* 2.0315	* 1.8467	* 1.9914	* 1.8414	* 1.6760	* 2.7600
10	* 1.8070	* 1.5582	* 1.3643	* 1.4411	* 1.7655	* 1.5565	* 1.8390	* 0.9542
	* 1.8951	* 2.0329	* 2.3453	* 2.1961	* 1.9098	* 2.0040	* 1.8154	* 2.9869
11	* 1.5363	* 1.8480	* 1.4403	* 1.6591	* 1.3701	* 1.6139	* 1.1213	* 0.6692
	* 2.0664	* 1.8469	* 2.1972	* 2.0181	* 2.1841	* 1.9830	* 2.5795	* 4.2774
12	* 1.8810	* 1.5850	* 1.7653	* 1.3693	* 1.0692	* 1.3819	* 0.8605	*
	* 1.8088	* 1.9916	* 1.9101	* 2.1847	* 1.9923	* 1.8718	* 2.9165	*
13	* 1.7033	* 1.6982	* 1.5576	* 1.6138	* 1.3814	* 1.2583	* 0.6725	*
	* 1.8326	* 1.8414	* 2.0034	* 1.9833	* 1.8719	* 2.0099	* 3.5460	*
14	* 2.0121	* 1.9891	* 1.8389	* 1.1211	* 0.8595	* 0.6723	*	*
	* 1.6544	* 1.6759	* 1.8154	* 2.5817	* 2.9171	* 3.5475	*	*
15	* 1.0424	* 1.0429	* 0.9540	* 0.6574	* F-SUB-Q			
	* 2.6703	* 2.7682	* 2.9876	* 4.2152	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0416	* 1.3377	* 1.8075	* 1.5295	* 1.8810	* 1.7136	* 2.0376	* 1.0473
	* 2.7462	* 2.5744	* 2.0346	* 2.2214	* 1.9377	* 1.9811	* 1.7780	* 2.8952
9	* 1.3377	* 1.6745	* 1.5557	* 1.8469	* 1.5779	* 1.7057	* 2.0093	* 1.0480
	* 2.5744	* 2.2118	* 2.1926	* 1.9772	* 2.1392	* 1.9922	* 1.8034	* 2.9878
10	* 1.8075	* 1.5534	* 1.3548	* 1.4344	* 1.7614	* 1.5530	* 1.8470	* 0.9511
	* 2.0346	* 2.1942	* 2.5516	* 2.3622	* 2.0520	* 2.1480	* 1.9420	* 3.2458
11	* 1.5295	* 1.8467	* 1.4336	* 1.6573	* 1.3576	* 1.6057	* 1.1099	* 0.6635
	* 2.2214	* 1.9774	* 2.3633	* 2.1873	* 2.3742	* 2.1429	* 2.8022	* 4.6149
12	* 1.8810	* 1.5779	* 1.7612	* 1.3566	* 1.0543	* 1.3722	* 0.8464	*
	* 1.9377	* 2.1394	* 2.0523	* 2.3749	* 2.1570	* 2.0197	* 3.1788	*
13	* 1.7136	* 1.7060	* 1.5541	* 1.6055	* 1.3718	* 1.2472	* 0.6599	*
	* 1.9811	* 1.9922	* 2.1473	* 2.1431	* 2.0198	* 2.1649	* 3.8570	*
14	* 2.0376	* 2.0095	* 1.8469	* 1.1097	* 0.8453	* 0.6597	*	*
	* 1.7780	* 1.8033	* 1.9422	* 2.8047	* 3.1797	* 3.8587	*	*
15	* 1.0473	* 1.0484	* 0.9508	* 0.6508	* F-SUB-Q			
	* 2.8952	* 2.9966	* 3.2470	* 4.5549	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0410	* 1.3344	* 1.7709	* 1.5010	* 1.8458	* 1.6906	* 2.0064	* 1.0555
	* 3.0345	* 2.8156	* 2.2574	* 2.4579	* 2.1390	* 2.1630	* 1.9494	* 3.1054
9	* 1.3344	* 1.6426	* 1.5275	* 1.8085	* 1.5507	* 1.6821	* 1.9769	* 1.0490
	* 2.8156	* 2.4488	* 2.4233	* 2.1925	* 2.3607	* 2.1708	* 1.9733	* 3.2180
10	* 1.7709	* 1.5256	* 1.3535	* 1.4097	* 1.7237	* 1.5370	* 1.8121	* 0.9587
	* 2.2574	* 2.4248	* 2.7652	* 2.6122	* 2.2821	* 2.3557	* 2.1348	* 3.4556
11	* 1.5010	* 1.8082	* 1.4089	* 1.6224	* 1.3466	* 1.5697	* 1.1172	* 0.6655
	* 2.4579	* 2.1928	* 2.6135	* 2.4352	* 2.6369	* 2.3876	* 3.0350	* 4.9879
12	* 1.8458	* 1.5507	* 1.7235	* 1.3458	* 1.0501	* 1.3429	* 0.8488	*
	* 2.1390	* 2.3609	* 2.2824	* 2.6377	* 2.3973	* 2.2503	* 3.4494	*
13	* 1.6906	* 1.6824	* 1.5379	* 1.5696	* 1.3425	* 1.2195	* 0.6628	*
	* 2.1630	* 2.1708	* 2.3553	* 2.3879	* 2.2505	* 2.4094	* 4.1749	*
14	* 2.0064	* 1.9771	* 1.8120	* 1.1168	* 0.8477	* 0.6625	*	*
	* 1.9494	* 1.9731	* 2.1350	* 3.0380	* 3.4503	* 4.1769	*	*
15	* 1.0555	* 1.0493	* 0.9583	* 0.6560	* F-SUB-Q			
	* 3.1054	* 3.2277	* 3.4568	* 4.8985	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0373	* 1.3123	* 1.7734	* 1.4922	* 1.8450	* 1.6857	* 2.0163	* 1.0367 *
	* 3.2650	* 3.1208	* 2.4914	* 2.7268	* 2.3531	* 2.3661	* 2.1114	* 3.4330 *
9	* 1.3123	* 1.6456	* 1.5190	* 1.8090	* 1.5398	* 1.6776	* 1.9865	* 1.0353 *
	* 3.1208	* 2.7030	* 2.6912	* 2.4183	* 2.6192	* 2.3777	* 2.1411	* 3.5454 *
10	* 1.7734	* 1.5168	* 1.3286	* 1.3995	* 1.7236	* 1.5218	* 1.8206	* 0.9401 *
	* 2.4914	* 2.6932	* 3.1090	* 2.9073	* 2.5222	* 2.6077	* 2.3304	* 3.8479 *
11	* 1.4922	* 1.8087	* 1.3988	* 1.6240	* 1.3253	* 1.5736	* 1.0892	* 0.6516 *
	* 2.7268	* 2.4186	* 2.9088	* 2.6663	* 2.8984	* 2.6133	* 3.4414	* 5.5997 *
12	* 1.8450	* 1.5398	* 1.7233	* 1.3246	* 1.0471	* 1.3531	* 0.8300	*
	* 2.3531	* 2.6194	* 2.5222	* 2.8993	* 2.6486	* 2.4688	* 3.8730	*
13	* 1.6857	* 1.6779	* 1.5228	* 1.5735	* 1.3527	* 1.2317	* 0.6482	*
	* 2.3661	* 2.3777	* 2.6068	* 2.6137	* 2.4690	* 2.6455	* 4.7161	*
14	* 2.0163	* 1.9866	* 1.8205	* 1.0889	* 0.8289	* 0.6480	*	
	* 2.1114	* 2.1409	* 2.3306	* 3.4447	* 3.8744	* 4.7183	*	
15	* 1.0367	* 1.0356	* 0.9397	* 0.6377	* F-SUB-Q			
	* 3.4330	* 3.5559	* 3.8494	* 5.5393	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0376	* 1.2999	* 1.7556	* 1.4728	* 1.8243	* 1.6661	* 1.9977	* 1.0263 *
	* 3.2679	* 3.1259	* 2.6133	* 2.8796	* 2.5159	* 2.5914	* 2.3317	* 3.7773 *
9	* 1.2999	* 1.6303	* 1.5000	* 1.7891	* 1.5197	* 1.6588	* 1.9682	* 1.0248 *
	* 3.1259	* 2.7427	* 2.8258	* 2.5638	* 2.7888	* 2.6093	* 2.3688	* 3.9102 *
10	* 1.7556	* 1.4977	* 1.3143	* 1.3821	* 1.7050	* 1.5053	* 1.8043	* 0.9323 *
	* 2.6133	* 2.8281	* 3.2638	* 3.0959	* 2.6946	* 2.8798	* 2.5896	* 4.2555 *
11	* 1.4728	* 1.7888	* 1.3813	* 1.6084	* 1.3125	* 1.5608	* 1.0797	* 0.6455 *
	* 2.8796	* 2.5641	* 3.0975	* 2.6830	* 2.9473	* 2.6839	* 3.6006	* 6.1780 *
12	* 1.8243	* 1.5198	* 1.7048	* 1.3117	* 1.0497	* 1.3508	* 0.8249	*
	* 2.5159	* 2.7890	* 2.6947	* 2.9483	* 2.7675	* 2.5640	* 3.9846	*
13	* 1.6661	* 1.6591	* 1.5063	* 1.5607	* 1.3505	* 1.2316	* 0.6460	*
	* 2.5914	* 2.6093	* 2.8787	* 2.6841	* 2.5643	* 2.7726	* 4.9047	*
14	* 1.9977	* 1.9683	* 1.8042	* 1.0794	* 0.8238	* 0.6457	*	
	* 2.3317	* 2.3687	* 2.5899	* 3.6039	* 3.9863	* 4.9072	*	
15	* 1.0263	* 1.0251	* 0.9318	* 0.6312	* F-SUB-Q			
	* 3.7773	* 3.9221	* 4.2575	* 6.1163	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0344	* 1.2939	* 1.7195	* 1.4432	* 1.7871	* 1.6340	* 1.9556	* 1.0217
	* 3.2995	* 3.1328	* 2.5239	* 2.7795	* 2.4275	* 2.4937	* 2.2465	* 3.5791
9	* 1.2939	* 1.5984	* 1.4709	* 1.7508	* 1.4906	* 1.6274	* 1.9271	* 1.0160
	* 3.1328	* 2.7270	* 2.7263	* 2.4778	* 2.6892	* 2.5112	* 2.2834	* 3.7222
10	* 1.7194	* 1.4688	* 1.3060	* 1.3572	* 1.6697	* 1.4890	* 1.7677	* 0.9297
	* 2.5239	* 2.7281	* 3.1086	* 2.9841	* 2.6290	* 2.7549	* 2.5061	* 4.0340
11	* 1.4432	* 1.7506	* 1.3565	* 1.5769	* 1.3047	* 1.5323	* 1.0831	* 0.6446
	* 2.7795	* 2.4781	* 2.9857	* 2.7208	* 2.9831	* 2.7243	* 3.5721	* 5.9360
12	* 1.7871	* 1.4906	* 1.6695	* 1.3039	* 1.0500	* 1.3329	* 0.8295	*
	* 2.4275	* 2.6893	* 2.6294	* 2.9841	* 2.8068	* 2.6057	* 3.9643	*
13	* 1.6340	* 1.6278	* 1.4899	* 1.5321	* 1.3325	* 1.2183	* 0.6527	*
	* 2.4937	* 2.5112	* 2.7542	* 2.7246	* 2.6060	* 2.8115	* 4.8759	*
14	* 1.9556	* 1.9272	* 1.7675	* 1.0827	* 0.8283	* 0.6525	*	*
	* 2.2465	* 2.2833	* 2.5064	* 3.5757	* 3.9660	* 4.8784	*	*
15	* 1.0217	* 1.0162	* 0.9292	* 0.6336	* F-SUB-Q			
	* 3.5791	* 3.7335	* 4.0359	* 5.8458	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0226	* 1.2734	* 1.7214	* 1.4342	* 1.7841	* 1.6242	* 1.9585	* 0.9993
	* 3.2597	* 3.0487	* 2.4142	* 2.6769	* 2.3263	* 2.3976	* 2.1436	* 3.4970
9	* 1.2734	* 1.6010	* 1.4626	* 1.7505	* 1.4794	* 1.6193	* 1.9308	* 0.9993
	* 3.0487	* 2.6077	* 2.6262	* 2.3726	* 2.5933	* 2.4133	* 2.1784	* 3.6182
10	* 1.7214	* 1.4603	* 1.2817	* 1.3488	* 1.6707	* 1.4720	* 1.7745	* 0.9098
	* 2.4142	* 2.6284	* 3.0349	* 2.8774	* 2.5173	* 2.6675	* 2.3905	* 3.9458
11	* 1.4342	* 1.7503	* 1.3480	* 1.5809	* 1.2875	* 1.5404	* 1.0601	* 0.6320
	* 2.6769	* 2.3729	* 2.8789	* 2.6830	* 2.9811	* 2.7046	* 3.5537	* 5.8083
12	* 1.7841	* 1.4794	* 1.6705	* 1.2867	* 1.0432	* 1.3491	* 0.8159	*
	* 2.3263	* 2.5935	* 2.5177	* 2.9822	* 2.7978	* 2.5829	* 4.0239	*
13	* 1.6242	* 1.6196	* 1.4731	* 1.5403	* 1.3487	* 1.2389	* 0.6443	*
	* 2.3976	* 2.4132	* 2.6667	* 2.7048	* 2.5832	* 2.7893	* 4.9468	*
14	* 1.9585	* 1.9309	* 1.7743	* 1.0597	* 0.8147	* 0.6441	*	*
	* 2.1436	* 2.1783	* 2.3909	* 3.5575	* 4.0259	* 4.9494	*	*
15	* 0.9993	* 0.9995	* 0.9092	* 0.6165	* F-SUB-Q			
	* 3.4970	* 3.6292	* 3.9479	* 5.7632	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0214	* 1.2693	* 1.7159	* 1.4229	* 1.7730	* 1.6103	* 1.9479	* 0.9861
	* 2.9804	* 2.8683	* 2.3272	* 2.5901	* 2.2494	* 2.3257	* 2.0746	* 3.3996
9	* 1.2693	* 1.5981	* 1.4531	* 1.7420	* 1.4670	* 1.6069	* 1.9216	* 0.9890
	* 2.8683	* 2.5098	* 2.5380	* 2.2909	* 2.5114	* 2.3389	* 2.1073	* 3.5085
10	* 1.7159	* 1.4508	* 1.2695	* 1.3407	* 1.6658	* 1.4642	* 1.7707	* 0.8995
	* 2.3272	* 2.5402	* 2.9404	* 2.7805	* 2.4294	* 2.5865	* 2.3075	* 3.8308
11	* 1.4229	* 1.7418	* 1.3400	* 1.5806	* 1.2859	* 1.5455	* 1.0554	* 0.6274
	* 2.5901	* 2.2912	* 2.7820	* 2.4745	* 2.7336	* 2.4799	* 3.3367	* 5.6134
12	* 1.7730	* 1.4670	* 1.6655	* 1.2848	* 1.0507	* 1.3664	* 0.8180	*
	* 2.2494	* 2.5115	* 2.4297	* 2.7346	* 2.5595	* 2.3613	* 3.6648	*
13	* 1.6103	* 1.6073	* 1.4653	* 1.5453	* 1.3660	* 1.2619	* 0.6503	*
	* 2.3257	* 2.3389	* 2.5858	* 2.4802	* 2.3617	* 2.5387	* 4.4800	*
14	* 1.9479	* 1.9217	* 1.7705	* 1.0550	* 0.8168	* 0.6501	*	*
	* 2.0746	* 2.1072	* 2.3079	* 3.3402	* 3.6669	* 4.4824	*	*
15	* 0.9861	* 0.9892	* 0.8989	* 0.6112	* F-SUB-Q			
	* 3.3996	* 3.5192	* 3.8331	* 5.5779	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0367	* 1.2736	* 1.7129	* 1.4160	* 1.7639	* 1.5976	* 1.9348	* 0.9833
	* 2.6461	* 2.5422	* 2.1150	* 2.3596	* 2.0606	* 2.1437	* 1.9163	* 3.0998
9	* 1.2736	* 1.6008	* 1.4480	* 1.7347	* 1.4582	* 1.5962	* 1.9101	* 0.9842
	* 2.5422	* 2.2250	* 2.3045	* 2.0909	* 2.2937	* 2.1509	* 1.9423	* 3.2013
10	* 1.7129	* 1.4456	* 1.2738	* 1.3380	* 1.6644	* 1.4607	* 1.7662	* 0.9013
	* 2.1150	* 2.3065	* 2.6415	* 2.5175	* 2.2040	* 2.3536	* 2.1065	* 3.4568
11	* 1.4160	* 1.7345	* 1.3372	* 1.5874	* 1.2965	* 1.5599	* 1.0646	* 0.6301
	* 2.3596	* 2.0911	* 2.5188	* 2.2016	* 2.4393	* 2.2111	* 2.9593	* 5.0038
12	* 1.7639	* 1.4583	* 1.6642	* 1.2957	* 1.0810	* 1.4030	* 0.8368	*
	* 2.0606	* 2.2937	* 2.2043	* 2.4402	* 2.2840	* 2.1061	* 3.2626	*
13	* 1.5976	* 1.5966	* 1.4618	* 1.5598	* 1.4027	* 1.3037	* 0.6727	*
	* 2.1437	* 2.1509	* 2.3530	* 2.2113	* 2.1064	* 2.2631	* 3.9818	*
14	* 1.9348	* 1.9102	* 1.7659	* 1.0641	* 0.8355	* 0.6724	*	*
	* 1.9163	* 1.9423	* 2.1069	* 2.9626	* 3.2645	* 3.9840	*	*
15	* 0.9833	* 0.9844	* 0.9007	* 0.6136	* F-SUB-Q			
	* 3.0998	* 3.2113	* 3.4591	* 4.9742	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0939	* 1.3006	* 1.7105	* 1.4126	* 1.7528	* 1.5864	* 1.9163	* 0.9897
	* 2.5468	* 2.4448	* 2.0201	* 2.2539	* 1.9729	* 2.0558	* 1.8413	* 2.9362
9	* 1.3006	* 1.6082	* 1.4472	* 1.7262	* 1.4531	* 1.5869	* 1.8938	* 0.9870
	* 2.4448	* 2.1451	* 2.1998	* 2.0006	* 2.1927	* 2.0608	* 1.8653	* 3.0435
10	* 1.7105	* 1.4450	* 1.2904	* 1.3408	* 1.6651	* 1.4681	* 1.7587	* 0.9112
	* 2.0201	* 2.2013	* 2.4892	* 2.3987	* 2.1045	* 2.2335	* 2.0180	* 3.2641
11	* 1.4126	* 1.7260	* 1.3400	* 1.6019	* 1.3315	* 1.5863	* 1.0942	* 0.6414
	* 2.2539	* 2.0008	* 2.4000	* 2.1268	* 2.3527	* 2.1383	* 2.8050	* 4.7111
12	* 1.7528	* 1.4532	* 1.6649	* 1.3307	* 1.1642	* 1.4804	* 0.8787	*
	* 1.9729	* 2.1928	* 2.1048	* 2.3536	* 2.2102	* 2.0437	* 3.0970	*
13	* 1.5864	* 1.5873	* 1.4690	* 1.5861	* 1.4800	* 1.3790	* 0.7172	*
	* 2.0558	* 2.0608	* 2.2329	* 2.1385	* 2.0440	* 2.1948	* 3.7895	*
14	* 1.9163	* 1.8938	* 1.7584	* 1.0937	* 0.8773	* 0.7169	*	*
	* 1.8413	* 1.8653	* 2.0184	* 2.8082	* 3.0988	* 3.7916	*	*
15	* 0.9897	* 0.9872	* 0.9105	* 0.6275	* F-SUB-Q			
	* 2.9362	* 3.0530	* 3.2664	* 4.6616	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2070	* 1.3324	* 1.7507	* 1.4313	* 1.7792	* 1.5993	* 1.9468	* 0.9787
	* 2.2573	* 2.1556	* 1.7712	* 1.9945	* 1.7394	* 1.8260	* 1.6224	* 2.6611
9	* 1.3324	* 1.6601	* 1.4706	* 1.7586	* 1.4667	* 1.6029	* 1.9262	* 0.9829
	* 2.1556	* 1.8753	* 1.9439	* 1.7593	* 1.9465	* 1.8277	* 1.6420	* 2.7403
10	* 1.7507	* 1.4681	* 1.2887	* 1.3615	* 1.7064	* 1.4843	* 1.7991	* 0.9020
	* 1.7712	* 1.9456	* 2.2378	* 2.1218	* 1.8449	* 1.9876	* 1.7692	* 2.9593
11	* 1.4313	* 1.7584	* 1.3608	* 1.6707	* 1.3766	* 1.6624	* 1.0995	* 0.6407
	* 1.9945	* 1.7594	* 2.1229	* 1.8712	* 2.0933	* 1.8855	* 2.5321	* 4.2470
12	* 1.7792	* 1.4667	* 1.7062	* 1.3754	* 1.3424	* 1.6492	* 0.9057	*
	* 1.7394	* 1.9466	* 1.8451	* 2.0941	* 1.9523	* 1.7992	* 2.8253	*
13	* 1.5993	* 1.6033	* 1.4855	* 1.6623	* 1.6489	* 1.5260	* 0.7490	*
	* 1.8260	* 1.8277	* 1.9869	* 1.8858	* 1.7995	* 1.9357	* 3.4568	*
14	* 1.9468	* 1.9262	* 1.7988	* 1.0990	* 0.9043	* 0.7488	*	*
	* 1.6224	* 1.6420	* 1.7696	* 2.5350	* 2.8271	* 3.4587	*	*
15	* 0.9787	* 0.9831	* 0.9013	* 0.6226	* F-SUB-Q			
	* 2.6611	* 2.7488	* 2.9615	* 4.2311	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3031	* 1.3670	* 1.7749	* 1.4443	* 1.7928	* 1.6069	* 1.9582	* 0.9819 *
	* 2.0156	* 1.9469	* 1.5907	* 1.7999	* 1.5696	* 1.6544	* 1.4672	* 2.4176 *
9	* 1.3670	* 1.7017	* 1.4878	* 1.7758	* 1.4769	* 1.6124	* 1.9395	* 0.9868 *
	* 1.9469	* 1.6872	* 1.7505	* 1.5853	* 1.7604	* 1.6541	* 1.4837	* 2.4875 *
10	* 1.7749	* 1.4853	* 1.3043	* 1.3792	* 1.7332	* 1.5024	* 1.8203	* 0.9082 *
	* 1.5907	* 1.7521	* 2.0155	* 1.9098	* 1.6553	* 1.7896	* 1.5923	* 2.6803 *
11	* 1.4443	* 1.7756	* 1.3786	* 1.7222	* 1.4257	* 1.7209	* 1.1240	* 0.6496 *
	* 1.7999	* 1.5855	* 1.9109	* 1.6799	* 1.8779	* 1.6890	* 2.2840	* 3.8274 *
12	* 1.7928	* 1.4770	* 1.7330	* 1.4246	* 1.5204	* 1.7798	* 0.9461	*
	* 1.5696	* 1.7604	* 1.6555	* 1.8787	* 1.7474	* 1.6091	* 2.5282	*
13	* 1.6069	* 1.6128	* 1.5036	* 1.7207	* 1.7795	* 1.6454	* 0.7918	*
	* 1.6544	* 1.6541	* 1.7889	* 1.6892	* 1.6094	* 1.7354	* 3.1077	*
14	* 1.9582	* 1.9395	* 1.8199	* 1.1235	* 0.9446	* 0.7916	*	
	* 1.4672	* 1.4837	* 1.5926	* 2.2866	* 2.5299	* 3.1095	*	
15	* 0.9819	* 0.9870	* 0.9074	* 0.6309	* F-SUB-Q			
	* 2.4176	* 2.4952	* 2.6824	* 3.8154	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3371	* 1.3820	* 1.7699	* 1.4446	* 1.7834	* 1.6026	* 1.9389	* 0.9967
	* 1.8697	* 1.7690	* 1.4717	* 1.6637	* 1.4594	* 1.5343	* 1.3692	* 2.2063
9	* 1.3820	* 1.7089	* 1.4914	* 1.7668	* 1.4776	* 1.6087	* 1.9218	* 0.9961
	* 1.7690	* 1.5432	* 1.6132	* 1.4724	* 1.6277	* 1.5333	* 1.3834	* 2.2826
10	* 1.7699	* 1.4888	* 1.3330	* 1.3869	* 1.7326	* 1.5079	* 1.8094	* 0.9277
	* 1.4717	* 1.6148	* 1.8235	* 1.7569	* 1.5283	* 1.6439	* 1.4795	* 2.4306
11	* 1.4446	* 1.7666	* 1.3863	* 1.7388	* 1.4539	* 1.7409	* 1.1643	* 0.6661
	* 1.6637	* 1.4725	* 1.7579	* 1.5490	* 1.7340	* 1.5682	* 2.0345	* 3.4579
12	* 1.7834	* 1.4776	* 1.7324	* 1.4527	* 1.5838	* 1.8306	* 0.9928	*
	* 1.4594	* 1.6277	* 1.5285	* 1.7350	* 1.6063	* 1.4908	* 2.2808	*
13	* 1.6026	* 1.6091	* 1.5090	* 1.7407	* 1.8303	* 1.7014	* 0.8383	*
	* 1.5343	* 1.5333	* 1.6434	* 1.5685	* 1.4910	* 1.6010	* 2.7924	*
14	* 1.9389	* 1.9218	* 1.8091	* 1.1637	* 0.9914	* 0.8381	*	
	* 1.3692	* 1.3834	* 1.4799	* 2.0370	* 2.2822	* 2.7941	*	
15	* 0.9967	* 0.9964	* 0.9269	* 0.6521	* F-SUB-Q			
	* 2.2063	* 2.2896	* 2.4325	* 3.4199	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3539	* 1.3888	* 1.7797	* 1.4477	* 1.7866	* 1.6041	* 1.9426	* 0.9768 *
	* 1.7065	* 1.6444	* 1.3674	* 1.5549	* 1.3642	* 1.4379	* 1.2809	* 2.1155 *
9	* 1.3888	* 1.7243	* 1.5005	* 1.7743	* 1.4787	* 1.6109	* 1.9268	* 0.9823 *
	* 1.6444	* 1.4256	* 1.4995	* 1.3730	* 1.5252	* 1.4359	* 1.2932	* 2.1745 *
10	* 1.7797	* 1.4979	* 1.3183	* 1.3946	* 1.7510	* 1.5143	* 1.8194	* 0.9101 *
	* 1.3674	* 1.5010	* 1.7267	* 1.6396	* 1.4172	* 1.5358	* 1.3776	* 2.3271 *
11	* 1.4477	* 1.7741	* 1.3940	* 1.7616	* 1.4714	* 1.7718	* 1.1510	* 0.6573 *
	* 1.5549	* 1.3732	* 1.6405	* 1.4267	* 1.5954	* 1.4392	* 1.9283	* 3.2883 *
12	* 1.7866	* 1.4788	* 1.7509	* 1.4703	* 1.6200	* 1.8705	* 0.9878	*
	* 1.3642	* 1.5252	* 1.4174	* 1.5962	* 1.5001	* 1.3842	* 2.1570	*
13	* 1.6041	* 1.6113	* 1.5155	* 1.7714	* 1.8702	* 1.7336	* 0.8347	*
	* 1.4379	* 1.4359	* 1.5352	* 1.4394	* 1.3844	* 1.5010	* 2.6778	*
14	* 1.9426	* 1.9268	* 1.8189	* 1.1504	* 0.9863	* 0.8345	*	
	* 1.2809	* 1.2932	* 1.3779	* 1.9306	* 2.1585	* 2.6793	*	
15	* 0.9768	* 0.9826	* 0.9093	* 0.6389	F-SUB-Q			
	* 2.1155	* 2.1811	* 2.3290	* 3.2752	M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3115	* 1.3362	* 1.6923	* 1.3904	* 1.6964	* 1.5366	* 1.8385	* 0.9296 *
	* 1.6665	* 1.6079	* 1.3619	* 1.5376	* 1.3644	* 1.4276	* 1.2861	* 2.1193 *
9	* 1.3362	* 1.6443	* 1.4485	* 1.6859	* 1.4208	* 1.5451	* 1.8247	* 0.9392 *
	* 1.6079	* 1.4069	* 1.4735	* 1.3718	* 1.5085	* 1.4234	* 1.2973	* 2.1686 *
10	* 1.6923	* 1.4460	* 1.2683	* 1.3438	* 1.6737	* 1.4573	* 1.7261	* 0.8684 *
	* 1.3619	* 1.4749	* 1.6997	* 1.6162	* 1.4077	* 1.5146	* 1.3785	* 2.3247 *
11	* 1.3904	* 1.6856	* 1.3433	* 1.6844	* 1.4239	* 1.6955	* 1.1091	* 0.6320 *
	* 1.5376	* 1.3719	* 1.6171	* 1.4140	* 1.5629	* 1.4267	* 1.8968	* 3.2580 *
12	* 1.6964	* 1.4206	* 1.6736	* 1.4227	* 1.5674	* 1.7883	* 0.9525	*
	* 1.3644	* 1.5089	* 1.4079	* 1.5637	* 1.4607	* 1.3659	* 2.1235	*
13	* 1.5366	* 1.5455	* 1.4585	* 1.6952	* 1.7881	* 1.6556	* 0.8028	*
	* 1.4276	* 1.4234	* 1.5140	* 1.4269	* 1.3661	* 1.4831	* 2.6393	*
14	* 1.8385	* 1.8247	* 1.7257	* 1.1086	* 0.9510	* 0.8025	*	
	* 1.2861	* 1.2973	* 1.3789	* 1.8991	* 2.1251	* 2.6409	*	
15	* 0.9296	* 0.9395	* 0.8676	* 0.6139	* F-SUB-Q			
	* 2.1193	* 2.1751	* 2.3268	* 3.2471	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 445 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1395	* 1.1508	* 1.4167	* 1.1966	* 1.4191	* 1.3103	* 1.5321	* 0.7968 *
	* 1.8219	* 1.7834	* 1.5582	* 1.7138	* 1.5649	* 1.6069	* 1.4806	* 2.3801 *
9	* 1.1508	* 1.3840	* 1.2563	* 1.4142	* 1.2171	* 1.3232	* 1.5217	* 0.8059 *
	* 1.7834	* 1.5962	* 1.6284	* 1.5662	* 1.6911	* 1.5955	* 1.4926	* 2.4351 *
10	* 1.4167	* 1.2544	* 1.1023	* 1.1600	* 1.4101	* 1.2545	* 1.4446	* 0.7357 *
	* 1.5582	* 1.6297	* 1.8761	* 1.7948	* 1.6022	* 1.6884	* 1.5812	* 2.6444 *
11	* 1.1966	* 1.4140	* 1.1595	* 1.4205	* 1.2348	* 1.4259	* 0.9538	* 0.5434 *
	* 1.7138	* 1.5669	* 1.7957	* 1.6002	* 1.7245	* 1.6213	* 2.1136	* 3.6526 *
12	* 1.4191	* 1.2170	* 1.4100	* 1.2339	* 1.3580	* 1.5009	* 0.8226 *	
	* 1.5649	* 1.6914	* 1.6025	* 1.7254	* 1.6163	* 1.5600	* 2.3666 *	
13	* 1.3103	* 1.3235	* 1.2553	* 1.4256	* 1.5007	* 1.3900	* 0.6829 *	
	* 1.6069	* 1.5955	* 1.6879	* 1.6216	* 1.5602	* 1.6937	* 2.9865 *	
14	* 1.5321	* 1.5217	* 1.4442	* 0.9532	* 0.8214	* 0.6827 *		
	* 1.4806	* 1.4927	* 1.5817	* 2.1163	* 2.3682	* 2.9883 *		
15	* 0.7968	* 0.8061	* 0.7350	* 0.5274	* F-SUB-Q			
	* 2.3801	* 2.4424	* 2.6469	* 3.6433	* M-SUB-Q			

AT 50% POWER, 445 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5338	* 0.5624	* 0.6728	* 0.5821	* 0.6736	* 0.5976	* 0.6609	* 0.3742 *
	* 3.7292	* 3.5092	* 3.1583	* 3.3935	* 3.1785	* 3.3875	* 3.2983	* 4.8944 *
9	* 0.5624	* 0.6575	* 0.5846	* 0.6716	* 0.5747	* 0.6015	* 0.6559	* 0.3741 *
	* 3.5092	* 3.2311	* 3.3660	* 3.1747	* 3.4499	* 3.3744	* 3.3282	* 5.0678 *
10	* 0.6728	* 0.5839	* 0.5422	* 0.5674	* 0.6690	* 0.5771	* 0.6194	* 0.3464 *
	* 3.1583	* 3.3675	* 3.6743	* 3.5334	* 3.2458	* 3.5370	* 3.5465	* 5.4259 *
11	* 0.5821	* 0.6715	* 0.5672	* 0.6628	* 0.5844	* 0.6570	* 0.4565	* 0.2567 *
	* 3.3935	* 3.1760	* 3.5351	* 3.2933	* 3.4930	* 3.3716	* 4.2523	* 7.4808 *
12	* 0.6736	* 0.5746	* 0.6689	* 0.5841	* 0.6104	* 0.6493	* 0.3891 *	
	* 3.1785	* 3.4505	* 3.2464	* 3.4941	* 3.4598	* 3.4707	* 4.8328 *	
13	* 0.5976	* 0.6016	* 0.5775	* 0.6568	* 0.6492	* 0.5905	* 0.3204 *	
	* 3.3875	* 3.3747	* 3.5358	* 3.3723	* 3.4714	* 3.8390	* 6.1574 *	
14	* 0.6609	* 0.6559	* 0.6192	* 0.4562	* 0.3886	* 0.3203 *		
	* 3.2983	* 3.3283	* 3.5479	* 4.2580	* 4.8351	* 6.1615 *		
15	* 0.3742	* 0.3743	* 0.3460	* 0.2516	* F-SUB-Q			
	* 4.8944	* 5.0818	* 5.4314	* 7.3882	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-2

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 4.0341	* 3.9672	* 3.1411	* 3.9431	* 3.2308	* 4.1181	* 3.6954	* 6.5284 *
	* 4.4406	* 4.3784	* 3.6134	* 4.3508	* 3.7281	* 4.5851	* 4.3054	* 7.2867 *
	* 4.5522	* 4.5147	* 3.8325	* 4.4862	* 3.9582	* 4.7497	* 4.5307	* 7.5357 *
	* 4.2564	* 4.2772	* 3.8500	* 4.2460	* 3.9552	* 4.4727	* 4.4137	* 6.9669 *
	* 3.6790	* 3.7825	* 3.5499	* 3.7742	* 3.6398	* 3.9684	* 4.0472	* 6.0164 *
	* 2.9384	* 3.1261	* 3.0349	* 3.1327	* 3.1051	* 3.2190	* 3.3624	* 4.6058 *
9	* 3.9672	* 3.1918	* 3.8360	* 3.1960	* 4.0115	* 4.1824	* 3.7242	* 6.6163 *
	* 4.3784	* 3.6709	* 4.2356	* 3.6773	* 4.4401	* 4.6449	* 4.3388	* 7.3764 *
	* 4.5147	* 3.8864	* 4.3710	* 3.8941	* 4.5909	* 4.7978	* 4.5623	* 7.6366 *
	* 4.2773	* 3.8861	* 4.1445	* 3.8934	* 4.3453	* 4.5065	* 4.4328	* 7.0797 *
	* 3.7825	* 3.5641	* 3.6852	* 3.5826	* 3.8613	* 3.9885	* 4.0644	* 6.1252 *
	* 3.1261	* 3.0380	* 3.0602	* 3.0637	* 3.1852	* 3.2500	* 3.3957	* 4.7535 *
10	* 3.1411	* 3.8376	* 4.1836	* 3.9731	* 3.2211	* 4.0662	* 3.9588	* 7.2010 *
	* 3.6133	* 4.2362	* 4.6232	* 4.4309	* 3.7162	* 4.5518	* 4.5893	* 8.0264 *
	* 3.8325	* 4.3715	* 4.7655	* 4.5972	* 3.9561	* 4.7192	* 4.7983	* 8.3047 *
	* 3.8500	* 4.1451	* 4.4972	* 4.3485	* 3.9346	* 4.4355	* 4.5943	* 7.6690 *
	* 3.5499	* 3.6853	* 3.9596	* 3.8569	* 3.6134	* 3.9325	* 4.1612	* 6.5843 *
	* 3.0349	* 3.0595	* 3.2626	* 3.1685	* 3.0536	* 3.2001	* 3.4974	* 5.1232 *
11	* 3.9431	* 3.1971	* 3.9739	* 3.2017	* 3.8777	* 3.4055	* 5.0591	*10.1414 *
	* 4.3508	* 3.6787	* 4.4320	* 3.6966	* 4.3230	* 3.9792	* 5.6790	*11.2877 *
	* 4.4862	* 3.8952	* 4.5984	* 3.9418	* 4.4849	* 4.1932	* 5.9228	*11.5920 *
	* 4.2460	* 3.8941	* 4.3496	* 3.9199	* 4.2261	* 4.0817	* 5.5708	*10.4384 *
	* 3.7742	* 3.5834	* 3.8577	* 3.5949	* 3.7547	* 3.7411	* 4.9061	* 8.5997 *
	* 3.1327	* 3.0644	* 3.1691	* 3.0221	* 3.0571	* 3.1345	* 3.9409	* 6.3828 *
12	* 3.2308	* 4.0131	* 3.2214	* 3.8787	* 3.9269	* 3.5266	* 5.8079 *	
	* 3.7281	* 4.4408	* 3.7168	* 4.3238	* 4.3860	* 4.1288	* 6.5058 *	
	* 3.9582	* 4.5914	* 3.9568	* 4.4858	* 4.5369	* 4.3409	* 6.7522 *	
	* 3.9552	* 4.3456	* 3.9353	* 4.2268	* 4.2081	* 4.1720	* 6.2570 *	
	* 3.6398	* 3.8616	* 3.6140	* 3.7553	* 3.6831	* 3.7927	* 5.4340 *	
	* 3.1051	* 3.1859	* 3.0540	* 3.0568	* 2.9173	* 3.1458	* 4.2334 *	
13	* 4.1182	* 4.1827	* 4.0659	* 3.4055	* 3.5263	* 3.9527	* 7.3676 *	
	* 4.5851	* 4.6452	* 4.5519	* 3.9793	* 4.1284	* 4.5867	* 8.2321 *	
	* 4.7497	* 4.7986	* 4.7193	* 4.1932	* 4.3403	* 4.7790	* 8.5006 *	
	* 4.4727	* 4.5071	* 4.4356	* 4.0818	* 4.1715	* 4.5038	* 7.7660 *	
	* 3.9684	* 3.9891	* 3.9326	* 3.7412	* 3.7924	* 4.0321	* 6.6613 *	
	* 3.2190	* 3.2505	* 3.2004	* 3.1347	* 3.1457	* 3.3616	* 5.1234 *	
14	* 3.6954	* 3.7236	* 3.9581	* 5.0584	* 5.8040	* 7.3683 *		
	* 4.3054	* 4.3381	* 4.5885	* 5.6786	* 6.5016	* 8.2329 *		
	* 4.5307	* 4.5616	* 4.7974	* 5.9225	* 6.7478	* 8.5014 *		
	* 4.4137	* 4.4323	* 4.5935	* 5.5710	* 6.2532	* 7.7668 *		
	* 4.0472	* 4.0641	* 4.1606	* 4.9069	* 5.4309	* 6.6620 *		
	* 3.3624	* 3.3956	* 3.4975	* 3.9422	* 4.2335	* 5.1245 *		
15	* 6.5284	* 6.6140	* 7.2008	*10.1042 *	4 EFPD	118 % POWER		
	* 7.2867	* 7.3741	* 8.0262	*11.2589 *	50 EFPD	118 % POWER		
	* 7.5357	* 7.6358	* 8.3047	*11.5739 *	100 EFPD	118 % POWER		
	* 6.9669	* 7.0808	* 7.6697	*10.4459 *	200 EFPD	118 % POWER		
	* 6.0164	* 6.1268	* 6.5858	* 8.6105 *	300 EFPD	118 % POWER		
	* 4.6058	* 4.7574	* 5.1248	* 6.3937 *	445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8688	* 1.8727	* 1.4725	* 1.8791	* 1.5072	* 1.8315	* 1.5200	* 2.9045
	* 2.0307	* 2.0419	* 1.6612	* 2.0286	* 1.7016	* 2.0007	* 1.7485	* 3.1829
	* 2.0941	* 2.1038	* 1.7655	* 2.0866	* 1.8107	* 2.0740	* 1.8560	* 3.2925
	* 2.0514	* 2.0643	* 1.8414	* 2.0426	* 1.8802	* 2.0318	* 1.8984	* 3.1587
	* 1.9485	* 1.9689	* 1.8245	* 1.9467	* 1.8551	* 1.9275	* 1.8648	* 2.9070
	* 1.7881	* 1.8309	* 1.7652	* 1.8184	* 1.7911	* 1.7802	* 1.7727	* 2.5354
9	* 1.8727	* 1.4732	* 1.7395	* 1.4846	* 1.8246	* 1.8364	* 1.5275	* 2.9237
	* 2.0419	* 1.6663	* 1.9002	* 1.6746	* 1.9868	* 2.0135	* 1.7575	* 3.2001
	* 2.1038	* 1.7718	* 1.9557	* 1.7801	* 2.0578	* 2.0902	* 1.8648	* 3.3111
	* 2.0643	* 1.8472	* 1.9201	* 1.8516	* 2.0198	* 2.0419	* 1.9038	* 3.1776
	* 1.9689	* 1.8322	* 1.8358	* 1.8335	* 1.9261	* 1.9288	* 1.8706	* 2.9288
	* 1.8309	* 1.7692	* 1.7148	* 1.7739	* 1.7913	* 1.7798	* 1.7851	* 2.5758
10	* 1.4725	* 1.7401	* 1.9601	* 1.8577	* 1.4721	* 1.7771	* 1.6025	* 3.1814
	* 1.6612	* 1.9010	* 2.1326	* 2.0481	* 1.6714	* 1.9719	* 1.8396	* 3.4856
	* 1.7655	* 1.9564	* 2.2048	* 2.1261	* 1.7896	* 2.0496	* 1.9422	* 3.6094
	* 1.8414	* 1.9207	* 2.1686	* 2.0867	* 1.8592	* 2.0077	* 1.9577	* 3.4586
	* 1.8245	* 1.8364	* 2.0664	* 1.9814	* 1.8297	* 1.8976	* 1.9049	* 3.1756
	* 1.7652	* 1.7148	* 1.9187	* 1.8366	* 1.7557	* 1.7457	* 1.8197	* 2.7947
11	* 1.8791	* 1.4852	* 1.8581	* 1.4401	* 1.7771	* 1.4850	* 2.2648	* 4.4456
	* 2.0286	* 1.6753	* 2.0486	* 1.6383	* 1.9447	* 1.7141	* 2.5048	* 4.8681
	* 2.0866	* 1.7807	* 2.1266	* 1.7575	* 2.0187	* 1.8248	* 2.6206	* 5.0085
	* 2.0426	* 1.8520	* 2.0873	* 1.8245	* 1.9768	* 1.8641	* 2.5687	* 4.6853
	* 1.9467	* 1.8339	* 1.9819	* 1.7915	* 1.8749	* 1.8274	* 2.4144	* 4.1696
	* 1.8184	* 1.7744	* 1.8370	* 1.7132	* 1.7307	* 1.7364	* 2.1615	* 3.4973
12	* 1.5072	* 1.8253	* 1.4723	* 1.7778	* 1.7204	* 1.4512	* 2.6085	*
	* 1.7016	* 1.9873	* 1.6717	* 1.9453	* 1.8983	* 1.6780	* 2.8696	*
	* 1.8107	* 2.0582	* 1.7899	* 2.0193	* 1.9727	* 1.7800	* 2.9792	*
	* 1.8802	* 2.0200	* 1.8595	* 1.9774	* 1.9099	* 1.8011	* 2.8641	*
	* 1.8551	* 1.9263	* 1.8300	* 1.8755	* 1.7882	* 1.7605	* 2.6478	*
	* 1.7911	* 1.7917	* 1.7559	* 1.7308	* 1.6255	* 1.6649	* 2.3317	*
13	* 1.8315	* 1.8363	* 1.7761	* 1.4850	* 1.4510	* 1.6226	* 3.2067	*
	* 2.0007	* 2.0134	* 1.9711	* 1.7141	* 1.6778	* 1.8624	* 3.5283	*
	* 2.0740	* 2.0902	* 2.0493	* 1.8248	* 1.7799	* 1.9570	* 3.6511	*
	* 2.0318	* 2.0420	* 2.0076	* 1.8641	* 1.8010	* 1.9430	* 3.4681	*
	* 1.9275	* 1.9289	* 1.8974	* 1.8275	* 1.7604	* 1.8626	* 3.1684	*
	* 1.7802	* 1.7799	* 1.7456	* 1.7365	* 1.6649	* 1.7590	* 2.7622	*
14	* 1.5200	* 1.5272	* 1.6022	* 2.2643	* 2.6075	* 3.2070	*	*
	* 1.7485	* 1.7572	* 1.8392	* 2.5044	* 2.8685	* 3.5286	*	*
	* 1.8560	* 1.8645	* 1.9418	* 2.6203	* 2.9781	* 3.6514	*	*
	* 1.8984	* 1.9035	* 1.9573	* 2.5686	* 2.8631	* 3.4684	*	*
	* 1.8648	* 1.8704	* 1.9046	* 2.4145	* 2.6470	* 3.1687	*	*
	* 1.7727	* 1.7850	* 1.8197	* 2.1622	* 2.3323	* 2.7627	*	*
15	* 2.9045	* 2.9228	* 3.1810	* 4.4245	* 4 EFPD	118 % POWER		
	* 3.1829	* 3.1995	* 3.4852	* 4.8498	* 50 EFPD	118 % POWER		
	* 3.2925	* 3.3112	* 3.6091	* 4.9947	* 100 EFPD	118 % POWER		
	* 3.1587	* 3.1786	* 3.4586	* 4.6853	* 200 EFPD	118 % POWER		
	* 2.9070	* 2.9300	* 3.1760	* 4.1742	* 300 EFPD	118 % POWER		
	* 2.5354	* 2.5785	* 2.7953	* 3.5038	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6381	* 1.6903	* 1.5847	* 1.7193	* 1.5885	* 1.5817	* 1.4312	* 2.6044
	* 1.7374	* 1.7652	* 1.6366	* 1.7688	* 1.6667	* 1.6834	* 1.5816	* 2.7626
	* 1.7741	* 1.7819	* 1.6390	* 1.7708	* 1.6799	* 1.7230	* 1.6375	* 2.8064
	* 1.7578	* 1.7429	* 1.5972	* 1.7194	* 1.6295	* 1.6940	* 1.6226	* 2.6726
	* 1.7186	* 1.6997	* 1.5624	* 1.6715	* 1.5867	* 1.6391	* 1.5849	* 2.4923
	* 1.6664	* 1.6602	* 1.5568	* 1.6361	* 1.5726	* 1.5763	* 1.5469	* 2.2573
9	* 1.6903	* 1.5014	* 1.5697	* 1.5366	* 1.5927	* 1.5737	* 1.4271	* 2.5870
	* 1.7652	* 1.5712	* 1.6466	* 1.6015	* 1.6815	* 1.6805	* 1.5821	* 2.7486
	* 1.7819	* 1.5875	* 1.6646	* 1.6085	* 1.7119	* 1.7244	* 1.6412	* 2.7969
	* 1.7429	* 1.5864	* 1.6279	* 1.5904	* 1.6835	* 1.6954	* 1.6286	* 2.6714
	* 1.6997	* 1.5709	* 1.5882	* 1.5649	* 1.6397	* 1.6386	* 1.5929	* 2.4997
	* 1.6602	* 1.5705	* 1.5575	* 1.5666	* 1.6036	* 1.5803	* 1.5588	* 2.2837
10	* 1.5847	* 1.5708	* 1.6958	* 1.6539	* 1.4667	* 1.5452	* 1.4209	* 2.7531
	* 1.6366	* 1.6474	* 1.7971	* 1.7422	* 1.5613	* 1.6567	* 1.5736	* 2.9293
	* 1.6390	* 1.6656	* 1.8376	* 1.7768	* 1.5905	* 1.7031	* 1.6337	* 2.9892
	* 1.5972	* 1.6287	* 1.8247	* 1.7484	* 1.5884	* 1.6781	* 1.6447	* 2.8602
	* 1.5624	* 1.5890	* 1.7873	* 1.7003	* 1.5615	* 1.6254	* 1.6167	* 2.6667
	* 1.5568	* 1.5577	* 1.7459	* 1.6554	* 1.5503	* 1.5713	* 1.5977	* 2.4312
11	* 1.7193	* 1.5373	* 1.6544	* 1.4508	* 1.5528	* 1.3744	* 1.9543	* 3.7832
	* 1.7688	* 1.6024	* 1.7427	* 1.5306	* 1.6494	* 1.5105	* 2.1006	* 4.0511
	* 1.7708	* 1.6092	* 1.7774	* 1.5658	* 1.6903	* 1.5657	* 2.1692	* 4.1313
	* 1.7194	* 1.5909	* 1.7489	* 1.5676	* 1.6628	* 1.5822	* 2.1305	* 3.8924
	* 1.6715	* 1.5653	* 1.7008	* 1.5359	* 1.6110	* 1.5570	* 2.0393	* 3.5382
	* 1.6361	* 1.5670	* 1.6558	* 1.5198	* 1.5581	* 1.5296	* 1.9213	* 3.0967
12	* 1.5885	* 1.5928	* 1.4669	* 1.5534	* 1.4904	* 1.3647	* 2.3311	*
	* 1.6667	* 1.6819	* 1.5613	* 1.6498	* 1.6028	* 1.5126	* 2.4746	*
	* 1.6799	* 1.7123	* 1.5909	* 1.6908	* 1.6495	* 1.5716	* 2.5210	*
	* 1.6295	* 1.6839	* 1.5888	* 1.6634	* 1.6033	* 1.5538	* 2.4115	*
	* 1.5867	* 1.6400	* 1.5618	* 1.6115	* 1.5387	* 1.5101	* 2.2641	*
	* 1.5726	* 1.6040	* 1.5505	* 1.5584	* 1.4728	* 1.4687	* 2.0681	*
13	* 1.5817	* 1.5737	* 1.5441	* 1.3745	* 1.3644	* 1.3737	* 2.7032	*
	* 1.6834	* 1.6804	* 1.6557	* 1.5105	* 1.5123	* 1.5332	* 2.9009	*
	* 1.7230	* 1.7244	* 1.7027	* 1.5657	* 1.5713	* 1.5908	* 2.9709	*
	* 1.6940	* 1.6954	* 1.6778	* 1.5822	* 1.5537	* 1.5816	* 2.8363	*
	* 1.6391	* 1.6387	* 1.6252	* 1.5570	* 1.5100	* 1.5513	* 2.6425	*
	* 1.5763	* 1.5804	* 1.5711	* 1.5296	* 1.4688	* 1.5405	* 2.4019	*
14	* 1.4312	* 1.4269	* 1.4204	* 1.9538	* 2.3305	* 2.7035	*	*
	* 1.5816	* 1.5818	* 1.5731	* 2.1001	* 2.4740	* 2.9012	*	*
	* 1.6375	* 1.6409	* 1.6332	* 2.1689	* 2.5204	* 2.9712	*	*
	* 1.6226	* 1.6283	* 1.6442	* 2.1303	* 2.4109	* 2.8366	*	*
	* 1.5849	* 1.5927	* 1.6162	* 2.0393	* 2.2636	* 2.6428	*	*
	* 1.5469	* 1.5587	* 1.5976	* 1.9219	* 2.0688	* 2.4023	*	*
15	* 2.6044	* 2.5863	* 2.7525	* 3.7480	* 4 EFPD	118 % POWER		
	* 2.7626	* 2.7480	* 2.9288	* 4.0183	* 50 EFPD	118 % POWER		
	* 2.8064	* 2.7969	* 2.9887	* 4.1024	* 100 EFPD	118 % POWER		
	* 2.6726	* 2.6722	* 2.8600	* 3.8759	* 200 EFPD	118 % POWER		
	* 2.4923	* 2.5007	* 2.6667	* 3.5259	* 300 EFPD	118 % POWER		
	* 2.2573	* 2.2862	* 2.4315	* 3.0880	* 445 EFPD	118 % POWER		



C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5681	* 1.6316	* 1.4725	* 1.6879	* 1.4932	* 1.4758	* 1.3180	* 2.5570
	* 1.6250	* 1.6653	* 1.5235	* 1.6718	* 1.5302	* 1.5457	* 1.4241	* 2.6470
	* 1.6429	* 1.6508	* 1.4791	* 1.6400	* 1.5106	* 1.5691	* 1.4572	* 2.6516
	* 1.6393	* 1.6167	* 1.4333	* 1.5858	* 1.4546	* 1.5431	* 1.4359	* 2.5141
	* 1.6321	* 1.6039	* 1.4273	* 1.5662	* 1.4410	* 1.5169	* 1.4274	* 2.3749
	* 1.6317	* 1.6128	* 1.4732	* 1.5738	* 1.4723	* 1.4959	* 1.4341	* 2.1990
9	* 1.6316	* 1.4284	* 1.5077	* 1.4737	* 1.5121	* 1.4593	* 1.3122	* 2.5196
	* 1.6653	* 1.4426	* 1.5379	* 1.4718	* 1.5660	* 1.5326	* 1.4233	* 2.6152
	* 1.6508	* 1.4294	* 1.5395	* 1.4510	* 1.5723	* 1.5600	* 1.4605	* 2.6270
	* 1.6167	* 1.4273	* 1.5066	* 1.4255	* 1.5514	* 1.5423	* 1.4420	* 2.5021
	* 1.6039	* 1.4428	* 1.4947	* 1.4306	* 1.5351	* 1.5176	* 1.4351	* 2.3704
	* 1.6128	* 1.4930	* 1.5066	* 1.4772	* 1.5401	* 1.4995	* 1.4447	* 2.2077
10	* 1.4725	* 1.5093	* 1.6228	* 1.5847	* 1.3662	* 1.4611	* 1.3014	* 2.6799
	* 1.5235	* 1.5389	* 1.6791	* 1.6213	* 1.4098	* 1.5229	* 1.4084	* 2.7905
	* 1.4791	* 1.5410	* 1.6990	* 1.6326	* 1.4193	* 1.5502	* 1.4495	* 2.8181
	* 1.4333	* 1.5076	* 1.6971	* 1.6135	* 1.4204	* 1.5401	* 1.4689	* 2.7001
	* 1.4273	* 1.4956	* 1.6927	* 1.5976	* 1.4269	* 1.5188	* 1.4671	* 2.5525
	* 1.4732	* 1.5070	* 1.6993	* 1.6011	* 1.4667	* 1.5131	* 1.4947	* 2.3744
11	* 1.6879	* 1.4744	* 1.5853	* 1.3655	* 1.4642	* 1.2709	* 1.8853	* 3.6851
	* 1.6718	* 1.4725	* 1.6218	* 1.3896	* 1.5180	* 1.3571	* 1.9808	* 3.8668
	* 1.6400	* 1.4517	* 1.6332	* 1.3991	* 1.5419	* 1.3914	* 2.0278	* 3.9125
	* 1.5858	* 1.4259	* 1.6140	* 1.4029	* 1.5278	* 1.4105	* 2.0032	* 3.7058
	* 1.5662	* 1.4310	* 1.5981	* 1.4049	* 1.5082	* 1.4156	* 1.9467	* 3.4182
	* 1.5738	* 1.4774	* 1.6015	* 1.4387	* 1.5037	* 1.4395	* 1.8629	* 3.0673
12	* 1.4932	* 1.5122	* 1.3662	* 1.4649	* 1.3935	* 1.2648	* 2.2839	*
	* 1.5302	* 1.5662	* 1.4098	* 1.5186	* 1.4614	* 1.3629	* 2.3586	*
	* 1.5106	* 1.5727	* 1.4198	* 1.5425	* 1.4868	* 1.4004	* 2.3743	*
	* 1.4546	* 1.5518	* 1.4207	* 1.5285	* 1.4566	* 1.3781	* 2.2749	*
	* 1.4410	* 1.5352	* 1.4272	* 1.5087	* 1.4225	* 1.3645	* 2.1689	*
	* 1.4723	* 1.5404	* 1.4669	* 1.5041	* 1.4047	* 1.3755	* 2.0331	*
13	* 1.4758	* 1.4591	* 1.4605	* 1.2709	* 1.2645	* 1.2454	* 2.6094	*
	* 1.5457	* 1.5324	* 1.5225	* 1.3571	* 1.3627	* 1.3603	* 2.7391	*
	* 1.5691	* 1.5599	* 1.5497	* 1.3915	* 1.4002	* 1.4023	* 2.7822	*
	* 1.5431	* 1.5423	* 1.5396	* 1.4105	* 1.3780	* 1.4053	* 2.6733	*
	* 1.5169	* 1.5176	* 1.5183	* 1.4156	* 1.3645	* 1.4068	* 2.5352	*
	* 1.4959	* 1.4996	* 1.5128	* 1.4396	* 1.3755	* 1.4408	* 2.3655	*
14	* 1.3180	* 1.3120	* 1.3009	* 1.8847	* 2.2838	* 2.6097	*	*
	* 1.4242	* 1.4229	* 1.4079	* 1.9803	* 2.3584	* 2.7394	*	*
	* 1.4572	* 1.4602	* 1.4490	* 2.0274	* 2.3740	* 2.7825	*	*
	* 1.4359	* 1.4418	* 1.4685	* 2.0030	* 2.2747	* 2.6736	*	*
	* 1.4274	* 1.4349	* 1.4667	* 1.9469	* 2.1687	* 2.5355	*	*
	* 1.4341	* 1.4446	* 1.4946	* 1.8634	* 2.0339	* 2.3660	*	*
15	* 2.5570	* 2.5187	* 2.6793	* 3.6595	* 4 EFPD	118 % POWER		
	* 2.6470	* 2.6144	* 2.7899	* 3.8445	* 50 EFPD	118 % POWER		
	* 2.6516	* 2.6269	* 2.8176	* 3.8945	* 100 EFPD	118 % POWER		
	* 2.5141	* 2.5026	* 2.6998	* 3.6990	* 200 EFPD	118 % POWER		
	* 2.3749	* 2.3714	* 2.5525	* 3.4155	* 300 EFPD	118 % POWER		
	* 2.1990	* 2.2100	* 2.3746	* 3.0665	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5953	* 1.6635	* 1.5398	* 1.7117	* 1.4787	* 1.4566	* 1.2902	* 2.5609
	* 1.6196	* 1.6577	* 1.4980	* 1.6617	* 1.4904	* 1.5077	* 1.3751	* 2.6101
	* 1.6234	* 1.6261	* 1.4327	* 1.6097	* 1.4563	* 1.5228	* 1.3992	* 2.5941
	* 1.6307	* 1.5979	* 1.3850	* 1.5553	* 1.4041	* 1.5059	* 1.3777	* 2.4626
	* 1.6418	* 1.6077	* 1.4033	* 1.5574	* 1.4155	* 1.5006	* 1.3920	* 2.3510
	* 1.6715	* 1.6433	* 1.4739	* 1.5811	* 1.4686	* 1.4987	* 1.4197	* 2.1973
9	* 1.6635	* 1.4345	* 1.5254	* 1.4680	* 1.5077	* 1.4379	* 1.2835	* 2.5196
	* 1.6577	* 1.4158	* 1.5284	* 1.4370	* 1.5411	* 1.4933	* 1.3740	* 2.5776
	* 1.6261	* 1.3875	* 1.5159	* 1.4040	* 1.5363	* 1.5136	* 1.4028	* 2.5717
	* 1.5979	* 1.3901	* 1.4816	* 1.3783	* 1.5204	* 1.5036	* 1.3842	* 2.4522
	* 1.6077	* 1.4280	* 1.4899	* 1.4068	* 1.5263	* 1.4993	* 1.3996	* 2.3497
	* 1.6433	* 1.5078	* 1.5224	* 1.4725	* 1.5484	* 1.5000	* 1.4295	* 2.2130
10	* 1.5398	* 1.5272	* 1.6426	* 1.5929	* 1.3495	* 1.4541	* 1.2689	* 2.6686
	* 1.4980	* 1.5296	* 1.6720	* 1.5955	* 1.3626	* 1.4888	* 1.3574	* 2.7447
	* 1.4327	* 1.5178	* 1.6774	* 1.5947	* 1.3631	* 1.5091	* 1.3912	* 2.7542
	* 1.3850	* 1.4828	* 1.6795	* 1.5911	* 1.3792	* 1.5137	* 1.4177	* 2.6418
	* 1.4033	* 1.4910	* 1.6971	* 1.5989	* 1.4094	* 1.5158	* 1.4360	* 2.5239
	* 1.4739	* 1.5229	* 1.7274	* 1.6297	* 1.4784	* 1.5358	* 1.4894	* 2.3669
11	* 1.7117	* 1.4686	* 1.5936	* 1.3535	* 1.4586	* 1.2496	* 1.8781	* 3.7032
	* 1.6617	* 1.4379	* 1.5961	* 1.3462	* 1.4849	* 1.3085	* 1.9403	* 3.8307
	* 1.6097	* 1.4047	* 1.5954	* 1.3459	* 1.5012	* 1.3348	* 1.9769	* 3.8546
	* 1.5553	* 1.3788	* 1.5917	* 1.3621	* 1.5027	* 1.3657	* 1.9695	* 3.6706
	* 1.5574	* 1.4072	* 1.5994	* 1.3880	* 1.5052	* 1.3911	* 1.9409	* 3.4241
	* 1.5811	* 1.4727	* 1.6301	* 1.4505	* 1.5266	* 1.4444	* 1.8925	* 3.1158
12	* 1.4787	* 1.5077	* 1.3495	* 1.4590	* 1.3720	* 1.2426	* 2.2897	*
	* 1.4904	* 1.5412	* 1.3626	* 1.4856	* 1.4134	* 1.3130	* 2.3186	*
	* 1.4563	* 1.5368	* 1.3632	* 1.5019	* 1.4319	* 1.3421	* 2.3187	*
	* 1.4041	* 1.5209	* 1.3795	* 1.5034	* 1.4174	* 1.3252	* 2.2379	*
	* 1.4155	* 1.5264	* 1.4097	* 1.5059	* 1.4052	* 1.3355	* 2.1613	*
	* 1.4686	* 1.5487	* 1.4785	* 1.5271	* 1.4131	* 1.3750	* 2.0576	*
13	* 1.4566	* 1.4376	* 1.4532	* 1.2496	* 1.2423	* 1.2114	* 2.6003	*
	* 1.5077	* 1.4930	* 1.4882	* 1.3086	* 1.3128	* 1.3011	* 2.6824	*
	* 1.5228	* 1.5135	* 1.5084	* 1.3348	* 1.3420	* 1.3369	* 2.7109	*
	* 1.5059	* 1.5035	* 1.5132	* 1.3657	* 1.3252	* 1.3547	* 2.6267	*
	* 1.5006	* 1.4992	* 1.5153	* 1.3911	* 1.3355	* 1.3785	* 2.5216	*
	* 1.4987	* 1.5000	* 1.5354	* 1.4445	* 1.3750	* 1.4393	* 2.3904	*
14	* 1.2902	* 1.2832	* 1.2685	* 1.8776	* 2.2898	* 2.6007	*	*
	* 1.3751	* 1.3736	* 1.3569	* 1.9399	* 2.3186	* 2.6827	*	*
	* 1.3992	* 1.4025	* 1.3906	* 1.9765	* 2.3186	* 2.7112	*	*
	* 1.3777	* 1.3839	* 1.4173	* 1.9693	* 2.2378	* 2.6270	*	*
	* 1.3920	* 1.3994	* 1.4356	* 1.9410	* 2.1612	* 2.5219	*	*
	* 1.4197	* 1.4294	* 1.4893	* 1.8931	* 2.0586	* 2.3909	*	*
15	* 2.5609	* 2.5186	* 2.6680	* 3.6843	* 4 EFPD	118 % POWER		
	* 2.6101	* 2.5767	* 2.7441	* 3.8154	* 50 EFPD	118 % POWER		
	* 2.5941	* 2.5714	* 2.7537	* 3.8439	* 100 EFPD	118 % POWER		
	* 2.4626	* 2.4528	* 2.6416	* 3.6699	* 200 EFPD	118 % POWER		
	* 2.3510	* 2.3506	* 2.5240	* 3.4271	* 300 EFPD	118 % POWER		
	* 2.1973	* 2.2155	* 2.3672	* 3.1198	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6479	* 1.7198	* 1.5854	* 1.7699	* 1.5078	* 1.4776	* 1.3033	* 2.6071
	* 1.6597	* 1.6967	* 1.5234	* 1.6959	* 1.5033	* 1.5174	* 1.3764	* 2.6288
	* 1.6531	* 1.6532	* 1.4431	* 1.6299	* 1.4603	* 1.5283	* 1.3948	* 2.6010
	* 1.6583	* 1.6220	* 1.3942	* 1.5777	* 1.4118	* 1.5194	* 1.3765	* 2.4765
	* 1.6864	* 1.6469	* 1.4293	* 1.5959	* 1.4407	* 1.5277	* 1.4062	* 2.3779
	* 1.7185	* 1.6891	* 1.5031	* 1.6221	* 1.5012	* 1.5321	* 1.4412	* 2.2331
9	* 1.7198	* 1.4748	* 1.5744	* 1.5010	* 1.5396	* 1.4563	* 1.2960	* 2.5669
	* 1.6967	* 1.4399	* 1.5630	* 1.4530	* 1.5616	* 1.5014	* 1.3754	* 2.6006
	* 1.6532	* 1.4003	* 1.5390	* 1.4096	* 1.5504	* 1.5182	* 1.3989	* 2.5834
	* 1.6220	* 1.4021	* 1.5050	* 1.3888	* 1.5399	* 1.5157	* 1.3831	* 2.4698
	* 1.6469	* 1.4557	* 1.5286	* 1.4334	* 1.5624	* 1.5257	* 1.4141	* 2.3831
	* 1.6891	* 1.5453	* 1.5614	* 1.5044	* 1.5875	* 1.5304	* 1.4503	* 2.2525
10	* 1.5854	* 1.5765	* 1.6966	* 1.6261	* 1.3671	* 1.4747	* 1.2775	* 2.7058
	* 1.5234	* 1.5644	* 1.7116	* 1.6170	* 1.3676	* 1.5020	* 1.3579	* 2.7606
	* 1.4431	* 1.5406	* 1.7070	* 1.6092	* 1.3627	* 1.5189	* 1.3884	* 2.7598
	* 1.3942	* 1.5063	* 1.7118	* 1.6091	* 1.3861	* 1.5299	* 1.4199	* 2.6519
	* 1.4293	* 1.5298	* 1.7454	* 1.6340	* 1.4323	* 1.5478	* 1.4521	* 2.5554
	* 1.5031	* 1.5620	* 1.7715	* 1.6754	* 1.5153	* 1.5797	* 1.5072	* 2.3986
11	* 1.7699	* 1.5016	* 1.6266	* 1.3776	* 1.4847	* 1.2647	* 1.8962	* 3.7682
	* 1.6959	* 1.4540	* 1.6177	* 1.3531	* 1.4979	* 1.3098	* 1.9478	* 3.8760
	* 1.6299	* 1.4104	* 1.6099	* 1.3471	* 1.5101	* 1.3323	* 1.9789	* 3.8864
	* 1.5777	* 1.3893	* 1.6098	* 1.3728	* 1.5225	* 1.3740	* 1.9782	* 3.7034
	* 1.5959	* 1.4339	* 1.6345	* 1.4147	* 1.5409	* 1.4157	* 1.9665	* 3.4830
	* 1.6221	* 1.5046	* 1.6758	* 1.4925	* 1.5752	* 1.4851	* 1.9446	* 3.1707
12	* 1.5078	* 1.5396	* 1.3672	* 1.4854	* 1.3896	* 1.2608	* 2.3356	*
	* 1.5033	* 1.5617	* 1.3676	* 1.4986	* 1.4123	* 1.3124	* 2.3319	*
	* 1.4603	* 1.5509	* 1.3628	* 1.5108	* 1.4276	* 1.3373	* 2.3231	*
	* 1.4118	* 1.5404	* 1.3865	* 1.5232	* 1.4283	* 1.3283	* 2.2623	*
	* 1.4407	* 1.5626	* 1.4327	* 1.5416	* 1.4319	* 1.3552	* 2.2007	*
	* 1.5012	* 1.5877	* 1.5154	* 1.5757	* 1.4539	* 1.4111	* 2.1097	*
13	* 1.4776	* 1.4559	* 1.4730	* 1.2648	* 1.2606	* 1.2206	* 2.6448	*
	* 1.5174	* 1.5011	* 1.5013	* 1.3099	* 1.3122	* 1.2940	* 2.6902	*
	* 1.5283	* 1.5181	* 1.5181	* 1.3324	* 1.3372	* 1.3271	* 2.7093	*
	* 1.5194	* 1.5156	* 1.5293	* 1.3739	* 1.3283	* 1.3603	* 2.6457	*
	* 1.5277	* 1.5256	* 1.5471	* 1.4158	* 1.3552	* 1.3994	* 2.5649	*
	* 1.5321	* 1.5304	* 1.5792	* 1.4853	* 1.4112	* 1.4761	* 2.4479	*
14	* 1.3033	* 1.2957	* 1.2770	* 1.8957	* 2.3359	* 2.6452	*	*
	* 1.3764	* 1.3750	* 1.3574	* 1.9475	* 2.3321	* 2.6906	*	*
	* 1.3948	* 1.3986	* 1.3878	* 1.9787	* 2.3233	* 2.7097	*	*
	* 1.3765	* 1.3828	* 1.4194	* 1.9781	* 2.2624	* 2.6460	*	*
	* 1.4062	* 1.4139	* 1.4517	* 1.9667	* 2.2007	* 2.5653	*	*
	* 1.4412	* 1.4502	* 1.5072	* 1.9452	* 2.1109	* 2.4484	*	*
15	* 2.6071	* 2.5658	* 2.7054	* 3.7495	* 4 EFPD	118 % POWER		
	* 2.6289	* 2.5996	* 2.7601	* 3.8611	* 50 EFPD	118 % POWER		
	* 2.6010	* 2.5831	* 2.7593	* 3.8755	* 100 EFPD	118 % POWER		
	* 2.4765	* 2.4704	* 2.6518	* 3.7020	* 200 EFPD	118 % POWER		
	* 2.3779	* 2.3840	* 2.5556	* 3.4840	* 300 EFPD	118 % POWER		
	* 2.2331	* 2.2550	* 2.3991	* 3.1712	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7130	* 1.7923	* 1.6423	* 1.8408	* 1.5452	* 1.5097	* 1.3251	* 2.7092
	* 1.7188	* 1.7580	* 1.5655	* 1.7495	* 1.5324	* 1.5429	* 1.3910	* 2.7130
	* 1.7051	* 1.7042	* 1.4709	* 1.6731	* 1.4820	* 1.5523	* 1.4035	* 2.6759
	* 1.7116	* 1.6735	* 1.4230	* 1.6240	* 1.4385	* 1.5512	* 1.3909	* 2.5556
	* 1.7483	* 1.7087	* 1.4646	* 1.6446	* 1.4708	* 1.5606	* 1.4231	* 2.4538
	* 1.7761	* 1.7353	* 1.5396	* 1.6739	* 1.5394	* 1.5716	* 1.4656	* 2.3117
9	* 1.7922	* 1.5267	* 1.6355	* 1.5433	* 1.5862	* 1.4865	* 1.3175	* 2.6616
	* 1.7580	* 1.4797	* 1.6144	* 1.4852	* 1.6015	* 1.5258	* 1.3905	* 2.6790
	* 1.7042	* 1.4308	* 1.5810	* 1.4335	* 1.5872	* 1.5415	* 1.4082	* 2.6530
	* 1.6735	* 1.4342	* 1.5499	* 1.4175	* 1.5832	* 1.5467	* 1.3978	* 2.5439
	* 1.7087	* 1.4990	* 1.5786	* 1.4679	* 1.6095	* 1.5588	* 1.4327	* 2.4540
	* 1.7352	* 1.5772	* 1.6104	* 1.5427	* 1.6377	* 1.5674	* 1.4741	* 2.3257
10	* 1.6423	* 1.6379	* 1.7641	* 1.6782	* 1.3936	* 1.5102	* 1.2975	* 2.8100
	* 1.5655	* 1.6161	* 1.7700	* 1.6607	* 1.3892	* 1.5336	* 1.3731	* 2.8508
	* 1.4709	* 1.5828	* 1.7593	* 1.6489	* 1.3806	* 1.5493	* 1.4019	* 2.8427
	* 1.4230	* 1.5514	* 1.7689	* 1.6540	* 1.4104	* 1.5665	* 1.4385	* 2.7400
	* 1.4646	* 1.5800	* 1.8082	* 1.6908	* 1.4686	* 1.5954	* 1.4799	* 2.6391
	* 1.5396	* 1.6111	* 1.8288	* 1.7164	* 1.5431	* 1.6154	* 1.5286	* 2.4786
11	* 1.8408	* 1.5441	* 1.6791	* 1.4088	* 1.5196	* 1.2854	* 1.9605	* 3.9269
	* 1.7495	* 1.4863	* 1.6615	* 1.3771	* 1.5304	* 1.3273	* 2.0083	* 4.0247
	* 1.6731	* 1.4344	* 1.6497	* 1.3668	* 1.5405	* 1.3476	* 2.0371	* 4.0273
	* 1.6240	* 1.4181	* 1.6547	* 1.3953	* 1.5581	* 1.3892	* 2.0409	* 3.8430
	* 1.6446	* 1.4683	* 1.6914	* 1.4487	* 1.5880	* 1.4419	* 2.0407	* 3.6331
	* 1.6739	* 1.5429	* 1.7169	* 1.5287	* 1.6202	* 1.5182	* 1.9970	* 3.2801
12	* 1.5452	* 1.5862	* 1.3937	* 1.5202	* 1.4107	* 1.2789	* 2.4204	*
	* 1.5324	* 1.6016	* 1.3892	* 1.5312	* 1.4304	* 1.3289	* 2.4127	*
	* 1.4820	* 1.5878	* 1.3807	* 1.5412	* 1.4445	* 1.3482	* 2.3974	*
	* 1.4385	* 1.5838	* 1.4108	* 1.5589	* 1.4504	* 1.3407	* 2.3322	*
	* 1.4708	* 1.6097	* 1.4687	* 1.5887	* 1.4646	* 1.3781	* 2.2845	*
	* 1.5394	* 1.6379	* 1.5433	* 1.6207	* 1.4911	* 1.4399	* 2.1966	*
13	* 1.5097	* 1.4861	* 1.5092	* 1.2855	* 1.2787	* 1.2351	* 2.7431	*
	* 1.5429	* 1.5255	* 1.5327	* 1.3274	* 1.3288	* 1.3044	* 2.7821	*
	* 1.5523	* 1.5413	* 1.5484	* 1.3476	* 1.3481	* 1.3364	* 2.7979	*
	* 1.5512	* 1.5465	* 1.5657	* 1.3893	* 1.3407	* 1.3769	* 2.7409	*
	* 1.5606	* 1.5587	* 1.5946	* 1.4420	* 1.3782	* 1.4259	* 2.6695	*
	* 1.5716	* 1.5674	* 1.6149	* 1.5184	* 1.4400	* 1.5080	* 2.5573	*
14	* 1.3251	* 1.3172	* 1.2970	* 1.9601	* 2.4210	* 2.7436	*	*
	* 1.3910	* 1.3901	* 1.3725	* 2.0080	* 2.4131	* 2.7826	*	*
	* 1.4035	* 1.4078	* 1.4014	* 2.0370	* 2.3978	* 2.7983	*	*
	* 1.3909	* 1.3975	* 1.4380	* 2.0409	* 2.3324	* 2.7413	*	*
	* 1.4231	* 1.4325	* 1.4795	* 2.0410	* 2.2848	* 2.6699	*	*
	* 1.4656	* 1.4740	* 1.5285	* 1.9980	* 2.1981	* 2.5579	*	*
15	* 2.7092	* 2.6604	* 2.8098	* 3.9213	* 4 EFPD	118 % POWER		
	* 2.7130	* 2.6779	* 2.8505	* 4.0229	* 50 EFPD	118 % POWER		
	* 2.6759	* 2.6527	* 2.8425	* 4.0297	* 100 EFPD	118 % POWER		
	* 2.5556	* 2.5446	* 2.7401	* 3.8555	* 200 EFPD	118 % POWER		
	* 2.4538	* 2.4548	* 2.6395	* 3.6481	* 300 EFPD	118 % POWER		
	* 2.3117	* 2.3283	* 2.4792	* 3.2945	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8201	* 1.9048	* 1.7371	* 1.9470	* 1.6164	* 1.5723	* 1.3761	* 2.8462
	* 1.8206	* 1.8586	* 1.6465	* 1.8409	* 1.5981	* 1.6024	* 1.4391	* 2.8368
	* 1.8010	* 1.7955	* 1.5373	* 1.7550	* 1.5406	* 1.6112	* 1.4477	* 2.7917
	* 1.8097	* 1.7643	* 1.4884	* 1.7068	* 1.5011	* 1.6163	* 1.4387	* 2.6712
	* 1.8414	* 1.7885	* 1.5261	* 1.7220	* 1.5311	* 1.6219	* 1.4690	* 2.5560
	* 1.8549	* 1.8139	* 1.6044	* 1.7514	* 1.6030	* 1.6320	* 1.5135	* 2.4057
9	* 1.9048	* 1.6129	* 1.7300	* 1.6208	* 1.6648	* 1.5470	* 1.3683	* 2.7949
	* 1.8586	* 1.5564	* 1.7007	* 1.5540	* 1.6763	* 1.5839	* 1.4391	* 2.8007
	* 1.7955	* 1.4990	* 1.6601	* 1.4948	* 1.6605	* 1.5996	* 1.4531	* 2.7675
	* 1.7643	* 1.5041	* 1.6303	* 1.4821	* 1.6616	* 1.6110	* 1.4463	* 2.6585
	* 1.7885	* 1.5625	* 1.6532	* 1.5293	* 1.6835	* 1.6187	* 1.4785	* 2.5552
	* 1.8139	* 1.6430	* 1.6852	* 1.6071	* 1.7115	* 1.6262	* 1.5216	* 2.4186
10	* 1.7371	* 1.7327	* 1.8663	* 1.7661	* 1.4551	* 1.5790	* 1.3473	* 2.9498
	* 1.6465	* 1.7038	* 1.8664	* 1.7419	* 1.4468	* 1.6008	* 1.4218	* 2.9814
	* 1.5373	* 1.6623	* 1.8511	* 1.7267	* 1.4354	* 1.6164	* 1.4504	* 2.9676
	* 1.4884	* 1.6320	* 1.8653	* 1.7366	* 1.4711	* 1.6394	* 1.4916	* 2.8655
	* 1.5261	* 1.6547	* 1.8964	* 1.7686	* 1.5304	* 1.6668	* 1.5269	* 2.7476
	* 1.6044	* 1.6861	* 1.9146	* 1.7871	* 1.5966	* 1.6746	* 1.5763	* 2.5753
11	* 1.9470	* 1.6217	* 1.7671	* 1.4763	* 1.5906	* 1.3396	* 2.0544	* 4.1378
	* 1.8409	* 1.5552	* 1.7428	* 1.4379	* 1.5994	* 1.3799	* 2.1002	* 4.2300
	* 1.7550	* 1.4957	* 1.7276	* 1.4241	* 1.6087	* 1.3991	* 2.1284	* 4.2267
	* 1.7068	* 1.4828	* 1.7373	* 1.4565	* 1.6317	* 1.4438	* 2.1356	* 4.0374
	* 1.7220	* 1.5296	* 1.7693	* 1.5167	* 1.6660	* 1.5040	* 2.1310	* 3.7897
	* 1.7514	* 1.6073	* 1.7876	* 1.5786	* 1.6774	* 1.5617	* 2.0663	* 3.4139
12	* 1.6164	* 1.6648	* 1.4552	* 1.5915	* 1.4676	* 1.3325	* 2.5456	*
	* 1.5981	* 1.6764	* 1.4468	* 1.6002	* 1.4875	* 1.3820	* 2.5327	*
	* 1.5406	* 1.6612	* 1.4355	* 1.6095	* 1.5010	* 1.3969	* 2.5122	*
	* 1.5011	* 1.6623	* 1.4712	* 1.6325	* 1.5096	* 1.3901	* 2.4442	*
	* 1.5311	* 1.6837	* 1.5304	* 1.6668	* 1.5297	* 1.4342	* 2.4003	*
	* 1.6030	* 1.7118	* 1.5967	* 1.6780	* 1.5423	* 1.4832	* 2.2733	*
13	* 1.5723	* 1.5466	* 1.5778	* 1.3397	* 1.3324	* 1.2795	* 2.8796	*
	* 1.6024	* 1.5835	* 1.5998	* 1.3800	* 1.3819	* 1.3514	* 2.9199	*
	* 1.6112	* 1.5993	* 1.6154	* 1.3993	* 1.3969	* 1.3837	* 2.9323	*
	* 1.6163	* 1.6108	* 1.6385	* 1.4439	* 1.3902	* 1.4274	* 2.8715	*
	* 1.6219	* 1.6186	* 1.6659	* 1.5042	* 1.4343	* 1.4828	* 2.8034	*
	* 1.6320	* 1.6262	* 1.6740	* 1.5619	* 1.4833	* 1.5555	* 2.6559	*
14	* 1.3761	* 1.3679	* 1.3467	* 2.0542	* 2.5463	* 2.8802	*	*
	* 1.4391	* 1.4387	* 1.4213	* 2.1001	* 2.5334	* 2.9204	*	*
	* 1.4477	* 1.4527	* 1.4499	* 2.1283	* 2.5128	* 2.9328	*	*
	* 1.4387	* 1.4460	* 1.4911	* 2.1358	* 2.4446	* 2.8719	*	*
	* 1.4690	* 1.4783	* 1.5266	* 2.1314	* 2.4008	* 2.8038	*	*
	* 1.5135	* 1.5216	* 1.5763	* 2.0675	* 2.2750	* 2.6566	*	*
15	* 2.8462	* 2.7935	* 2.9498	* 4.1381	* 4 EFPD	118 % POWER		
	* 2.8368	* 2.7995	* 2.9813	* 4.2343	* 50 EFPD	118 % POWER		
	* 2.7917	* 2.7672	* 2.9676	* 4.2352	* 100 EFPD	118 % POWER		
	* 2.6712	* 2.6591	* 2.8658	* 4.0564	* 200 EFPD	118 % POWER		
	* 2.5560	* 2.5560	* 2.7482	* 3.8106	* 300 EFPD	118 % POWER		
	* 2.4057	* 2.4213	* 2.5762	* 3.4337	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9585	* 2.0458	* 1.8524	* 2.0777	* 1.7048	* 1.6538	* 1.4426	* 3.0280
	* 1.9514	* 1.9830	* 1.7459	* 1.9533	* 1.6831	* 1.6835	* 1.5056	* 2.9999
	* 1.9313	* 1.9163	* 1.6270	* 1.8645	* 1.6207	* 1.6930	* 1.5115	* 2.9563
	* 1.9404	* 1.8825	* 1.5751	* 1.8140	* 1.5839	* 1.7032	* 1.5047	* 2.8288
	* 1.9612	* 1.8981	* 1.6081	* 1.8234	* 1.6096	* 1.7018	* 1.5306	* 2.6976
	* 1.9704	* 1.9206	* 1.6882	* 1.8506	* 1.6806	* 1.7045	* 1.5717	* 2.5231
9	* 2.0458	* 1.7173	* 1.8459	* 1.7169	* 1.7654	* 1.6265	* 1.4346	* 2.9698
	* 1.9830	* 1.6523	* 1.8072	* 1.6439	* 1.7757	* 1.6635	* 1.5063	* 2.9597
	* 1.9163	* 1.5900	* 1.7650	* 1.5781	* 1.7603	* 1.6805	* 1.5177	* 2.9289
	* 1.8825	* 1.5964	* 1.7347	* 1.5677	* 1.7658	* 1.6973	* 1.5133	* 2.8134
	* 1.8981	* 1.6490	* 1.7508	* 1.6095	* 1.7800	* 1.6978	* 1.5404	* 2.6933
	* 1.9206	* 1.7309	* 1.7810	* 1.6890	* 1.8050	* 1.7001	* 1.5821	* 2.5323
10	* 1.8524	* 1.8489	* 1.9921	* 1.8793	* 1.5364	* 1.6680	* 1.4134	* 3.1387
	* 1.7459	* 1.8111	* 1.9856	* 1.8505	* 1.5258	* 1.6925	* 1.4894	* 3.1612
	* 1.6270	* 1.7679	* 1.9716	* 1.8333	* 1.5124	* 1.7092	* 1.5188	* 3.1472
	* 1.5751	* 1.7366	* 1.9874	* 1.8471	* 1.5521	* 1.7376	* 1.5639	* 3.0433
	* 1.6081	* 1.7524	* 2.0110	* 1.8685	* 1.6042	* 1.7534	* 1.5912	* 2.9030
	* 1.6882	* 1.7820	* 2.0237	* 1.8836	* 1.6710	* 1.7563	* 1.6394	* 2.7143
11	* 2.0777	* 1.7178	* 1.8804	* 1.5656	* 1.6865	* 1.4135	* 2.1853	* 4.4177
	* 1.9533	* 1.6452	* 1.8516	* 1.5211	* 1.6945	* 1.4537	* 2.2315	* 4.5092
	* 1.8645	* 1.5791	* 1.8343	* 1.5045	* 1.7040	* 1.4731	* 2.2603	* 4.5020
	* 1.8140	* 1.5684	* 1.8479	* 1.5407	* 1.7324	* 1.5219	* 2.2710	* 4.3042
	* 1.8234	* 1.6098	* 1.8692	* 1.5912	* 1.7534	* 1.5739	* 2.2468	* 4.0079
	* 1.8506	* 1.6892	* 1.8841	* 1.6534	* 1.7613	* 1.6271	* 2.1646	* 3.5999
12	* 1.7048	* 1.7655	* 1.5365	* 1.6875	* 1.5547	* 1.4083	* 2.7204	*
	* 1.6831	* 1.7758	* 1.5258	* 1.6955	* 1.5747	* 1.4585	* 2.7030	*
	* 1.6207	* 1.7610	* 1.5125	* 1.7051	* 1.5883	* 1.4700	* 2.6783	*
	* 1.5839	* 1.7666	* 1.5523	* 1.7334	* 1.5999	* 1.4638	* 2.6070	*
	* 1.6096	* 1.7802	* 1.6043	* 1.7543	* 1.6138	* 1.5029	* 2.5392	*
	* 1.6806	* 1.8052	* 1.6711	* 1.7620	* 1.6121	* 1.5419	* 2.3929	*
13	* 1.6538	* 1.6260	* 1.6666	* 1.4136	* 1.4082	* 1.3464	* 3.0774	*
	* 1.6835	* 1.6631	* 1.6913	* 1.4538	* 1.4584	* 1.4214	* 3.1185	*
	* 1.6930	* 1.6802	* 1.7081	* 1.4732	* 1.4700	* 1.4550	* 3.1287	*
	* 1.7032	* 1.6971	* 1.7365	* 1.5221	* 1.4639	* 1.5029	* 3.0646	*
	* 1.7018	* 1.6977	* 1.7524	* 1.5740	* 1.5030	* 1.5555	* 2.9787	*
	* 1.7045	* 1.7001	* 1.7557	* 1.6274	* 1.5420	* 1.6128	* 2.7899	*
14	* 1.4426	* 1.4342	* 1.4129	* 2.1851	* 2.7214	* 3.0781	*	*
	* 1.5056	* 1.5058	* 1.4888	* 2.2314	* 2.7039	* 3.1191	*	*
	* 1.5115	* 1.5173	* 1.5183	* 2.2603	* 2.6791	* 3.1293	*	*
	* 1.5047	* 1.5130	* 1.5635	* 2.2713	* 2.6076	* 3.0651	*	*
	* 1.5306	* 1.5402	* 1.5909	* 2.2473	* 2.5398	* 2.9792	*	*
	* 1.5717	* 1.5820	* 1.6394	* 2.1660	* 2.3948	* 2.7907	*	*
15	* 3.0280	* 2.9683	* 3.1389	* 4.4243	* 4 EFPD	118 % POWER		
	* 2.9999	* 2.9587	* 3.1613	* 4.5201	* 50 EFPD	118 % POWER		
	* 2.9563	* 2.9285	* 3.1474	* 4.5174	* 100 EFPD	118 % POWER		
	* 2.8288	* 2.8140	* 3.0438	* 4.3307	* 200 EFPD	118 % POWER		
	* 2.6976	* 2.6941	* 2.9038	* 4.0362	* 300 EFPD	118 % POWER		
	* 2.5231	* 2.5350	* 2.7154	* 3.6265	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.1134	* 2.2017	* 1.9950	* 2.2359	* 1.8420	* 1.7782	* 1.5534	* 3.1877
	* 2.0973	* 2.1270	* 1.8798	* 2.1000	* 1.8043	* 1.7969	* 1.6089	* 3.1390
	* 2.0828	* 2.0665	* 1.7573	* 2.0032	* 1.7419	* 1.8108	* 1.6186	* 3.0928
	* 2.1091	* 2.0391	* 1.7077	* 1.9602	* 1.7118	* 1.8272	* 1.6153	* 2.9763
	* 2.1361	* 2.0603	* 1.7470	* 1.9765	* 1.7439	* 1.8272	* 1.6430	* 2.8424
	* 2.1281	* 2.0682	* 1.8159	* 1.9836	* 1.8020	* 1.8118	* 1.6714	* 2.6311
9	* 2.2017	* 1.8603	* 2.0000	* 1.8650	* 1.9066	* 1.7489	* 1.5453	* 3.1423
	* 2.1270	* 1.7850	* 1.9446	* 1.7701	* 1.9035	* 1.7763	* 1.6114	* 3.1119
	* 2.0665	* 1.7205	* 1.9010	* 1.7034	* 1.8926	* 1.7983	* 1.6263	* 3.0786
	* 2.0391	* 1.7342	* 1.8775	* 1.6980	* 1.9051	* 1.8205	* 1.6254	* 2.9740
	* 2.0603	* 1.7944	* 1.8995	* 1.7454	* 1.9236	* 1.8215	* 1.6538	* 2.8516
	* 2.0682	* 1.8689	* 1.9128	* 1.8119	* 1.9293	* 1.8056	* 1.6818	* 2.6560
10	* 1.9950	* 2.0031	* 2.1551	* 2.0322	* 1.6727	* 1.7997	* 1.5254	* 3.3148
	* 1.8798	* 1.9490	* 2.1381	* 1.9906	* 1.6479	* 1.8227	* 1.5967	* 3.3132
	* 1.7573	* 1.9046	* 2.1228	* 1.9759	* 1.6376	* 1.8448	* 1.6323	* 3.3019
	* 1.7077	* 1.8797	* 2.1520	* 1.9969	* 1.6842	* 1.8795	* 1.6847	* 3.2015
	* 1.7470	* 1.9013	* 2.1694	* 2.0189	* 1.7347	* 1.8913	* 1.7104	* 3.0546
	* 1.8159	* 1.9139	* 2.1557	* 2.0275	* 1.7998	* 1.8846	* 1.7508	* 2.8184
11	* 2.2359	* 1.8661	* 2.0332	* 1.7077	* 1.8308	* 1.5395	* 2.3217	* 4.6805
	* 2.1000	* 1.7715	* 1.9917	* 1.6488	* 1.8304	* 1.5739	* 2.3534	* 4.7338
	* 2.0032	* 1.7046	* 1.9770	* 1.6348	* 1.8446	* 1.5994	* 2.3889	* 4.7362
	* 1.9602	* 1.6982	* 1.9978	* 1.6776	* 1.8785	* 1.6564	* 2.4050	* 4.5459
	* 1.9765	* 1.7457	* 2.0197	* 1.7235	* 1.8923	* 1.6981	* 2.3700	* 4.2327
	* 1.9836	* 1.8122	* 2.0282	* 1.7840	* 1.8921	* 1.7483	* 2.2841	* 3.7684
12	* 1.8420	* 1.9066	* 1.6728	* 1.8314	* 1.6923	* 1.5374	* 2.9071	*
	* 1.8043	* 1.9037	* 1.6480	* 1.8315	* 1.7098	* 1.5834	* 2.8657	*
	* 1.7419	* 1.8935	* 1.6377	* 1.8457	* 1.7270	* 1.6008	* 2.8471	*
	* 1.7118	* 1.9054	* 1.6844	* 1.8795	* 1.7403	* 1.5940	* 2.7801	*
	* 1.7439	* 1.9238	* 1.7348	* 1.8933	* 1.7363	* 1.6191	* 2.6788	*
	* 1.8020	* 1.9296	* 1.7999	* 1.8927	* 1.7277	* 1.6551	* 2.5076	*
13	* 1.7782	* 1.7484	* 1.7982	* 1.5397	* 1.5373	* 1.4664	* 3.2910	*
	* 1.7969	* 1.7758	* 1.8215	* 1.5741	* 1.5833	* 1.5470	* 3.3127	*
	* 1.8108	* 1.7980	* 1.8436	* 1.5996	* 1.6008	* 1.5831	* 3.3282	*
	* 1.8272	* 1.8203	* 1.8783	* 1.6566	* 1.5942	* 1.6352	* 3.2566	*
	* 1.8272	* 1.8213	* 1.8902	* 1.6983	* 1.6192	* 1.6725	* 3.1250	*
	* 1.8118	* 1.8056	* 1.8841	* 1.7486	* 1.6552	* 1.7276	* 2.9150	*
14	* 1.5534	* 1.5449	* 1.5249	* 2.3217	* 2.9084	* 3.2918	*	*
	* 1.6089	* 1.6109	* 1.5962	* 2.3535	* 2.8667	* 3.3135	*	*
	* 1.6186	* 1.6258	* 1.6317	* 2.3890	* 2.8480	* 3.3289	*	*
	* 1.6153	* 1.6251	* 1.6843	* 2.4054	* 2.7808	* 3.2573	*	*
	* 1.6430	* 1.6536	* 1.7100	* 2.3708	* 2.6795	* 3.1257	*	*
	* 1.6714	* 1.6817	* 1.7509	* 2.2853	* 2.5096	* 2.9160	*	*
15	* 3.1877	* 3.1409	* 3.3153	* 4.6772	* 4 EFPD	118 % POWER		
	* 3.1390	* 3.1107	* 3.3136	* 4.7344	* 50 EFPD	118 % POWER		
	* 3.0928	* 3.0783	* 3.3022	* 4.7407	* 100 EFPD	118 % POWER		
	* 2.9763	* 2.9748	* 3.2021	* 4.5593	* 200 EFPD	118 % POWER		
	* 2.8424	* 2.8525	* 3.0555	* 4.2448	* 300 EFPD	118 % POWER		
	* 2.6311	* 2.6589	* 2.8197	* 3.7773	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.2134	* 2.3072	* 2.0716	* 2.3304	* 1.9218	* 1.8565	* 1.6132	* 3.4024
	* 2.1933	* 2.2249	* 1.9498	* 2.1899	* 1.8829	* 1.8723	* 1.6663	* 3.3386
	* 2.1808	* 2.1635	* 1.8310	* 2.1035	* 1.8169	* 1.8900	* 1.6760	* 3.2885
	* 2.2271	* 2.1615	* 1.8010	* 2.0828	* 1.8002	* 1.9222	* 1.6842	* 3.1846
	* 2.2708	* 2.1989	* 1.8525	* 2.1083	* 1.8432	* 1.9310	* 1.7213	* 3.0498
	* 2.2681	* 2.2090	* 1.9265	* 2.1196	* 1.9088	* 1.9178	* 1.7528	* 2.8279
9	* 2.3072	* 1.9325	* 2.0859	* 1.9476	* 2.0111	* 1.8274	* 1.6063	* 3.3413
	* 2.2249	* 1.8519	* 2.0331	* 1.8482	* 2.0039	* 1.8518	* 1.6711	* 3.2971
	* 2.1635	* 1.7954	* 1.9978	* 1.7839	* 1.9968	* 1.8777	* 1.6855	* 3.2618
	* 2.1615	* 1.8311	* 1.9947	* 1.7883	* 2.0224	* 1.9157	* 1.6962	* 3.1703
	* 2.1989	* 1.9071	* 2.0272	* 1.8484	* 2.0511	* 1.9253	* 1.7338	* 3.0469
	* 2.2090	* 1.9830	* 2.0426	* 1.9210	* 2.0600	* 1.9097	* 1.7629	* 2.8396
10	* 2.0716	* 2.0893	* 2.2504	* 2.1607	* 1.7635	* 1.8903	* 1.5924	* 3.5387
	* 1.9498	* 2.0376	* 2.2317	* 2.1071	* 1.7310	* 1.9227	* 1.6612	* 3.5247
	* 1.8310	* 2.0006	* 2.2259	* 2.0941	* 1.7207	* 1.9485	* 1.6993	* 3.5136
	* 1.8010	* 1.9972	* 2.2788	* 2.1324	* 1.7831	* 2.0010	* 1.7654	* 3.4328
	* 1.8525	* 2.0293	* 2.3242	* 2.1657	* 1.8464	* 2.0218	* 1.7991	* 3.2849
	* 1.9265	* 2.0438	* 2.3201	* 2.1601	* 1.9030	* 1.9926	* 1.8319	* 3.0286
11	* 2.3304	* 1.9487	* 2.1620	* 1.8111	* 1.9492	* 1.6258	* 2.4964	* 5.0260
	* 2.1899	* 1.8497	* 2.1084	* 1.7410	* 1.9402	* 1.6557	* 2.5226	* 5.0671
	* 2.1035	* 1.7852	* 2.0954	* 1.7257	* 1.9573	* 1.6834	* 2.5627	* 5.0723
	* 2.0828	* 1.7885	* 2.1334	* 1.7801	* 2.0095	* 1.7530	* 2.5996	* 4.8992
	* 2.1083	* 1.8487	* 2.1665	* 1.8402	* 2.0315	* 1.8043	* 2.5708	* 4.5732
	* 2.1196	* 1.9213	* 2.1608	* 1.8944	* 2.0196	* 1.8541	* 2.4532	* 4.0503
12	* 1.9218	* 2.0112	* 1.7636	* 1.9504	* 1.7947	* 1.6246	* 3.1537	*
	* 1.8829	* 2.0041	* 1.7311	* 1.9414	* 1.8021	* 1.6658	* 3.0979	*
	* 1.8169	* 1.9977	* 1.7209	* 1.9585	* 1.8229	* 1.6799	* 3.0757	*
	* 1.8002	* 2.0227	* 1.7832	* 2.0107	* 1.8506	* 1.6841	* 3.0182	*
	* 1.8432	* 2.0513	* 1.8465	* 2.0326	* 1.8516	* 1.7162	* 2.9219	*
	* 1.9088	* 2.0604	* 1.9031	* 2.0203	* 1.8415	* 1.7527	* 2.7276	*
13	* 1.8565	* 1.8268	* 1.8886	* 1.6260	* 1.6245	* 1.5482	* 3.5742	*
	* 1.8723	* 1.8512	* 1.9213	* 1.6559	* 1.6658	* 1.6202	* 3.5826	*
	* 1.8900	* 1.8774	* 1.9471	* 1.6836	* 1.6800	* 1.6627	* 3.6013	*
	* 1.9222	* 1.9154	* 1.9996	* 1.7533	* 1.6842	* 1.7295	* 3.5538	*
	* 1.9310	* 1.9252	* 2.0205	* 1.8045	* 1.7163	* 1.7708	* 3.4185	*
	* 1.9178	* 1.9096	* 1.9919	* 1.8544	* 1.7529	* 1.8264	* 3.1775	*
14	* 1.6132	* 1.6059	* 1.5918	* 2.4965	* 3.1554	* 3.5751	*	*
	* 1.6663	* 1.6706	* 1.6606	* 2.5228	* 3.0993	* 3.5834	*	*
	* 1.6760	* 1.6851	* 1.6988	* 2.5630	* 3.0770	* 3.6021	*	*
	* 1.6842	* 1.6959	* 1.7651	* 2.6002	* 3.0192	* 3.5545	*	*
	* 1.7213	* 1.7336	* 1.7988	* 2.5717	* 2.9229	* 3.4192	*	*
	* 1.7528	* 1.7628	* 1.8321	* 2.4551	* 2.7300	* 3.1785	*	*
15	* 3.4024	* 3.3396	* 3.5394	* 5.0452	* 4 EFPD	118 % POWER		
	* 3.3386	* 3.2960	* 3.5253	* 5.0909	* 50 EFPD	118 % POWER		
	* 3.2885	* 3.2615	* 3.5143	* 5.1010	* 100 EFPD	118 % POWER		
	* 3.1846	* 3.1709	* 3.4337	* 4.9410	* 200 EFPD	118 % POWER		
	* 3.0498	* 3.0478	* 3.2862	* 4.6169	* 300 EFPD	118 % POWER		
	* 2.8279	* 2.8426	* 3.0302	* 4.0896	* 445 EFPD	118 % POWER		



C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.3179	* 2.4077	* 2.1560	* 2.4335	* 2.0143	* 1.9672	* 1.7058	* 3.6030
	* 2.2548	* 2.2776	* 1.9976	* 2.2511	* 1.9468	* 1.9697	* 1.7547	* 3.5358
	* 2.2545	* 2.2301	* 1.8850	* 2.1683	* 1.8963	* 2.0016	* 1.7686	* 3.4827
	* 2.3685	* 2.2862	* 1.9081	* 2.2076	* 1.9171	* 2.0496	* 1.7887	* 3.3940
	* 2.4262	* 2.3502	* 1.9785	* 2.2520	* 1.9750	* 2.0678	* 1.8356	* 3.2588
	* 2.4379	* 2.3761	* 2.0736	* 2.2824	* 2.0582	* 2.0618	* 1.8766	* 3.0297
9	* 2.4077	* 2.0176	* 2.1829	* 2.0353	* 2.1142	* 1.9360	* 1.6992	* 3.5406
	* 2.2776	* 1.8985	* 2.0936	* 1.9020	* 2.0856	* 1.9507	* 1.7638	* 3.4920
	* 2.2301	* 1.8485	* 2.0608	* 1.8428	* 2.0862	* 1.9884	* 1.7793	* 3.4556
	* 2.2862	* 1.9364	* 2.1160	* 1.9017	* 2.1546	* 2.0427	* 1.8022	* 3.3786
	* 2.3502	* 2.0326	* 2.1665	* 1.9788	* 2.1979	* 2.0616	* 1.8495	* 3.2571
	* 2.3761	* 2.1303	* 2.2003	* 2.0705	* 2.2221	* 2.0528	* 1.8878	* 3.0433
10	* 2.1560	* 2.1864	* 2.3523	* 2.2628	* 1.8701	* 2.0090	* 1.6870	* 3.7503
	* 1.9976	* 2.0980	* 2.2948	* 2.1844	* 1.8131	* 2.0302	* 1.7556	* 3.7325
	* 1.8850	* 2.0638	* 2.3025	* 2.1940	* 1.8251	* 2.0755	* 1.7976	* 3.7226
	* 1.9081	* 2.1186	* 2.4214	* 2.2728	* 1.9093	* 2.1466	* 1.8801	* 3.6595
	* 1.9785	* 2.1687	* 2.4829	* 2.3202	* 1.9849	* 2.1763	* 1.9228	* 3.5115
	* 2.0736	* 2.2017	* 2.4940	* 2.3284	* 2.0527	* 2.1445	* 1.9627	* 3.2430
11	* 2.4335	* 2.0367	* 2.2643	* 1.9097	* 2.0752	* 1.7276	* 2.6545	* 5.2875
	* 2.2511	* 1.9037	* 2.1858	* 1.8274	* 2.0509	* 1.7555	* 2.6766	* 5.3260
	* 2.1683	* 1.8444	* 2.1954	* 1.8284	* 2.0840	* 1.7869	* 2.7215	* 5.3374
	* 2.2076	* 1.9025	* 2.2739	* 1.9015	* 2.1549	* 1.8770	* 2.7782	* 5.1923
	* 2.2520	* 1.9790	* 2.3211	* 1.9748	* 2.1884	* 1.9401	* 2.7551	* 4.8698
	* 2.2824	* 2.0707	* 2.3291	* 2.0431	* 2.1795	* 1.9883	* 2.6360	* 4.3344
12	* 2.0143	* 2.1144	* 1.8703	* 2.0765	* 1.9151	* 1.7309	* 3.3436	*
	* 1.9468	* 2.0859	* 1.8133	* 2.0524	* 1.9175	* 1.7700	* 3.2873	*
	* 1.8963	* 2.0873	* 1.8254	* 2.0854	* 1.9416	* 1.7863	* 3.2715	*
	* 1.9171	* 2.1549	* 1.9095	* 2.1563	* 1.9867	* 1.8038	* 3.2342	*
	* 1.9750	* 2.1982	* 1.9850	* 2.1897	* 1.9970	* 1.8467	* 3.1419	*
	* 2.0582	* 2.2224	* 2.0529	* 2.1803	* 1.9789	* 1.8790	* 2.9253	*
13	* 1.9672	* 1.9354	* 2.0072	* 1.7279	* 1.7309	* 1.6511	* 3.8247	*
	* 1.9697	* 1.9502	* 2.0287	* 1.7558	* 1.7700	* 1.7223	* 3.8205	*
	* 2.0016	* 1.9880	* 2.0739	* 1.7872	* 1.7864	* 1.7689	* 3.8418	*
	* 2.0496	* 2.0424	* 2.1450	* 1.8772	* 1.8040	* 1.8546	* 3.8173	*
	* 2.0678	* 2.0614	* 2.1751	* 1.9404	* 1.8468	* 1.9068	* 3.6816	*
	* 2.0618	* 2.0527	* 2.1437	* 1.9887	* 1.8792	* 1.9577	* 3.4062	*
14	* 1.7058	* 1.6988	* 1.6865	* 2.6547	* 3.3456	* 3.8258	*	*
	* 1.7547	* 1.7634	* 1.7550	* 2.6769	* 3.2891	* 3.8215	*	*
	* 1.7686	* 1.7788	* 1.7970	* 2.7219	* 3.2731	* 3.8427	*	*
	* 1.7887	* 1.8018	* 1.8797	* 2.7789	* 3.2354	* 3.8182	*	*
	* 1.8356	* 1.8493	* 1.9225	* 2.7562	* 3.1433	* 3.6824	*	*
	* 1.8766	* 1.8877	* 1.9629	* 2.6382	* 2.9280	* 3.4073	*	*
15	* 3.6030	* 3.5392	* 3.7515	* 5.3136	* 4 EFPD	118 % POWER		
	* 3.5358	* 3.4907	* 3.7335	* 5.3577	* 50 EFPD	118 % POWER		
	* 3.4827	* 3.4551	* 3.7235	* 5.3749	* 100 EFPD	118 % POWER		
	* 3.3940	* 3.3792	* 3.6607	* 5.2421	* 200 EFPD	118 % POWER		
	* 3.2588	* 3.2580	* 3.5130	* 4.9202	* 300 EFPD	118 % POWER		
	* 3.0297	* 3.0466	* 3.2449	* 4.3801	* 445 EFPD	118 % POWER		

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	2.2809	2.3708	2.1279	2.3928	1.9974	1.9432	1.6921	3.5444
	2.2193	2.2405	1.9703	2.2136	1.9307	1.9420	1.7313	3.4537
	2.2057	2.1794	1.8564	2.1308	1.8758	1.9778	1.7620	3.4332
	2.3046	2.2306	1.8721	2.1626	1.8959	2.0760	1.8340	3.4298
	2.3979	2.3142	1.9628	2.2290	1.9767	2.1222	1.9095	3.3300
	2.4827	2.4041	2.1239	2.3249	2.1313	2.1978	2.0365	3.1994
9	2.3708	1.9873	2.1469	2.0113	2.0918	1.9153	1.6877	3.4977
	2.2405	1.8717	2.0603	1.8804	2.0655	1.9238	1.7411	3.4273
	2.1794	1.8180	2.0276	1.8191	2.0587	1.9687	1.7760	3.4218
	2.2306	1.9009	2.0749	1.8704	2.1241	2.0714	1.8494	3.4305
	2.3142	2.0144	2.1472	1.9728	2.1912	2.1183	1.9255	3.3445
	2.4041	2.1773	2.2443	2.1364	2.2840	2.1911	2.0501	3.2322
10	2.1279	2.1506	2.3120	2.2348	1.8538	1.9906	1.6837	3.7017
	1.9703	2.0642	2.2565	2.1604	1.7981	2.0097	1.7448	3.6634
	1.8564	2.0305	2.2550	2.1639	1.8031	2.0531	1.8031	3.6862
	1.8721	2.0775	2.3667	2.2573	1.9129	2.1718	1.9351	3.7013
	1.9628	2.1495	2.4497	2.3316	2.0186	2.2317	2.0070	3.5905
	2.1239	2.2456	2.5175	2.4164	2.1754	2.2968	2.1362	3.4294
11	2.3928	2.0126	2.2363	1.9015	2.0419	1.7246	2.5995	5.2912
	2.2136	1.8821	2.1618	1.8144	2.0294	1.7444	2.6118	5.3042
	2.1308	1.8205	2.1653	1.8084	2.0630	1.7914	2.6801	5.3622
	2.1626	1.8713	2.2588	1.9129	2.1806	1.9256	2.7975	5.3317
	2.2290	1.9735	2.3328	2.0130	2.2479	2.0316	2.8095	5.0399
	2.3249	2.1366	2.4173	2.1627	2.3268	2.1708	2.7970	4.5936
12	1.9974	2.0920	1.8540	2.0428	1.9542	1.7474	3.3433	
	1.9307	2.0658	1.7983	2.0304	1.9478	1.7781	3.2636	
	1.8758	2.0598	1.8034	2.0645	1.9909	1.8259	3.2749	
	1.8959	2.1245	1.9136	2.1821	2.0871	1.8937	3.3115	
	1.9767	2.1914	2.0190	2.2492	2.1274	1.9675	3.2486	
	2.1313	2.2844	2.1756	2.3277	2.1565	2.0534	3.1115	
13	1.9432	1.9147	1.9888	1.7249	1.7474	1.7032	3.8621	
	1.9420	1.9232	2.0082	1.7447	1.7781	1.7692	3.8455	
	1.9778	1.9684	2.0514	1.7917	1.8260	1.8339	3.9025	
	2.0760	2.0711	2.1703	1.9257	1.8939	1.9719	3.9567	
	2.1222	2.1182	2.2303	2.0317	1.9677	2.0562	3.8556	
	2.1978	2.1911	2.2962	2.1712	2.0537	2.1364	3.6170	
14	1.6921	1.6873	1.6831	2.5998	3.3455	3.8633		
	1.7313	1.7407	1.7443	2.6122	3.2653	3.8466		
	1.7620	1.7756	1.8025	2.6806	3.2764	3.9036		
	1.8340	1.8491	1.9348	2.7984	3.3129	3.9577		
	1.9095	1.9253	2.0068	2.8107	3.2499	3.8566		
	2.0365	2.0500	2.1366	2.7989	3.1145	3.6183		
15	3.5444	3.4960	3.7029	5.3050	4	EFFD 118	% POWER	
	3.4537	3.4261	3.6644	5.3229	50	EFFD 118	% POWER	

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.2067	* 2.2949	* 2.0436	* 2.3063	* 1.9194	* 1.8735	* 1.6232	* 3.4886
	* 2.1496	* 2.1703	* 1.8946	* 2.1349	* 1.8551	* 1.8758	* 1.6629	* 3.3902
	* 2.1246	* 2.0990	* 1.7711	* 2.0443	* 1.7897	* 1.9067	* 1.6870	* 3.3669
	* 2.2093	* 2.1372	* 1.7835	* 2.0727	* 1.8154	* 2.0043	* 1.7547	* 3.3737
	* 2.2944	* 2.2167	* 1.8763	* 2.1415	* 1.8978	* 2.0469	* 1.8254	* 3.2705
	* 2.3508	* 2.2820	* 1.9987	* 2.2029	* 2.0056	* 2.0772	* 1.9089	* 3.0786
9	* 2.2949	* 1.9072	* 2.0690	* 1.9232	* 2.0246	* 1.8444	* 1.6184	* 3.4274
	* 2.1703	* 1.7992	* 1.9871	* 1.8026	* 1.9947	* 1.8566	* 1.6718	* 3.3481
	* 2.0990	* 1.7358	* 1.9463	* 1.7334	* 1.9797	* 1.8963	* 1.6997	* 3.3413
	* 2.1372	* 1.8066	* 1.9889	* 1.7849	* 2.0460	* 1.9984	* 1.7695	* 3.3608
	* 2.2167	* 1.9215	* 2.0625	* 1.8889	* 2.1143	* 2.0416	* 1.8405	* 3.2708
	* 2.2820	* 2.0508	* 2.1271	* 2.0110	* 2.1665	* 2.0694	* 1.9212	* 3.0936
10	* 2.0436	* 2.0727	* 2.2300	* 2.1561	* 1.7915	* 1.9236	* 1.6175	* 3.6381
	* 1.8946	* 1.9919	* 2.1797	* 2.0862	* 1.7371	* 1.9537	* 1.6764	* 3.5847
	* 1.7711	* 1.9493	* 2.1680	* 2.0818	* 1.7323	* 1.9919	* 1.7280	* 3.6097
	* 1.7835	* 1.9914	* 2.2701	* 2.1695	* 1.8323	* 2.0993	* 1.8523	* 3.6441
	* 1.8763	* 2.0646	* 2.3565	* 2.2447	* 1.9382	* 2.1545	* 1.9185	* 3.5314
	* 1.9987	* 2.1285	* 2.4090	* 2.2920	* 2.0469	* 2.1706	* 2.0031	* 3.3024
11	* 2.3063	* 1.9245	* 2.1576	* 1.8317	* 2.0021	* 1.6685	* 2.5657	* 5.1821
	* 2.1349	* 1.8043	* 2.0876	* 1.7523	* 1.9794	* 1.6900	* 2.5724	* 5.1932
	* 2.0443	* 1.7349	* 2.0831	* 1.7357	* 2.0056	* 1.7287	* 2.6377	* 5.2350
	* 2.0727	* 1.7858	* 2.1709	* 1.8322	* 2.1089	* 1.8435	* 2.7470	* 5.2015
	* 2.1415	* 1.8895	* 2.2459	* 1.9307	* 2.1697	* 1.9442	* 2.7544	* 4.9222
	* 2.2029	* 2.0112	* 2.2929	* 2.0347	* 2.2027	* 2.0477	* 2.6852	* 4.4334
12	* 1.9194	* 2.0249	* 1.7911	* 2.0036	* 1.8893	* 1.6881	* 3.2970	*
	* 1.8551	* 1.9960	* 1.7373	* 1.9810	* 1.8864	* 1.7209	* 3.2149	*
	* 1.7897	* 1.9808	* 1.7331	* 2.0072	* 1.9223	* 1.7558	* 3.2256	*
	* 1.8154	* 2.0463	* 1.8330	* 2.1105	* 2.0029	* 1.8070	* 3.2427	*
	* 1.8978	* 2.1146	* 1.9386	* 2.1711	* 2.0424	* 1.8781	* 3.1919	*
	* 2.0056	* 2.1668	* 2.0472	* 2.2037	* 2.0845	* 1.9687	* 3.0250	*
13	* 1.8735	* 1.8438	* 1.9217	* 1.6688	* 1.6882	* 1.6374	* 3.8172	*
	* 1.8758	* 1.8560	* 1.9521	* 1.6903	* 1.7210	* 1.7035	* 3.7803	*
	* 1.9067	* 1.8960	* 1.9902	* 1.7290	* 1.7560	* 1.7602	* 3.8391	*
	* 2.0043	* 1.9981	* 2.0977	* 1.8436	* 1.8072	* 1.8810	* 3.8979	*
	* 2.0469	* 2.0414	* 2.1530	* 1.9444	* 1.8783	* 1.9620	* 3.8009	*
	* 2.0772	* 2.0694	* 2.1699	* 2.0480	* 1.9690	* 2.0765	* 3.5820	*
14	* 1.6232	* 1.6180	* 1.6170	* 2.5661	* 3.2993	* 3.8184	*	*
	* 1.6629	* 1.6715	* 1.6759	* 2.5730	* 3.2170	* 3.7814	*	*
	* 1.6870	* 1.6993	* 1.7275	* 2.6383	* 3.2276	* 3.8401	*	*
	* 1.7547	* 1.7692	* 1.8520	* 2.7478	* 3.2442	* 3.8989	*	*
	* 1.8254	* 1.8403	* 1.9183	* 2.7556	* 3.1934	* 3.8019	*	*
	* 1.9089	* 1.9212	* 2.0033	* 2.6877	* 3.0281	* 3.5832	*	*
15	* 3.4886	* 3.4256	* 3.6394	* 5.2209	* 4 EFPD	118 % POWER		
	* 3.3902	* 3.3469	* 3.5860	* 5.2366	* 50 EFPD	118 % POWER		
	* 3.3669	* 3.3409	* 3.6109	* 5.2834	* 100 EFPD	118 % POWER		
	* 3.3737	* 3.3615	* 3.6457	* 5.2626	* 200 EFPD	118 % POWER		
	* 3.2705	* 3.2718	* 3.5333	* 4.9836	* 300 EFPD	118 % POWER		
	* 3.0786	* 3.0972	* 3.3046	* 4.4899	* 445 EFPD	118 % POWER		

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	2.0917	2.1733	1.9302	2.1862	1.8092	1.7681	1.5275	3.2946
	2.0295	2.0479	1.7866	2.0182	1.7476	1.7612	1.5566	3.1918
	2.0091	1.9832	1.6728	1.9340	1.6913	1.7923	1.5806	3.1673
	2.1000	2.0282	1.6902	1.9676	1.7208	1.8980	1.6582	3.1847
	2.1965	2.1203	1.7911	2.0495	1.8121	1.9636	1.7492	3.1293
	2.2307	2.1668	1.8992	2.0965	1.9107	1.9830	1.8138	2.9579
9	2.1733	1.8039	1.9623	1.8193	1.9122	1.7397	1.5226	3.2322
	2.0479	1.6958	1.8780	1.7004	1.8787	1.7413	1.5640	3.1476
	1.9832	1.6381	1.8423	1.6370	1.8707	1.7806	1.5912	3.1382
	2.0282	1.7120	1.8897	1.6919	1.9438	1.8912	1.6714	3.1683
	2.1203	1.8351	1.9751	1.8036	2.0253	1.9579	1.7632	3.1258
	2.1668	1.9462	2.0254	1.9135	2.0669	1.9745	1.8254	2.9643
10	1.9302	1.9660	2.1141	2.0439	1.6783	1.8114	1.5186	3.4264
	1.7866	1.8826	2.0586	1.9668	1.6188	1.8229	1.5626	3.3689
	1.6728	1.8454	2.0493	1.9648	1.6207	1.8620	1.6125	3.3852
	1.6902	1.8921	2.1539	2.0607	1.7349	1.9858	1.7458	3.4347
	1.7911	1.9772	2.2531	2.1496	1.8524	2.0676	1.8352	3.3759
	1.8992	2.0268	2.2869	2.1832	1.9504	2.0719	1.9028	3.1724
11	2.1862	1.8205	2.0454	1.7289	1.8781	1.5622	2.4081	4.9060
	2.0182	1.7020	1.9683	1.6376	1.8433	1.5675	2.4011	4.8899
	1.9340	1.6384	1.9661	1.6278	1.8724	1.6075	2.4616	4.9322
	1.9676	1.6927	2.0621	1.7339	1.9958	1.7403	2.5938	4.9281
	2.0495	1.8043	2.1507	1.8473	2.0844	1.8651	2.6419	4.7021
	2.0965	1.9140	2.1841	1.9382	2.1043	1.9474	2.5651	4.2311
12	1.8092	1.9124	1.6785	1.8796	1.7803	1.5820	3.1019	
	1.7476	1.8790	1.6190	1.8446	1.7628	1.5984	3.0043	
	1.6913	1.8718	1.6210	1.8740	1.8010	1.6367	3.0109	
	1.7208	1.9441	1.7355	1.9974	1.9000	1.7072	3.0633	
	1.8121	2.0256	1.8528	2.0857	1.9727	1.8074	3.0622	
	1.9107	2.0672	1.9506	2.1053	1.9819	1.8670	2.8994	
13	1.7681	1.7391	1.8095	1.5626	1.5820	1.5310	3.5704	
	1.7612	1.7408	1.8214	1.5678	1.5985	1.5805	3.5333	
	1.7923	1.7803	1.8603	1.6079	1.6369	1.6378	3.5867	
	1.8980	1.8909	1.9843	1.7404	1.7074	1.7729	3.6656	
	1.9636	1.9577	2.0662	1.8653	1.8076	1.8857	3.6462	
	1.9830	1.9744	2.0712	1.9477	1.8673	1.9668	3.4316	
14	1.5275	1.5223	1.5181	2.4086	3.1044	3.5716		
	1.5566	1.5635	1.5622	2.4017	3.0064	3.5344		
	1.5806	1.5909	1.6121	2.4623	3.0129	3.5878		
	1.6582	1.6712	1.7456	2.5948	3.0649	3.6665		
	1.7492	1.7630	1.8351	2.6432	3.0638	3.6471		
	1.8138	1.8254	1.9031	2.5676	2.9026	3.4328		
15	3.2946	3.2306	3.4279	4.9493	4 EFPD	118 %	POWER	
	3.1918	3.1465	3.3702	4.9381	50 EFPD	118 %	POWER	

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9856	* 2.0653	* 1.8338	* 2.0791	* 1.7110	* 1.6663	* 1.4378	* 3.1156
	* 1.9283	* 1.9477	* 1.6988	* 1.9204	* 1.6565	* 1.6622	* 1.4669	* 3.0205
	* 1.9025	* 1.8785	* 1.5838	* 1.8329	* 1.5999	* 1.6882	* 1.4858	* 2.9898
	* 1.9722	* 1.9025	* 1.5808	* 1.8458	* 1.6098	* 1.7746	* 1.5461	* 2.9805
	* 2.0606	* 1.9863	* 1.6737	* 1.9200	* 1.6925	* 1.8341	* 1.6283	* 2.9215
	* 2.1126	* 2.0503	* 1.7952	* 1.9847	* 1.8064	* 1.8766	* 1.7154	* 2.7783
9	* 2.0653	* 1.7108	* 1.8628	* 1.7221	* 1.8075	* 1.6379	* 1.4327	* 3.0573
	* 1.9477	* 1.6098	* 1.7832	* 1.6118	* 1.7781	* 1.6417	* 1.4729	* 2.9795
	* 1.8785	* 1.5485	* 1.7432	* 1.5475	* 1.7669	* 1.6757	* 1.4953	* 2.9634
	* 1.9025	* 1.6013	* 1.7728	* 1.5822	* 1.8230	* 1.7673	* 1.5584	* 2.9670
	* 1.9863	* 1.7147	* 1.8509	* 1.6860	* 1.8970	* 1.8276	* 1.6414	* 2.9206
	* 2.0503	* 1.8398	* 1.9184	* 1.8092	* 1.9563	* 1.8676	* 1.7260	* 2.7909
10	* 1.8338	* 1.8664	* 2.0077	* 1.9317	* 1.5775	* 1.7047	* 1.4263	* 3.2326
	* 1.6988	* 1.7878	* 1.9569	* 1.8602	* 1.5245	* 1.7181	* 1.4691	* 3.1813
	* 1.5838	* 1.7475	* 1.9420	* 1.8527	* 1.5222	* 1.7513	* 1.5131	* 3.1897
	* 1.5808	* 1.7752	* 2.0241	* 1.9323	* 1.6207	* 1.8585	* 1.6282	* 3.2118
	* 1.6737	* 1.8529	* 2.1148	* 2.0144	* 1.7293	* 1.9332	* 1.7095	* 3.1458
	* 1.7952	* 1.9197	* 2.1654	* 2.0657	* 1.8437	* 1.9584	* 1.7976	* 2.9702
11	* 2.0791	* 1.7234	* 1.9332	* 1.6264	* 1.7649	* 1.4642	* 2.2596	* 4.6343
	* 1.9204	* 1.6134	* 1.8616	* 1.5420	* 1.7339	* 1.4699	* 2.2546	* 4.6204
	* 1.8329	* 1.5490	* 1.8540	* 1.5303	* 1.7591	* 1.5042	* 2.3066	* 4.6549
	* 1.8458	* 1.5830	* 1.9336	* 1.6186	* 1.8659	* 1.6218	* 2.4171	* 4.6232
	* 1.9200	* 1.6866	* 2.0155	* 1.7237	* 1.9469	* 1.7364	* 2.4582	* 4.4015
	* 1.9847	* 1.8096	* 2.0665	* 1.8316	* 1.9902	* 1.8404	* 2.4181	* 3.9785
12	* 1.7110	* 1.8077	* 1.5778	* 1.7664	* 1.6634	* 1.4819	* 2.9153	*
	* 1.6565	* 1.7784	* 1.5247	* 1.7351	* 1.6453	* 1.4957	* 2.8217	*
	* 1.5999	* 1.7681	* 1.5224	* 1.7606	* 1.6783	* 1.5268	* 2.8213	*
	* 1.6098	* 1.8234	* 1.6214	* 1.8674	* 1.7670	* 1.5864	* 2.8567	*
	* 1.6925	* 1.8973	* 1.7297	* 1.9481	* 1.8345	* 1.6781	* 2.8492	*
	* 1.8064	* 1.9566	* 1.8439	* 1.9912	* 1.8760	* 1.7649	* 2.7206	*
13	* 1.6663	* 1.6373	* 1.7029	* 1.4646	* 1.4820	* 1.4276	* 3.3476	*
	* 1.6622	* 1.6412	* 1.7166	* 1.4702	* 1.4958	* 1.4715	* 3.3067	*
	* 1.6882	* 1.6754	* 1.7497	* 1.5045	* 1.5270	* 1.5226	* 3.3503	*
	* 1.7746	* 1.7670	* 1.8570	* 1.6219	* 1.5867	* 1.6452	* 3.4137	*
	* 1.8341	* 1.8274	* 1.9318	* 1.7366	* 1.6784	* 1.7497	* 3.3851	*
	* 1.8766	* 1.8676	* 1.9576	* 1.8406	* 1.7651	* 1.8572	* 3.2140	*
14	* 1.4378	* 1.4323	* 1.4259	* 2.2602	* 2.9176	* 3.3488	*	*
	* 1.4669	* 1.4724	* 1.4687	* 2.2553	* 2.8238	* 3.3078	*	*
	* 1.4858	* 1.4950	* 1.5127	* 2.3073	* 2.8232	* 3.3513	*	*
	* 1.5461	* 1.5582	* 1.6280	* 2.4181	* 2.8583	* 3.4146	*	*
	* 1.6283	* 1.6412	* 1.7094	* 2.4595	* 2.8509	* 3.3861	*	*
	* 1.7154	* 1.7260	* 1.7979	* 2.4206	* 2.7237	* 3.2152	*	*
15	* 3.1156	* 3.0557	* 3.2342	* 4.6785	* 4 EFPD	118 % POWER		
	* 3.0205	* 2.9784	* 3.1827	* 4.6692	* 50 EFPD	118 % POWER		
	* 2.9898	* 2.9629	* 3.1911	* 4.7073	* 100 EFPD	118 % POWER		
	* 2.9805	* 2.9676	* 3.2135	* 4.6864	* 200 EFPD	118 % POWER		
	* 2.9215	* 2.9215	* 3.1478	* 4.4644	* 300 EFPD	118 % POWER		
	* 2.7783	* 2.7942	* 2.9725	* 4.0365	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9054	* 1.9837	* 1.7668	* 1.9990	* 1.6425	* 1.5906	* 1.3738	* 2.9528
	* 1.8564	* 1.8761	* 1.6416	* 1.8518	* 1.5971	* 1.5924	* 1.4065	* 2.8715
	* 1.8256	* 1.8021	* 1.5255	* 1.7604	* 1.5396	* 1.6137	* 1.4214	* 2.8355
	* 1.8637	* 1.8008	* 1.4982	* 1.7482	* 1.5264	* 1.6763	* 1.4619	* 2.7932
	* 1.9440	* 1.8723	* 1.5781	* 1.8114	* 1.5953	* 1.7250	* 1.5318	* 2.7221
	* 2.0036	* 1.9406	* 1.7006	* 1.8805	* 1.7095	* 1.7707	* 1.6189	* 2.5904
9	* 1.9837	* 1.6451	* 1.7887	* 1.6539	* 1.7284	* 1.5619	* 1.3683	* 2.9056
	* 1.8761	* 1.5533	* 1.7170	* 1.5531	* 1.7064	* 1.5713	* 1.4114	* 2.8408
	* 1.8021	* 1.4890	* 1.6728	* 1.4880	* 1.6922	* 1.5998	* 1.4303	* 2.8182
	* 1.8008	* 1.5175	* 1.6799	* 1.4994	* 1.7256	* 1.6692	* 1.4737	* 2.7891
	* 1.8723	* 1.6173	* 1.7475	* 1.5898	* 1.7883	* 1.7187	* 1.5443	* 2.7304
	* 1.9406	* 1.7432	* 1.8188	* 1.7138	* 1.8509	* 1.7617	* 1.6289	* 2.6130
10	* 1.7668	* 1.7923	* 1.9281	* 1.8453	* 1.5059	* 1.6251	* 1.3597	* 3.0557
	* 1.6416	* 1.7216	* 1.8854	* 1.7834	* 1.4617	* 1.6444	* 1.4057	* 3.0178
	* 1.5255	* 1.6770	* 1.8653	* 1.7711	* 1.4554	* 1.6709	* 1.4449	* 3.0190
	* 1.4982	* 1.6823	* 1.9196	* 1.8281	* 1.5348	* 1.7575	* 1.5400	* 3.0024
	* 1.5781	* 1.7495	* 1.9864	* 1.8986	* 1.6289	* 1.8208	* 1.6096	* 2.9250
	* 1.7006	* 1.8200	* 2.0338	* 1.9531	* 1.7433	* 1.8465	* 1.6970	* 2.7665
11	* 1.9990	* 1.6552	* 1.8468	* 1.5526	* 1.6707	* 1.3932	* 2.1267	* 4.3864
	* 1.8518	* 1.5547	* 1.7848	* 1.4782	* 1.6549	* 1.4032	* 2.1284	* 4.3870
	* 1.7604	* 1.4895	* 1.7723	* 1.4649	* 1.6762	* 1.4326	* 2.1722	* 4.4108
	* 1.7482	* 1.5002	* 1.8294	* 1.5316	* 1.7609	* 1.5317	* 2.2540	* 4.3390
	* 1.8114	* 1.5904	* 1.8996	* 1.6222	* 1.8299	* 1.6321	* 2.2813	* 4.1098
	* 1.8805	* 1.7142	* 1.9537	* 1.7299	* 1.8757	* 1.7357	* 2.2490	* 3.7163
12	* 1.6425	* 1.7286	* 1.5062	* 1.6716	* 1.5719	* 1.4072	* 2.7414	*
	* 1.5971	* 1.7067	* 1.4619	* 1.6557	* 1.5598	* 1.4245	* 2.6612	*
	* 1.5396	* 1.6933	* 1.4557	* 1.6778	* 1.5881	* 1.4509	* 2.6561	*
	* 1.5264	* 1.7259	* 1.5355	* 1.7624	* 1.6589	* 1.4937	* 2.6651	*
	* 1.5953	* 1.7886	* 1.6292	* 1.8309	* 1.7163	* 1.5727	* 2.6383	*
	* 1.7095	* 1.8512	* 1.7435	* 1.8765	* 1.7596	* 1.6597	* 2.5193	*
13	* 1.5906	* 1.5614	* 1.6234	* 1.3935	* 1.4073	* 1.3495	* 3.1361	*
	* 1.5924	* 1.5708	* 1.6429	* 1.4036	* 1.4246	* 1.3956	* 3.1060	*
	* 1.6137	* 1.5995	* 1.6693	* 1.4329	* 1.4511	* 1.4417	* 3.1397	*
	* 1.6763	* 1.6689	* 1.7560	* 1.5318	* 1.4939	* 1.5447	* 3.1663	*
	* 1.7250	* 1.7185	* 1.8194	* 1.6323	* 1.5729	* 1.6382	* 3.1221	*
	* 1.7707	* 1.7617	* 1.8459	* 1.7360	* 1.6599	* 1.7451	* 2.9694	*
14	* 1.3738	* 1.3680	* 1.3593	* 2.1272	* 2.7438	* 3.1372	*	*
	* 1.4065	* 1.4109	* 1.4053	* 2.1290	* 2.6631	* 3.1071	*	*
	* 1.4214	* 1.4300	* 1.4445	* 2.1730	* 2.6578	* 3.1408	*	*
	* 1.4619	* 1.4735	* 1.5398	* 2.2549	* 2.6666	* 3.1673	*	*
	* 1.5318	* 1.5442	* 1.6095	* 2.2826	* 2.6397	* 3.1230	*	*
	* 1.6189	* 1.6289	* 1.6973	* 2.2508	* 2.5220	* 2.9706	*	*
15	* 2.9528	* 2.9041	* 3.0573	* 4.4150	* 4 EFPD	118 % POWER		
	* 2.8715	* 2.8397	* 3.0192	* 4.4203	* 50 EFPD	118 % POWER		
	* 2.8355	* 2.8178	* 3.0203	* 4.4471	* 100 EFPD	118 % POWER		
	* 2.7932	* 2.7897	* 3.0040	* 4.3836	* 200 EFPD	118 % POWER		
	* 2.7221	* 2.7312	* 2.9270	* 4.1533	* 300 EFPD	118 % POWER		
	* 2.5904	* 2.6162	* 2.7687	* 3.7530	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7996	* 1.8811	* 1.6664	* 1.9016	* 1.5462	* 1.4985	* 1.2873	* 2.8614
	* 1.7691	* 1.7975	* 1.5636	* 1.7737	* 1.5186	* 1.5113	* 1.3271	* 2.8003
	* 1.7373	* 1.7233	* 1.4482	* 1.6823	* 1.4603	* 1.5306	* 1.3390	* 2.7600
	* 1.7520	* 1.6954	* 1.3967	* 1.6452	* 1.4236	* 1.5713	* 1.3579	* 2.6813
	* 1.8141	* 1.7500	* 1.4593	* 1.6914	* 1.4773	* 1.6070	* 1.4133	* 2.5932
	* 1.8757	* 1.8242	* 1.5831	* 1.7651	* 1.5895	* 1.6545	* 1.4984	* 2.4710
9	* 1.8811	* 1.5500	* 1.6952	* 1.5564	* 1.6386	* 1.4703	* 1.2821	* 2.8019
	* 1.7975	* 1.4758	* 1.6395	* 1.4751	* 1.6299	* 1.4901	* 1.3314	* 2.7569
	* 1.7233	* 1.4106	* 1.5949	* 1.4105	* 1.6137	* 1.5166	* 1.3472	* 2.7304
	* 1.6954	* 1.4136	* 1.5792	* 1.3978	* 1.6248	* 1.5633	* 1.3688	* 2.6649
	* 1.7500	* 1.4962	* 1.6300	* 1.4711	* 1.6722	* 1.5999	* 1.4248	* 2.5884
	* 1.8242	* 1.6238	* 1.7067	* 1.5951	* 1.7391	* 1.6448	* 1.5074	* 2.4773
10	* 1.6664	* 1.6988	* 1.8310	* 1.7478	* 1.4104	* 1.5313	* 1.2733	* 2.9615
	* 1.5636	* 1.6442	* 1.8043	* 1.7009	* 1.3819	* 1.5631	* 1.3249	* 2.9432
	* 1.4482	* 1.5993	* 1.7831	* 1.6871	* 1.3725	* 1.5871	* 1.3599	* 2.9390
	* 1.3967	* 1.5816	* 1.8119	* 1.7183	* 1.4270	* 1.6458	* 1.4294	* 2.8869
	* 1.4593	* 1.6320	* 1.8719	* 1.7764	* 1.5079	* 1.6961	* 1.4855	* 2.7942
	* 1.5831	* 1.7080	* 1.9323	* 1.8335	* 1.6196	* 1.7258	* 1.5694	* 2.6465
11	* 1.9016	* 1.5576	* 1.7493	* 1.4572	* 1.5819	* 1.3019	* 2.0477	* 4.2574
	* 1.7737	* 1.4767	* 1.7023	* 1.3980	* 1.5718	* 1.3210	* 2.0632	* 4.2888
	* 1.6823	* 1.4120	* 1.6884	* 1.3822	* 1.5909	* 1.3460	* 2.1025	* 4.3051
	* 1.6452	* 1.3986	* 1.7193	* 1.4228	* 1.6484	* 1.4181	* 2.1510	* 4.1799
	* 1.6914	* 1.4717	* 1.7774	* 1.4980	* 1.7018	* 1.5001	* 2.1644	* 3.9350
	* 1.7651	* 1.5952	* 1.8340	* 1.6053	* 1.7530	* 1.6033	* 2.1338	* 3.5578
12	* 1.5462	* 1.6387	* 1.4107	* 1.5833	* 1.4602	* 1.3108	* 2.6442	*
	* 1.5186	* 1.6301	* 1.3821	* 1.5731	* 1.4623	* 1.3384	* 2.5876	*
	* 1.4603	* 1.6148	* 1.3727	* 1.5921	* 1.4873	* 1.3581	* 2.5757	*
	* 1.4236	* 1.6252	* 1.4277	* 1.6496	* 1.5295	* 1.3738	* 2.5408	*
	* 1.4773	* 1.6724	* 1.5083	* 1.7030	* 1.5725	* 1.4368	* 2.5035	*
	* 1.5895	* 1.7393	* 1.6198	* 1.7539	* 1.6263	* 1.5276	* 2.4056	*
13	* 1.4985	* 1.4697	* 1.5295	* 1.3022	* 1.3109	* 1.2504	* 3.0231	*
	* 1.5113	* 1.4896	* 1.5616	* 1.3213	* 1.3385	* 1.3041	* 3.0191	*
	* 1.5306	* 1.5162	* 1.5854	* 1.3463	* 1.3583	* 1.3455	* 3.0478	*
	* 1.5713	* 1.5630	* 1.6443	* 1.4182	* 1.3740	* 1.4195	* 3.0279	*
	* 1.6070	* 1.5997	* 1.6947	* 1.5004	* 1.4370	* 1.4948	* 2.9695	*
	* 1.6545	* 1.6447	* 1.7251	* 1.6036	* 1.5278	* 1.6054	* 2.8383	*
14	* 1.2873	* 1.2818	* 1.2729	* 2.0482	* 2.6465	* 3.0242	*	*
	* 1.3271	* 1.3310	* 1.3245	* 2.0638	* 2.5897	* 3.0201	*	*
	* 1.3390	* 1.3469	* 1.3595	* 2.1032	* 2.5777	* 3.0488	*	*
	* 1.3579	* 1.3685	* 1.4292	* 2.1519	* 2.5424	* 3.0287	*	*
	* 1.4133	* 1.4247	* 1.4854	* 2.1656	* 2.5050	* 2.9703	*	*
	* 1.4984	* 1.5074	* 1.5697	* 2.1362	* 2.4084	* 2.8394	*	*
15	* 2.8614	* 2.8005	* 2.9631	* 4.3069	* 4 EFPD	118 % POWER		
	* 2.8003	* 2.7557	* 2.9446	* 4.3422	* 50 EFPD	118 % POWER		
	* 2.7600	* 2.7298	* 2.9405	* 4.3627	* 100 EFPD	118 % POWER		
	* 2.6813	* 2.6653	* 2.8886	* 4.2461	* 200 EFPD	118 % POWER		
	* 2.5932	* 2.5890	* 2.7961	* 4.0000	* 300 EFPD	118 % POWER		
	* 2.4710	* 2.4802	* 2.6487	* 3.6177	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7210	* 1.8037	* 1.5974	* 1.8278	* 1.4879	* 1.4389	* 1.2353	* 2.7734
	* 1.7172	* 1.7510	* 1.5234	* 1.7301	* 1.4770	* 1.4678	* 1.2883	* 2.7422
	* 1.6854	* 1.6772	* 1.4109	* 1.6396	* 1.4224	* 1.4863	* 1.3001	* 2.7014
	* 1.6633	* 1.6120	* 1.3249	* 1.5655	* 1.3513	* 1.4953	* 1.2900	* 2.5703
	* 1.6991	* 1.6420	* 1.3647	* 1.5880	* 1.3846	* 1.5069	* 1.3214	* 2.4456
	* 1.7482	* 1.7026	* 1.4731	* 1.6488	* 1.4835	* 1.5469	* 1.3972	* 2.3204
9	* 1.8037	* 1.4830	* 1.6232	* 1.4904	* 1.5760	* 1.4108	* 1.2300	* 2.7144
	* 1.7510	* 1.4346	* 1.5940	* 1.4347	* 1.5877	* 1.4465	* 1.2920	* 2.6983
	* 1.6772	* 1.3702	* 1.5498	* 1.3718	* 1.5673	* 1.4717	* 1.3079	* 2.6710
	* 1.6120	* 1.3396	* 1.5007	* 1.3257	* 1.5450	* 1.4871	* 1.3002	* 2.5534
	* 1.6420	* 1.3984	* 1.5292	* 1.3757	* 1.5696	* 1.4995	* 1.3319	* 2.4397
	* 1.7026	* 1.5106	* 1.5935	* 1.4863	* 1.6255	* 1.5374	* 1.4055	* 2.3260
10	* 1.5974	* 1.6268	* 1.7562	* 1.6737	* 1.3511	* 1.4690	* 1.2200	* 2.8681
	* 1.5234	* 1.5988	* 1.7568	* 1.6515	* 1.3440	* 1.5176	* 1.2846	* 2.8799
	* 1.4109	* 1.5543	* 1.7356	* 1.6365	* 1.3338	* 1.5423	* 1.3179	* 2.8745
	* 1.3249	* 1.5031	* 1.7246	* 1.6314	* 1.3545	* 1.5674	* 1.3577	* 2.7667
	* 1.3647	* 1.5312	* 1.7597	* 1.6649	* 1.4084	* 1.5880	* 1.3876	* 2.6336
	* 1.4731	* 1.5947	* 1.8081	* 1.7130	* 1.5081	* 1.6125	* 1.4629	* 2.4848
11	* 1.8278	* 1.4917	* 1.6751	* 1.3935	* 1.5161	* 1.2452	* 1.9683	* 4.1146
	* 1.7301	* 1.4363	* 1.6529	* 1.3577	* 1.5266	* 1.2801	* 2.0080	* 4.1937
	* 1.6396	* 1.3732	* 1.6378	* 1.3412	* 1.5441	* 1.3031	* 2.0446	* 4.2065
	* 1.5655	* 1.3265	* 1.6324	* 1.3496	* 1.5682	* 1.3460	* 2.0509	* 3.9994
	* 1.5880	* 1.3763	* 1.6657	* 1.3982	* 1.5918	* 1.3963	* 2.0279	* 3.7221
	* 1.6488	* 1.4867	* 1.7135	* 1.4938	* 1.6344	* 1.4871	* 1.9951	* 3.3519
12	* 1.4879	* 1.5762	* 1.3514	* 1.5176	* 1.3888	* 1.2521	* 2.5477	*
	* 1.4770	* 1.5880	* 1.3442	* 1.5279	* 1.4085	* 1.2946	* 2.5241	*
	* 1.4224	* 1.5684	* 1.3341	* 1.5454	* 1.4318	* 1.3127	* 2.5104	*
	* 1.3513	* 1.5454	* 1.3551	* 1.5694	* 1.4451	* 1.3005	* 2.4277	*
	* 1.3846	* 1.5699	* 1.4089	* 1.5929	* 1.4599	* 1.3351	* 2.3481	*
	* 1.4835	* 1.6258	* 1.5082	* 1.6352	* 1.5035	* 1.4137	* 2.2449	*
13	* 1.4389	* 1.4102	* 1.4672	* 1.2455	* 1.2522	* 1.1909	* 2.9106	*
	* 1.4678	* 1.4460	* 1.5161	* 1.2804	* 1.2947	* 1.2572	* 2.9418	*
	* 1.4863	* 1.4713	* 1.5406	* 1.3034	* 1.3129	* 1.2963	* 2.9676	*
	* 1.4953	* 1.4868	* 1.5659	* 1.3462	* 1.3008	* 1.3419	* 2.8928	*
	* 1.5069	* 1.4993	* 1.5867	* 1.3966	* 1.3353	* 1.3886	* 2.7857	*
	* 1.5469	* 1.5373	* 1.6118	* 1.4875	* 1.4139	* 1.4858	* 2.6489	*
14	* 1.2353	* 1.2297	* 1.2196	* 1.9688	* 2.5500	* 2.9116	*	*
	* 1.2883	* 1.2915	* 1.2842	* 2.0086	* 2.5263	* 2.9428	*	*
	* 1.3001	* 1.3075	* 1.3175	* 2.0453	* 2.5124	* 2.9685	*	*
	* 1.2900	* 1.3000	* 1.3575	* 2.0517	* 2.4293	* 2.8936	*	*
	* 1.3214	* 1.3318	* 1.3875	* 2.0291	* 2.3496	* 2.7865	*	*
	* 1.3972	* 1.4055	* 1.4632	* 1.9973	* 2.2476	* 2.6500	*	*
15	* 2.7734	* 2.7130	* 2.8697	* 4.1651	* 4 EFPD	118 % POWER		
	* 2.7422	* 2.6971	* 2.8814	* 4.2486	* 50 EFPD	118 % POWER		
	* 2.7014	* 2.6703	* 2.8760	* 4.2654	* 100 EFPD	118 % POWER		
	* 2.5703	* 2.5537	* 2.7683	* 4.0651	* 200 EFPD	118 % POWER		
	* 2.4456	* 2.4403	* 2.6355	* 3.7858	* 300 EFPD	118 % POWER		
	* 2.3204	* 2.3287	* 2.4870	* 3.4107	* 445 EFPD	118 % POWER		



C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6813	* 1.7630	* 1.5734	* 1.7875	* 1.4646	* 1.4123	* 1.2200	* 2.6837
	* 1.7093	* 1.7443	* 1.5308	* 1.7255	* 1.4821	* 1.4659	* 1.2954	* 2.7004
	* 1.6814	* 1.6744	* 1.4258	* 1.6396	* 1.4333	* 1.4861	* 1.3114	* 2.6658
	* 1.6214	* 1.5736	* 1.3047	* 1.5288	* 1.3307	* 1.4618	* 1.2715	* 2.4835
	* 1.6282	* 1.5722	* 1.3141	* 1.5211	* 1.3336	* 1.4408	* 1.2710	* 2.3095
	* 1.6549	* 1.6089	* 1.3972	* 1.5602	* 1.4069	* 1.4569	* 1.3221	* 2.1521
9	* 1.7630	* 1.4572	* 1.5852	* 1.4691	* 1.5391	* 1.3845	* 1.2145	* 2.6389
	* 1.7443	* 1.4395	* 1.5869	* 1.4411	* 1.5788	* 1.4443	* 1.2980	* 2.6693
	* 1.6744	* 1.3790	* 1.5466	* 1.3815	* 1.5627	* 1.4707	* 1.3191	* 2.6467
	* 1.5736	* 1.3164	* 1.4651	* 1.3037	* 1.5074	* 1.4541	* 1.2816	* 2.4776
	* 1.5722	* 1.3457	* 1.4654	* 1.3238	* 1.5025	* 1.4343	* 1.2813	* 2.3138
	* 1.6089	* 1.4329	* 1.5065	* 1.4099	* 1.5347	* 1.4485	* 1.3300	* 2.1702
10	* 1.5734	* 1.5888	* 1.7154	* 1.6356	* 1.3346	* 1.4415	* 1.2046	* 2.7728
	* 1.5308	* 1.5917	* 1.7484	* 1.6442	* 1.3500	* 1.5144	* 1.2907	* 2.8323
	* 1.4258	* 1.5510	* 1.7311	* 1.6307	* 1.3422	* 1.5412	* 1.3255	* 2.8314
	* 1.3047	* 1.4676	* 1.6809	* 1.5895	* 1.3284	* 1.5298	* 1.3378	* 2.6632
	* 1.3141	* 1.4674	* 1.6725	* 1.5917	* 1.3542	* 1.5200	* 1.3362	* 2.4793
	* 1.3972	* 1.5077	* 1.6888	* 1.6163	* 1.4264	* 1.5176	* 1.3856	* 2.2969
11	* 1.7875	* 1.4704	* 1.6371	* 1.3689	* 1.4803	* 1.2284	* 1.8959	* 3.9662
	* 1.7255	* 1.4427	* 1.6456	* 1.3604	* 1.5227	* 1.2858	* 1.9660	* 4.1083
	* 1.6396	* 1.3829	* 1.6320	* 1.3466	* 1.5416	* 1.3104	* 2.0037	* 4.1257
	* 1.5288	* 1.3045	* 1.5905	* 1.3239	* 1.5270	* 1.3251	* 1.9652	* 3.8462
	* 1.5211	* 1.3244	* 1.5925	* 1.3447	* 1.5204	* 1.3409	* 1.9022	* 3.5137
	* 1.5602	* 1.4103	* 1.6169	* 1.4134	* 1.5370	* 1.4039	* 1.8434	* 3.1104
12	* 1.4646	* 1.5393	* 1.3349	* 1.4812	* 1.3597	* 1.2347	* 2.4529	*
	* 1.4821	* 1.5791	* 1.3502	* 1.5239	* 1.4025	* 1.2987	* 2.4749	*
	* 1.4333	* 1.5639	* 1.3424	* 1.5430	* 1.4270	* 1.3215	* 2.4661	*
	* 1.3307	* 1.5078	* 1.3290	* 1.5284	* 1.4108	* 1.2798	* 2.3342	*
	* 1.3336	* 1.5027	* 1.3546	* 1.5214	* 1.3926	* 1.2814	* 2.2019	*
	* 1.4069	* 1.5349	* 1.4265	* 1.5378	* 1.4091	* 1.3334	* 2.0644	*
13	* 1.4123	* 1.3840	* 1.4398	* 1.2287	* 1.2348	* 1.1748	* 2.8025	*
	* 1.4659	* 1.4438	* 1.5129	* 1.2862	* 1.2989	* 1.2609	* 2.8776	*
	* 1.4861	* 1.4703	* 1.5395	* 1.3107	* 1.3218	* 1.3006	* 2.9043	*
	* 1.4618	* 1.4539	* 1.5284	* 1.3253	* 1.2800	* 1.3176	* 2.7692	*
	* 1.4408	* 1.4341	* 1.5187	* 1.3411	* 1.2816	* 1.3320	* 2.6032	*
	* 1.4569	* 1.4484	* 1.5170	* 1.4042	* 1.3336	* 1.4016	* 2.4332	*
14	* 1.2200	* 1.2142	* 1.2043	* 1.8964	* 2.4549	* 2.8036	*	*
	* 1.2954	* 1.2977	* 1.2903	* 1.9666	* 2.4768	* 2.8787	*	*
	* 1.3114	* 1.3188	* 1.3251	* 2.0044	* 2.4679	* 2.9053	*	*
	* 1.2715	* 1.2814	* 1.3376	* 1.9662	* 2.3357	* 2.7701	*	*
	* 1.2710	* 1.2811	* 1.3361	* 1.9033	* 2.2033	* 2.6040	*	*
	* 1.3221	* 1.3300	* 1.3859	* 1.8449	* 2.0668	* 2.4343	*	*
15	* 2.6837	* 2.6374	* 2.7744	* 3.9967	* 4 EFPD	118 % POWER		
	* 2.7004	* 2.6681	* 2.8338	* 4.1430	* 50 EFPD	118 % POWER		
	* 2.6658	* 2.6462	* 2.8329	* 4.1634	* 100 EFPD	118 % POWER		
	* 2.4835	* 2.4780	* 2.6648	* 3.8879	* 200 EFPD	118 % POWER		
	* 2.3095	* 2.3144	* 2.4810	* 3.5504	* 300 EFPD	118 % POWER		
	* 2.1521	* 2.1728	* 2.2988	* 3.1400	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6298	* 1.7091	* 1.5225	* 1.7249	* 1.4228	* 1.3758	* 1.1916	* 2.6641
	* 1.6988	* 1.7379	* 1.5270	* 1.7143	* 1.4811	* 1.4615	* 1.2957	* 2.7515
	* 1.6837	* 1.6827	* 1.4376	* 1.6454	* 1.4446	* 1.4902	* 1.3227	* 2.7323
	* 1.5999	* 1.5555	* 1.2897	* 1.5094	* 1.3154	* 1.4400	* 1.2573	* 2.4981
	* 1.5716	* 1.5212	* 1.2669	* 1.4713	* 1.2857	* 1.3880	* 1.2239	* 2.2782
	* 1.5647	* 1.5262	* 1.3181	* 1.4773	* 1.3265	* 1.3735	* 1.2427	* 2.0775
9	* 1.7091	* 1.4106	* 1.5310	* 1.4257	* 1.4966	* 1.3498	* 1.1869	* 2.6119
	* 1.7379	* 1.4355	* 1.5743	* 1.4398	* 1.5731	* 1.4408	* 1.2985	* 2.7102
	* 1.6827	* 1.3861	* 1.5470	* 1.3910	* 1.5692	* 1.4754	* 1.3306	* 2.7027
	* 1.5555	* 1.2984	* 1.4417	* 1.2872	* 1.4883	* 1.4327	* 1.2676	* 2.4818
	* 1.5212	* 1.2962	* 1.4115	* 1.2755	* 1.4518	* 1.3815	* 1.2339	* 2.2707
	* 1.5262	* 1.3510	* 1.4218	* 1.3295	* 1.4533	* 1.3657	* 1.2501	* 2.0826
10	* 1.5225	* 1.5345	* 1.6614	* 1.5919	* 1.2988	* 1.4075	* 1.1810	* 2.7677
	* 1.5270	* 1.5791	* 1.7371	* 1.6419	* 1.3506	* 1.5125	* 1.2936	* 2.8946
	* 1.4376	* 1.5515	* 1.7333	* 1.6389	* 1.3499	* 1.5441	* 1.3344	* 2.9072
	* 1.2897	* 1.4442	* 1.6582	* 1.5689	* 1.3084	* 1.5023	* 1.3227	* 2.6864
	* 1.2669	* 1.4135	* 1.6294	* 1.5377	* 1.3045	* 1.4633	* 1.2868	* 2.4514
	* 1.3181	* 1.4230	* 1.6220	* 1.5306	* 1.3414	* 1.4316	* 1.3023	* 2.2199
11	* 1.7249	* 1.4269	* 1.5933	* 1.3347	* 1.4482	* 1.2017	* 1.8863	* 3.9639
	* 1.7143	* 1.4414	* 1.6433	* 1.3600	* 1.5195	* 1.2883	* 1.9997	* 4.1946
	* 1.6454	* 1.3925	* 1.6402	* 1.3536	* 1.5446	* 1.3192	* 2.0443	* 4.2320
	* 1.5094	* 1.2881	* 1.5699	* 1.3043	* 1.5012	* 1.3045	* 1.9658	* 3.8799
	* 1.4713	* 1.2761	* 1.5385	* 1.2950	* 1.4656	* 1.2901	* 1.8656	* 3.4721
	* 1.4773	* 1.3299	* 1.5311	* 1.3294	* 1.4501	* 1.3179	* 1.7758	* 3.0070
12	* 1.4228	* 1.4969	* 1.2991	* 1.4495	* 1.3244	* 1.2076	* 2.4427	*
	* 1.4811	* 1.5735	* 1.3509	* 1.5208	* 1.3986	* 1.3010	* 2.5225	*
	* 1.4446	* 1.5703	* 1.3502	* 1.5462	* 1.4304	* 1.3332	* 2.5239	*
	* 1.3154	* 1.4887	* 1.3091	* 1.5027	* 1.3893	* 1.2653	* 2.3453	*
	* 1.2857	* 1.4521	* 1.3047	* 1.4667	* 1.3375	* 1.2328	* 2.1725	*
	* 1.3265	* 1.4536	* 1.3415	* 1.4509	* 1.3234	* 1.2501	* 1.9918	*
13	* 1.3758	* 1.3493	* 1.4058	* 1.2020	* 1.2077	* 1.1518	* 2.8150	*
	* 1.4615	* 1.4402	* 1.5110	* 1.2887	* 1.3011	* 1.2637	* 2.9548	*
	* 1.4902	* 1.4750	* 1.5425	* 1.3195	* 1.3334	* 1.3089	* 2.9980	*
	* 1.4400	* 1.4324	* 1.5009	* 1.3046	* 1.2655	* 1.3002	* 2.8134	*
	* 1.3880	* 1.3813	* 1.4619	* 1.2904	* 1.2330	* 1.2812	* 2.5860	*
	* 1.3735	* 1.3657	* 1.4311	* 1.3182	* 1.2503	* 1.3156	* 2.3561	*
14	* 1.1916	* 1.1866	* 1.1806	* 1.8869	* 2.4450	* 2.8161	*	*
	* 1.2957	* 1.2982	* 1.2933	* 2.0005	* 2.5247	* 2.9559	*	*
	* 1.3227	* 1.3303	* 1.3340	* 2.0451	* 2.5259	* 2.9990	*	*
	* 1.2573	* 1.2674	* 1.3225	* 1.9668	* 2.3470	* 2.8143	*	*
	* 1.2239	* 1.2338	* 1.2868	* 1.8667	* 2.1739	* 2.5868	*	*
	* 1.2427	* 1.2501	* 1.3026	* 1.7775	* 1.9942	* 2.3571	*	*
15	* 2.6641	* 2.6106	* 2.7695	* 4.0117	* 4 EFPD	118 % POWER		
	* 2.7515	* 2.7090	* 2.8965	* 4.2487	* 50 EFPD	118 % POWER		
	* 2.7323	* 2.7022	* 2.9090	* 4.2902	* 100 EFPD	118 % POWER		
	* 2.4981	* 2.4821	* 2.6882	* 3.9420	* 200 EFPD	118 % POWER		
	* 2.2782	* 2.2713	* 2.4532	* 3.5296	* 300 EFPD	118 % POWER		
	* 2.0775	* 2.0848	* 2.2220	* 3.0572	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6588	* 1.7164	* 1.4120	* 1.6983	* 1.3816	* 1.4069	* 1.2241	* 2.6630
	* 1.7779	* 1.7978	* 1.5811	* 1.7597	* 1.5492	* 1.5387	* 1.3761	* 2.8471
	* 1.7818	* 1.7721	* 1.5278	* 1.7244	* 1.5424	* 1.5831	* 1.4254	* 2.8714
	* 1.6714	* 1.6274	* 1.3712	* 1.5760	* 1.3995	* 1.5057	* 1.3416	* 2.6134
	* 1.6023	* 1.5543	* 1.3118	* 1.5031	* 1.3319	* 1.4203	* 1.2703	* 2.3412
	* 1.5437	* 1.5127	* 1.3165	* 1.4642	* 1.3253	* 1.3597	* 1.2421	* 2.0750
9	* 1.7164	* 1.4059	* 1.5421	* 1.3837	* 1.5152	* 1.3829	* 1.2210	* 2.6208
	* 1.7978	* 1.5077	* 1.6341	* 1.5076	* 1.6399	* 1.5187	* 1.3798	* 2.8097
	* 1.7721	* 1.4834	* 1.6302	* 1.4828	* 1.6560	* 1.5680	* 1.4365	* 2.8404
	* 1.6274	* 1.3803	* 1.5013	* 1.3682	* 1.5550	* 1.4984	* 1.3524	* 2.5923
	* 1.5543	* 1.3398	* 1.4372	* 1.3189	* 1.4825	* 1.4130	* 1.2803	* 2.3308
	* 1.5127	* 1.3482	* 1.4025	* 1.3278	* 1.4383	* 1.3507	* 1.2491	* 2.0715
10	* 1.4120	* 1.5455	* 1.6846	* 1.6001	* 1.3274	* 1.4488	* 1.2258	* 2.8061
	* 1.5811	* 1.6390	* 1.8131	* 1.7099	* 1.4300	* 1.5854	* 1.3836	* 3.0247
	* 1.5278	* 1.6336	* 1.8301	* 1.7326	* 1.4514	* 1.6335	* 1.4421	* 3.0733
	* 1.3712	* 1.5038	* 1.7300	* 1.6414	* 1.3904	* 1.5684	* 1.4079	* 2.8147
	* 1.3118	* 1.4392	* 1.6611	* 1.5694	* 1.3470	* 1.4921	* 1.3360	* 2.5234
	* 1.3165	* 1.4036	* 1.6018	* 1.5145	* 1.3362	* 1.4144	* 1.3016	* 2.2155
11	* 1.6983	* 1.3850	* 1.6015	* 1.3246	* 1.4678	* 1.2343	* 1.9170	* 4.0656
	* 1.7597	* 1.5093	* 1.7113	* 1.4336	* 1.5888	* 1.3694	* 2.0923	* 4.4135
	* 1.7244	* 1.4844	* 1.7339	* 1.4508	* 1.6324	* 1.4172	* 2.1599	* 4.4919
	* 1.5760	* 1.3692	* 1.6424	* 1.3860	* 1.5658	* 1.3865	* 2.0517	* 4.0717
	* 1.5031	* 1.3195	* 1.5702	* 1.3376	* 1.4948	* 1.3369	* 1.9069	* 3.5624
	* 1.4642	* 1.3282	* 1.5150	* 1.3249	* 1.4303	* 1.3139	* 1.7577	* 2.9935
12	* 1.3816	* 1.5154	* 1.3277	* 1.4691	* 1.3486	* 1.2375	* 2.4586	*
	* 1.5492	* 1.6412	* 1.4303	* 1.5899	* 1.4698	* 1.3807	* 2.6248	*
	* 1.5424	* 1.6572	* 1.4517	* 1.6341	* 1.5205	* 1.4334	* 2.6615	*
	* 1.3995	* 1.5555	* 1.3912	* 1.5672	* 1.4591	* 1.3504	* 2.4514	*
	* 1.3319	* 1.4827	* 1.3475	* 1.4959	* 1.3675	* 1.2790	* 2.2273	*
	* 1.3253	* 1.4386	* 1.3363	* 1.4310	* 1.3087	* 1.2471	* 1.9799	*
13	* 1.4069	* 1.3825	* 1.4473	* 1.2346	* 1.2376	* 1.2003	* 2.8879	*
	* 1.5387	* 1.5182	* 1.5840	* 1.3698	* 1.3809	* 1.3551	* 3.1177	*
	* 1.5831	* 1.5677	* 1.6319	* 1.4176	* 1.4336	* 1.4172	* 3.1953	*
	* 1.5057	* 1.4981	* 1.5669	* 1.3867	* 1.3506	* 1.3888	* 2.9574	*
	* 1.4203	* 1.4128	* 1.4908	* 1.3371	* 1.2792	* 1.3294	* 2.6616	*
	* 1.3597	* 1.3507	* 1.4137	* 1.3142	* 1.2473	* 1.3159	* 2.3534	*
14	* 1.2241	* 1.2207	* 1.2255	* 1.9177	* 2.4608	* 2.8890	*	*
	* 1.3761	* 1.3795	* 1.3833	* 2.0932	* 2.6270	* 3.1188	*	*
	* 1.4254	* 1.4362	* 1.4418	* 2.1609	* 2.6637	* 3.1964	*	*
	* 1.3416	* 1.3522	* 1.4077	* 2.0527	* 2.4532	* 2.9584	*	*
	* 1.2703	* 1.2802	* 1.3360	* 1.9080	* 2.2288	* 2.6624	*	*
	* 1.2421	* 1.2491	* 1.3019	* 1.7594	* 1.9823	* 2.3545	*	*
15	* 2.6630	* 2.6197	* 2.8081	* 4.1177	* 4 EFPD	118 % POWER		
	* 2.8471	* 2.8087	* 3.0268	* 4.4735	* 50 EFPD	118 % POWER		
	* 2.8714	* 2.8400	* 3.0754	* 4.5566	* 100 EFPD	118 % POWER		
	* 2.6134	* 2.5926	* 2.8168	* 4.1394	* 200 EFPD	118 % POWER		
	* 2.3412	* 2.3315	* 2.5255	* 3.6240	* 300 EFPD	118 % POWER		
	* 2.0750	* 2.0736	* 2.2176	* 3.0453	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9329	* 1.8827	* 1.4120	* 1.8534	* 1.3816	* 1.6408	* 1.2911	* 2.9293
	* 2.1292	* 2.0670	* 1.5894	* 2.0190	* 1.5912	* 1.8522	* 1.5180	* 3.2571
	* 2.1572	* 2.0991	* 1.6397	* 2.0364	* 1.6631	* 1.9290	* 1.6084	* 3.3534
	* 1.9959	* 1.9334	* 1.5924	* 1.8734	* 1.6260	* 1.8178	* 1.5766	* 3.0662
	* 1.8514	* 1.8010	* 1.5394	* 1.7407	* 1.5624	* 1.6712	* 1.5010	* 2.7078
	* 1.6901	* 1.6689	* 1.4898	* 1.6142	* 1.4998	* 1.5136	* 1.4108	* 2.3051
9	* 1.8827	* 1.4059	* 1.7291	* 1.3837	* 1.7439	* 1.6143	* 1.2998	* 2.9001
	* 2.0670	* 1.6002	* 1.8989	* 1.5794	* 1.9369	* 1.8270	* 1.5298	* 3.2293
	* 2.0991	* 1.6592	* 1.9198	* 1.6414	* 1.9931	* 1.9072	* 1.6221	* 3.3287
	* 1.9334	* 1.6216	* 1.7740	* 1.6025	* 1.8602	* 1.8005	* 1.5888	* 3.0447
	* 1.8010	* 1.5734	* 1.6526	* 1.5496	* 1.7266	* 1.6556	* 1.5121	* 2.6919
	* 1.6689	* 1.5188	* 1.5340	* 1.4964	* 1.5928	* 1.4981	* 1.4184	* 2.2995
10	* 1.4120	* 1.7305	* 1.9591	* 1.7823	* 1.3296	* 1.6609	* 1.3849	* 3.1691
	* 1.5894	* 1.9013	* 2.1690	* 2.0005	* 1.5360	* 1.8815	* 1.6306	* 3.5371
	* 1.6397	* 1.9228	* 2.2140	* 2.0759	* 1.6399	* 1.9650	* 1.7274	* 3.6555
	* 1.5924	* 1.7766	* 2.0620	* 1.9582	* 1.6411	* 1.8667	* 1.6810	* 3.3465
	* 1.5394	* 1.6546	* 1.9138	* 1.8187	* 1.5824	* 1.7235	* 1.5825	* 2.9448
	* 1.4898	* 1.5351	* 1.7521	* 1.6662	* 1.5081	* 1.5612	* 1.4758	* 2.4942
11	* 1.8534	* 1.3850	* 1.7835	* 1.3246	* 1.6791	* 1.3219	* 2.1667	* 4.6993
	* 2.0190	* 1.5809	* 2.0017	* 1.5254	* 1.8837	* 1.5536	* 2.4469	* 5.2366
	* 2.0364	* 1.6428	* 2.0774	* 1.6240	* 1.9659	* 1.6583	* 2.5656	* 5.3844
	* 1.8734	* 1.6035	* 1.9594	* 1.6248	* 1.8683	* 1.6465	* 2.4256	* 4.8399
	* 1.7407	* 1.5504	* 1.8196	* 1.5654	* 1.7289	* 1.5830	* 2.2047	* 4.1294
	* 1.6142	* 1.4969	* 1.6668	* 1.4930	* 1.5723	* 1.4885	* 1.9481	* 3.3262
12	* 1.3816	* 1.7452	* 1.3299	* 1.6801	* 1.5528	* 1.2944	* 2.6820	*
	* 1.5912	* 1.9383	* 1.5364	* 1.8854	* 1.7521	* 1.5163	* 2.9874	*
	* 1.6631	* 1.9945	* 1.6408	* 1.9676	* 1.8381	* 1.6109	* 3.0982	*
	* 1.6260	* 1.8606	* 1.6419	* 1.8697	* 1.7407	* 1.5828	* 2.8704	*
	* 1.5624	* 1.7270	* 1.5829	* 1.7300	* 1.5912	* 1.5076	* 2.5628	*
	* 1.4998	* 1.5930	* 1.5082	* 1.5731	* 1.4405	* 1.4142	* 2.1917	*
13	* 1.6408	* 1.6138	* 1.6592	* 1.3222	* 1.2947	* 1.4354	* 3.3528	*
	* 1.8522	* 1.8265	* 1.8800	* 1.5539	* 1.5167	* 1.6761	* 3.7312	*
	* 1.9290	* 1.9069	* 1.9636	* 1.6586	* 1.6112	* 1.7753	* 3.8647	*
	* 1.8178	* 1.8003	* 1.8652	* 1.6467	* 1.5830	* 1.7202	* 3.5546	*
	* 1.6712	* 1.6554	* 1.7225	* 1.5833	* 1.5079	* 1.5988	* 3.1363	*
	* 1.5136	* 1.4981	* 1.5603	* 1.4888	* 1.4144	* 1.4922	* 2.6511	*
14	* 1.2911	* 1.2995	* 1.3848	* 2.1676	* 2.6840	* 3.3542	*	*
	* 1.5180	* 1.5294	* 1.6306	* 2.4481	* 2.9896	* 3.7326	*	*
	* 1.6084	* 1.6218	* 1.7274	* 2.5669	* 3.1004	* 3.8661	*	*
	* 1.5766	* 1.5887	* 1.6810	* 2.4269	* 2.8723	* 3.5558	*	*
	* 1.5010	* 1.5121	* 1.5825	* 2.2062	* 2.5645	* 3.1373	*	*
	* 1.4108	* 1.4184	* 1.4762	* 1.9498	* 2.1943	* 2.6523	*	*
15	* 2.9293	* 2.8989	* 3.1716	* 4.7570	* 4 EFPD	118 % POWER		
	* 3.2571	* 3.2283	* 3.5397	* 5.3061	* 50 EFPD	118 % POWER		
	* 3.3534	* 3.3283	* 3.6582	* 5.4614	* 100 EFPD	118 % POWER		
	* 3.0662	* 3.0453	* 3.3492	* 4.9217	* 200 EFPD	118 % POWER		
	* 2.7078	* 2.6927	* 2.9475	* 4.2027	* 300 EFPD	118 % POWER		
	* 2.3051	* 2.3020	* 2.4968	* 3.3863	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 4.6271	* 4.2631	* 3.2768	* 4.1300	* 3.2417	* 4.0586	* 3.4466	* 6.7309
	* 5.1793	* 4.7709	* 3.7851	* 4.6171	* 3.7985	* 4.6549	* 4.1082	* 7.6491
	* 5.2353	* 4.8258	* 3.9156	* 4.6847	* 3.9866	* 4.8369	* 4.3315	* 7.9104
	* 4.6584	* 4.3156	* 3.6838	* 4.1899	* 3.7776	* 4.3754	* 4.0560	* 7.0537
	* 4.0666	* 3.7979	* 3.3500	* 3.6797	* 3.4091	* 3.7675	* 3.6131	* 5.9162
	* 3.3719	* 3.1928	* 2.9276	* 3.1012	* 2.9507	* 3.0913	* 3.0486	* 4.6057
9	* 4.2631	* 3.3418	* 4.0888	* 3.2568	* 4.1022	* 4.0255	* 3.4801	* 6.7644
	* 4.7709	* 3.8716	* 4.5736	* 3.7891	* 4.6497	* 4.6224	* 4.1499	* 7.6919
	* 4.8258	* 4.0111	* 4.6389	* 3.9527	* 4.7777	* 4.8050	* 4.3761	* 7.9584
	* 4.3156	* 3.7779	* 4.1527	* 3.7289	* 4.3133	* 4.3545	* 4.0923	* 7.0942
	* 3.7979	* 3.4348	* 3.6513	* 3.3807	* 3.7732	* 3.7477	* 3.6437	* 5.9570
	* 3.1928	* 2.9867	* 3.0749	* 2.9410	* 3.1494	* 3.0697	* 3.0684	* 4.6547
10	* 3.2768	* 4.0948	* 4.4606	* 4.0680	* 3.1888	* 4.0745	* 3.7628	* 7.3429
	* 3.7851	* 4.5787	* 5.0197	* 4.6453	* 3.7483	* 4.6670	* 4.4798	* 8.3564
	* 3.9156	* 4.6435	* 5.1128	* 4.8084	* 3.9829	* 4.8631	* 4.7121	* 8.6529
	* 3.6838	* 4.1565	* 4.5885	* 4.3848	* 3.8215	* 4.4407	* 4.3644	* 7.7057
	* 3.3500	* 3.6541	* 4.0102	* 3.8352	* 3.4496	* 3.8511	* 3.8370	* 6.4363
	* 2.9276	* 3.0759	* 3.3332	* 3.1861	* 2.9627	* 3.1556	* 3.2153	* 4.9780
11	* 4.1300	* 3.2599	* 4.0705	* 3.2189	* 3.9750	* 3.3221	* 5.0440	* 10.8845
	* 4.6171	* 3.7926	* 4.6486	* 3.7743	* 4.5404	* 3.9621	* 5.7926	* 12.3390
	* 4.6847	* 3.9559	* 4.8116	* 4.0080	* 4.7300	* 4.1981	* 6.0629	* 12.6978
	* 4.1899	* 3.7310	* 4.3871	* 3.8519	* 4.3246	* 3.9750	* 5.5310	* 11.0976
	* 3.6797	* 3.3824	* 3.8370	* 3.4765	* 3.7602	* 3.5677	* 4.7419	* 9.0070
	* 3.1012	* 2.9421	* 3.1873	* 2.9833	* 3.1014	* 3.0242	* 3.8115	* 6.6500
12	* 3.2417	* 4.1050	* 3.1897	* 3.9777	* 3.9393	* 3.4460	* 6.1716	*
	* 3.7985	* 4.6532	* 3.7497	* 4.5431	* 4.5118	* 4.0961	* 7.0256	*
	* 3.9866	* 4.7794	* 3.9846	* 4.7328	* 4.7060	* 4.3291	* 7.3088	*
	* 3.7776	* 4.3144	* 3.8228	* 4.3269	* 4.2761	* 4.0653	* 6.5882	*
	* 3.4091	* 3.7738	* 3.4505	* 3.7622	* 3.6786	* 3.6301	* 5.5802	*
	* 2.9507	* 3.1499	* 2.9631	* 3.1026	* 2.9980	* 3.0574	* 4.3559	*
13	* 4.0586	* 4.0248	* 4.0724	* 3.3229	* 3.4468	* 3.9222	* 7.8679	*
	* 4.6549	* 4.6216	* 4.6653	* 3.9630	* 4.0970	* 4.6456	* 8.9177	*
	* 4.8369	* 4.8047	* 4.8612	* 4.1991	* 4.3299	* 4.8766	* 9.2460	*
	* 4.3754	* 4.3543	* 4.4390	* 3.9757	* 4.0660	* 4.5005	* 8.2574	*
	* 3.7675	* 3.7478	* 3.8496	* 3.5684	* 3.6307	* 3.9458	* 6.9120	*
	* 3.0913	* 3.0699	* 3.1547	* 3.0249	* 3.0580	* 3.3133	* 5.3380	*
14	* 3.4466	* 3.4795	* 3.7631	* 5.0466	* 6.1740	* 7.8714	*	*
	* 4.1082	* 4.1493	* 4.4801	* 5.7958	* 7.0283	* 8.9215	*	*
	* 4.3315	* 4.3756	* 4.7125	* 6.0665	* 7.3116	* 9.2499	*	*
	* 4.0560	* 4.0920	* 4.3648	* 5.5346	* 6.5906	* 8.2607	*	*
	* 3.6131	* 3.6436	* 3.8376	* 4.7456	* 5.5824	* 6.9148	*	*
	* 3.0486	* 3.0685	* 3.2166	* 3.8153	* 4.3603	* 5.3407	*	*
15	* 6.7309	* 6.7616	* 7.3485	* 10.9147	* 4 EFPD	118 % POWER		
	* 7.6491	* 7.6891	* 8.3627	* 12.3865	* 50 EFPD	118 % POWER		
	* 7.9104	* 7.9569	* 8.6595	* 12.7601	* 100 EFPD	118 % POWER		
	* 7.0537	* 7.0946	* 7.7121	* 11.1809	* 200 EFPD	118 % POWER		
	* 5.9162	* 5.9579	* 6.4425	* 9.0824	* 300 EFPD	118 % POWER		
	* 4.6057	* 4.6585	* 4.9837	* 6.7032	* 445 EFPD	118 % POWER		

C1C26 Core Operating Limits Report

TABLE A-3

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 4 EFPD								
	H	G	F	E	D	C	B	A
8	* 1.2070	* 1.1671	* 1.2028	* 1.1607	* 1.2685	* 1.3876	* 1.4410	* 0.6851
	* 1.4481	* 1.5117	* 1.4712	* 1.4889	* 1.3668	* 1.2614	* 1.2336	* 2.4129
9	* 1.1671	* 1.2884	* 1.2914	* 1.2788	* 1.3093	* 1.4076	* 1.4451	* 0.6971
	* 1.5117	* 1.3882	* 1.3554	* 1.3722	* 1.3291	* 1.2491	* 1.2324	* 2.3810
10	* 1.2028	* 1.2887	* 1.1944	* 1.2402	* 1.3744	* 1.3561	* 1.4447	* 0.6496
	* 1.4712	* 1.3591	* 1.4629	* 1.4373	* 1.3039	* 1.3290	* 1.2411	* 2.5778
11	* 1.1607	* 1.2777	* 1.2393	* 1.3707	* 1.3375	* 1.4463	* 0.9564	* 0.4596
	* 1.4889	* 1.3732	* 1.4381	* 1.3014	* 1.3288	* 1.2655	* 1.8447	* 3.6743
12	* 1.2685	* 1.3091	* 1.3741	* 1.3364	* 1.3969	* 1.4275	* 0.7379	*
	* 1.3668	* 1.3292	* 1.3041	* 1.3298	* 1.2693	* 1.2729	* 2.3358	*
13	* 1.3876	* 1.4081	* 1.3574	* 1.4461	* 1.4275	* 1.4320	* 0.6253	*
	* 1.2614	* 1.2487	* 1.3277	* 1.2657	* 1.2728	* 1.2602	* 2.7207	*
14	* 1.4410	* 1.4454	* 1.4452	* 0.9564	* 0.7368	* 0.6251	*	*
	* 1.2336	* 1.2322	* 1.2408	* 1.8440	* 2.3383	* 2.7212	*	*
15	* 0.6851	* 0.6976	* 0.6494	* 0.4499	* F-DEL-H			
	* 2.4129	* 2.3790	* 2.5769	* 3.7334	* M-DEL-H			

AT 100% POWER, 50 EFPD								
	H	G	F	E	D	C	B	A
8	* 1.1940	* 1.1833	* 1.2935	* 1.1976	* 1.3129	* 1.3409	* 1.4238	* 0.6771
	* 1.4766	* 1.5293	* 1.4107	* 1.4746	* 1.3561	* 1.3159	* 1.2440	* 2.4860
9	* 1.1833	* 1.3604	* 1.2906	* 1.3539	* 1.2789	* 1.3540	* 1.4168	* 0.6859
	* 1.5293	* 1.3534	* 1.4019	* 1.3339	* 1.4045	* 1.3080	* 1.2536	* 2.4610
10	* 1.2935	* 1.2879	* 1.1759	* 1.2309	* 1.4131	* 1.3140	* 1.4100	* 0.6344
	* 1.4107	* 1.4057	* 1.5407	* 1.4736	* 1.3001	* 1.3892	* 1.2839	* 2.6793
11	* 1.1976	* 1.3527	* 1.2301	* 1.4127	* 1.3052	* 1.4424	* 0.9221	* 0.4444
	* 1.4746	* 1.3349	* 1.4745	* 1.2976	* 1.3992	* 1.2684	* 1.9337	* 3.8572
12	* 1.3129	* 1.2782	* 1.4129	* 1.3040	* 1.3591	* 1.4162	* 0.7292	*
	* 1.3561	* 1.4047	* 1.3002	* 1.4004	* 1.3215	* 1.2824	* 2.4047	*
13	* 1.3409	* 1.3545	* 1.3154	* 1.4422	* 1.4162	* 1.3975	* 0.6097	*
	* 1.3159	* 1.3076	* 1.3879	* 1.2686	* 1.2823	* 1.2850	* 2.8370	*
14	* 1.4238	* 1.4172	* 1.4105	* 0.9221	* 0.7282	* 0.6096	*	*
	* 1.2440	* 1.2533	* 1.2835	* 1.9331	* 2.4073	* 2.8376	*	*
15	* 0.6771	* 0.6864	* 0.6343	* 0.4351	* F-DEL-H			
	* 2.4860	* 2.4591	* 2.6788	* 3.9242	* M-DEL-H			

C1C26 Core Operating Limits Report

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 100 EFPD

	H	G	F	E	D	C	B	A
8	* 1.1896	* 1.2017	* 1.3851	* 1.2284	* 1.3679	* 1.3074	* 1.4158	* 0.6770
	* 1.5143	* 1.5122	* 1.3170	* 1.4657	* 1.3053	* 1.3444	* 1.2448	* 2.4805
9	* 1.2017	* 1.4153	* 1.2970	* 1.4125	* 1.2701	* 1.3142	* 1.4057	* 0.6831
	* 1.5122	* 1.3052	* 1.3979	* 1.2802	* 1.4143	* 1.3419	* 1.2563	* 2.4635
10	* 1.3851	* 1.2943	* 1.1650	* 1.2169	* 1.4287	* 1.2767	* 1.3794	* 0.6281
	* 1.3170	* 1.4005	* 1.5575	* 1.4880	* 1.2832	* 1.4249	* 1.3075	* 2.6964
11	* 1.2284	* 1.4112	* 1.2161	* 1.4316	* 1.2727	* 1.4231	* 0.8961	* 0.4383
	* 1.4657	* 1.2808	* 1.4888	* 1.2818	* 1.4098	* 1.2821	* 1.9792	* 3.8936
12	* 1.3679	* 1.2694	* 1.4280	* 1.2716	* 1.3233	* 1.3963	* 0.7237	*
	* 1.3053	* 1.4150	* 1.2833	* 1.4110	* 1.3497	* 1.2922	* 2.4085	*
13	* 1.3074	* 1.3146	* 1.2781	* 1.4228	* 1.3962	* 1.3626	* 0.6003	*
	* 1.3444	* 1.3415	* 1.4235	* 1.2823	* 1.2922	* 1.3104	* 2.8625	*
14	* 1.4158	* 1.4060	* 1.3798	* 0.8961	* 0.7228	* 0.6002	*	*
	* 1.2448	* 1.2560	* 1.3071	* 1.9787	* 2.4111	* 2.8630	*	*
15	* 0.6770	* 0.6836	* 0.6280	* 0.4292	* F-DEL-H			
	* 2.4805	* 2.4617	* 2.6959	* 3.9609	* M-DEL-H			

AT 100% POWER, 200 EFPD

	H	G	F	E	D	C	B	A
8	* 1.1624	* 1.2003	* 1.4717	* 1.2369	* 1.4446	* 1.2743	* 1.4480	* 0.6982
	* 1.5236	* 1.4940	* 1.2471	* 1.4354	* 1.2449	* 1.3559	* 1.2174	* 2.3643
9	* 1.2003	* 1.4530	* 1.2932	* 1.4695	* 1.2509	* 1.2766	* 1.4335	* 0.7020
	* 1.4940	* 1.2634	* 1.3833	* 1.2374	* 1.4083	* 1.3584	* 1.2318	* 2.3569
10	* 1.4717	* 1.2909	* 1.1354	* 1.1866	* 1.4396	* 1.2318	* 1.3581	* 0.6429
	* 1.2471	* 1.3855	* 1.5717	* 1.4952	* 1.2618	* 1.4334	* 1.3108	* 2.6354
11	* 1.2369	* 1.4686	* 1.1860	* 1.4477	* 1.2296	* 1.4082	* 0.8822	* 0.4527
	* 1.4354	* 1.2380	* 1.4958	* 1.2503	* 1.4258	* 1.2751	* 1.9715	* 3.7060
12	* 1.4446	* 1.2506	* 1.4391	* 1.2285	* 1.2890	* 1.4267	* 0.7361	*
	* 1.2449	* 1.4086	* 1.2622	* 1.4269	* 1.3338	* 1.2427	* 2.3111	*
13	* 1.2743	* 1.2770	* 1.2330	* 1.4081	* 1.4266	* 1.3361	* 0.6099	*
	* 1.3559	* 1.3580	* 1.4322	* 1.2751	* 1.2428	* 1.3114	* 2.7485	*
14	* 1.4480	* 1.4338	* 1.3583	* 0.8821	* 0.7352	* 0.6098	*	*
	* 1.2174	* 1.2315	* 1.3105	* 1.9709	* 2.3132	* 2.7489	*	*
15	* 0.6982	* 0.7024	* 0.6427	* 0.4433	* F-DEL-H			
	* 2.3643	* 2.3554	* 2.6351	* 3.7650	* M-DEL-H			

C1C26 Core Operating Limits Report

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 300 EFPD

	H	G	F	E	D	C	B	A
8	* 1.1274	* 1.1683	* 1.4562	* 1.2092	* 1.4393	* 1.2587	* 1.4629	* 0.7304
	* 1.5641	* 1.5280	* 1.2202	* 1.4387	* 1.2081	* 1.3490	* 1.1733	* 2.2664
9	* 1.1683	* 1.4222	* 1.2577	* 1.4476	* 1.2232	* 1.2612	* 1.4498	* 0.7339
	* 1.5280	* 1.2675	* 1.3936	* 1.2120	* 1.4123	* 1.3520	* 1.1865	* 2.2602
10	* 1.4562	* 1.2557	* 1.1036	* 1.1589	* 1.4182	* 1.2110	* 1.3721	* 0.6750
	* 1.2202	* 1.3955	* 1.5860	* 1.5131	* 1.2513	* 1.4517	* 1.2628	* 2.4742
11	* 1.2092	* 1.4470	* 1.1584	* 1.4294	* 1.2057	* 1.4022	* 0.8933	* 0.4857
	* 1.4387	* 1.2122	* 1.5139	* 1.2411	* 1.4483	* 1.2533	* 1.9477	* 3.4515
12	* 1.4393	* 1.2230	* 1.4178	* 1.2047	* 1.2785	* 1.4457	* 0.7641	*
	* 1.2081	* 1.4125	* 1.2515	* 1.4492	* 1.3399	* 1.2051	* 2.2287	*
13	* 1.2587	* 1.2615	* 1.2120	* 1.4021	* 1.4456	* 1.3384	* 0.6393	*
	* 1.3490	* 1.3517	* 1.4507	* 1.2534	* 1.2051	* 1.2865	* 2.6268	*
14	* 1.4629	* 1.4499	* 1.3721	* 0.8932	* 0.7632	* 0.6392	*	*
	* 1.1733	* 1.1864	* 1.2627	* 1.9473	* 2.2307	* 2.6272	*	*
15	* 0.7304	* 0.7343	* 0.6748	* 0.4757	* F-DEL-H			
	* 2.2664	* 2.2590	* 2.4738	* 3.5018	* M-DEL-H			

AT 100% POWER, 445 EFPD

	H	G	F	E	D	C	B	A
8	* 1.0946	* 1.1278	* 1.3924	* 1.1659	* 1.3879	* 1.2356	* 1.4482	* 0.7726
	* 1.5730	* 1.5508	* 1.2538	* 1.4633	* 1.2312	* 1.3520	* 1.1885	* 2.1084
9	* 1.1278	* 1.3597	* 1.2085	* 1.3850	* 1.1827	* 1.2413	* 1.4395	* 0.7780
	* 1.5508	* 1.3008	* 1.4223	* 1.2418	* 1.4335	* 1.3526	* 1.1980	* 2.0997
10	* 1.3924	* 1.2069	* 1.0741	* 1.1295	* 1.3718	* 1.1908	* 1.3763	* 0.7240
	* 1.2538	* 1.4240	* 1.5986	* 1.5296	* 1.2750	* 1.4422	* 1.2629	* 2.2748
11	* 1.1659	* 1.3849	* 1.1291	* 1.3852	* 1.1833	* 1.3788	* 0.9175	* 0.5420
	* 1.4633	* 1.2419	* 1.5301	* 1.2575	* 1.4488	* 1.2526	* 1.8653	* 3.0574
12	* 1.3879	* 1.1826	* 1.3716	* 1.1825	* 1.2622	* 1.4393	* 0.8063	*
	* 1.2312	* 1.4335	* 1.2751	* 1.4496	* 1.3307	* 1.1922	* 2.0728	*
13	* 1.2356	* 1.2415	* 1.1917	* 1.3786	* 1.4392	* 1.3392	* 0.6871	*
	* 1.3520	* 1.3524	* 1.4414	* 1.2527	* 1.1923	* 1.2687	* 2.3990	*
14	* 1.4482	* 1.4395	* 1.3761	* 0.9172	* 0.8053	* 0.6870	*	*
	* 1.1885	* 1.1979	* 1.2630	* 1.8649	* 2.0745	* 2.3993	*	*
15	* 0.7726	* 0.7781	* 0.7236	* 0.5310	* F-DEL-H			
	* 2.1084	* 2.0992	* 2.2745	* 3.1010	* M-DEL-H			



F-DEL-H &amp; M-DEL-H VALUES - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	* 1.1374	* 1.1434	* 1.1968	* 1.1648	* 1.2970	* 1.4345	* 1.4890	* 0.6972
	* 1.7539	* 1.8342	* 1.6094	* 1.6976	* 1.5564	* 1.4219	* 1.3871	* 2.7359
9	* 1.1434	* 1.2841	* 1.2955	* 1.2883	* 1.3322	* 1.4537	* 1.4918	* 0.7083
	* 1.8342	* 1.6337	* 1.5557	* 1.5832	* 1.5136	* 1.4091	* 1.3929	* 2.7057
10	* 1.1968	* 1.2913	* 1.1962	* 1.2418	* 1.3874	* 1.3880	* 1.4811	* 0.6572
	* 1.6094	* 1.5601	* 1.6966	* 1.6656	* 1.5376	* 1.5023	* 1.4130	* 2.9542
11	* 1.1648	* 1.2872	* 1.2409	* 1.3543	* 1.3390	* 1.4404	* 0.9600	* 0.4574
	* 1.6976	* 1.5841	* 1.6666	* 1.5945	* 1.6199	* 1.5047	* 2.1810	* 4.2822
12	* 1.2970	* 1.3320	* 1.3876	* 1.3383	* 1.2818	* 1.3886	* 0.7190	
	* 1.5564	* 1.5137	* 1.5373	* 1.6211	* 1.5156	* 1.5115	* 2.8170	
13	* 1.4345	* 1.4543	* 1.3895	* 1.4402	* 1.3886	* 1.3935	* 0.6010	
	* 1.4219	* 1.4086	* 1.5009	* 1.5048	* 1.5114	* 1.4882	* 3.2893	
14	* 1.4890	* 1.4922	* 1.4816	* 0.9601	* 0.7180	* 0.6009	*	
	* 1.3871	* 1.3925	* 1.4123	* 2.1796	* 2.8196	* 3.2898	*	
15	* 0.6972	* 0.7089	* 0.6571	* 0.4478	* F-DEL-H			
	* 2.7359	* 2.7033	* 2.9523	* 4.3376	* M-DEL-H			

	H	G	F	E	D	C	B	A
8	* 1.1377	* 1.1680	* 1.2955	* 1.2060	* 1.3400	* 1.3830	* 1.4692	* 0.6884
	* 1.8346	* 1.8691	* 1.6251	* 1.7004	* 1.5302	* 1.4734	* 1.4103	* 2.8591
9	* 1.1680	* 1.3584	* 1.3003	* 1.3683	* 1.2967	* 1.3948	* 1.4591	* 0.6963
	* 1.8691	* 1.5941	* 1.6000	* 1.5253	* 1.5880	* 1.4669	* 1.4257	* 2.8382
10	* 1.2955	* 1.2963	* 1.1792	* 1.2333	* 1.4219	* 1.3256	* 1.4425	* 0.6410
	* 1.6251	* 1.6042	* 1.7749	* 1.7080	* 1.5056	* 1.5778	* 1.4602	* 3.1084
11	* 1.2060	* 1.3670	* 1.2324	* 1.4032	* 1.3013	* 1.4352	* 0.9236	* 0.4414
	* 1.7004	* 1.5258	* 1.7092	* 1.5468	* 1.6612	* 1.5376	* 2.3243	* 4.5712
12	* 1.3400	* 1.2966	* 1.4217	* 1.3001	* 1.2477	* 1.3761	* 0.7096	*
	* 1.5302	* 1.5881	* 1.5056	* 1.6625	* 1.5568	* 1.5516	* 2.9211	*
13	* 1.3830	* 1.3953	* 1.3270	* 1.4349	* 1.3760	* 1.3548	* 0.5848	*
	* 1.4734	* 1.4665	* 1.5762	* 1.5377	* 1.5515	* 1.5531	* 3.4450	*
14	* 1.4692	* 1.4596	* 1.4429	* 0.9236	* 0.7087	* 0.5846	*	
	* 1.4103	* 1.4254	* 1.4595	* 2.3230	* 2.9238	* 3.4456	*	
15	* 0.6884	* 0.6969	* 0.6409	* 0.4322	* F-DEL-H			
	* 2.8591	* 2.8357	* 3.1068	* 4.6359	* M-DEL-H			

C1C26 Core Operating Limits Report

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 100 EFPD

	H	G	F	E	D	C	B	A
8	* 1.1414	* 1.1926	* 1.3983	* 1.2423	* 1.3938	* 1.3476	* 1.4619	* 0.6887
	* 1.8494	* 1.8394	* 1.5221	* 1.6632	* 1.4830	* 1.5094	* 1.4440	* 2.8634
9	* 1.1926	* 1.4202	* 1.3104	* 1.4319	* 1.2880	* 1.3525	* 1.4486	* 0.6938
	* 1.8394	* 1.5343	* 1.5895	* 1.4658	* 1.6033	* 1.5118	* 1.4525	* 2.8515
10	* 1.3983	* 1.3076	* 1.1709	* 1.2196	* 1.4398	* 1.2848	* 1.4096	* 0.6344
	* 1.5221	* 1.5923	* 1.7962	* 1.7187	* 1.4959	* 1.6336	* 1.4903	* 3.1414
11	* 1.2423	* 1.4306	* 1.2187	* 1.4281	* 1.2663	* 1.4124	* 0.8957	* 0.4346
	* 1.6632	* 1.4664	* 1.7198	* 1.5571	* 1.6991	* 1.5547	* 2.3895	* 4.6373
12	* 1.3938	* 1.2872	* 1.4391	* 1.2651	* 1.2095	* 1.3488	* 0.7022	*
	* 1.4830	* 1.6038	* 1.4962	* 1.7004	* 1.5947	* 1.5625	* 2.9290	*
13	* 1.3476	* 1.3530	* 1.2862	* 1.4122	* 1.3487	* 1.3134	* 0.5731	*
	* 1.5094	* 1.5113	* 1.6321	* 1.5549	* 1.5626	* 1.5880	* 3.4820	*
14	* 1.4619	* 1.4490	* 1.4101	* 0.8957	* 0.7013	* 0.5729	*	*
	* 1.4440	* 1.4521	* 1.4896	* 2.3883	* 2.9317	* 3.4825	*	*
15	* 0.6887	* 0.6944	* 0.6343	* 0.4256	* F-DEL-H			
	* 2.8634	* 2.8491	* 3.1399	* 4.7030	* M-DEL-H			

AT 75% POWER, 200 EFPD

	H	G	F	E	D	C	B	A
8	* 1.1161	* 1.1973	* 1.4981	* 1.2587	* 1.4826	* 1.3177	* 1.5024	* 0.7138
	* 1.8876	* 1.8380	* 1.4188	* 1.6454	* 1.3982	* 1.5399	* 1.3759	* 2.7732
9	* 1.1973	* 1.4597	* 1.3139	* 1.5002	* 1.2777	* 1.3170	* 1.4837	* 0.7160
	* 1.8380	* 1.4929	* 1.5883	* 1.3935	* 1.6055	* 1.5460	* 1.3929	* 2.7710
10	* 1.4981	* 1.3114	* 1.1447	* 1.1976	* 1.4609	* 1.2375	* 1.3879	* 0.6511
	* 1.4188	* 1.5908	* 1.8374	* 1.7401	* 1.4523	* 1.6816	* 1.4986	* 3.0650
11	* 1.2587	* 1.4992	* 1.1967	* 1.4437	* 1.2182	* 1.3973	* 0.8804	* 0.4488
	* 1.6454	* 1.3939	* 1.7412	* 1.5064	* 1.7417	* 1.5356	* 2.4105	* 4.4193
12	* 1.4826	* 1.2774	* 1.4604	* 1.2172	* 1.1628	* 1.3624	* 0.7100	*
	* 1.3982	* 1.6058	* 1.4527	* 1.7430	* 1.6213	* 1.4936	* 2.8636	*
13	* 1.3177	* 1.3175	* 1.2387	* 1.3972	* 1.3622	* 1.2726	* 0.5768	*
	* 1.5399	* 1.5456	* 1.6802	* 1.5356	* 1.4936	* 1.5750	* 3.4129	*
14	* 1.5024	* 1.4840	* 1.3881	* 0.8803	* 0.7091	* 0.5767	*	*
	* 1.3759	* 1.3925	* 1.4981	* 2.4096	* 2.8660	* 3.4133	*	*
15	* 0.7138	* 0.7165	* 0.6510	* 0.4394	* F-DEL-H			
	* 2.7732	* 2.7691	* 3.0637	* 4.4764	* M-DEL-H			

C1C26 Core Operating Limits Report

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 300 EFPD

	H	G	F	E	D	C	B	A
8	* 1.0702	* 1.1646	* 1.4870	* 1.2349	* 1.4846	* 1.3092	* 1.5290	* 0.7522
	* 1.8943	* 1.8461	* 1.4268	* 1.6494	* 1.3970	* 1.5524	* 1.3574	* 2.5971
9	* 1.1646	* 1.4287	* 1.2808	* 1.4837	* 1.2544	* 1.3081	* 1.5108	* 0.7539
	* 1.8461	* 1.5231	* 1.5986	* 1.4051	* 1.6094	* 1.5324	* 1.3728	* 2.5951
10	* 1.4870	* 1.2787	* 1.1139	* 1.1720	* 1.4419	* 1.2193	* 1.4090	* 0.6877
	* 1.4268	* 1.6008	* 1.8436	* 1.7465	* 1.4674	* 1.6688	* 1.4785	* 2.8635
11	* 1.2349	* 1.4833	* 1.1712	* 1.4231	* 1.1900	* 1.3880	* 0.8924	* 0.4827
	* 1.6494	* 1.4054	* 1.7474	* 1.5173	* 1.7316	* 1.5291	* 2.3226	* 4.0877
12	* 1.4846	* 1.2542	* 1.4416	* 1.1890	* 1.1361	* 1.3685	* 0.7342	*
	* 1.3970	* 1.6095	* 1.4677	* 1.7327	* 1.6301	* 1.4661	* 2.6950	*
13	* 1.3092	* 1.3085	* 1.2203	* 1.3879	* 1.3683	* 1.2620	* 0.6002	*
	* 1.5524	* 1.5321	* 1.6676	* 1.5292	* 1.4662	* 1.5696	* 3.1893	*
14	* 1.5290	* 1.5110	* 1.4091	* 0.8923	* 0.7333	* 0.6001	*	*
	* 1.3574	* 1.3725	* 1.4782	* 2.3218	* 2.6971	* 3.1897	*	*
15	* 0.7522	* 0.7543	* 0.6874	* 0.4727	* F-DEL-H			
	* 2.5971	* 2.5936	* 2.8623	* 4.1409	* M-DEL-H			

AT 75% POWER, 445 EFPD

	H	G	F	E	D	C	B	A
8	* 1.0151	* 1.1207	* 1.4264	* 1.1961	* 1.4418	* 1.2989	* 1.5307	* 0.8054
	* 1.9451	* 1.9062	* 1.4618	* 1.7064	* 1.4200	* 1.5481	* 1.3423	* 2.4613
9	* 1.1207	* 1.3631	* 1.2343	* 1.4312	* 1.2208	* 1.3005	* 1.5164	* 0.8086
	* 1.9062	* 1.5589	* 1.6622	* 1.4370	* 1.6576	* 1.5515	* 1.3524	* 2.4531
10	* 1.4264	* 1.2325	* 1.0868	* 1.1440	* 1.3969	* 1.2189	* 1.4258	* 0.7452
	* 1.4618	* 1.6643	* 1.8896	* 1.7926	* 1.4878	* 1.6721	* 1.4459	* 2.6734
11	* 1.1961	* 1.4310	* 1.1434	* 1.3753	* 1.1607	* 1.3594	* 0.9197	* 0.5418
	* 1.7064	* 1.4372	* 1.7933	* 1.5242	* 1.7583	* 1.5144	* 2.2480	* 3.6663
12	* 1.4418	* 1.2209	* 1.3967	* 1.1598	* 1.1037	* 1.3426	* 0.7708	*
	* 1.4200	* 1.6576	* 1.4880	* 1.7593	* 1.6057	* 1.4364	* 2.5521	*
13	* 1.2989	* 1.3008	* 1.2197	* 1.3593	* 1.3424	* 1.2429	* 0.6387	*
	* 1.5481	* 1.5513	* 1.6712	* 1.5145	* 1.4365	* 1.5349	* 2.9692	*
14	* 1.5307	* 1.5165	* 1.4256	* 0.9194	* 0.7698	* 0.6385	*	*
	* 1.3423	* 1.3522	* 1.4457	* 2.2475	* 2.5541	* 2.9697	*	*
15	* 0.8054	* 0.8087	* 0.7448	* 0.5308	* F-DEL-H			
	* 2.4613	* 2.4525	* 2.6727	* 3.7204	* M-DEL-H			

C1C26 Core Operating Limits Report

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 4 EFPD								
	H	G	F	E	D	C	B	A
8	* 1.0874	* 1.1218	* 1.1982	* 1.1723	* 1.3301	* 1.4874	* 1.5440	* 0.7123
	* 1.6544	* 1.8231	* 1.5755	* 1.6614	* 1.4469	* 1.3336	* 1.3224	* 2.6765
9	* 1.1218	* 1.2796	* 1.3007	* 1.2982	* 1.3562	* 1.5053	* 1.5446	* 0.7225
	* 1.8231	* 1.6169	* 1.5216	* 1.5562	* 1.4660	* 1.3248	* 1.3532	* 2.6532
10	* 1.1982	* 1.2963	* 1.1962	* 1.2417	* 1.4059	* 1.4232	* 1.5215	* 0.6670
	* 1.5755	* 1.5255	* 1.6602	* 1.6298	* 1.4806	* 1.4302	* 1.3810	* 2.9103
11	* 1.1723	* 1.2969	* 1.2408	* 1.3415	* 1.3400	* 1.4338	* 0.9646	* 0.4560
	* 1.6614	* 1.5571	* 1.6309	* 1.5405	* 1.5344	* 1.4555	* 2.1577	* 4.2945
12	* 1.3301	* 1.3561	* 1.4063	* 1.3393	* 1.2333	* 1.3427	* 0.6998	*
	* 1.4469	* 1.4660	* 1.4802	* 1.5353	* 1.4222	* 1.4870	* 2.7422	*
13	* 1.4874	* 1.5059	* 1.4249	* 1.4339	* 1.3426	* 1.3442	* 0.5751	*
	* 1.3336	* 1.3244	* 1.4288	* 1.4555	* 1.4868	* 1.4380	* 3.1876	*
14	* 1.5440	* 1.5451	* 1.5221	* 0.9647	* 0.6988	* 0.5749	*	*
	* 1.3224	* 1.3527	* 1.3801	* 2.1561	* 2.7444	* 3.1880	*	*
15	* 0.7123	* 0.7231	* 0.6669	* 0.4465	* F-DEL-H			
	* 2.6765	* 2.6507	* 2.9081	* 4.3414	* M-DEL-H			

AT 50% POWER, 50 EFPD								
	H	G	F	E	D	C	B	A
8	* 1.0908	* 1.1551	* 1.2979	* 1.2146	* 1.3707	* 1.4314	* 1.5221	* 0.7032
	* 1.7887	* 1.8260	* 1.6233	* 1.6484	* 1.5060	* 1.4234	* 1.3689	* 2.7642
9	* 1.1551	* 1.3549	* 1.3092	* 1.3830	* 1.3188	* 1.4413	* 1.5093	* 0.7101
	* 1.8260	* 1.5882	* 1.5441	* 1.5137	* 1.5326	* 1.4211	* 1.3857	* 2.7510
10	* 1.2979	* 1.3050	* 1.1814	* 1.2341	* 1.4366	* 1.3511	* 1.4793	* 0.6500
	* 1.6233	* 1.5481	* 1.7180	* 1.6625	* 1.4892	* 1.5460	* 1.4285	* 3.0402
11	* 1.2146	* 1.3817	* 1.2332	* 1.3963	* 1.2951	* 1.4275	* 0.9260	* 0.4393
	* 1.6484	* 1.5148	* 1.6636	* 1.5275	* 1.6199	* 1.4859	* 2.2772	* 4.5466
12	* 1.3707	* 1.3187	* 1.4366	* 1.2942	* 1.1966	* 1.3286	* 0.6893	*
	* 1.5060	* 1.5327	* 1.4891	* 1.6209	* 1.5030	* 1.4963	* 2.8122	*
13	* 1.4314	* 1.4419	* 1.3527	* 1.4275	* 1.3284	* 1.3018	* 0.5579	*
	* 1.4234	* 1.4207	* 1.5444	* 1.4859	* 1.4961	* 1.4775	* 3.3152	*
14	* 1.5221	* 1.5097	* 1.4798	* 0.9261	* 0.6884	* 0.5578	*	*
	* 1.3689	* 1.3853	* 1.4277	* 2.2757	* 2.8145	* 3.3156	*	*
15	* 0.7032	* 0.7107	* 0.6499	* 0.4301	* F-DEL-H			
	* 2.7642	* 2.7485	* 3.0380	* 4.5971	* M-DEL-H			

C1C26 Core Operating Limits Report

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 100 EFPD

	H	G	F	E	D	C	B	A
8	* 1.0940	* 1.1867	* 1.4131	* 1.2582	* 1.4310	* 1.3967	* 1.5185	* 0.7054
	* 1.8108	* 1.8175	* 1.4958	* 1.6396	* 1.4419	* 1.4598	* 1.3760	* 2.8362
9	* 1.1867	* 1.4241	* 1.3252	* 1.4563	* 1.3082	* 1.3989	* 1.5012	* 0.7092
	* 1.8175	* 1.5198	* 1.5622	* 1.4307	* 1.5706	* 1.4643	* 1.3924	* 2.8291
10	* 1.4131	* 1.3222	* 1.1771	* 1.2295	* 1.4574	* 1.3010	* 1.4459	* 0.6441
	* 1.4958	* 1.5650	* 1.7759	* 1.6937	* 1.4598	* 1.5960	* 1.4554	* 3.1414
11	* 1.2582	* 1.4554	* 1.2284	* 1.4206	* 1.2567	* 1.4008	* 0.8963	* 0.4322
	* 1.6396	* 1.4313	* 1.6948	* 1.5016	* 1.6551	* 1.4963	* 2.3838	* 4.6367
12	* 1.4310	* 1.3074	* 1.4567	* 1.2555	* 1.1483	* 1.2932	* 0.6784	*
	* 1.4419	* 1.5710	* 1.4597	* 1.6562	* 1.5352	* 1.4967	* 2.8309	*
13	* 1.3967	* 1.3995	* 1.3024	* 1.4007	* 1.2929	* 1.2475	* 0.5421	*
	* 1.4598	* 1.4638	* 1.5945	* 1.4964	* 1.4966	* 1.5070	* 3.4235	*
14	* 1.5185	* 1.5017	* 1.4464	* 0.8964	* 0.6775	* 0.5419	*	*
	* 1.3760	* 1.3919	* 1.4546	* 2.3825	* 2.8331	* 3.4239	*	*
15	* 0.7054	* 0.7098	* 0.6441	* 0.4233	* F-DEL-H			
	* 2.8362	* 2.8265	* 3.1396	* 4.6886	* M-DEL-H			

AT 50% POWER, 200 EFPD

	H	G	F	E	D	C	B	A
8	* 1.0486	* 1.1960	* 1.5404	* 1.2976	* 1.5458	* 1.3805	* 1.5563	* 0.7371
	* 1.8340	* 1.7875	* 1.3901	* 1.5883	* 1.3627	* 1.4868	* 1.3295	* 2.6758
9	* 1.1960	* 1.4742	* 1.3475	* 1.5511	* 1.3244	* 1.3785	* 1.5559	* 0.7400
	* 1.7875	* 1.4706	* 1.5270	* 1.3595	* 1.5426	* 1.4687	* 1.3484	* 2.6782
10	* 1.5404	* 1.3449	* 1.1501	* 1.2212	* 1.4953	* 1.2650	* 1.4365	* 0.6695
	* 1.3901	* 1.5294	* 1.7707	* 1.6827	* 1.4219	* 1.6168	* 1.4659	* 2.9865
11	* 1.2976	* 1.5505	* 1.2201	* 1.4351	* 1.2007	* 1.3766	* 0.8823	* 0.4495
	* 1.5883	* 1.3600	* 1.6838	* 1.4738	* 1.6630	* 1.4951	* 2.3504	* 4.4419
12	* 1.5458	* 1.3240	* 1.4948	* 1.1997	* 1.0538	* 1.2521	* 0.6733	*
	* 1.3627	* 1.5428	* 1.4223	* 1.6641	* 1.5601	* 1.4444	* 2.7520	*
13	* 1.3805	* 1.3790	* 1.2662	* 1.3766	* 1.2519	* 1.1543	* 0.5277	*
	* 1.4868	* 1.4684	* 1.6155	* 1.4952	* 1.4444	* 1.5206	* 3.2754	*
14	* 1.5563	* 1.5562	* 1.4368	* 0.8823	* 0.6724	* 0.5275	*	*
	* 1.3295	* 1.3480	* 1.4653	* 2.3491	* 2.7540	* 3.2758	*	*
15	* 0.7371	* 0.7405	* 0.6694	* 0.4402	* F-DEL-H			
	* 2.6758	* 2.6763	* 2.9846	* 4.4912	* M-DEL-H			

C1C26 Core Operating Limits Report

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 300 EFPD

	H	G	F	E	D	C	B	A
8	* 0.9987	* 1.1644	* 1.5351	* 1.2787	* 1.5578	* 1.3603	* 1.5331	* 0.7645
	* 1.6129	* 1.8148	* 1.3659	* 1.5987	* 1.3304	* 1.4564	* 1.2961	* 2.5322
9	* 1.1644	* 1.4383	* 1.3145	* 1.5469	* 1.3076	* 1.3645	* 1.5756	* 0.7721
	* 1.8148	* 1.4607	* 1.5485	* 1.3404	* 1.5515	* 1.4662	* 1.2968	* 2.5360
10	* 1.5351	* 1.3122	* 1.1177	* 1.1974	* 1.4835	* 1.2613	* 1.4658	* 0.7075
	* 1.3659	* 1.5507	* 1.7872	* 1.6986	* 1.3944	* 1.6112	* 1.4139	* 2.8190
11	* 1.2787	* 1.5465	* 1.1966	* 1.4169	* 1.1779	* 1.3777	* 0.9007	* 0.4867
	* 1.5987	* 1.3407	* 1.6996	* 1.4480	* 1.6766	* 1.4535	* 2.2115	* 4.0285
12	* 1.5578	* 1.3076	* 1.4832	* 1.1769	* 1.0255	* 1.2599	* 0.7015	*
	* 1.3304	* 1.5516	* 1.3947	* 1.6776	* 1.5259	* 1.3893	* 2.6368	*
13	* 1.3603	* 1.3649	* 1.2625	* 1.3776	* 1.2597	* 1.1484	* 0.5532	*
	* 1.4564	* 1.4659	* 1.6100	* 1.4536	* 1.3893	* 1.4852	* 3.1172	*
14	* 1.5331	* 1.5759	* 1.4658	* 0.9006	* 0.7006	* 0.5531	*	*
	* 1.2961	* 1.2965	* 1.4135	* 2.2106	* 2.6387	* 3.1176	*	*
15	* 0.7645	* 0.7725	* 0.7073	* 0.4767	* F-DEL-H			
	* 2.5322	* 2.5344	* 2.8176	* 4.0748	* M-DEL-H			

AT 50% POWER, 445 EFPD

	H	G	F	E	D	C	B	A
8	* 0.9386	* 1.1167	* 1.4708	* 1.2398	* 1.5160	* 1.3268	* 1.4601	* 0.7984
	* 1.5555	* 1.7637	* 1.4201	* 1.6512	* 1.3644	* 1.4728	* 1.2735	* 2.3827
9	* 1.1167	* 1.3644	* 1.2606	* 1.4938	* 1.2764	* 1.3430	* 1.5612	* 0.8159
	* 1.7637	* 1.4724	* 1.6143	* 1.3878	* 1.5989	* 1.4798	* 1.2860	* 2.3821
10	* 1.4708	* 1.2587	* 1.0776	* 1.1676	* 1.4427	* 1.2665	* 1.4892	* 0.7655
	* 1.4201	* 1.6163	* 1.8372	* 1.7462	* 1.4187	* 1.6070	* 1.3901	* 2.6197
11	* 1.2398	* 1.4936	* 1.1670	* 1.3732	* 1.1593	* 1.3678	* 0.9391	* 0.5514
	* 1.6512	* 1.3879	* 1.7470	* 1.4803	* 1.7054	* 1.4608	* 2.1105	* 3.5697
12	* 1.5160	* 1.2764	* 1.4425	* 1.1584	* 0.9996	* 1.2559	* 0.7512	*
	* 1.3644	* 1.5989	* 1.4187	* 1.7064	* 1.4721	* 1.3766	* 2.4988	*
13	* 1.3268	* 1.3432	* 1.2673	* 1.3677	* 1.2557	* 1.1577	* 0.6036	*
	* 1.4728	* 1.4796	* 1.6062	* 1.4609	* 1.3767	* 1.4726	* 2.9080	*
14	* 1.4601	* 1.5613	* 1.4890	* 0.9388	* 0.7502	* 0.6034	*	*
	* 1.2735	* 1.2858	* 1.3899	* 2.1100	* 2.5006	* 2.9083	*	*
15	* 0.7984	* 0.8159	* 0.7651	* 0.5402	* F-DEL-H			
	* 2.3827	* 2.3812	* 2.6188	* 3.6099	* M-DEL-H			

C1C26 Core Operating Limits Report

TABLE A-4

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4821	* 0.5514	* 0.6475	* 0.5621	* 0.6303	* 0.5354	* 0.5346	* 0.2994 *
	* 3.6704	* 3.6191	* 2.9946	* 3.3899	* 2.9666	* 3.4730	* 3.4446	* 5.5420 *
9	* 0.5514	* 0.6304	* 0.5775	* 0.6372	* 0.5504	* 0.5233	* 0.5288	* 0.2960 *
	* 3.6191	* 3.1608	* 3.3245	* 2.9867	* 3.4215	* 3.5649	* 3.4990	* 5.6460 *
10	* 0.6475	* 0.5772	* 0.5278	* 0.5424	* 0.6170	* 0.5246	* 0.4899	* 0.2674 *
	* 2.9946	* 3.3262	* 3.6756	* 3.5495	* 3.1468	* 3.7072	* 3.8741	* 6.2830 *
11	* 0.5621	* 0.6370	* 0.5422	* 0.6101	* 0.5418	* 0.5500	* 0.3807	* 0.1883 *
	* 3.3899	* 2.9879	* 3.5509	* 3.1961	* 3.6051	* 3.4973	* 4.7682	* 9.2890 *
12	* 0.6303	* 0.5504	* 0.6169	* 0.5416	* 0.4841	* 0.4896	* 0.3102	*
	* 2.9666	* 3.4220	* 3.1474	* 3.6064	* 3.6641	* 3.6448	* 5.5120	*
13	* 0.5354	* 0.5233	* 0.5248	* 0.5500	* 0.4896	* 0.4288	* 0.2354	*
	* 3.4730	* 3.5648	* 3.7061	* 3.4973	* 3.6445	* 4.1006	* 7.0409	*
14	* 0.5346	* 0.5288	* 0.4899	* 0.3808	* 0.3101	* 0.2354	*	*
	* 3.4446	* 3.4984	* 3.8734	* 4.7677	* 5.5088	* 7.0416	*	*
15	* 0.2994	* 0.2962	* 0.2675	* 0.1857	* F-SUB-Q			
	* 5.5420	* 5.6412	* 6.2827	* 9.2699	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1384	* 1.1894	* 1.3940	* 1.1921	* 1.3655	* 1.2145	* 1.3125	* 0.6791 *
	* 1.6986	* 1.7047	* 1.4146	* 1.6322	* 1.4023	* 1.5651	* 1.4348	* 2.5019 *
9	* 1.1894	* 1.3878	* 1.2918	* 1.3868	* 1.2114	* 1.1998	* 1.3022	* 0.6755 *
	* 1.7047	* 1.4599	* 1.5191	* 1.4052	* 1.5928	* 1.5855	* 1.4526	* 2.5333 *
10	* 1.3940	* 1.2909	* 1.1399	* 1.1732	* 1.3622	* 1.2092	* 1.2234	* 0.6107 *
	* 1.4146	* 1.5202	* 1.7393	* 1.6750	* 1.4507	* 1.6449	* 1.5831	* 2.8140 *
11	* 1.1921	* 1.3862	* 1.1728	* 1.3735	* 1.2060	* 1.2849	* 0.8629	* 0.4334 *
	* 1.6322	* 1.4057	* 1.6756	* 1.4401	* 1.6487	* 1.5237	* 2.1316	* 4.1218 *
12	* 1.3655	* 1.2110	* 1.3620	* 1.2055	* 1.1482	* 1.2493	* 0.7046	*
	* 1.4023	* 1.5930	* 1.4509	* 1.6494	* 1.6081	* 1.4975	* 2.4745	*
13	* 1.2145	* 1.1999	* 1.2098	* 1.2849	* 1.2494	* 1.0987	* 0.5523	*
	* 1.5651	* 1.5853	* 1.6443	* 1.5236	* 1.4974	* 1.6796	* 3.0675	*
14	* 1.3125	* 1.3025	* 1.2236	* 0.8632	* 0.7042	* 0.5523	*	*
	* 1.4348	* 1.4524	* 1.5828	* 2.1312	* 2.4737	* 3.0678	*	*
15	* 0.6791	* 0.6759	* 0.6108	* 0.4277	* F-SUB-Q			
	* 2.5019	* 2.5325	* 2.8136	* 4.1092	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3717	* 1.3401	* 1.3291	* 1.3332	* 1.3200	* 1.4298	* 1.4216	* 0.7720 *
	* 1.4757	* 1.5240	* 1.5091	* 1.4818	* 1.4635	* 1.3486	* 1.3457	* 2.2347 *
9	* 1.3401	* 1.4008	* 1.4557	* 1.3700	* 1.4074	* 1.4277	* 1.4243	* 0.7772 *
	* 1.5240	* 1.4638	* 1.3892	* 1.4432	* 1.4045	* 1.3521	* 1.3486	* 2.2340 *
10	* 1.3291	* 1.4542	* 1.3470	* 1.3441	* 1.3863	* 1.4179	* 1.4081	* 0.7203 *
	* 1.5091	* 1.3915	* 1.4957	* 1.4929	* 1.4396	* 1.4116	* 1.3937	* 2.4219 *
11	* 1.3332	* 1.3690	* 1.3436	* 1.3971	* 1.3952	* 1.4187	* 1.0225	* 0.5202 *
	* 1.4818	* 1.4439	* 1.4935	* 1.4328	* 1.4343	* 1.3988	* 1.8233	* 3.4844 *
12	* 1.3200	* 1.4073	* 1.3860	* 1.3947	* 1.4103	* 1.3980	* 0.8112	*
	* 1.4635	* 1.4045	* 1.4398	* 1.4349	* 1.3828	* 1.3920	* 2.1906	*
13	* 1.4298	* 1.4278	* 1.4187	* 1.4187	* 1.3983	* 1.3434	* 0.6740	*
	* 1.3486	* 1.3519	* 1.4109	* 1.3988	* 1.3917	* 1.4199	* 2.5660	*
14	* 1.4216	* 1.4245	* 1.4085	* 1.0229	* 0.8107	* 0.6740	*	
	* 1.3457	* 1.3485	* 1.3933	* 1.8229	* 2.1903	* 2.5663	*	
15	* 0.7720	* 0.7777	* 0.7204	* 0.5158	* F-SUB-Q			
	* 2.2347	* 2.2333	* 2.4213	* 3.4581	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4833	* 1.4328	* 1.4255	* 1.3990	* 1.4337	* 1.5582	* 1.5763	* 0.8059 *
	* 1.3932	* 1.4493	* 1.4393	* 1.4343	* 1.3689	* 1.2524	* 1.2309	* 2.1718 *
9	* 1.4328	* 1.5178	* 1.5605	* 1.4688	* 1.5226	* 1.5689	* 1.5810	* 0.8176 *
	* 1.4493	* 1.3705	* 1.3163	* 1.3695	* 1.3171	* 1.2459	* 1.2319	* 2.1549 *
10	* 1.4255	* 1.5586	* 1.4490	* 1.4446	* 1.5266	* 1.5509	* 1.5755	* 0.7589 *
	* 1.4393	* 1.3189	* 1.4120	* 1.4239	* 1.3271	* 1.3073	* 1.2625	* 2.3318 *
11	* 1.3990	* 1.4676	* 1.4441	* 1.5259	* 1.5192	* 1.5791	* 1.0904	* 0.5500 *
	* 1.4343	* 1.3701	* 1.4246	* 1.3334	* 1.3386	* 1.2797	* 1.7372	* 3.3412 *
12	* 1.4337	* 1.5225	* 1.5263	* 1.5184	* 1.5498	* 1.5570	* 0.8559 *	
	* 1.3689	* 1.3172	* 1.3271	* 1.3393	* 1.2820	* 1.2773	* 2.1180	*
13	* 1.5582	* 1.5692	* 1.5520	* 1.5791	* 1.5574	* 1.5258	* 0.7214	*
	* 1.2524	* 1.2456	* 1.3064	* 1.2797	* 1.2770	* 1.2776	* 2.4490	*
14	* 1.5763	* 1.5813	* 1.5760	* 1.0909	* 0.8552	* 0.7213	*	
	* 1.2309	* 1.2317	* 1.2621	* 1.7367	* 2.1180	* 2.4493	*	
15	* 0.8059	* 0.8182	* 0.7591	* 0.5440	* F-SUB-Q			
	* 2.1718	* 2.1541	* 2.3312	* 3.3236	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5150	* 1.4606	* 1.4643	* 1.4228	* 1.4898	* 1.6162	* 1.6543	* 0.8292
	* 1.3911	* 1.4490	* 1.4274	* 1.4350	* 1.3392	* 1.2225	* 1.1918	* 2.1490
9	* 1.4606	* 1.5639	* 1.5932	* 1.5163	* 1.5708	* 1.6334	* 1.6599	* 0.8423
	* 1.4490	* 1.3534	* 1.3093	* 1.3476	* 1.2976	* 1.2156	* 1.1920	* 2.1270
10	* 1.4643	* 1.5909	* 1.4786	* 1.4895	* 1.5967	* 1.6072	* 1.6591	* 0.7843
	* 1.4274	* 1.3122	* 1.4073	* 1.4088	* 1.2934	* 1.2811	* 1.2169	* 2.2930
11	* 1.4228	* 1.5154	* 1.4888	* 1.5943	* 1.5771	* 1.6611	* 1.1329	* 0.5659
	* 1.4350	* 1.3482	* 1.4096	* 1.3009	* 1.3136	* 1.2403	* 1.7020	* 3.2957
12	* 1.4898	* 1.5707	* 1.5963	* 1.5762	* 1.6126	* 1.6399	* 0.8860	*
	* 1.3392	* 1.2976	* 1.2933	* 1.3143	* 1.2537	* 1.2383	* 2.0899	*
13	* 1.6162	* 1.6337	* 1.6084	* 1.6611	* 1.6402	* 1.6210	* 0.7512	*
	* 1.2225	* 1.2153	* 1.2801	* 1.2404	* 1.2381	* 1.2290	* 2.4055	*
14	* 1.6543	* 1.6602	* 1.6597	* 1.1333	* 0.8852	* 0.7511	*	*
	* 1.1918	* 1.1917	* 1.2165	* 1.7016	* 2.0901	* 2.4058	*	*
15	* 0.8292	* 0.8429	* 0.7845	* 0.5587	* F-SUB-Q			
	* 2.1490	* 2.1261	* 2.2924	* 3.2843	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5228	* 1.4664	* 1.4764	* 1.4311	* 1.5160	* 1.6499	* 1.6958	* 0.8453
	* 1.4040	* 1.4638	* 1.4408	* 1.4536	* 1.3410	* 1.2196	* 1.1840	* 2.1492
9	* 1.4664	* 1.5792	* 1.6028	* 1.5378	* 1.5945	* 1.6686	* 1.7019	* 0.8579
	* 1.4638	* 1.3577	* 1.3233	* 1.3533	* 1.3010	* 1.2115	* 1.1836	* 2.1279
10	* 1.4764	* 1.6003	* 1.4871	* 1.5115	* 1.6331	* 1.6356	* 1.7036	* 0.8021
	* 1.4408	* 1.3265	* 1.4240	* 1.4084	* 1.2903	* 1.2770	* 1.2046	* 2.2823
11	* 1.4311	* 1.5367	* 1.5107	* 1.6284	* 1.6135	* 1.7050	* 1.1618	* 0.5763
	* 1.4536	* 1.3540	* 1.4091	* 1.2955	* 1.3083	* 1.2292	* 1.6804	* 3.2860
12	* 1.5160	* 1.5944	* 1.6329	* 1.6130	* 1.6498	* 1.6851	* 0.9070	*
	* 1.3410	* 1.3010	* 1.2902	* 1.3088	* 1.2475	* 1.2304	* 2.0823	*
13	* 1.6499	* 1.6691	* 1.6370	* 1.7049	* 1.6853	* 1.6752	* 0.7720	*
	* 1.2196	* 1.2111	* 1.2760	* 1.2293	* 1.2302	* 1.2187	* 2.3988	*
14	* 1.6958	* 1.7022	* 1.7042	* 1.1621	* 0.9061	* 0.7719	*	*
	* 1.1840	* 1.1834	* 1.2042	* 1.6801	* 2.0828	* 2.3992	*	*
15	* 0.8453	* 0.8586	* 0.8022	* 0.5689	* F-SUB-Q			
	* 2.1492	* 2.1269	* 2.2820	* 3.2750	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5356	* 1.4765	* 1.4957	* 1.4441	* 1.5484	* 1.6871	* 1.7423	* 0.8511
	* 1.4087	* 1.4692	* 1.4485	* 1.4701	* 1.3413	* 1.2184	* 1.1771	* 2.1817
9	* 1.4765	* 1.6007	* 1.6185	* 1.5630	* 1.6200	* 1.7075	* 1.7486	* 0.8656
	* 1.4692	* 1.3541	* 1.3339	* 1.3582	* 1.3053	* 1.2086	* 1.1762	* 2.1545
10	* 1.4957	* 1.6157	* 1.5008	* 1.5340	* 1.6742	* 1.6672	* 1.7509	* 0.8079
	* 1.4485	* 1.3373	* 1.4371	* 1.4014	* 1.2752	* 1.2716	* 1.1934	* 2.3114
11	* 1.4441	* 1.5618	* 1.5332	* 1.6641	* 1.6407	* 1.7508	* 1.1743	* 0.5785
	* 1.4701	* 1.3590	* 1.4021	* 1.2857	* 1.3005	* 1.2141	* 1.6776	* 3.3211
12	* 1.5484	* 1.6199	* 1.6740	* 1.6401	* 1.6901	* 1.7321	* 0.9140	*
	* 1.3413	* 1.3054	* 1.2754	* 1.3012	* 1.2374	* 1.2203	* 2.1032	*
13	* 1.6871	* 1.7081	* 1.6687	* 1.7507	* 1.7323	* 1.7302	* 0.7794	*
	* 1.2184	* 1.2082	* 1.2705	* 1.2142	* 1.2201	* 1.2025	* 2.4231	*
14	* 1.7423	* 1.7490	* 1.7515	* 1.1746	* 0.9130	* 0.7793	*	*
	* 1.1771	* 1.1760	* 1.1930	* 1.6774	* 2.1039	* 2.4235	*	*
15	* 0.8511	* 0.8663	* 0.8080	* 0.5691	* F-SUB-Q			
	* 2.1817	* 2.1535	* 2.3112	* 3.3218	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5375	* 1.4765	* 1.5006	* 1.4471	* 1.5648	* 1.7092	* 1.7698	* 0.8552
	* 1.4299	* 1.4940	* 1.4722	* 1.4997	* 1.3597	* 1.2322	* 1.1873	* 2.2250
9	* 1.4765	* 1.6074	* 1.6224	* 1.5746	* 1.6330	* 1.7313	* 1.7762	* 0.8703
	* 1.4940	* 1.3717	* 1.3537	* 1.3788	* 1.3224	* 1.2205	* 1.1857	* 2.1949
10	* 1.5006	* 1.6195	* 1.5041	* 1.5451	* 1.6972	* 1.6845	* 1.7793	* 0.8126
	* 1.4722	* 1.3562	* 1.4580	* 1.4174	* 1.2797	* 1.2800	* 1.1982	* 2.3491
11	* 1.4471	* 1.5737	* 1.5442	* 1.6828	* 1.6585	* 1.7779	* 1.1848	* 0.5802
	* 1.4997	* 1.3797	* 1.4182	* 1.2915	* 1.3068	* 1.2144	* 1.6927	* 3.3565
12	* 1.5648	* 1.6329	* 1.6970	* 1.6577	* 1.7190	* 1.7598	* 0.9198	*
	* 1.3597	* 1.3224	* 1.2799	* 1.3076	* 1.2372	* 1.2184	* 2.1187	*
13	* 1.7092	* 1.7319	* 1.6861	* 1.7777	* 1.7600	* 1.7651	* 0.7856	*
	* 1.2322	* 1.2200	* 1.2788	* 1.2145	* 1.2183	* 1.2000	* 2.4431	*
14	* 1.7698	* 1.7766	* 1.7799	* 1.1850	* 0.9187	* 0.7854	*	*
	* 1.1873	* 1.1854	* 1.1978	* 1.6926	* 2.1195	* 2.4436	*	*
15	* 0.8552	* 0.8710	* 0.8126	* 0.5699	* F-SUB-Q			
	* 2.2250	* 2.1939	* 2.3492	* 3.3621	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5403	* 1.4771	* 1.5077	* 1.4502	* 1.5826	* 1.7305	* 1.7973	* 0.8559 *
	* 1.4679	* 1.5333	* 1.4934	* 1.5338	* 1.3816	* 1.2513	* 1.2019	* 2.2854 *
9	* 1.4771	* 1.6162	* 1.6274	* 1.5896	* 1.6452	* 1.7540	* 1.8039	* 0.8721 *
	* 1.5333	* 1.3891	* 1.3769	* 1.4000	* 1.3443	* 1.2376	* 1.1996	* 2.2504 *
10	* 1.5077	* 1.6244	* 1.5080	* 1.5550	* 1.7206	* 1.7012	* 1.8073	* 0.8136 *
	* 1.4934	* 1.3795	* 1.4852	* 1.4380	* 1.2940	* 1.2926	* 1.2072	* 2.4055 *
11	* 1.4502	* 1.5886	* 1.5540	* 1.7018	* 1.6756	* 1.8045	* 1.1901	* 0.5797 *
	* 1.5338	* 1.4008	* 1.4388	* 1.3103	* 1.3269	* 1.2273	* 1.7189	* 3.4240 *
12	* 1.5826	* 1.6451	* 1.7204	* 1.6744	* 1.7462	* 1.7870	* 0.9217 *	
	* 1.3816	* 1.3444	* 1.2937	* 1.3279	* 1.2521	* 1.2315	* 2.1670 *	
13	* 1.7305	* 1.7546	* 1.7027	* 1.8043	* 1.7871	* 1.7981	* 0.7877 *	
	* 1.2513	* 1.2371	* 1.2914	* 1.2275	* 1.2314	* 1.2077	* 2.4953 *	
14	* 1.7973	* 1.8043	* 1.8079	* 1.1903	* 0.9205	* 0.7875 *		
	* 1.2019	* 1.1993	* 1.2068	* 1.7189	* 2.1681	* 2.4959 *		
15	* 0.8559	* 0.8728	* 0.8136	* 0.5687	* F-SUB-Q			
	* 2.2854	* 2.2494	* 2.4057	* 3.4346	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5178	* 1.4544	* 1.4798	* 1.4299	* 1.5632	* 1.7198	* 1.7830	* 0.8608 *
	* 1.5255	* 1.5913	* 1.5585	* 1.6001	* 1.4427	* 1.2993	* 1.2501	* 2.3442 *
9	* 1.4544	* 1.5899	* 1.6043	* 1.5666	* 1.6316	* 1.7444	* 1.7899	* 0.8740 *
	* 1.5913	* 1.4488	* 1.4340	* 1.4605	* 1.3938	* 1.2831	* 1.2467	* 2.3151 *
10	* 1.4798	* 1.6011	* 1.4877	* 1.5426	* 1.7034	* 1.6921	* 1.7945	* 0.8207 *
	* 1.5585	* 1.4368	* 1.5465	* 1.4876	* 1.3384	* 1.3364	* 1.2492	* 2.4540 *
11	* 1.4299	* 1.5656	* 1.5418	* 1.6843	* 1.6751	* 1.7903	* 1.2028	* 0.5839 *
	* 1.6001	* 1.4615	* 1.4885	* 1.3604	* 1.3621	* 1.2706	* 1.7419	* 3.4862 *
12	* 1.5632	* 1.6314	* 1.7031	* 1.6743	* 1.7405	* 1.7738	* 0.9300 *	
	* 1.4427	* 1.3939	* 1.3386	* 1.3627	* 1.2991	* 1.2818	* 2.2105 *	
13	* 1.7198	* 1.7450	* 1.6951	* 1.7901	* 1.7739	* 1.7888	* 0.7971 *	
	* 1.2993	* 1.2826	* 1.3351	* 1.2708	* 1.2817	* 1.2544	* 2.5456 *	
14	* 1.7830	* 1.7903	* 1.7950	* 1.2028	* 0.9288	* 0.7969 *		
	* 1.2501	* 1.2465	* 1.2489	* 1.7420	* 2.2117	* 2.5463 *		
15	* 0.8608	* 0.8747	* 0.8205	* 0.5740	* F-SUB-Q			
	* 2.3442	* 2.3140	* 2.4544	* 3.4894	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5243	* 1.4585	* 1.4945	* 1.4357	* 1.5879	* 1.7453	* 1.8184	* 0.8530
	* 1.5636	* 1.6346	* 1.5914	* 1.6459	* 1.4700	* 1.3259	* 1.2692	* 2.4477
9	* 1.4585	* 1.6057	* 1.6137	* 1.5890	* 1.6453	* 1.7711	* 1.8253	* 0.8696
	* 1.6346	* 1.4798	* 1.4719	* 1.4868	* 1.4277	* 1.3080	* 1.2654	* 2.4067
10	* 1.4945	* 1.6104	* 1.4946	* 1.5522	* 1.7338	* 1.7117	* 1.8295	* 0.8127
	* 1.5914	* 1.4749	* 1.5894	* 1.5250	* 1.3562	* 1.3600	* 1.2648	* 2.5592
11	* 1.4357	* 1.5879	* 1.5511	* 1.7085	* 1.6836	* 1.8231	* 1.1958	* 0.5768
	* 1.6459	* 1.4879	* 1.5260	* 1.3816	* 1.3969	* 1.2851	* 1.8069	* 3.6354
12	* 1.5879	* 1.6451	* 1.7335	* 1.6822	* 1.7712	* 1.8071	* 0.9207	*
	* 1.4700	* 1.4278	* 1.3565	* 1.3980	* 1.3164	* 1.2943	* 2.2930	*
13	* 1.7453	* 1.7718	* 1.7134	* 1.8228	* 1.8071	* 1.8290	* 0.7886	*
	* 1.3259	* 1.3075	* 1.3586	* 1.2853	* 1.2942	* 1.2656	* 2.6465	*
14	* 1.8184	* 1.8257	* 1.8300	* 1.1959	* 0.9194	* 0.7884	*	*
	* 1.2692	* 1.2651	* 1.2644	* 1.8070	* 2.2945	* 2.6472	*	*
15	* 0.8530	* 0.8703	* 0.8125	* 0.5645	* F-SUB-Q			
	* 2.4477	* 2.4055	* 2.5598	* 3.6551	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5128	* 1.4461	* 1.4851	* 1.4253	* 1.5867	* 1.7478	* 1.8243	* 0.8494
	* 1.5872	* 1.6544	* 1.6051	* 1.6672	* 1.5023	* 1.3675	* 1.3093	* 2.5468
9	* 1.4461	* 1.5974	* 1.6030	* 1.5851	* 1.6410	* 1.7749	* 1.8311	* 0.8660
	* 1.6544	* 1.4944	* 1.4896	* 1.5073	* 1.4586	* 1.3484	* 1.3055	* 2.5060
10	* 1.4851	* 1.5995	* 1.4843	* 1.5469	* 1.7362	* 1.7136	* 1.8360	* 0.8100
	* 1.6051	* 1.4927	* 1.6080	* 1.5524	* 1.3909	* 1.4017	* 1.3058	* 2.6596
11	* 1.4253	* 1.5839	* 1.5457	* 1.7077	* 1.6831	* 1.8281	* 1.1956	* 0.5740
	* 1.6672	* 1.5084	* 1.5535	* 1.4161	* 1.4384	* 1.3266	* 1.8652	* 3.7733
12	* 1.5867	* 1.6409	* 1.7358	* 1.6817	* 1.7788	* 1.8124	* 0.9177	*
	* 1.5023	* 1.4588	* 1.3912	* 1.4392	* 1.3552	* 1.3350	* 2.3779	*
13	* 1.7478	* 1.7756	* 1.7154	* 1.8278	* 1.8124	* 1.8400	* 0.7869	*
	* 1.3675	* 1.3479	* 1.4003	* 1.3268	* 1.3350	* 1.2996	* 2.7371	*
14	* 1.8243	* 1.8316	* 1.8365	* 1.1956	* 0.9164	* 0.7866	*	*
	* 1.3093	* 1.3053	* 1.3054	* 1.8654	* 2.3795	* 2.7379	*	*
15	* 0.8494	* 0.8667	* 0.8098	* 0.5610	* F-SUB-Q			
	* 2.5468	* 2.5048	* 2.6604	* 3.7985	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4851	* 1.4186	* 1.4533	* 1.3995	* 1.5617	* 1.7296	* 1.8030	* 0.8481 *
	* 1.5744	* 1.6419	* 1.5967	* 1.6529	* 1.4866	* 1.3458	* 1.2901	* 2.4851 *
9	* 1.4186	* 1.5656	* 1.5739	* 1.5566	* 1.6200	* 1.7577	* 1.8102	* 0.8622 *
	* 1.6419	* 1.4845	* 1.4770	* 1.4946	* 1.4390	* 1.3262	* 1.2862	* 2.4520 *
10	* 1.4533	* 1.5705	* 1.4584	* 1.5270	* 1.7121	* 1.6957	* 1.8159	* 0.8108 *
	* 1.5967	* 1.4802	* 1.5932	* 1.5331	* 1.3751	* 1.3802	* 1.2874	* 2.5923 *
11	* 1.3995	* 1.5554	* 1.5260	* 1.6832	* 1.6727	* 1.8063	* 1.1988	* 0.5736 *
	* 1.6529	* 1.4957	* 1.5342	* 1.4010	* 1.4081	* 1.3096	* 1.8126	* 3.7002 *
12	* 1.5617	* 1.6198	* 1.7117	* 1.6717	* 1.7650	* 1.7917	* 0.9189	*
	* 1.4866	* 1.4392	* 1.3754	* 1.4089	* 1.3597	* 1.3293	* 2.3334	*
13	* 1.7296	* 1.7584	* 1.6976	* 1.8059	* 1.7917	* 1.8232	* 0.7901	*
	* 1.3458	* 1.3257	* 1.3787	* 1.3098	* 1.3293	* 1.3138	* 2.7188	*
14	* 1.8030	* 1.8106	* 1.8164	* 1.1987	* 0.9175	* 0.7898	*	
	* 1.2901	* 1.2859	* 1.2870	* 1.8130	* 2.3352	* 2.7197	*	
15	* 0.8481	* 0.8629	* 0.8105	* 0.5618	* F-SUB-Q			
	* 2.4851	* 2.4508	* 2.5932	* 3.7165	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4816	* 1.4131	* 1.4573	* 1.3952	* 1.5745	* 1.7430	* 1.8258	* 0.8347 *
	* 1.5384	* 1.6042	* 1.5487	* 1.6130	* 1.4392	* 1.3056	* 1.2453	* 2.4581 *
9	* 1.4131	* 1.5713	* 1.5720	* 1.5669	* 1.6216	* 1.7721	* 1.8328	* 0.8520 *
	* 1.6042	* 1.4408	* 1.4407	* 1.4477	* 1.4033	* 1.2860	* 1.2417	* 2.4156 *
10	* 1.4573	* 1.5684	* 1.4549	* 1.5254	* 1.7292	* 1.7074	* 1.8379	* 0.7977 *
	* 1.5487	* 1.4439	* 1.5551	* 1.4961	* 1.3288	* 1.3391	* 1.2425	* 2.5645 *
11	* 1.3952	* 1.5656	* 1.5242	* 1.6940	* 1.6704	* 1.8253	* 1.1838	* 0.5630 *
	* 1.6130	* 1.4489	* 1.4973	* 1.3589	* 1.3799	* 1.2640	* 1.7904	* 3.6614 *
12	* 1.5745	* 1.6214	* 1.7288	* 1.6688	* 1.7833	* 1.8116	* 0.9034	*
	* 1.4392	* 1.4035	* 1.3291	* 1.3812	* 1.3120	* 1.2813	* 2.3116	*
13	* 1.7430	* 1.7729	* 1.7093	* 1.8249	* 1.8116	* 1.8511	* 0.7766	*
	* 1.3056	* 1.2854	* 1.3376	* 1.2642	* 1.2814	* 1.2611	* 2.6920	*
14	* 1.8258	* 1.8332	* 1.8385	* 1.1837	* 0.9020	* 0.7764	*	
	* 1.2453	* 1.2414	* 1.2422	* 1.7908	* 2.3134	* 2.6929	*	
15	* 0.8347	* 0.8527	* 0.7974	* 0.5488	* F-SUB-Q			
	* 2.4581	* 2.4144	* 2.5655	* 3.6954	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4651	* 1.3961	* 1.4435	* 1.3793	* 1.5675	* 1.7388	* 1.8257	* 0.8245 *
	* 1.4909	* 1.5560	* 1.4984	* 1.5640	* 1.3872	* 1.2569	* 1.1959	* 2.3867 *
9	* 1.3960	* 1.5581	* 1.5555	* 1.5574	* 1.6100	* 1.7689	* 1.8327	* 0.8425 *
	* 1.5560	* 1.3921	* 1.3951	* 1.3962	* 1.3558	* 1.2374	* 1.1923	* 2.3427 *
10	* 1.4435	* 1.5518	* 1.4392	* 1.5131	* 1.7250	* 1.7023	* 1.8379	* 0.7884 *
	* 1.4984	* 1.3984	* 1.5064	* 1.4456	* 1.2790	* 1.2899	* 1.1930	* 2.4872 *
11	* 1.3793	* 1.5561	* 1.5118	* 1.6857	* 1.6622	* 1.8227	* 1.1731	* 0.5551 *
	* 1.5640	* 1.3974	* 1.4467	* 1.3103	* 1.3322	* 1.2166	* 1.7314	* 3.5574 *
12	* 1.5675	* 1.6098	* 1.7246	* 1.6606	* 1.7835	* 1.8100	* 0.8931 *	
	* 1.3872	* 1.3560	* 1.2793	* 1.3334	* 1.2667	* 1.2343	* 2.2383 *	
13	* 1.7388	* 1.7696	* 1.7043	* 1.8223	* 1.8099	* 1.8562	* 0.7684 *	
	* 1.2569	* 1.2369	* 1.2883	* 1.2169	* 1.2343	* 1.2116	* 2.6034 *	
14	* 1.8257	* 1.8332	* 1.8384	* 1.1730	* 0.8916	* 0.7682 *		
	* 1.1959	* 1.1921	* 1.1927	* 1.7319	* 2.2402	* 2.6043 *		
15	* 0.8245	* 0.8432	* 0.7881	* 0.5404	* F-SUB-Q			
	* 2.3866	* 2.3415	* 2.4883	* 3.5952	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4424	* 1.3732	* 1.4212	* 1.3575	* 1.5501	* 1.7237	* 1.8118	* 0.8160 *
	* 1.4563	* 1.5214	* 1.4642	* 1.5292	* 1.3498	* 1.2195	* 1.1590	* 2.3212 *
9	* 1.3732	* 1.5356	* 1.5321	* 1.5375	* 1.5908	* 1.7546	* 1.8188	* 0.8334 *
	* 1.5214	* 1.3585	* 1.3624	* 1.3602	* 1.3194	* 1.1997	* 1.1554	* 2.2793 *
10	* 1.4212	* 1.5281	* 1.4172	* 1.4938	* 1.7082	* 1.6870	* 1.8244	* 0.7813 *
	* 1.4642	* 1.3657	* 1.4715	* 1.4072	* 1.2403	* 1.2510	* 1.1549	* 2.4147 *
11	* 1.3575	* 1.5361	* 1.4925	* 1.6676	* 1.6451	* 1.8073	* 1.1650	* 0.5494 *
	* 1.5292	* 1.3614	* 1.4084	* 1.2721	* 1.2919	* 1.1775	* 1.6751	* 3.4569 *
12	* 1.5501	* 1.5906	* 1.7078	* 1.6435	* 1.7719	* 1.7954	* 0.8846 *	
	* 1.3498	* 1.3196	* 1.2406	* 1.2930	* 1.2225	* 1.1936	* 2.1693 *	
13	* 1.7237	* 1.7554	* 1.6892	* 1.8069	* 1.7953	* 1.8457	* 0.7621 *	
	* 1.2195	* 1.1991	* 1.2494	* 1.1778	* 1.1937	* 1.1674	* 2.5174 *	
14	* 1.8118	* 1.8193	* 1.8249	* 1.1649	* 0.8831	* 0.7618 *		
	* 1.1590	* 1.1551	* 1.1546	* 1.6755	* 2.1713	* 2.5183 *		
15	* 0.8160	* 0.8341	* 0.7809	* 0.5345	* F-SUB-Q			
	* 2.3212	* 2.2781	* 2.4159	* 3.4961	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4112	* 1.3430	* 1.3867	* 1.3282	* 1.5181	* 1.6955	* 1.7801	* 0.8102
	* 1.5499	* 1.6203	* 1.5640	* 1.6301	* 1.4372	* 1.2921	* 1.2294	* 2.4386
9	* 1.3430	* 1.5002	* 1.4997	* 1.5034	* 1.5621	* 1.7269	* 1.7873	* 0.8249
	* 1.6203	* 1.4492	* 1.4508	* 1.4498	* 1.4001	* 1.2700	* 1.2251	* 2.4016
10	* 1.3867	* 1.4950	* 1.3869	* 1.4670	* 1.6753	* 1.6592	* 1.7936	* 0.7771
	* 1.5640	* 1.4550	* 1.5672	* 1.4928	* 1.3157	* 1.3245	* 1.2231	* 2.5314
11	* 1.3282	* 1.5020	* 1.4659	* 1.6350	* 1.6236	* 1.7755	* 1.1602	* 0.5456
	* 1.6301	* 1.4511	* 1.4941	* 1.3494	* 1.3574	* 1.2459	* 1.7509	* 3.6279
12	* 1.5181	* 1.5619	* 1.6749	* 1.6225	* 1.7462	* 1.7640	* 0.8803	*
	* 1.4372	* 1.4003	* 1.3160	* 1.3583	* 1.2868	* 1.2616	* 2.2667	*
13	* 1.6955	* 1.7277	* 1.6613	* 1.7751	* 1.7639	* 1.8169	* 0.7601	*
	* 1.2921	* 1.2695	* 1.3229	* 1.2462	* 1.2617	* 1.2296	* 2.6215	*
14	* 1.7801	* 1.7878	* 1.7941	* 1.1600	* 0.8788	* 0.7598	*	*
	* 1.2294	* 1.2248	* 1.2228	* 1.7514	* 2.2689	* 2.6225	*	*
15	* 0.8102	* 0.8256	* 0.7767	* 0.5324	* F-SUB-Q			
	* 2.4386	* 2.4004	* 2.5327	* 3.6580	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4048	* 1.3353	* 1.3889	* 1.3205	* 1.5242	* 1.6988	* 1.7928	* 0.7912
	* 1.4952	* 1.5682	* 1.5049	* 1.5826	* 1.3833	* 1.2465	* 1.1798	* 2.4190
9	* 1.3353	* 1.5033	* 1.4945	* 1.5082	* 1.5558	* 1.7310	* 1.7997	* 0.8092
	* 1.5682	* 1.3938	* 1.4040	* 1.3940	* 1.3569	* 1.2244	* 1.1757	* 2.3711
10	* 1.3889	* 1.4896	* 1.3798	* 1.4587	* 1.6836	* 1.6602	* 1.8049	* 0.7581
	* 1.5049	* 1.4078	* 1.5192	* 1.4459	* 1.2603	* 1.2776	* 1.1731	* 2.5114
11	* 1.3205	* 1.5067	* 1.4573	* 1.6383	* 1.6140	* 1.7840	* 1.1361	* 0.5312
	* 1.5826	* 1.3953	* 1.4472	* 1.2952	* 1.3173	* 1.1922	* 1.7238	* 3.6073
12	* 1.5242	* 1.5556	* 1.6832	* 1.6123	* 1.7522	* 1.7727	* 0.8584	*
	* 1.3833	* 1.3571	* 1.2606	* 1.3186	* 1.2272	* 1.2045	* 2.2378	*
13	* 1.6988	* 1.7318	* 1.6625	* 1.7836	* 1.7726	* 1.8318	* 0.7400	*
	* 1.2465	* 1.2238	* 1.2759	* 1.1925	* 1.2046	* 1.1687	* 2.5886	*
14	* 1.7929	* 1.8002	* 1.8054	* 1.1359	* 0.8569	* 0.7397	*	*
	* 1.1798	* 1.1754	* 1.1727	* 1.7243	* 2.2400	* 2.5896	*	*
15	* 0.7912	* 0.8099	* 0.7577	* 0.5157	* F-SUB-Q			
	* 2.4190	* 2.3699	* 2.5128	* 3.6556	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3843	* 1.3151	* 1.3690	* 1.2999	* 1.5042	* 1.6788	* 1.7723	* 0.7770
	* 1.4536	* 1.5281	* 1.4667	* 1.5455	* 1.3474	* 1.2120	* 1.1466	* 2.3700
9	* 1.3151	* 1.4832	* 1.4737	* 1.4869	* 1.5332	* 1.7110	* 1.7790	* 0.7949
	* 1.5281	* 1.3567	* 1.3679	* 1.3584	* 1.3226	* 1.1898	* 1.1425	* 2.3220
10	* 1.3690	* 1.4688	* 1.3595	* 1.4362	* 1.6616	* 1.6393	* 1.7834	* 0.7446
	* 1.4667	* 1.3715	* 1.4815	* 1.4096	* 1.2245	* 1.2422	* 1.1396	* 2.4592
11	* 1.2999	* 1.4854	* 1.4349	* 1.6162	* 1.5914	* 1.7610	* 1.1191	* 0.5213
	* 1.5455	* 1.3597	* 1.4109	* 1.2593	* 1.2804	* 1.1570	* 1.6799	* 3.5354
12	* 1.5042	* 1.5330	* 1.6612	* 1.5897	* 1.7320	* 1.7497	* 0.8432	*
	* 1.3474	* 1.3228	* 1.2248	* 1.2817	* 1.1845	* 1.1673	* 2.1850	*
13	* 1.6788	* 1.7119	* 1.6417	* 1.7606	* 1.7496	* 1.8099	* 0.7265	*
	* 1.2120	* 1.1893	* 1.2405	* 1.1573	* 1.1674	* 1.1301	* 2.5262	*
14	* 1.7723	* 1.7795	* 1.7839	* 1.1189	* 0.8417	* 0.7262	*	
	* 1.1466	* 1.1422	* 1.1393	* 1.6804	* 2.1872	* 2.5271	*	
15	* 0.7770	* 0.7956	* 0.7442	* 0.5058	F-SUB-Q			
	* 2.3700	* 2.3208	* 2.4606	* 3.5850	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3475	* 1.2801	* 1.3229	* 1.2655	* 1.4523	* 1.6300	* 1.7100	* 0.7673
	* 1.4418	* 1.5163	* 1.4669	* 1.5350	* 1.3491	* 1.2060	* 1.1481	* 2.3224
9	* 1.2801	* 1.4353	* 1.4351	* 1.4340	* 1.4912	* 1.6612	* 1.7166	* 0.7814
	* 1.5163	* 1.3547	* 1.3574	* 1.3611	* 1.3138	* 1.1838	* 1.1438	* 2.2859
10	* 1.3229	* 1.4303	* 1.3241	* 1.3961	* 1.6017	* 1.5915	* 1.7199	* 0.7358
	* 1.4669	* 1.3610	* 1.4701	* 1.4003	* 1.2255	* 1.2355	* 1.1409	* 2.4078
11	* 1.2655	* 1.4325	* 1.3949	* 1.5586	* 1.5513	* 1.6984	* 1.1076	* 0.5155
	* 1.5350	* 1.3624	* 1.4016	* 1.2579	* 1.2649	* 1.1566	* 1.6392	* 3.4593
12	* 1.4523	* 1.4910	* 1.6013	* 1.5502	* 1.6793	* 1.6869	* 0.8342	*
	* 1.3491	* 1.3140	* 1.2259	* 1.2657	* 1.1755	* 1.1664	* 2.1318	*
13	* 1.6300	* 1.6621	* 1.5936	* 1.6979	* 1.6867	* 1.7407	* 0.7187	*
	* 1.2060	* 1.1832	* 1.2339	* 1.1569	* 1.1665	* 1.1304	* 2.4628	*
14	* 1.7100	* 1.7171	* 1.7204	* 1.1074	* 0.8328	* 0.7184	*	
	* 1.1481	* 1.1435	* 1.1405	* 1.6397	* 2.1338	* 2.4638	*	
15	* 0.7673	* 0.7821	* 0.7353	* 0.5024	* F-SUB-Q			
	* 2.3224	* 2.2846	* 2.4093	* 3.4920	* M-SUB-Q			



# C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3325	* 1.2660	* 1.3109	* 1.2575	* 1.4315	* 1.6049	* 1.6789	* 0.7416 *
	* 1.4175	* 1.4908	* 1.4398	* 1.5026	* 1.3310	* 1.1904	* 1.1365	* 2.3398 *
9	* 1.2660	* 1.4205	* 1.4230	* 1.4153	* 1.4677	* 1.6342	* 1.6845	* 0.7579 *
	* 1.4908	* 1.3308	* 1.3304	* 1.3408	* 1.2975	* 1.1693	* 1.1327	* 2.2944 *
10	* 1.3109	* 1.4188	* 1.3104	* 1.3733	* 1.5732	* 1.5631	* 1.6820	* 0.7080 *
	* 1.4398	* 1.3340	* 1.4447	* 1.3835	* 1.2117	* 1.2221	* 1.1334	* 2.4360 *
11	* 1.2575	* 1.4139	* 1.3720	* 1.5337	* 1.5187	* 1.6635	* 1.0691	* 0.4955 *
	* 1.5026	* 1.3421	* 1.3848	* 1.2440	* 1.2565	* 1.1461	* 1.6508	* 3.5044 *
12	* 1.4315	* 1.4675	* 1.5727	* 1.5170	* 1.6497	* 1.6522	* 0.8028	*
	* 1.3310	* 1.2977	* 1.2121	* 1.2578	* 1.1600	* 1.1554	* 2.1532	*
13	* 1.6049	* 1.6350	* 1.5652	* 1.6631	* 1.6521	* 1.6980	* 0.6870	*
	* 1.1904	* 1.1688	* 1.2205	* 1.1464	* 1.1555	* 1.1232	* 2.5028	*
14	* 1.6789	* 1.6849	* 1.6824	* 1.0689	* 0.8013	* 0.6868	*	
	* 1.1365	* 1.1325	* 1.1331	* 1.6513	* 2.1554	* 2.5038	*	
15	* 0.7416	* 0.7586	* 0.7075	* 0.4809	* F-SUB-Q			
	* 2.3398	* 2.2930	* 2.4376	* 3.5528	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2645	* 1.2154	* 1.2673	* 1.2330	* 1.3552	* 1.5161	* 1.5779	* 0.7170
	* 1.4618	* 1.5182	* 1.4585	* 1.4995	* 1.3751	* 1.2320	* 1.1822	* 2.3698
9	* 1.2154	* 1.3512	* 1.3647	* 1.3507	* 1.3978	* 1.5408	* 1.5810	* 0.7302
	* 1.5182	* 1.3685	* 1.3578	* 1.3741	* 1.3323	* 1.2124	* 1.1799	* 2.3326
10	* 1.2673	* 1.3595	* 1.2480	* 1.3176	* 1.4826	* 1.4677	* 1.5653	* 0.6753
	* 1.4585	* 1.3623	* 1.4844	* 1.4100	* 1.2565	* 1.2725	* 1.1907	* 2.5020
11	* 1.2330	* 1.3494	* 1.3164	* 1.4547	* 1.4439	* 1.5623	* 1.0154	* 0.4681
	* 1.4995	* 1.3754	* 1.4113	* 1.2789	* 1.2916	* 1.1923	* 1.7007	* 3.6370
12	* 1.3552	* 1.3976	* 1.4822	* 1.4424	* 1.5623	* 1.5559	* 0.7704	
	* 1.3751	* 1.3325	* 1.2569	* 1.2930	* 1.1959	* 1.1985	* 2.1954	
13	* 1.5161	* 1.5415	* 1.4696	* 1.5619	* 1.5558	* 1.5719	* 0.6484	
	* 1.2320	* 1.2119	* 1.2710	* 1.1927	* 1.1986	* 1.1848	* 2.5952	
14	* 1.5779	* 1.5814	* 1.5656	* 1.0152	* 0.7690	* 0.6482	*	
	* 1.1822	* 1.1796	* 1.1904	* 1.7013	* 2.1975	* 2.5962	*	
15	* 0.7170	* 0.7309	* 0.6748	* 0.4539	* F-SUB-Q			
	* 2.3698	* 2.3314	* 2.5037	* 3.6901	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0547	* 1.0769	* 1.3234	* 1.0975	* 1.3724	* 1.2640	* 1.4517	* 0.6350
	* 1.7253	* 1.6863	* 1.3720	* 1.6579	* 1.3320	* 1.4529	* 1.2624	* 2.6377
9	* 1.0769	* 1.3297	* 1.1767	* 1.3608	* 1.1745	* 1.2831	* 1.4413	* 0.6429
	* 1.6863	* 1.3652	* 1.5453	* 1.3392	* 1.5564	* 1.4309	* 1.2716	* 2.6115
10	* 1.3234	* 1.1753	* 1.0421	* 1.1496	* 1.4327	* 1.2396	* 1.3501	* 0.5826
	* 1.3720	* 1.5472	* 1.7494	* 1.5903	* 1.2769	* 1.4782	* 1.3577	* 2.8587
11	* 1.0975	* 1.3594	* 1.1488	* 1.4400	* 1.2233	* 1.4145	* 0.8733	* 0.3954
	* 1.6579	* 1.3405	* 1.5915	* 1.2707	* 1.4976	* 1.2947	* 1.9469	* 4.2488
12	* 1.3724	* 1.1736	* 1.4323	* 1.2225	* 1.3217	* 1.4404	* 0.6874	*
	* 1.3320	* 1.5576	* 1.2772	* 1.4987	* 1.3887	* 1.2725	* 2.4235	*
13	* 1.2640	* 1.2837	* 1.2411	* 1.4142	* 1.4401	* 1.2911	* 0.5456	*
	* 1.4529	* 1.4303	* 1.4764	* 1.2950	* 1.2728	* 1.4196	* 3.0398	*
14	* 1.4517	* 1.4417	* 1.3501	* 0.8730	* 0.6863	* 0.5454	*	*
	* 1.2624	* 1.2713	* 1.3577	* 1.9477	* 2.4256	* 3.0411	*	*
15	* 0.6350	* 0.6434	* 0.5822	* 0.3837	* F-SUB-Q			
	* 2.6377	* 2.6103	* 2.8608	* 4.3084	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4291	* 0.4641	* 0.5567	* 0.4811	* 0.5696	* 0.4971	* 0.5315	* 0.2708
	* 4.1956	* 3.8743	* 3.2297	* 3.7477	* 3.1736	* 3.6527	* 3.4146	* 6.1352
9	* 0.4641	* 0.5463	* 0.4859	* 0.5636	* 0.4867	* 0.5009	* 0.5262	* 0.2700
	* 3.8743	* 3.2909	* 3.7075	* 3.1987	* 3.7168	* 3.6255	* 3.4490	* 6.1666
10	* 0.5567	* 0.4850	* 0.4467	* 0.4910	* 0.5824	* 0.4929	* 0.4856	* 0.2464
	* 3.2297	* 3.7144	* 4.0422	* 3.6845	* 3.1067	* 3.6804	* 3.7388	* 6.7048
11	* 0.4811	* 0.5630	* 0.4907	* 0.5772	* 0.5037	* 0.5497	* 0.3662	* 0.1676
	* 3.7477	* 3.2020	* 3.6869	* 3.1342	* 3.5996	* 3.2996	* 4.5975	* 9.9496
12	* 0.5696	* 0.4864	* 0.5822	* 0.5033	* 0.5094	* 0.5293	* 0.2925	*
	* 3.1736	* 3.7194	* 3.1079	* 3.6025	* 3.5650	* 3.4289	* 5.6474	*
13	* 0.4971	* 0.5011	* 0.4932	* 0.5496	* 0.5292	* 0.4639	* 0.2279	*
	* 3.6527	* 3.6245	* 3.6778	* 3.3004	* 3.4296	* 3.9135	* 7.2175	*
14	* 0.5315	* 0.5263	* 0.4856	* 0.3661	* 0.2921	* 0.2278	*	*
	* 3.4146	* 3.4484	* 3.7391	* 4.5998	* 5.6500	* 7.2208	*	*
15	* 0.2708	* 0.2703	* 0.2462	* 0.1641	* F-SUB-Q			
	* 6.1352	* 6.1637	* 6.7097	* 9.9946	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5063	* 0.5797	* 0.6840	* 0.5927	* 0.6734	* 0.5755	* 0.5832	* 0.3177
	* 4.3400	* 3.9940	* 3.2436	* 3.6507	* 3.1590	* 3.6999	* 3.6935	* 6.1036
9	* 0.5797	* 0.6676	* 0.6098	* 0.6774	* 0.5841	* 0.5655	* 0.5767	* 0.3139
	* 3.9940	* 3.4628	* 3.6087	* 3.2074	* 3.6718	* 3.7867	* 3.7565	* 6.2231
10	* 0.6840	* 0.6092	* 0.5570	* 0.5772	* 0.6649	* 0.5656	* 0.5330	* 0.2830
	* 3.2436	* 3.6108	* 4.0998	* 3.8272	* 3.3558	* 3.9409	* 4.0906	* 6.8280
11	* 0.5927	* 0.6771	* 0.5770	* 0.6562	* 0.5806	* 0.5981	* 0.4071	* 0.1970
	* 3.6507	* 3.2084	* 3.8288	* 3.6042	* 4.0653	* 3.9831	* 5.2203	* 10.1969
12	* 0.6734	* 0.5840	* 0.6648	* 0.5804	* 0.5221	* 0.5329	* 0.3288	*
	* 3.1590	* 3.6724	* 3.3565	* 4.0669	* 4.1837	* 4.1354	* 6.4295	*
13	* 0.5755	* 0.5655	* 0.5658	* 0.5981	* 0.5329	* 0.4669	* 0.2490	*
	* 3.6999	* 3.7865	* 3.9395	* 3.9831	* 4.1350	* 4.6504	* 8.2196	*
14	* 0.5832	* 0.5768	* 0.5331	* 0.4072	* 0.3287	* 0.2490	*	*
	* 3.6935	* 3.7558	* 4.0897	* 5.2196	* 6.4258	* 8.2204	*	*
15	* 0.3177	* 0.3141	* 0.2830	* 0.1942	* F-SUB-Q			
	* 6.1036	* 6.2174	* 6.8275	* 10.1764	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2305	* 1.2870	* 1.5146	* 1.2944	* 1.4976	* 1.3525	* 1.4748	* 0.7385
	* 1.9597	* 1.8612	* 1.5042	* 1.7320	* 1.4665	* 1.6246	* 1.4990	* 2.6997
9	* 1.2870	* 1.5138	* 1.4025	* 1.5143	* 1.3313	* 1.3453	* 1.4629	* 0.7343
	* 1.8612	* 1.5614	* 1.6168	* 1.4786	* 1.6721	* 1.6394	* 1.5062	* 2.7112
10	* 1.5146	* 1.4014	* 1.2401	* 1.2864	* 1.5093	* 1.3440	* 1.3712	* 0.6624
	* 1.5042	* 1.6181	* 1.8774	* 1.7685	* 1.5174	* 1.7171	* 1.6371	* 3.0016
11	* 1.2944	* 1.5134	* 1.2859	* 1.5231	* 1.3321	* 1.4380	* 0.9494	* 0.4634
	* 1.7320	* 1.4790	* 1.7692	* 1.5945	* 1.8307	* 1.6961	* 2.3100	* 4.4697
12	* 1.4976	* 1.3309	* 1.5090	* 1.3314	* 1.2839	* 1.3998	* 0.7656	*
	* 1.4665	* 1.6723	* 1.5178	* 1.8316	* 1.7823	* 1.6613	* 2.8321	*
13	* 1.3525	* 1.3455	* 1.3448	* 1.4381	* 1.3999	* 1.2307	* 0.5983	*
	* 1.6246	* 1.6392	* 1.7164	* 1.6961	* 1.6611	* 1.8627	* 3.5163	*
14	* 1.4748	* 1.4632	* 1.3715	* 0.9498	* 0.7653	* 0.5983	*	*
	* 1.4990	* 1.5059	* 1.6367	* 2.3095	* 2.8313	* 3.5167	*	*
15	* 0.7385	* 0.7349	* 0.6625	* 0.4574	* F-SUB-Q			
	* 2.6997	* 2.7102	* 3.0011	* 4.4562	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4924	* 1.4533	* 1.4419	* 1.4505	* 1.4591	* 1.6000	* 1.5992	* 0.8413
	* 1.7016	* 1.7055	* 1.6124	* 1.5789	* 1.5334	* 1.3988	* 1.3924	* 2.3813
9	* 1.4533	* 1.5299	* 1.5951	* 1.4967	* 1.5644	* 1.6073	* 1.6023	* 0.8468
	* 1.7055	* 1.5670	* 1.4767	* 1.5317	* 1.4703	* 1.3948	* 1.3945	* 2.3797
10	* 1.4419	* 1.5932	* 1.4717	* 1.4824	* 1.5424	* 1.5877	* 1.5821	* 0.7833
	* 1.6124	* 1.4795	* 1.5995	* 1.5822	* 1.5086	* 1.4712	* 1.4454	* 2.5858
11	* 1.4505	* 1.4956	* 1.4818	* 1.5484	* 1.5576	* 1.5889	* 1.1285	* 0.5584
	* 1.5789	* 1.5323	* 1.5829	* 1.6144	* 1.6062	* 1.5612	* 1.9874	* 3.7910
12	* 1.4591	* 1.5643	* 1.5420	* 1.5569	* 1.5806	* 1.5639	* 0.8833	
	* 1.5334	* 1.4703	* 1.5085	* 1.6069	* 1.5343	* 1.5528	* 2.5108	
13	* 1.6000	* 1.6076	* 1.5886	* 1.5889	* 1.5642	* 1.5081	* 0.7322	
	* 1.3988	* 1.3946	* 1.4703	* 1.5612	* 1.5525	* 1.5753	* 2.9429	
14	* 1.5992	* 1.6026	* 1.5826	* 1.1290	* 0.8827	* 0.7321		
	* 1.3924	* 1.3942	* 1.4449	* 1.9869	* 2.5105	* 2.9433		
15	* 0.8413	* 0.8474	* 0.7835	* 0.5536	* F-SUB-Q			
	* 2.3813	* 2.3788	* 2.5851	* 3.7626	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6062	* 1.5469	* 1.5391	* 1.5139	* 1.5851	* 1.7422	* 1.7646	* 0.8746
	* 1.6193	* 1.6829	* 1.5584	* 1.5464	* 1.4451	* 1.3043	* 1.2843	* 2.3296
9	* 1.5469	* 1.6510	* 1.7022	* 1.5978	* 1.6846	* 1.7606	* 1.7702	* 0.8872
	* 1.6829	* 1.4839	* 1.4159	* 1.4703	* 1.3959	* 1.2977	* 1.2858	* 2.3140
10	* 1.5391	* 1.6997	* 1.5759	* 1.5851	* 1.6925	* 1.7284	* 1.7619	* 0.8223
	* 1.5584	* 1.4189	* 1.5260	* 1.5307	* 1.4055	* 1.3788	* 1.3249	* 2.5147
11	* 1.5139	* 1.5968	* 1.5844	* 1.6844	* 1.6885	* 1.7594	* 1.1984	* 0.5885
	* 1.5464	* 1.4710	* 1.5316	* 1.5145	* 1.5111	* 1.4411	* 1.9141	* 3.6785
12	* 1.5851	* 1.6846	* 1.6924	* 1.6876	* 1.7285	* 1.7329	* 0.9279	
	* 1.4451	* 1.3960	* 1.4054	* 1.5118	* 1.4356	* 1.4377	* 2.4472	
13	* 1.7422	* 1.7610	* 1.7297	* 1.7593	* 1.7332	* 1.7047	* 0.7807	
	* 1.3043	* 1.2974	* 1.3777	* 1.4411	* 1.4374	* 1.4297	* 2.8294	
14	* 1.7646	* 1.7706	* 1.7626	* 1.1989	* 0.9272	* 0.7806		
	* 1.2843	* 1.2855	* 1.3244	* 1.9135	* 2.4472	* 2.8297		
15	* 0.8746	* 0.8879	* 0.8225	* 0.5821	* F-SUB-Q			
	* 2.3296	* 2.3130	* 2.5140	* 3.6592	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6278	* 1.5649	* 1.5691	* 1.5279	* 1.6349	* 1.7983	* 1.8379	* 0.8943
	* 1.6366	* 1.7069	* 1.5699	* 1.5665	* 1.4340	* 1.2945	* 1.2637	* 2.3390
9	* 1.5649	* 1.6877	* 1.7242	* 1.6396	* 1.7245	* 1.8186	* 1.8442	* 0.9082
	* 1.7069	* 1.4927	* 1.4328	* 1.4677	* 1.3941	* 1.2872	* 1.2650	* 2.3192
10	* 1.5691	* 1.7215	* 1.5956	* 1.6219	* 1.7589	* 1.7772	* 1.8413	* 0.8447
	* 1.5699	* 1.4363	* 1.5482	* 1.5367	* 1.3885	* 1.3667	* 1.2960	* 2.5082
11	* 1.5279	* 1.6384	* 1.6211	* 1.7463	* 1.7392	* 1.8361	* 1.2363	* 0.6021
	* 1.5665	* 1.4684	* 1.5376	* 1.4962	* 1.5012	* 1.4142	* 1.8953	* 3.6682
12	* 1.6349	* 1.7245	* 1.7588	* 1.7381	* 1.7886	* 1.8110	* 0.9544	*
	* 1.4340	* 1.3941	* 1.3884	* 1.5021	* 1.4164	* 1.4112	* 2.4414	*
13	* 1.7983	* 1.8191	* 1.7787	* 1.8361	* 1.8113	* 1.7973	* 0.8079	*
	* 1.2945	* 1.2869	* 1.3655	* 1.4143	* 1.4109	* 1.3923	* 2.8091	*
14	* 1.8379	* 1.8447	* 1.8421	* 1.2368	* 0.9535	* 0.8078	*	*
	* 1.2637	* 1.2647	* 1.2955	* 1.8947	* 2.4417	* 2.8095	*	*
15	* 0.8943	* 0.9090	* 0.8449	* 0.5945	* F-SUB-Q			
	* 2.3390	* 2.3181	* 2.5075	* 3.6556	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6209	* 1.5569	* 1.5678	* 1.5232	* 1.6485	* 1.8183	* 1.8664	* 0.9046
	* 1.6750	* 1.7510	* 1.6114	* 1.6109	* 1.4561	* 1.3070	* 1.2707	* 2.3651
9	* 1.5569	* 1.6884	* 1.7182	* 1.6485	* 1.7342	* 1.8406	* 1.8733	* 0.9179
	* 1.7510	* 1.5308	* 1.4726	* 1.4989	* 1.4228	* 1.2994	* 1.2716	* 2.3441
10	* 1.5678	* 1.7152	* 1.5899	* 1.6307	* 1.7828	* 1.7914	* 1.8730	* 0.8572
	* 1.6114	* 1.4764	* 1.5926	* 1.5700	* 1.4114	* 1.3850	* 1.3048	* 2.5279
11	* 1.5232	* 1.6476	* 1.6298	* 1.7669	* 1.7608	* 1.8668	* 1.2570	* 0.6087
	* 1.6109	* 1.4997	* 1.5709	* 1.5121	* 1.5189	* 1.4228	* 1.9174	* 3.7261
12	* 1.6485	* 1.7341	* 1.7826	* 1.7602	* 1.8126	* 1.8436	* 0.9693	*
	* 1.4561	* 1.4228	* 1.4113	* 1.5199	* 1.4319	* 1.4237	* 2.4669	*
13	* 1.8183	* 1.8412	* 1.7930	* 1.8667	* 1.8438	* 1.8401	* 0.8239	*
	* 1.3070	* 1.2989	* 1.3837	* 1.4229	* 1.4235	* 1.4017	* 2.8421	*
14	* 1.8664	* 1.8738	* 1.8738	* 1.2574	* 0.9683	* 0.8238	*	*
	* 1.2707	* 1.2713	* 1.3042	* 1.9170	* 2.4674	* 2.8426	*	*
15	* 0.9046	* 0.9187	* 0.8574	* 0.6010	* F-SUB-Q			
	* 2.3651	* 2.3429	* 2.5274	* 3.7135	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6178	* 1.5516	* 1.5725	* 1.5219	* 1.6667	* 1.8398	* 1.8979	* 0.9027 *
	* 1.7064	* 1.7839	* 1.6619	* 1.6674	* 1.4885	* 1.3322	* 1.2884	* 2.4413 *
9	* 1.5516	* 1.6938	* 1.7170	* 1.6635	* 1.7438	* 1.8635	* 1.9048	* 0.9178 *
	* 1.7839	* 1.5790	* 1.5244	* 1.5425	* 1.4650	* 1.3242	* 1.2899	* 2.4176 *
10	* 1.5725	* 1.7138	* 1.5881	* 1.6382	* 1.8085	* 1.8068	* 1.9052	* 0.8556 *
	* 1.6619	* 1.5286	* 1.6512	* 1.6265	* 1.4440	* 1.4161	* 1.3258	* 2.6158 *
11	* 1.5219	* 1.6625	* 1.6373	* 1.7876	* 1.7732	* 1.8968	* 1.2581	* 0.6058 *
	* 1.6674	* 1.5434	* 1.6276	* 1.5255	* 1.5335	* 1.4287	* 1.9856	* 3.8751 *
12	* 1.6667	* 1.7437	* 1.8083	* 1.7720	* 1.8424	* 1.8755	* 0.9678	*
	* 1.4885	* 1.4650	* 1.4439	* 1.5345	* 1.4445	* 1.4356	* 2.5323	*
13	* 1.8398	* 1.8642	* 1.8085	* 1.8967	* 1.8758	* 1.8812	* 0.8244	*
	* 1.3322	* 1.3237	* 1.4147	* 1.4288	* 1.4354	* 1.4072	* 2.9150	*
14	* 1.8979	* 1.9053	* 1.9060	* 1.2585	* 0.9668	* 0.8243	*	
	* 1.2884	* 1.2896	* 1.3253	* 1.9852	* 2.5331	* 2.9155	*	
15	* 0.9027	* 0.9186	* 0.8557	* 0.5960	F-SUB-Q			
	* 2.4413	* 2.4164	* 2.6154	* 3.8758	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6018	* 1.5347	* 1.5607	* 1.5087	* 1.6656	* 1.8423	* 1.9057	* 0.8980
	* 1.7638	* 1.8470	* 1.7463	* 1.7542	* 1.5525	* 1.3846	* 1.3351	* 2.5524
9	* 1.5347	* 1.6819	* 1.7018	* 1.6595	* 1.7379	* 1.8675	* 1.9128	* 0.9136
	* 1.8470	* 1.6599	* 1.6048	* 1.6175	* 1.5344	* 1.3759	* 1.3370	* 2.5276
10	* 1.5607	* 1.6986	* 1.5739	* 1.6316	* 1.8124	* 1.8048	* 1.9138	* 0.8521
	* 1.7463	* 1.6095	* 1.7403	* 1.7092	* 1.5074	* 1.4751	* 1.3757	* 2.7359
11	* 1.5087	* 1.6584	* 1.6306	* 1.7876	* 1.7729	* 1.9039	* 1.2558	* 0.6018
	* 1.7542	* 1.6185	* 1.7105	* 1.5601	* 1.5691	* 1.4554	* 2.0508	* 4.0681
12	* 1.6656	* 1.7378	* 1.8122	* 1.7717	* 1.8522	* 1.8840	* 0.9642	
	* 1.5525	* 1.5345	* 1.5072	* 1.5702	* 1.4726	* 1.4604	* 2.5938	
13	* 1.8423	* 1.8682	* 1.8066	* 1.9038	* 1.8842	* 1.8972	* 0.8227	
	* 1.3846	* 1.3754	* 1.4736	* 1.4555	* 1.4603	* 1.4320	* 2.9934	
14	* 1.9057	* 1.9133	* 1.9145	* 1.2561	* 0.9630	* 0.8225	*	
	* 1.3350	* 1.3367	* 1.3752	* 2.0506	* 2.5949	* 2.9940	*	
15	* 0.8980	* 0.9144	* 0.8521	* 0.5912	* F-SUB-Q			
	* 2.5524	* 2.5262	* 2.7357	* 4.0747	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5864	* 1.5180	* 1.5507	* 1.4952	* 1.6651	* 1.8428	* 1.9124	* 0.8892 *
	* 1.8481	* 1.9342	* 1.8465	* 1.8596	* 1.6309	* 1.4521	* 1.3954	* 2.7000 *
9	* 1.5180	* 1.6718	* 1.6873	* 1.6563	* 1.7304	* 1.8691	* 1.9193	* 0.9058 *
	* 1.9342	* 1.7381	* 1.7015	* 1.7081	* 1.6209	* 1.4426	* 1.3979	* 2.6728 *
10	* 1.5507	* 1.6839	* 1.5600	* 1.6232	* 1.8155	* 1.8045	* 1.9206	* 0.8441 *
	* 1.8465	* 1.7066	* 1.8478	* 1.7838	* 1.5851	* 1.5502	* 1.4398	* 2.8972 *
11	* 1.4952	* 1.6551	* 1.6221	* 1.7871	* 1.7700	* 1.9093	* 1.2472	* 0.5952 *
	* 1.8596	* 1.7092	* 1.7849	* 1.6152	* 1.6263	* 1.5015	* 2.1251	* 4.3179 *
12	* 1.6651	* 1.7302	* 1.8152	* 1.7687	* 1.8588	* 1.8904	* 0.9558 *	
	* 1.6309	* 1.6210	* 1.5849	* 1.6275	* 1.5217	* 1.5065	* 2.7041 *	
13	* 1.8428	* 1.8698	* 1.8064	* 1.9091	* 1.8905	* 1.9096	* 0.8162 *	
	* 1.4521	* 1.4421	* 1.5485	* 1.5017	* 1.5064	* 1.4709	* 3.1155 *	
14	* 1.9124	* 1.9198	* 1.9214	* 1.2474	* 0.9546	* 0.8160 *		
	* 1.3954	* 1.3975	* 1.4392	* 2.1250	* 2.7054	* 3.1162 *		
15	* 0.8892	* 0.9066	* 0.8441	* 0.5839	* F-SUB-Q			
	* 2.7000	* 2.6713	* 2.8972	* 4.3311	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5447	* 1.4771	* 1.5044	* 1.4572	* 1.6248	* 1.8080	* 1.8730	* 0.8844 *
	* 1.9616	* 2.0494	* 2.0044	* 2.0174	* 1.7668	* 1.5634	* 1.5045	* 2.8694 *
9	* 1.4771	* 1.6248	* 1.6433	* 1.6128	* 1.6948	* 1.8351	* 1.8803	* 0.8977 *
	* 2.0494	* 1.8536	* 1.8306	* 1.8534	* 1.7516	* 1.5525	* 1.5071	* 2.8462 *
10	* 1.5044	* 1.6399	* 1.5207	* 1.5934	* 1.7748	* 1.7709	* 1.8827	* 0.8420 *
	* 2.0044	* 1.8345	* 1.9775	* 1.8841	* 1.6797	* 1.6652	* 1.5525	* 3.0664 *
11	* 1.4572	* 1.6117	* 1.5926	* 1.7472	* 1.7452	* 1.8703	* 1.2456	* 0.5932 *
	* 2.0174	* 1.8547	* 1.8851	* 1.7159	* 1.7104	* 1.5913	* 2.2001	* 4.4870 *
12	* 1.6248	* 1.6947	* 1.7745	* 1.7444	* 1.8289	* 1.8530	* 0.9537 *	
	* 1.7668	* 1.7517	* 1.6799	* 1.7112	* 1.6161	* 1.6043	* 2.8234 *	
13	* 1.8080	* 1.8359	* 1.7728	* 1.8701	* 1.8531	* 1.8753	* 0.8168 *	
	* 1.5634	* 1.5519	* 1.6634	* 1.5915	* 1.6042	* 1.5637	* 3.2468 *	
14	* 1.8730	* 1.8808	* 1.8834	* 1.2457	* 0.9525	* 0.8166 *		
	* 1.5045	* 1.5068	* 1.5518	* 2.2001	* 2.8250	* 3.2476 *		
15	* 0.8844	* 0.8985	* 0.8419	* 0.5831	* F-SUB-Q			
	* 2.8694	* 2.8448	* 3.0666	* 4.4908	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5325	* 1.4635	* 1.5014	* 1.4458	* 1.6300	* 1.8112	* 1.8859	* 0.8663
	* 2.0579	* 2.1546	* 2.0946	* 2.1561	* 1.8683	* 1.6553	* 1.5842	* 3.0972
9	* 1.4635	* 1.6218	* 1.6326	* 1.6160	* 1.6877	* 1.8390	* 1.8929	* 0.8828
	* 2.1546	* 1.9375	* 1.9239	* 1.9331	* 1.8413	* 1.6432	* 1.5873	* 3.0646
10	* 1.5014	* 1.6290	* 1.5092	* 1.5809	* 1.7834	* 1.7726	* 1.8948	* 0.8242
	* 2.0946	* 1.9283	* 2.0812	* 1.9789	* 1.7428	* 1.7380	* 1.6162	* 3.3169
11	* 1.4458	* 1.6147	* 1.5797	* 1.7501	* 1.7336	* 1.8801	* 1.2233	* 0.5795
	* 2.1561	* 1.9345	* 1.9803	* 1.7835	* 1.7939	* 1.6480	* 2.3359	* 4.7878
12	* 1.6300	* 1.6875	* 1.7831	* 1.7322	* 1.8370	* 1.8637	* 0.9332	*
	* 1.8683	* 1.8414	* 1.7431	* 1.7953	* 1.6806	* 1.6607	* 2.9942	*
13	* 1.8112	* 1.8397	* 1.7745	* 1.8798	* 1.8638	* 1.8929	* 0.7987	*
	* 1.6553	* 1.6425	* 1.7361	* 1.6482	* 1.6607	* 1.6197	* 3.4621	*
14	* 1.8859	* 1.8934	* 1.8955	* 1.2233	* 0.9319	* 0.7985	*	*
	* 1.5842	* 1.5869	* 1.6156	* 2.3360	* 2.9961	* 3.4630	*	*
15	* 0.8663	* 0.8836	* 0.8240	* 0.5671	* F-SUB-Q			
	* 3.0972	* 3.0629	* 3.3173	* 4.8135	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5022	* 1.4334	* 1.4739	* 1.4180	* 1.6083	* 1.7897	* 1.8670	* 0.8526
	* 2.0942	* 2.1858	* 2.1179	* 2.1919	* 1.9382	* 1.7460	* 1.6732	* 3.3280
9	* 1.4334	* 1.5934	* 1.6015	* 1.5920	* 1.6616	* 1.8185	* 1.8741	* 0.8689
	* 2.1858	* 1.9613	* 1.9518	* 1.9639	* 1.8851	* 1.7216	* 1.6690	* 3.2764
10	* 1.4740	* 1.5979	* 1.4802	* 1.5556	* 1.7627	* 1.7511	* 1.8763	* 0.8119
	* 2.1179	* 1.9562	* 2.1104	* 2.0205	* 1.7935	* 1.7959	* 1.6749	* 3.4901
11	* 1.4180	* 1.5908	* 1.5544	* 1.7268	* 1.7105	* 1.8604	* 1.2078	* 0.5701
	* 2.1919	* 1.9655	* 2.0220	* 1.8351	* 1.8549	* 1.7074	* 2.4216	* 5.0272
12	* 1.6083	* 1.6614	* 1.7623	* 1.7090	* 1.8200	* 1.8450	* 0.9192	*
	* 1.9382	* 1.8853	* 1.7938	* 1.8565	* 1.7698	* 1.7349	* 3.1442	*
13	* 1.7897	* 1.8193	* 1.7531	* 1.8601	* 1.8450	* 1.8789	* 0.7876	*
	* 1.7460	* 1.7209	* 1.7939	* 1.7077	* 1.7348	* 1.7062	* 3.6672	*
14	* 1.8670	* 1.8746	* 1.8770	* 1.2079	* 0.9178	* 0.7874	*	*
	* 1.6732	* 1.6686	* 1.6744	* 2.4219	* 3.1463	* 3.6682	*	*
15	* 0.8526	* 0.8697	* 0.8117	* 0.5572	* F-SUB-Q			
	* 3.3280	* 3.2747	* 3.4909	* 5.0602	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4563	* 1.3887	* 1.4248	* 1.3754	* 1.5625	* 1.7473	* 1.8206	* 0.8411 *
	* 2.0988	* 2.1917	* 2.1285	* 2.1958	* 1.9370	* 1.7361	* 1.6656	* 3.2675 *
9	* 1.3887	* 1.5420	* 1.5525	* 1.5437	* 1.6190	* 1.7764	* 1.8277	* 0.8547 *
	* 2.1917	* 1.9691	* 1.9558	* 1.9685	* 1.8807	* 1.7124	* 1.6623	* 3.2283 *
10	* 1.4248	* 1.5489	* 1.4362	* 1.5184	* 1.7152	* 1.7095	* 1.8308	* 0.8029 *
	* 2.1285	* 1.9606	* 2.1131	* 2.0173	* 1.7937	* 1.7892	* 1.6697	* 3.4285 *
11	* 1.3754	* 1.5424	* 1.5175	* 1.6800	* 1.6757	* 1.8135	* 1.1956	* 0.5632 *
	* 2.1958	* 1.9701	* 2.0189	* 1.8362	* 1.8378	* 1.7057	* 2.3800	* 4.9452 *
12	* 1.5625	* 1.6188	* 1.7148	* 1.6748	* 1.7813	* 1.7996	* 0.9093 *	
	* 1.9370	* 1.8809	* 1.7938	* 1.8388	* 1.7666	* 1.7334	* 3.0954 *	
13	* 1.7473	* 1.7772	* 1.7115	* 1.8131	* 1.7996	* 1.8366	* 0.7813 *	
	* 1.7361	* 1.7117	* 1.7872	* 1.7060	* 1.7334	* 1.7126	* 3.6155 *	
14	* 1.8206	* 1.8281	* 1.8314	* 1.1956	* 0.9079	* 0.7811 *		
	* 1.6656	* 1.6619	* 1.6691	* 2.3804	* 3.0976	* 3.6167 *		
15	* 0.8411	* 0.8555	* 0.8027	* 0.5517	* F-SUB-Q			
	* 3.2675	* 3.2265	* 3.4295	* 4.9669	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4345	* 1.3661	* 1.4111	* 1.3541	* 1.5549	* 1.7368	* 1.8188	* 0.8177 *
	* 2.0241	* 2.1091	* 2.0317	* 2.1113	* 1.8663	* 1.6743	* 1.5978	* 3.1930 *
9	* 1.3661	* 1.5280	* 1.5314	* 1.5341	* 1.5992	* 1.7667	* 1.8257	* 0.8344 *
	* 2.1091	* 1.8859	* 1.8844	* 1.8898	* 1.8266	* 1.6562	* 1.5986	* 3.1496 *
10	* 1.4111	* 1.5272	* 1.4145	* 1.4949	* 1.7093	* 1.6980	* 1.8281	* 0.7804 *
	* 2.0317	* 1.8883	* 2.0357	* 1.9573	* 1.7357	* 1.7356	* 1.6105	* 3.3519 *
11	* 1.3541	* 1.5328	* 1.4936	* 1.6686	* 1.6527	* 1.8079	* 1.1656	* 0.5463 *
	* 2.1113	* 1.8914	* 1.9589	* 1.7776	* 1.8040	* 1.6531	* 2.3415	* 4.8206 *
12	* 1.5549	* 1.5991	* 1.7090	* 1.6511	* 1.7750	* 1.7955	* 0.8831 *	
	* 1.8663	* 1.8269	* 1.7354	* 1.8060	* 1.7217	* 1.6771	* 3.0295 *	
13	* 1.7368	* 1.7675	* 1.7000	* 1.8076	* 1.7954	* 1.8393	* 0.7586 *	
	* 1.6743	* 1.6555	* 1.7336	* 1.6535	* 1.6771	* 1.6507	* 3.5285 *	
14	* 1.8188	* 1.8262	* 1.8287	* 1.1656	* 0.8817	* 0.7584 *		
	* 1.5978	* 1.5982	* 1.6100	* 2.3419	* 3.0319	* 3.5297 *		
15	* 0.8177	* 0.8351	* 0.7801	* 0.5325	* F-SUB-Q			
	* 3.1930	* 3.1478	* 3.3532	* 4.8654	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4007	* 1.3328	* 1.3806	* 1.3226	* 1.5278	* 1.7091	* 1.7942	* 0.7979
	* 1.8725	* 1.9536	* 1.8795	* 1.9607	* 1.7268	* 1.5552	* 1.4802	* 2.9735
9	* 1.3328	* 1.4959	* 1.4967	* 1.5054	* 1.5669	* 1.7392	* 1.8008	* 0.8149
	* 1.9536	* 1.7435	* 1.7463	* 1.7449	* 1.6900	* 1.5352	* 1.4790	* 2.9267
10	* 1.3806	* 1.4916	* 1.3816	* 1.4637	* 1.6823	* 1.6698	* 1.8032	* 0.7619
	* 1.8795	* 1.7503	* 1.8873	* 1.8073	* 1.5956	* 1.6035	* 1.4836	* 3.1203
11	* 1.3226	* 1.5040	* 1.4624	* 1.6389	* 1.6225	* 1.7811	* 1.1403	* 0.5323
	* 1.9607	* 1.7464	* 1.8088	* 1.6366	* 1.6614	* 1.5173	* 2.1651	* 4.4877
12	* 1.5278	* 1.5667	* 1.6819	* 1.6208	* 1.7509	* 1.7698	* 0.8622	*
	* 1.7268	* 1.6903	* 1.5954	* 1.6630	* 1.5773	* 1.5384	* 2.8099	*
13	* 1.7091	* 1.7400	* 1.6719	* 1.7807	* 1.7697	* 1.8193	* 0.7414	*
	* 1.5552	* 1.5346	* 1.6016	* 1.5177	* 1.5385	* 1.5076	* 3.2670	*
14	* 1.7942	* 1.8013	* 1.8038	* 1.1402	* 0.8608	* 0.7412	*	
	* 1.4802	* 1.4787	* 1.4832	* 2.1656	* 2.8123	* 3.2681	*	
15	* 0.7979	* 0.8157	* 0.7616	* 0.5182	* F-SUB-Q			
	* 2.9735	* 2.9251	* 3.1216	* 4.5353	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3622	* 1.2952	* 1.3429	* 1.2866	* 1.4917	* 1.6716	* 1.7568	* 0.7803
	* 1.7582	* 1.8364	* 1.7669	* 1.8450	* 1.6130	* 1.4514	* 1.3800	* 2.7816
9	* 1.2952	* 1.4562	* 1.4564	* 1.4677	* 1.5283	* 1.7021	* 1.7635	* 0.7965
	* 1.8364	* 1.6374	* 1.6412	* 1.6372	* 1.5854	* 1.4302	* 1.3776	* 2.7359
10	* 1.3429	* 1.4508	* 1.3436	* 1.4269	* 1.6442	* 1.6327	* 1.7660	* 0.7461
	* 1.7669	* 1.6456	* 1.7744	* 1.6934	* 1.4890	* 1.5000	* 1.3858	* 2.9132
11	* 1.2866	* 1.4663	* 1.4257	* 1.6010	* 1.5844	* 1.7426	* 1.1183	* 0.5207
	* 1.8450	* 1.6386	* 1.6948	* 1.5281	* 1.5511	* 1.4133	* 2.0173	* 4.2023
12	* 1.4917	* 1.5281	* 1.6438	* 1.5828	* 1.7159	* 1.7325	* 0.8438	
	* 1.6130	* 1.5856	* 1.4893	* 1.5521	* 1.4656	* 1.4323	* 2.6223	
13	* 1.6716	* 1.7029	* 1.6350	* 1.7423	* 1.7324	* 1.7844	* 0.7265	
	* 1.4514	* 1.4295	* 1.4981	* 1.4136	* 1.4324	* 1.3990	* 3.0426	
14	* 1.7568	* 1.7639	* 1.7666	* 1.1182	* 0.8424	* 0.7263		
	* 1.3800	* 1.3772	* 1.3854	* 2.0179	* 2.6247	* 3.0437		
15	* 0.7803	* 0.7973	* 0.7457	* 0.5066	* F-SUB-Q			
	* 2.7816	* 2.7344	* 2.9146	* 4.2498	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3167	* 1.2517	* 1.2949	* 1.2442	* 1.4423	* 1.6225	* 1.7033	* 0.7657
	* 1.8080	* 1.8893	* 1.8221	* 1.8910	* 1.6571	* 1.4858	* 1.4144	* 2.8229
9	* 1.2517	* 1.4051	* 1.4082	* 1.4174	* 1.4817	* 1.6529	* 1.7099	* 0.7791
	* 1.8893	* 1.6854	* 1.6842	* 1.6824	* 1.6209	* 1.4619	* 1.4107	* 2.7831
10	* 1.2949	* 1.4026	* 1.2992	* 1.3863	* 1.5916	* 1.5846	* 1.7131	* 0.7332
	* 1.8221	* 1.6904	* 1.8215	* 1.7377	* 1.5297	* 1.5330	* 1.4159	* 2.9430
11	* 1.2442	* 1.4160	* 1.3852	* 1.5493	* 1.5430	* 1.6894	* 1.0998	* 0.5113
	* 1.8910	* 1.6840	* 1.7392	* 1.5688	* 1.5779	* 1.4480	* 2.0421	* 4.2583
12	* 1.4423	* 1.4815	* 1.5912	* 1.5420	* 1.6684	* 1.6799	* 0.8298	*
	* 1.6571	* 1.6211	* 1.5300	* 1.5790	* 1.4928	* 1.4650	* 2.6521	*
13	* 1.6225	* 1.6537	* 1.5867	* 1.6891	* 1.6798	* 1.7330	* 0.7160	*
	* 1.4858	* 1.4612	* 1.5311	* 1.4483	* 1.4651	* 1.4267	* 3.0677	*
14	* 1.7033	* 1.7104	* 1.7137	* 1.0996	* 0.8284	* 0.7157	*	*
	* 1.4144	* 1.4103	* 1.4155	* 2.0427	* 2.6545	* 3.0688	*	*
15	* 0.7657	* 0.7798	* 0.7329	* 0.4989	* F-SUB-Q			
	* 2.8229	* 2.7816	* 2.9445	* 4.2934	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2951	* 1.2298	* 1.2818	* 1.2225	* 1.4301	* 1.6042	* 1.6931	* 0.7388
	* 1.6918	* 1.7739	* 1.7004	* 1.7837	* 1.5515	* 1.3948	* 1.3209	* 2.7212
9	* 1.2298	* 1.3911	* 1.3862	* 1.4047	* 1.4571	* 1.6350	* 1.6993	* 0.7553
	* 1.7739	* 1.5730	* 1.5827	* 1.5709	* 1.5258	* 1.3709	* 1.3170	* 2.6692
10	* 1.2818	* 1.3805	* 1.2768	* 1.3591	* 1.5791	* 1.5647	* 1.7013	* 0.7069
	* 1.7004	* 1.5877	* 1.7139	* 1.6334	* 1.4244	* 1.4359	* 1.3189	* 2.8335
11	* 1.2225	* 1.4033	* 1.3578	* 1.5356	* 1.5145	* 1.6756	* 1.0637	* 0.4921
	* 1.7837	* 1.5724	* 1.6349	* 1.4678	* 1.4912	* 1.3509	* 1.9508	* 4.0944
12	* 1.4301	* 1.4569	* 1.5787	* 1.5130	* 1.6518	* 1.6666	* 0.7996	*
	* 1.5515	* 1.5261	* 1.4248	* 1.4927	* 1.3905	* 1.3674	* 2.5535	*
13	* 1.6042	* 1.6358	* 1.5670	* 1.6752	* 1.6665	* 1.7241	* 0.6888	*
	* 1.3948	* 1.3702	* 1.4339	* 1.3512	* 1.3675	* 1.3266	* 2.9600	*
14	* 1.6931	* 1.6998	* 1.7019	* 1.0635	* 0.7982	* 0.6886	*	*
	* 1.3209	* 1.3167	* 1.3185	* 1.9513	* 2.5560	* 2.9610	*	*
15	* 0.7388	* 0.7559	* 0.7066	* 0.4778	* F-SUB-Q			
	* 2.7212	* 2.6678	* 2.8350	* 4.1491	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2616	* 1.1974	* 1.2492	* 1.1896	* 1.3942	* 1.5652	* 1.6525	* 0.7174 *
	* 1.6175	* 1.7005	* 1.6316	* 1.7172	* 1.4922	* 1.3401	* 1.2686	* 2.6330 *
9	* 1.1974	* 1.3566	* 1.3509	* 1.3685	* 1.4184	* 1.5954	* 1.6584	* 0.7335 *
	* 1.7005	* 1.5082	* 1.5196	* 1.5089	* 1.4670	* 1.3162	* 1.2645	* 2.5811 *
10	* 1.2492	* 1.3453	* 1.2435	* 1.3223	* 1.5390	* 1.5253	* 1.6597	* 0.6865 *
	* 1.6316	* 1.5240	* 1.6466	* 1.5678	* 1.3621	* 1.3773	* 1.2644	* 2.7374 *
11	* 1.1896	* 1.3671	* 1.3210	* 1.4963	* 1.4747	* 1.6332	* 1.0353	* 0.4776 *
	* 1.7172	* 1.5103	* 1.5693	* 1.4028	* 1.4254	* 1.2890	* 1.8716	* 3.9512 *
12	* 1.3942	* 1.4182	* 1.5386	* 1.4731	* 1.6118	* 1.6244	* 0.7765 *	
	* 1.4922	* 1.4672	* 1.3625	* 1.4269	* 1.3236	* 1.3036	* 2.4487 *	
13	* 1.5652	* 1.5962	* 1.5276	* 1.6328	* 1.6243	* 1.6816	* 0.6685 *	
	* 1.3401	* 1.3155	* 1.3754	* 1.2893	* 1.3037	* 1.2669	* 2.8432 *	
14	* 1.6525	* 1.6589	* 1.6603	* 1.0351	* 0.7751	* 0.6682 *		
	* 1.2686	* 1.2642	* 1.2640	* 1.8721	* 2.4511	* 2.8443 *		
15	* 0.7174	* 0.7341	* 0.6861	* 0.4634	* F-SUB-Q			
	* 2.6330	* 2.5797	* 2.7390	* 4.0065	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2148	* 1.1531	* 1.1942	* 1.1448	* 1.3305	* 1.5010	* 1.5748	* 0.7008 *
	* 1.5871	* 1.6692	* 1.6148	* 1.6887	* 1.4809	* 1.3226	* 1.2599	* 2.5576 *
9	* 1.1531	* 1.2982	* 1.3007	* 1.3049	* 1.3634	* 1.5299	* 1.5807	* 0.7132 *
	* 1.6692	* 1.4905	* 1.4930	* 1.4969	* 1.4435	* 1.2986	* 1.2555	* 2.5183 *
10	* 1.1942	* 1.2954	* 1.1978	* 1.2729	* 1.4659	* 1.4628	* 1.5809	* 0.6710 *
	* 1.6148	* 1.4970	* 1.6173	* 1.5413	* 1.3490	* 1.3574	* 1.2545	* 2.6552 *
11	* 1.1448	* 1.3036	* 1.2719	* 1.4260	* 1.4206	* 1.5561	* 1.0130	* 0.4674 *
	* 1.6887	* 1.4984	* 1.5427	* 1.3857	* 1.3926	* 1.2745	* 1.8073	* 3.8254 *
12	* 1.3305	* 1.3632	* 1.4656	* 1.4196	* 1.5433	* 1.5473	* 0.7599 *	
	* 1.4809	* 1.4437	* 1.3494	* 1.3935	* 1.2976	* 1.2872	* 2.3598 *	
13	* 1.5010	* 1.5307	* 1.4648	* 1.5557	* 1.5472	* 1.5972	* 0.6542 *	
	* 1.3226	* 1.2980	* 1.3557	* 1.2749	* 1.2873	* 1.2512	* 2.7345 *	
14	* 1.5748	* 1.5811	* 1.5814	* 1.0128	* 0.7586	* 0.6539 *		
	* 1.2599	* 1.2551	* 1.2541	* 1.8079	* 2.3619	* 2.7355 *		
15	* 0.7008	* 0.7139	* 0.6707	* 0.4556	* F-SUB-Q			
	* 2.5576	* 2.5169	* 2.6568	* 3.8615	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1885	* 1.1283	* 1.1709	* 1.1252	* 1.2964	* 1.4603	* 1.5279	* 0.6701
	* 1.5501	* 1.6304	* 1.5744	* 1.6427	* 1.4530	* 1.2989	* 1.2408	* 2.5623
9	* 1.1283	* 1.2709	* 1.2757	* 1.2737	* 1.3266	* 1.4869	* 1.5326	* 0.6844
	* 1.6304	* 1.4548	* 1.4540	* 1.4655	* 1.4173	* 1.2762	* 1.2370	* 2.5134
10	* 1.1709	* 1.2705	* 1.1725	* 1.2361	* 1.4231	* 1.4197	* 1.5279	* 0.6389
	* 1.5744	* 1.4580	* 1.5793	* 1.5129	* 1.3254	* 1.3353	* 1.2394	* 2.6705
11	* 1.1252	* 1.2724	* 1.2349	* 1.3871	* 1.3745	* 1.5064	* 0.9670	* 0.4449
	* 1.6427	* 1.4669	* 1.5143	* 1.3613	* 1.3747	* 1.2547	* 1.8084	* 3.8496
12	* 1.2964	* 1.3264	* 1.4227	* 1.3730	* 1.4980	* 1.4979	* 0.7236	*
	* 1.4530	* 1.4176	* 1.3258	* 1.3761	* 1.2715	* 1.2662	* 2.3657	*
13	* 1.4603	* 1.4876	* 1.4217	* 1.5060	* 1.4978	* 1.5396	* 0.6188	*
	* 1.2989	* 1.2756	* 1.3335	* 1.2551	* 1.2663	* 1.2341	* 2.7563	*
14	* 1.5279	* 1.5330	* 1.5283	* 0.9668	* 0.7223	* 0.6186	*	*
	* 1.2408	* 1.2367	* 1.2391	* 1.8090	* 2.3680	* 2.7574	*	*
15	* 0.6701	* 0.6851	* 0.6385	* 0.4318	* F-SUB-Q			
	* 2.5623	* 2.5119	* 2.6722	* 3.9026	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1163	* 1.0726	* 1.1225	* 1.0918	* 1.2135	* 1.3633	* 1.4193	* 0.6412
	* 1.5931	* 1.6548	* 1.5891	* 1.6337	* 1.4971	* 1.3412	* 1.2877	* 2.5876
9	* 1.0726	* 1.1961	* 1.2105	* 1.2024	* 1.2493	* 1.3857	* 1.4219	* 0.6528
	* 1.6548	* 1.4912	* 1.4791	* 1.4970	* 1.4512	* 1.3201	* 1.2854	* 2.5475
10	* 1.1225	* 1.2058	* 1.1051	* 1.1730	* 1.3260	* 1.3179	* 1.4056	* 0.6033
	* 1.5891	* 1.4841	* 1.6174	* 1.5369	* 1.3700	* 1.3867	* 1.2987	* 2.7342
11	* 1.0918	* 1.2012	* 1.1719	* 1.2989	* 1.2920	* 1.3986	* 0.9087	* 0.4163
	* 1.6337	* 1.4985	* 1.5383	* 1.3945	* 1.4085	* 1.3012	* 1.8571	* 3.9810
12	* 1.2135	* 1.2491	* 1.3257	* 1.2906	* 1.4022	* 1.3947	* 0.6874	*
	* 1.4971	* 1.4514	* 1.3704	* 1.4100	* 1.3063	* 1.3088	* 2.4026	*
13	* 1.3633	* 1.3863	* 1.3196	* 1.3983	* 1.3946	* 1.4091	* 0.5783	*
	* 1.3412	* 1.3195	* 1.3850	* 1.3015	* 1.3089	* 1.2970	* 2.8457	*
14	* 1.4193	* 1.4222	* 1.4059	* 0.9085	* 0.6862	* 0.5781	*	*
	* 1.2877	* 1.2851	* 1.2984	* 1.8578	* 2.4049	* 2.8469	*	*
15	* 0.6412	* 0.6534	* 0.6029	* 0.4037	* F-SUB-Q			
	* 2.5876	* 2.5462	* 2.7361	* 4.0390	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9211	* 0.9416	* 1.1578	* 0.9634	* 1.2119	* 1.1227	* 1.2902	* 0.5622
	* 1.8787	* 1.8359	* 1.4939	* 1.8049	* 1.4497	* 1.5814	* 1.3751	* 2.8774
9	* 0.9416	* 1.1626	* 1.0319	* 1.1958	* 1.0350	* 1.1394	* 1.2808	* 0.5690
	* 1.8359	* 1.4867	* 1.6821	* 1.4581	* 1.6943	* 1.5579	* 1.3853	* 2.8496
10	* 1.1578	* 1.0302	* 0.9127	* 1.0139	* 1.2655	* 1.0972	* 1.1980	* 0.5154
	* 1.4939	* 1.6841	* 1.9047	* 1.7320	* 1.3912	* 1.6106	* 1.4804	* 3.1210
11	* 0.9634	* 1.1946	* 1.0132	* 1.2713	* 1.0826	* 1.2514	* 0.7731	* 0.3484
	* 1.8049	* 1.4596	* 1.7333	* 1.3846	* 1.6319	* 1.4118	* 2.1242	* 4.6443
12	* 1.2119	* 1.0342	* 1.2652	* 1.0819	* 1.1722	* 1.2767	* 0.6071	*
	* 1.4497	* 1.6956	* 1.3916	* 1.6330	* 1.5160	* 1.3892	* 2.6488	*
13	* 1.1227	* 1.1399	* 1.0986	* 1.2512	* 1.2765	* 1.1454	* 0.4818	*
	* 1.5814	* 1.5573	* 1.6086	* 1.4121	* 1.3895	* 1.5511	* 3.3279	*
14	* 1.2902	* 1.2810	* 1.1981	* 0.7729	* 0.6061	* 0.4816	*	*
	* 1.3751	* 1.3850	* 1.4804	* 2.1251	* 2.6510	* 3.3292	*	*
15	* 0.5622	* 0.5694	* 0.5150	* 0.3380	F-SUB-Q			
	* 2.8774	* 2.8483	* 3.1233	* 4.7093	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3688	* 0.3996	* 0.4792	* 0.4161	* 0.4941	* 0.4340	* 0.4642	* 0.2362
	* 4.5715	* 4.2206	* 3.5188	* 4.0824	* 3.4569	* 3.9803	* 3.7225	* 6.6940
9	* 0.3996	* 0.4698	* 0.4192	* 0.4869	* 0.4221	* 0.4373	* 0.4596	* 0.2355
	* 4.2206	* 3.5858	* 4.0387	* 3.4849	* 4.0493	* 3.9512	* 3.7607	* 6.7294
10	* 0.4792	* 0.4184	* 0.3856	* 0.4263	* 0.5056	* 0.4291	* 0.4236	* 0.2148
	* 3.5188	* 4.0463	* 4.4039	* 4.0156	* 3.3864	* 4.0131	* 4.0795	* 7.3201
11	* 0.4161	* 0.4864	* 0.4260	* 0.5006	* 0.4382	* 0.4785	* 0.3191	* 0.1457
	* 4.0824	* 3.4885	* 4.0183	* 3.4168	* 3.9253	* 3.6004	* 5.0185	* 10.8724
12	* 0.4941	* 0.4218	* 0.5055	* 0.4378	* 0.4441	* 0.4612	* 0.2545	*
	* 3.4569	* 4.0521	* 3.3877	* 3.9284	* 3.8946	* 3.7458	* 6.1723	*
13	* 0.4340	* 0.4375	* 0.4294	* 0.4784	* 0.4611	* 0.4046	* 0.1984	*
	* 3.9803	* 3.9500	* 4.0103	* 3.6012	* 3.7466	* 4.2784	* 7.8988	*
14	* 0.4642	* 0.4596	* 0.4236	* 0.3190	* 0.2542	* 0.1983	*	*
	* 3.7225	* 3.7600	* 4.0798	* 5.0210	* 6.1751	* 7.9024	*	*
15	* 0.2362	* 0.2357	* 0.2147	* 0.1427	F-SUB-Q			
	* 6.6940	* 6.7262	* 7.3254	* 10.9212	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5220	* 0.5980	* 0.7090	* 0.6143	* 0.7073	* 0.6098	* 0.6266	* 0.3329
	* 5.0803	* 4.7784	* 3.8468	* 4.3120	* 3.6953	* 4.2989	* 4.2059	* 7.1434
9	* 0.5980	* 0.6935	* 0.6325	* 0.7074	* 0.6108	* 0.6013	* 0.6195	* 0.3289
	* 4.7784	* 4.1087	* 4.2851	* 3.7722	* 4.3194	* 4.3849	* 4.2817	* 7.2871
10	* 0.7090	* 0.6319	* 0.5772	* 0.6041	* 0.7042	* 0.5998	* 0.5709	* 0.2958
	* 3.8468	* 4.2879	* 4.8466	* 4.5138	* 3.9195	* 4.5885	* 4.7189	* 8.0820
11	* 0.6143	* 0.7070	* 0.6038	* 0.6931	* 0.6117	* 0.6395	* 0.4291	* 0.2037
	* 4.3120	* 3.7736	* 4.5159	* 4.1533	* 4.7086	* 4.4550	* 6.1593	* 12.2569
12	* 0.7073	* 0.6107	* 0.7040	* 0.6114	* 0.5541	* 0.5710	* 0.3439	
	* 3.6953	* 4.3200	* 3.9204	* 4.7107	* 4.6778	* 4.5875	* 7.3182	
13	* 0.6098	* 0.6013	* 0.6000	* 0.6395	* 0.5710	* 0.5008	* 0.2601	
	* 4.2989	* 4.3846	* 4.5866	* 4.4550	* 4.5871	* 5.1483	* 9.3315	
14	* 0.6266	* 0.6196	* 0.5711	* 0.4292	* 0.3438	* 0.2601		
	* 4.2059	* 4.2807	* 4.7176	* 6.1581	* 7.3139	* 9.3324		
15	* 0.3329	* 0.3291	* 0.2958	* 0.2008	* F-SUB-Q			
	* 7.1434	* 7.2799	* 8.0810	* 12.2326	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3064	* 1.3680	* 1.6167	* 1.3820	* 1.6271	* 1.4846	* 1.6350	* 0.7947
	* 2.2523	* 2.1786	* 1.7469	* 2.0038	* 1.6690	* 1.8339	* 1.6757	* 3.1145
9	* 1.3680	* 1.6221	* 1.4970	* 1.6258	* 1.4434	* 1.4895	* 1.6214	* 0.7900
	* 2.1786	* 1.8109	* 1.8786	* 1.7003	* 1.9179	* 1.8367	* 1.6858	* 3.1344
10	* 1.6167	* 1.4957	* 1.3257	* 1.3885	* 1.6478	* 1.4713	* 1.5159	* 0.7109
	* 1.7469	* 1.8802	* 2.1812	* 2.0378	* 1.7335	* 1.9486	* 1.8439	* 3.4855
11	* 1.3820	* 1.6250	* 1.3881	* 1.6614	* 1.4491	* 1.5846	* 1.0314	* 0.4906
	* 2.0038	* 1.7009	* 2.0387	* 1.7839	* 2.0579	* 1.8642	* 2.6649	* 5.2854
12	* 1.6271	* 1.4430	* 1.6476	* 1.4482	* 1.4143	* 1.5463	* 0.8223	
	* 1.6690	* 1.9182	* 1.7335	* 2.0589	* 1.9423	* 1.8114	* 3.1803	
13	* 1.4846	* 1.4898	* 1.4722	* 1.5847	* 1.5464	* 1.3601	* 0.6411	
	* 1.8339	* 1.8363	* 1.9475	* 1.8641	* 1.8112	* 2.0270	* 3.9407	
14	* 1.6350	* 1.6218	* 1.5164	* 1.0318	* 0.8219	* 0.6411		
	* 1.6757	* 1.6854	* 1.8433	* 2.6642	* 3.1794	* 3.9411		
15	* 0.7947	* 0.7906	* 0.7111	* 0.4842	* F-SUB-Q			
	* 3.1145	* 3.1330	* 3.4848	* 5.2696	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5960	* 1.5500	* 1.5394	* 1.5538	* 1.5947	* 1.7721	* 1.7770	* 0.9085
	* 1.9629	* 2.0019	* 1.8789	* 1.8310	* 1.7480	* 1.5693	* 1.5624	* 2.7563
9	* 1.5500	* 1.6445	* 1.7188	* 1.6138	* 1.7148	* 1.7886	* 1.7805	* 0.9139
	* 2.0019	* 1.8215	* 1.7088	* 1.7722	* 1.6761	* 1.5633	* 1.5655	* 2.7573
10	* 1.5394	* 1.7165	* 1.5821	* 1.6105	* 1.6933	* 1.7539	* 1.7557	* 0.8440
	* 1.8789	* 1.7123	* 1.8586	* 1.8272	* 1.7177	* 1.6664	* 1.6305	* 3.0075
11	* 1.5538	* 1.6129	* 1.6098	* 1.6933	* 1.7141	* 1.7548	* 1.2312	* 0.5940
	* 1.8310	* 1.7729	* 1.8281	* 1.8040	* 1.7831	* 1.7264	* 2.2944	* 4.4848
12	* 1.5947	* 1.7147	* 1.6929	* 1.7133	* 1.7471	* 1.7265	* 0.9517	*
	* 1.7480	* 1.6762	* 1.7176	* 1.7836	* 1.6806	* 1.7109	* 2.8360	*
13	* 1.7721	* 1.7890	* 1.7551	* 1.7547	* 1.7269	* 1.6726	* 0.7877	*
	* 1.5693	* 1.5629	* 1.6653	* 1.7264	* 1.7105	* 1.7204	* 3.3134	*
14	* 1.7770	* 1.7809	* 1.7564	* 1.2317	* 0.9511	* 0.7876	*	*
	* 1.5624	* 1.5652	* 1.6298	* 2.2936	* 2.8356	* 3.3138	*	*
15	* 0.9085	* 0.9147	* 0.8443	* 0.5888	* F-SUB-Q			
	* 2.7563	* 2.7561	* 3.0066	* 4.4512	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7119	* 1.6442	* 1.6370	* 1.6154	* 1.7319	* 1.9310	* 1.9538	* 0.9417
	* 1.8943	* 1.9851	* 1.8368	* 1.8124	* 1.6604	* 1.4768	* 1.4566	* 2.7244
9	* 1.6442	* 1.7681	* 1.8286	* 1.7209	* 1.8403	* 1.9530	* 1.9601	* 0.9549
	* 1.9851	* 1.7432	* 1.6558	* 1.7182	* 1.6076	* 1.4694	* 1.4590	* 2.7085
10	* 1.6370	* 1.8257	* 1.6884	* 1.7156	* 1.8557	* 1.9027	* 1.9485	* 0.8838
	* 1.8368	* 1.6597	* 1.7916	* 1.7867	* 1.6171	* 1.5759	* 1.5101	* 2.9528
11	* 1.6154	* 1.7201	* 1.7148	* 1.8356	* 1.8526	* 1.9354	* 1.3034	* 0.6249
	* 1.8124	* 1.7191	* 1.7878	* 1.7150	* 1.6975	* 1.6175	* 2.2335	* 4.3886
12	* 1.7319	* 1.8403	* 1.8556	* 1.8516	* 1.9089	* 1.9057	* 0.9969	*
	* 1.6604	* 1.6076	* 1.6169	* 1.6981	* 1.5883	* 1.6073	* 2.8031	*
13	* 1.9310	* 1.9535	* 1.9043	* 1.9354	* 1.9060	* 1.8834	* 0.8379	*
	* 1.4768	* 1.4690	* 1.5745	* 1.6175	* 1.6070	* 1.5832	* 3.2270	*
14	* 1.9538	* 1.9606	* 1.9493	* 1.3040	* 0.9961	* 0.8378	*	*
	* 1.4566	* 1.4587	* 1.5094	* 2.2326	* 2.8031	* 3.2274	*	*
15	* 0.9417	* 0.9557	* 0.8841	* 0.6181	* F-SUB-Q			
	* 2.7244	* 2.7071	* 2.9518	* 4.3655	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7237	* 1.6529	* 1.6589	* 1.6202	* 1.7754	* 1.9806	* 2.0222	* 0.9580
	* 1.9554	* 2.0518	* 1.8840	* 1.8690	* 1.6767	* 1.4899	* 1.4566	* 2.7764
9	* 1.6529	* 1.7960	* 1.8401	* 1.7585	* 1.8720	* 2.0039	* 2.0291	* 0.9726
	* 2.0518	* 1.7850	* 1.7068	* 1.7453	* 1.6337	* 1.4823	* 1.4588	* 2.7548
10	* 1.6589	* 1.8369	* 1.6987	* 1.7444	* 1.9159	* 1.9435	* 2.0235	* 0.9034
	* 1.8840	* 1.7113	* 1.8505	* 1.8256	* 1.6257	* 1.5850	* 1.5029	* 2.9936
11	* 1.6202	* 1.7576	* 1.7435	* 1.8914	* 1.8957	* 2.0067	* 1.3370	* 0.6365
	* 1.8690	* 1.7462	* 1.8268	* 1.7309	* 1.7223	* 1.6213	* 2.2458	* 4.4444
12	* 1.7754	* 1.8719	* 1.9157	* 1.8946	* 1.9618	* 1.9788	* 1.0199	*
	* 1.6767	* 1.6337	* 1.6255	* 1.7229	* 1.5981	* 1.6105	* 2.8520	*
13	* 1.9806	* 2.0045	* 1.9453	* 2.0067	* 1.9791	* 1.9734	* 0.8628	*
	* 1.4899	* 1.4819	* 1.5834	* 1.6213	* 1.6102	* 1.5732	* 3.2653	*
14	* 2.0222	* 2.0297	* 2.0245	* 1.3375	* 1.0190	* 0.8627	*	*
	* 1.4566	* 1.4584	* 1.5022	* 2.2450	* 2.8523	* 3.2658	*	*
15	* 0.9580	* 0.9734	* 0.9037	* 0.6285	* F-SUB-Q			
	* 2.7764	* 2.7533	* 2.9926	* 4.4290	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7028	* 1.6317	* 1.6449	* 1.6032	* 1.7762	* 1.9858	* 2.0367	* 0.9627
	* 2.0513	* 2.1526	* 1.9730	* 1.9609	* 1.7368	* 1.5372	* 1.4966	* 2.8654
9	* 1.6317	* 1.7824	* 1.8189	* 1.7557	* 1.8672	* 2.0116	* 2.0444	* 0.9766
	* 2.1526	* 1.8694	* 1.7904	* 1.8183	* 1.7015	* 1.5282	* 1.4983	* 2.8416
10	* 1.6449	* 1.8155	* 1.6792	* 1.7400	* 1.9260	* 1.9427	* 2.0414	* 0.9109
	* 1.9730	* 1.7954	* 1.9434	* 1.9028	* 1.6862	* 1.6387	* 1.5434	* 3.0725
11	* 1.6032	* 1.7547	* 1.7393	* 1.8986	* 1.9021	* 2.0233	* 1.3493	* 0.6396
	* 1.9609	* 1.8194	* 1.9040	* 1.7996	* 1.7954	* 1.6770	* 2.3158	* 4.5950
12	* 1.7762	* 1.8671	* 1.9258	* 1.9015	* 1.9773	* 1.9982	* 1.0290	*
	* 1.7368	* 1.7015	* 1.6859	* 1.7965	* 1.6614	* 1.6735	* 2.9657	*
13	* 1.9858	* 2.0123	* 1.9447	* 2.0232	* 1.9985	* 2.0040	* 0.8743	*
	* 1.5372	* 1.5276	* 1.6370	* 1.6771	* 1.6732	* 1.6267	* 3.3885	*
14	* 2.0367	* 2.0450	* 2.0424	* 1.3498	* 1.0279	* 0.8741	*	*
	* 1.4966	* 1.4978	* 1.5427	* 2.3151	* 2.9663	* 3.3891	*	*
15	* 0.9627	* 0.9775	* 0.9111	* 0.6315	* F-SUB-Q			
	* 2.8654	* 2.8399	* 3.0717	* 4.5794	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6842	* 1.6117	* 1.6357	* 1.5878	* 1.7794	* 1.9904	* 2.0520	* 0.9530 *
	* 2.1481	* 2.2521	* 2.0860	* 2.0809	* 1.8200	* 1.6067	* 1.5556	* 3.0270 *
9	* 1.6117	* 1.7720	* 1.8008	* 1.7560	* 1.8602	* 2.0172	* 2.0593	* 0.9686 *
	* 2.2521	* 1.9778	* 1.9011	* 1.9184	* 1.7961	* 1.5970	* 1.5581	* 2.9996 *
10	* 1.6357	* 1.7973	* 1.6622	* 1.7324	* 1.9357	* 1.9455	* 2.0573	* 0.9019 *
	* 2.0860	* 1.9067	* 2.0668	* 2.0214	* 1.7688	* 1.7178	* 1.6078	* 3.2541 *
11	* 1.5878	* 1.7548	* 1.7314	* 1.9036	* 1.9001	* 2.0368	* 1.3388	* 0.6317 *
	* 2.0809	* 1.9196	* 2.0229	* 1.8721	* 1.8690	* 1.7375	* 2.4549	* 4.8888 *
12	* 1.7794	* 1.8601	* 1.9355	* 1.8988	* 1.9915	* 2.0142	* 1.0192	*
	* 1.8200	* 1.7959	* 1.7685	* 1.8702	* 1.7332	* 1.7401	* 3.1397	*
13	* 1.9904	* 2.0180	* 1.9475	* 2.0367	* 2.0144	* 2.0303	* 0.8678	*
	* 1.6067	* 1.5964	* 1.7160	* 1.7375	* 1.7399	* 1.6915	* 3.5970	*
14	* 2.0520	* 2.0599	* 2.0583	* 1.3392	* 1.0180	* 0.8677	*	
	* 1.5556	* 1.5576	* 1.6070	* 2.4543	* 3.1407	* 3.5977	*	
15	* 0.9530	* 0.9695	* 0.9021	* 0.6215	* F-SUB-Q			
	* 3.0270	* 2.9978	* 3.2534	* 4.8894	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6509	* 1.5785	* 1.6077	* 1.5591	* 1.7605	* 1.9718	* 2.0389	* 0.9396 *
	* 2.3011	* 2.4167	* 2.2599	* 2.2571	* 1.9569	* 1.7219	* 1.6617	* 3.2568 *
9	* 1.5785	* 1.7422	* 1.7671	* 1.7346	* 1.8348	* 2.0001	* 2.0465	* 0.9556 *
	* 2.4167	* 2.1444	* 2.0646	* 2.0739	* 1.9391	* 1.7111	* 1.6649	* 3.2275 *
10	* 1.6077	* 1.7635	* 1.6308	* 1.7081	* 1.9198	* 1.9274	* 2.0449	* 0.8902 *
	* 2.2599	* 2.0711	* 2.2471	* 2.1903	* 1.9037	* 1.8453	* 1.7199	* 3.5026 *
11	* 1.5591	* 1.7334	* 1.7070	* 1.8841	* 1.8801	* 2.0231	* 1.3234	* 0.6221 *
	* 2.2570	* 2.0753	* 2.1921	* 1.9815	* 1.9797	* 1.8319	* 2.6087	* 5.2791 *
12	* 1.7605	* 1.8347	* 1.9196	* 1.8788	* 1.9808	* 2.0027	* 1.0062	*
	* 1.9569	* 1.9389	* 1.9033	* 1.9811	* 1.8375	* 1.8366	* 3.3289	*
13	* 1.9718	* 2.0010	* 1.9295	* 2.0230	* 2.0029	* 2.0262	* 0.8584	*
	* 1.7219	* 1.7103	* 1.8432	* 1.8320	* 1.8364	* 1.7912	* 3.8405	*
14	* 2.0389	* 2.0471	* 2.0458	* 1.3237	* 1.0050	* 0.8582	*	
	* 1.6617	* 1.6644	* 1.7190	* 2.6082	* 3.3302	* 3.8413	*	
15	* 0.9396	* 0.9565	* 0.8903	* 0.6112	* F-SUB-Q			
	* 3.2568	* 3.2255	* 3.5021	* 5.2874	* M-SUB-Q			

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

	H	G	F	E	D	C	B	A
8	1.5586	1.4878	1.5180	1.4755	1.6799	1.8908	1.9584	0.9070
	2.7921	2.9207	2.7377	2.7122	2.3300	2.0454	1.9709	3.8217
9	1.4878	1.6474	1.6698	1.6501	1.7498	1.9202	1.9660	0.9203
	2.9207	2.6186	2.5125	2.4905	2.3144	2.0298	1.9735	3.7877
10	1.5180	1.6662	1.5424	1.6354	1.8381	1.8479	1.9659	0.8623
	2.7377	2.5206	2.7350	2.6222	2.2724	2.1908	2.0339	4.0767
11	1.4755	1.6488	1.6345	1.8013	1.8074	1.9426	1.2849	0.6016
	2.7122	2.4923	2.6241	2.3794	2.3589	2.1876	3.0445	6.1291
12	1.6799	1.7497	1.8378	1.8066	1.9110	1.9259	0.9755	
	2.3300	2.3142	2.2719	2.3600	2.2077	2.2063	3.9478	
13	1.8908	1.9210	1.8501	1.9423	1.9260	1.9575	0.8354	
	2.0454	2.0289	2.1883	2.1877	2.2062	2.1359	4.5285	
14	1.9584	1.9666	1.9668	1.2851	0.9742	0.8352		
	1.9710	1.9729	2.0330	3.0443	3.9499	4.5296		
15	0.9070	0.9211	0.8622	0.5914	F-SUB-Q			
	3.8217	3.7856	4.0769	6.1343	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5289	* 1.4576	* 1.4985	* 1.4490	* 1.6656	* 1.8709	* 1.9481	* 0.8788
	* 3.0891	* 3.2379	* 2.9126	* 2.9071	* 2.4717	* 2.1684	* 2.0763	* 4.1112
9	* 1.4576	* 1.6263	* 1.6401	* 1.6344	* 1.7219	* 1.9004	* 1.9551	* 0.8951
	* 3.2379	* 2.7930	* 2.6868	* 2.6573	* 2.4808	* 2.1541	* 2.0817	* 4.0708
10	* 1.4985	* 1.6360	* 1.5134	* 1.6008	* 1.8249	* 1.8269	* 1.9547	* 0.8347
	* 2.9126	* 2.6958	* 2.9290	* 2.8349	* 2.4196	* 2.3385	* 2.1561	* 4.4182
11	* 1.4490	* 1.6331	* 1.5996	* 1.7834	* 1.7755	* 1.9293	* 1.2473	* 0.5814
	* 2.9071	* 2.6593	* 2.8374	* 2.6062	* 2.6052	* 2.3873	* 3.3786	* 6.6719
12	* 1.6656	* 1.7217	* 1.8246	* 1.7740	* 1.8960	* 1.9140	* 0.9440	*
	* 2.4717	* 2.4806	* 2.4191	* 2.6073	* 2.4221	* 2.4055	* 4.4014	*
13	* 1.8709	* 1.9013	* 1.8291	* 1.9291	* 1.9141	* 1.9523	* 0.8079	*
	* 2.1684	* 2.1531	* 2.3357	* 2.3876	* 2.4054	* 2.3357	* 5.0918	*
14	* 1.9481	* 1.9557	* 1.9556	* 1.2475	* 0.9427	* 0.8077	*	*
	* 2.0763	* 2.0811	* 2.1551	* 3.3785	* 4.4040	* 5.0931	*	*
15	* 0.8788	* 0.8959	* 0.8347	* 0.5690	F-SUB-Q			
	* 4.1112	* 4.0683	* 4.4186	* 6.7077	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4814	* 1.4115	* 1.4545	* 1.4058	* 1.6236	* 1.8253	* 1.9044	* 0.8551
	* 3.1236	* 3.2634	* 3.1118	* 3.1220	* 2.6759	* 2.3449	* 2.2400	* 4.4436
9	* 1.4115	* 1.5795	* 1.5907	* 1.5914	* 1.6746	* 1.8555	* 1.9115	* 0.8712
	* 3.2634	* 2.9070	* 2.8827	* 2.8570	* 2.6949	* 2.3287	* 2.2463	* 4.3994
10	* 1.4545	* 1.5861	* 1.4670	* 1.5565	* 1.7815	* 1.7822	* 1.9113	* 0.8131
	* 3.1118	* 2.8926	* 3.1269	* 2.9658	* 2.6065	* 2.5329	* 2.3271	* 4.7705
11	* 1.4058	* 1.5901	* 1.5553	* 1.7383	* 1.7302	* 1.8853	* 1.2172	* 0.5659
	* 3.1220	* 2.8594	* 2.9682	* 2.6801	* 2.6956	* 2.4773	* 3.5395	* 7.2186
12	* 1.6236	* 1.6745	* 1.7812	* 1.7288	* 1.8546	* 1.8714	* 0.9195	*
	* 2.6759	* 2.6946	* 2.6059	* 2.6979	* 2.5639	* 2.5194	* 4.6383	*
13	* 1.8253	* 1.8564	* 1.7844	* 1.8850	* 1.8715	* 1.9134	* 0.7878	*
	* 2.3449	* 2.3277	* 2.5298	* 2.4777	* 2.5194	* 2.4871	* 5.4369	*
14	* 1.9044	* 1.9121	* 1.9121	* 1.2173	* 0.9181	* 0.7876	*	*
	* 2.2400	* 2.2457	* 2.3261	* 3.5397	* 4.6413	* 5.4385	*	*
15	* 0.8551	* 0.8720	* 0.8130	* 0.5531	F-SUB-Q			
	* 4.4436	* 4.3967	* 4.7712	* 7.2664	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4196	* 1.3518	* 1.3900	* 1.3488	* 1.5580	* 1.7591	* 1.8334	* 0.8340
	* 3.1637	* 3.3066	* 3.0300	* 3.0340	* 2.6100	* 2.3052	* 2.2114	* 4.3683
9	* 1.3518	* 1.5104	* 1.5253	* 1.5247	* 1.6116	* 1.7890	* 1.8402	* 0.8470
	* 3.3066	* 2.8997	* 2.7984	* 2.7783	* 2.6223	* 2.2912	* 2.2199	* 4.3399
10	* 1.3900	* 1.5198	* 1.4068	* 1.5040	* 1.7117	* 1.7174	* 1.8410	* 0.7950
	* 3.0300	* 2.8082	* 3.0474	* 2.9510	* 2.5636	* 2.5031	* 2.3171	* 4.7027
11	* 1.3488	* 1.5234	* 1.5031	* 1.6706	* 1.6728	* 1.8145	* 1.1904	* 0.5529
	* 3.0340	* 2.7806	* 2.9536	* 2.7124	* 2.7047	* 2.5042	* 3.5182	* 7.1968
12	* 1.5580	* 1.6114	* 1.7114	* 1.6719	* 1.7918	* 1.8024	* 0.8991	*
	* 2.6100	* 2.6223	* 2.5631	* 2.7061	* 2.5868	* 2.5474	* 4.6170	*
13	* 1.7591	* 1.7898	* 1.7195	* 1.8142	* 1.8024	* 1.8463	* 0.7726	*
	* 2.3052	* 2.2902	* 2.5001	* 2.5046	* 2.5474	* 2.5140	* 5.4036	*
14	* 1.8334	* 1.8407	* 1.8418	* 1.1904	* 0.8978	* 0.7723	*	*
	* 2.2114	* 2.2193	* 2.3162	* 3.5185	* 4.6203	* 5.4053	*	*
15	* 0.8340	* 0.8478	* 0.7948	* 0.5416	* F-SUB-Q			
	* 4.3683	* 4.3373	* 4.7037	* 7.2279	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3816	* 1.3141	* 1.3606	* 1.3130	* 1.5312	* 1.7257	* 1.8079	* 0.8013
	* 3.0167	* 3.1463	* 2.9002	* 2.9242	* 2.4944	* 2.2066	* 2.1062	* 4.2634
9	* 1.3141	* 1.4789	* 1.4862	* 1.4969	* 1.5718	* 1.7561	* 1.8146	* 0.8172
	* 3.1463	* 2.7712	* 2.6903	* 2.6632	* 2.5225	* 2.1922	* 2.1146	* 4.2271
10	* 1.3606	* 1.4806	* 1.3688	* 1.4597	* 1.6844	* 1.6837	* 1.8145	* 0.7636
	* 2.9002	* 2.7001	* 2.9323	* 2.8579	* 2.4467	* 2.3967	* 2.2072	* 4.5994
11	* 1.3130	* 1.4956	* 1.4584	* 1.6404	* 1.6298	* 1.7859	* 1.1463	* 0.5301
	* 2.9242	* 2.6655	* 2.8609	* 2.6028	* 2.6284	* 2.4043	* 3.4268	* 7.0433
12	* 1.5312	* 1.5717	* 1.6841	* 1.6282	* 1.7620	* 1.7756	* 0.8630	*
	* 2.4944	* 2.5224	* 2.4462	* 2.6310	* 2.4952	* 2.4412	* 4.4857	*
13	* 1.7257	* 1.7569	* 1.6859	* 1.7856	* 1.7755	* 1.8251	* 0.7413	*
	* 2.2066	* 2.1912	* 2.3937	* 2.4048	* 2.4413	* 2.3972	* 5.2338	*
14	* 1.8079	* 1.8152	* 1.8152	* 1.1463	* 0.8616	* 0.7411	*	*
	* 2.1062	* 2.1140	* 2.2064	* 3.4274	* 4.4893	* 5.2355	*	*
15	* 0.8013	* 0.8180	* 0.7634	* 0.5168	* F-SUB-Q			
	* 4.2634	* 4.2244	* 4.6005	* 7.1080	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3331	* 1.2671	* 1.3158	* 1.2677	* 1.4856	* 1.6760	* 1.7604	* 0.7727
	* 2.7593	* 2.8815	* 2.6811	* 2.7251	* 2.3401	* 2.0832	* 1.9822	* 4.0125
9	* 1.2671	* 1.4305	* 1.4350	* 1.4510	* 1.5207	* 1.7059	* 1.7665	* 0.7887
	* 2.8815	* 2.5563	* 2.4969	* 2.4762	* 2.3690	* 2.0675	* 1.9890	* 3.9724
10	* 1.3158	* 1.4294	* 1.3218	* 1.4118	* 1.6365	* 1.6339	* 1.7666	* 0.7367
	* 2.6811	* 2.5062	* 2.7211	* 2.6275	* 2.2878	* 2.2514	* 2.0679	* 4.3128
11	* 1.2677	* 1.4497	* 1.4106	* 1.5926	* 1.5793	* 1.7368	* 1.1076	* 0.5106
	* 2.7251	* 2.4785	* 2.6297	* 2.3670	* 2.3927	* 2.1823	* 3.1385	* 6.5626
12	* 1.4856	* 1.5206	* 1.6362	* 1.5777	* 1.7154	* 1.7277	* 0.8327	*
	* 2.3401	* 2.3689	* 2.2874	* 2.3951	* 2.2677	* 2.2175	* 4.1108	*
13	* 1.6760	* 1.7068	* 1.6362	* 1.7364	* 1.7276	* 1.7818	* 0.7160	*
	* 2.0832	* 2.0666	* 2.2485	* 2.1828	* 2.2176	* 2.1745	* 4.8000	*
14	* 1.7604	* 1.7671	* 1.7673	* 1.1076	* 0.8313	* 0.7158	*	*
	* 1.9822	* 1.9885	* 2.0671	* 3.1391	* 4.1143	* 4.8016	*	*
15	* 0.7727	* 0.7895	* 0.7365	* 0.4971	* F-SUB-Q			
	* 4.0125	* 3.9700	* 4.3143	* 6.6319	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2816	* 1.2174	* 1.2653	* 1.2190	* 1.4328	* 1.6181	* 1.7016	* 0.7469
	* 2.5420	* 2.6544	* 2.4347	* 2.4792	* 2.1268	* 1.8920	* 1.7987	* 3.6517
9	* 1.2174	* 1.3764	* 1.3800	* 1.3980	* 1.4650	* 1.6481	* 1.7078	* 0.7620
	* 2.6544	* 2.3161	* 2.2652	* 2.2473	* 2.1506	* 1.8757	* 1.8040	* 3.6134
10	* 1.2653	* 1.3745	* 1.2716	* 1.3599	* 1.5797	* 1.5774	* 1.7079	* 0.7130
	* 2.4347	* 2.2739	* 2.4678	* 2.4113	* 2.0722	* 2.0390	* 1.8707	* 3.9106
11	* 1.2190	* 1.3967	* 1.3586	* 1.5367	* 1.5232	* 1.6778	* 1.0732	* 0.4939
	* 2.4792	* 2.2492	* 2.4140	* 2.1824	* 2.2049	* 2.0102	* 2.8767	* 5.9385
12	* 1.4328	* 1.4649	* 1.5793	* 1.5216	* 1.6593	* 1.6702	* 0.8055	*
	* 2.1268	* 2.1505	* 2.0719	* 2.2064	* 2.0899	* 2.0479	* 3.7951	*
13	* 1.6181	* 1.6490	* 1.5797	* 1.6775	* 1.6701	* 1.7250	* 0.6935	*
	* 1.8920	* 1.8748	* 2.0362	* 2.0106	* 2.0480	* 2.0015	* 4.4265	*
14	* 1.7016	* 1.7084	* 1.7085	* 1.0731	* 0.8042	* 0.6933	*	*
	* 1.7987	* 1.8035	* 1.8700	* 2.8774	* 3.7985	* 4.4280	*	*
15	* 0.7469	* 0.7628	* 0.7128	* 0.4805	* F-SUB-Q			
	* 3.6517	* 3.6112	* 3.9121	* 6.0054	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2249	* 1.1633	* 1.2066	* 1.1657	* 1.3687	* 1.5506	* 1.6289	* 0.7245
	* 2.5414	* 2.6547	* 2.4343	* 2.4771	* 2.1305	* 1.8900	* 1.7991	* 3.6191
9	* 1.1633	* 1.3128	* 1.3189	* 1.3344	* 1.4032	* 1.5799	* 1.6348	* 0.7367
	* 2.6547	* 2.3086	* 2.2569	* 2.2440	* 2.1416	* 1.8713	* 1.8031	* 3.5853
10	* 1.2066	* 1.3136	* 1.2164	* 1.3083	* 1.5102	* 1.5113	* 1.6357	* 0.6927
	* 2.4343	* 2.2656	* 2.4571	* 2.3943	* 2.0676	* 2.0291	* 1.8637	* 3.8552
11	* 1.1657	* 1.3331	* 1.3073	* 1.4682	* 1.4649	* 1.6063	* 1.0428	* 0.4796
	* 2.4771	* 2.2464	* 2.3967	* 2.1849	* 2.1870	* 2.0112	* 2.8374	* 5.8394
12	* 1.3687	* 1.4031	* 1.5099	* 1.4640	* 1.5928	* 1.5993	* 0.7831	*
	* 2.1305	* 2.1424	* 2.0675	* 2.1885	* 2.0898	* 2.0502	* 3.7469	*
13	* 1.5506	* 1.5807	* 1.5134	* 1.6060	* 1.5992	* 1.6539	* 0.6755	*
	* 1.8900	* 1.8704	* 2.0265	* 2.0117	* 2.0503	* 2.0070	* 4.3754	*
14	* 1.6289	* 1.6354	* 1.6364	* 1.0427	* 0.7817	* 0.6753	*	
	* 1.7991	* 1.8026	* 1.8631	* 2.8381	* 3.7505	* 4.3771	*	
15	* 0.7245	* 0.7374	* 0.6924	* 0.4680	F-SUB-Q			
	* 3.6191	* 3.5832	* 3.8569	* 5.8874	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1912	* 1.1303	* 1.1811	* 1.1322	* 1.3408	* 1.5138	* 1.5988	* 0.6910
	* 2.3262	* 2.4277	* 2.2189	* 2.2796	* 1.9483	* 1.7348	* 1.6430	* 3.4053
9	* 1.1303	* 1.2851	* 1.2832	* 1.3071	* 1.3631	* 1.5431	* 1.6045	* 0.7060
	* 2.4277	* 2.0960	* 2.0652	* 2.0445	* 1.9672	* 1.7155	* 1.6460	* 3.3608
10	* 1.1811	* 1.2778	* 1.1815	* 1.2649	* 1.4801	* 1.4737	* 1.6041	* 0.6602
	* 2.2189	* 2.0736	* 2.2510	* 2.1974	* 1.8814	* 1.8559	* 1.6961	* 3.6257
11	* 1.1322	* 1.3058	* 1.2637	* 1.4384	* 1.4203	* 1.5735	* 0.9967	* 0.4565
	* 2.2796	* 2.0464	* 2.2000	* 1.9961	* 2.0180	* 1.8345	* 2.6306	* 5.4742
12	* 1.3408	* 1.3630	* 1.4798	* 1.4187	* 1.5569	* 1.5673	* 0.7460	
	* 1.9483	* 1.9675	* 1.8811	* 2.0195	* 1.8992	* 1.8672	* 3.5262	
13	* 1.5138	* 1.5439	* 1.4759	* 1.5731	* 1.5671	* 1.6246	* 0.6425	
	* 1.7348	* 1.7146	* 1.8533	* 1.8349	* 1.8674	* 1.8216	* 4.1113	
14	* 1.5988	* 1.6050	* 1.6047	* 0.9966	* 0.7447	* 0.6423		
	* 1.6430	* 1.6456	* 1.6955	* 2.6312	* 3.5296	* 4.1128		
15	* 0.6910	* 0.7067	* 0.6599	* 0.4432	F-SUB-Q			
	* 3.4053	* 3.3589	* 3.6273	* 5.5471	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1479	* 1.0887	* 1.1389	* 1.0898	* 1.2920	* 1.4590	* 1.5417	* 0.6636 *
	* 2.1458	* 2.2534	* 2.0772	* 2.1440	* 1.8342	* 1.6341	* 1.5474	* 3.2301 *
9	* 1.0887	* 1.2394	* 1.2369	* 1.2592	* 1.3117	* 1.4872	* 1.5468	* 0.6780 *
	* 2.2534	* 1.9502	* 1.9302	* 1.9147	* 1.8461	* 1.6139	* 1.5490	* 3.1838 *
10	* 1.1389	* 1.2316	* 1.1374	* 1.2169	* 1.4255	* 1.4192	* 1.5459	* 0.6341 *
	* 2.0772	* 1.9381	* 2.1029	* 2.0554	* 1.7589	* 1.7386	* 1.5895	* 3.4267 *
11	* 1.0898	* 1.2579	* 1.2157	* 1.3852	* 1.3664	* 1.5155	* 0.9589	* 0.4383 *
	* 2.1440	* 1.9164	* 2.0578	* 1.8531	* 1.8792	* 1.7012	* 2.4648	* 5.1455 *
12	* 1.2920	* 1.3115	* 1.4252	* 1.3650	* 1.5007	* 1.5094	* 0.7164 *	
	* 1.8342	* 1.8464	* 1.7583	* 1.8812	* 1.7631	* 1.7322	* 3.2806 *	
13	* 1.4590	* 1.4880	* 1.4214	* 1.5151	* 1.5092	* 1.5653	* 0.6166 *	
	* 1.6341	* 1.6130	* 1.7360	* 1.7016	* 1.7323	* 1.6969	* 3.8491 *	
14	* 1.5417	* 1.5473	* 1.5465	* 0.9588	* 0.7151	* 0.6164 *		
	* 1.5474	* 1.5486	* 1.5890	* 2.4654	* 3.2839	* 3.8506 *		
15	* 0.6636	* 0.6787	* 0.6338	* 0.4253	* F-SUB-Q			
	* 3.2301	* 3.1820	* 3.4284	* 5.2171	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0941	* 1.0379	* 1.0777	* 1.0381	* 1.2194	* 1.3829	* 1.4520	* 0.6414 *
	* 2.0643	* 2.1447	* 2.0062	* 2.0654	* 1.7872	* 1.5860	* 1.5115	* 3.0887 *
9	* 1.0379	* 1.1738	* 1.1784	* 1.1880	* 1.2469	* 1.4096	* 1.4572	* 0.6524 *
	* 2.1447	* 1.8696	* 1.8485	* 1.8540	* 1.7763	* 1.5647	* 1.5118	* 3.0528 *
10	* 1.0777	* 1.1734	* 1.0828	* 1.1614	* 1.3427	* 1.3454	* 1.4553	* 0.6133 *
	* 2.0062	* 1.8560	* 2.0108	* 1.9551	* 1.7011	* 1.6761	* 1.5445	* 3.2600 *
11	* 1.0381	* 1.1868	* 1.1605	* 1.3056	* 1.3022	* 1.4274	* 0.9281	* 0.4246 *
	* 2.0654	* 1.8560	* 1.9570	* 1.7974	* 1.7890	* 1.6533	* 2.3055	* 4.8569 *
12	* 1.2194	* 1.2467	* 1.3424	* 1.3013	* 1.4200	* 1.4214	* 0.6938 *	
	* 1.7872	* 1.7766	* 1.7004	* 1.7903	* 1.6904	* 1.6757	* 3.0987 *	
13	* 1.3829	* 1.4104	* 1.3473	* 1.4271	* 1.4213	* 1.4691	* 0.5971 *	
	* 1.5860	* 1.5639	* 1.6738	* 1.6537	* 1.6758	* 1.6391	* 3.6171 *	
14	* 1.4520	* 1.4577	* 1.4559	* 0.9280	* 0.6926	* 0.5969 *		
	* 1.5115	* 1.5114	* 1.5440	* 2.3062	* 3.1015	* 3.6186 *		
15	* 0.6414	* 0.6531	* 0.6130	* 0.4139	* F-SUB-Q			
	* 3.0887	* 3.0509	* 3.2618	* 4.9024	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0597	* 1.0055	* 1.0462	* 1.0087	* 1.1753	* 1.3301	* 1.3929	* 0.6070 *
	* 1.9334	* 2.0251	* 1.9112	* 1.9758	* 1.7276	* 1.5372	* 1.4693	* 3.0499 *
9	* 1.0055	* 1.1373	* 1.1439	* 1.1474	* 1.2001	* 1.3543	* 1.3969	* 0.6195 *
	* 2.0251	* 1.7758	* 1.7618	* 1.7771	* 1.7111	* 1.5163	* 1.4694	* 3.0045 *
10	* 1.0462	* 1.1391	* 1.0493	* 1.1136	* 1.2892	* 1.2910	* 1.3907	* 0.5779 *
	* 1.9112	* 1.7690	* 1.9186	* 1.8721	* 1.6361	* 1.6178	* 1.4993	* 3.2267 *
11	* 1.0087	* 1.1463	* 1.1125	* 1.2562	* 1.2456	* 1.3666	* 0.8766	* 0.4001 *
	* 1.9758	* 1.7789	* 1.8739	* 1.7104	* 1.7235	* 1.5784	* 2.2521	* 4.7808 *
12	* 1.1753	* 1.1999	* 1.2888	* 1.2442	* 1.3627	* 1.3608	* 0.6538 *	
	* 1.7276	* 1.7113	* 1.6355	* 1.7254	* 1.6380	* 1.6199	* 3.0339 *	
13	* 1.3301	* 1.3551	* 1.2928	* 1.3663	* 1.3607	* 1.4002	* 0.5590 *	
	* 1.5372	* 1.5156	* 1.6156	* 1.5788	* 1.6200	* 1.5982	* 3.5999 *	
14	* 1.3929	* 1.3973	* 1.3912	* 0.8764	* 0.6527	* 0.5588 *		
	* 1.4693	* 1.4690	* 1.4988	* 2.2527	* 3.0370	* 3.6013 *		
15	* 0.6070	* 0.6202	* 0.5776	* 0.3883	* F-SUB-Q			
	* 3.0499	* 3.0026	* 3.2286	* 4.8463	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9858	* 0.9473	* 0.9955	* 0.9680	* 1.0886	* 1.2282	* 1.2798	* 0.5748 *
	* 1.9416	* 1.9978	* 1.8891	* 1.9378	* 1.7627	* 1.5741	* 1.5122	* 3.0532 *
9	* 0.9473	* 1.0598	* 1.0746	* 1.0721	* 1.1184	* 1.2485	* 1.2819	* 0.5852 *
	* 1.9978	* 1.7855	* 1.7635	* 1.7849	* 1.7292	* 1.5545	* 1.5135	* 3.0172 *
10	* 0.9955	* 1.0704	* 0.9794	* 1.0461	* 1.1885	* 1.1857	* 1.2655	* 0.5404 *
	* 1.8891	* 1.7702	* 1.9336	* 1.8647	* 1.6704	* 1.6587	* 1.5523	* 3.2681 *
11	* 0.9680	* 1.0710	* 1.0451	* 1.1624	* 1.1584	* 1.2553	* 0.8154	* 0.3710 *
	* 1.9378	* 1.7868	* 1.8665	* 1.7132	* 1.7317	* 1.6043	* 2.2744	* 4.8670 *
12	* 1.0886	* 1.1182	* 1.1882	* 1.1572	* 1.2617	* 1.2536	* 0.6151 *	
	* 1.7627	* 1.7295	* 1.6699	* 1.7336	* 1.6364	* 1.6302	* 3.0086 *	
13	* 1.2282	* 1.2491	* 1.1873	* 1.2550	* 1.2535	* 1.2675	* 0.5173 *	
	* 1.5741	* 1.5538	* 1.6566	* 1.6047	* 1.6303	* 1.6388	* 3.6215 *	
14	* 1.2798	* 1.2822	* 1.2659	* 0.8152	* 0.6140	* 0.5171 *		
	* 1.5122	* 1.5132	* 1.5519	* 2.2752	* 3.0115	* 3.6229 *		
15	* 0.5748	* 0.5857	* 0.5401	* 0.3598	* F-SUB-Q			
	* 3.0532	* 3.0156	* 3.2702	* 4.9376	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8051	* 0.8246	* 1.0150	* 0.8492	* 1.0728	* 0.9999	* 1.1503	* 0.4991
	* 2.2528	* 2.1799	* 1.7639	* 2.1290	* 1.6994	* 1.8510	* 1.6095	* 3.3821
9	* 0.8246	* 1.0185	* 0.9065	* 1.0534	* 0.9154	* 1.0145	* 1.1416	* 0.5049
	* 2.1799	* 1.7649	* 1.9847	* 1.7245	* 2.0075	* 1.8290	* 1.6262	* 3.3606
10	* 1.0150	* 0.9047	* 0.8007	* 0.8966	* 1.1210	* 0.9740	* 1.0664	* 0.4570
	* 1.7639	* 1.9871	* 2.2599	* 2.0889	* 1.6729	* 1.9447	* 1.7616	* 3.7108
11	* 0.8492	* 1.0523	* 0.8959	* 1.1256	* 0.9608	* 1.1105	* 0.6864	* 0.3074
	* 2.1290	* 1.7263	* 2.0905	* 1.6834	* 1.9795	* 1.7244	* 2.5756	* 5.6307
12	* 1.0728	* 0.9153	* 1.1208	* 0.9602	* 1.0430	* 1.1355	* 0.5378	*
	* 1.6994	* 2.0091	* 1.6733	* 1.9809	* 1.8779	* 1.7173	* 3.2827	*
13	* 0.9999	* 1.0150	* 0.9753	* 1.1103	* 1.1353	* 1.0199	* 0.4266	*
	* 1.8509	* 1.8283	* 1.9423	* 1.7247	* 1.7176	* 1.9291	* 4.1778	*
14	* 1.1503	* 1.1419	* 1.0665	* 0.6862	* 0.5369	* 0.4265	*	*
	* 1.6095	* 1.6258	* 1.7615	* 2.5766	* 3.2854	* 4.1795	*	*
15	* 0.4991	* 0.5053	* 0.4567	* 0.2983	* F-SUB-Q			
	* 3.3821	* 3.3590	* 3.7133	* 5.7090	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3172	* 0.3445	* 0.4131	* 0.3605	* 0.4296	* 0.3798	* 0.4065	* 0.2065
	* 5.4523	* 5.0010	* 4.1569	* 4.8073	* 4.0582	* 4.6694	* 4.3663	* 7.8724
9	* 0.3445	* 0.4046	* 0.3621	* 0.4214	* 0.3668	* 0.3827	* 0.4023	* 0.2059
	* 5.0010	* 4.2531	* 4.7712	* 4.1148	* 4.7996	* 4.6479	* 4.4230	* 7.9384
10	* 0.4131	* 0.3614	* 0.3334	* 0.3709	* 0.4400	* 0.3745	* 0.3703	* 0.1876
	* 4.1569	* 4.7801	* 5.2261	* 4.8326	* 4.0556	* 4.8168	* 4.8581	* 8.7001
11	* 0.3605	* 0.4210	* 0.3707	* 0.4353	* 0.3821	* 0.4175	* 0.2788	* 0.1267
	* 4.8073	* 4.1192	* 4.8358	* 4.1289	* 4.7598	* 4.3837	* 6.0740	* 13.1483
12	* 0.4296	* 0.3666	* 0.4398	* 0.3818	* 0.3883	* 0.4029	* 0.2220	*
	* 4.0582	* 4.8030	* 4.0570	* 4.7635	* 4.8087	* 4.6309	* 7.6416	*
13	* 0.3798	* 0.3828	* 0.3747	* 0.4174	* 0.4028	* 0.3538	* 0.1730	*
	* 4.6694	* 4.6465	* 4.8135	* 4.3846	* 4.6319	* 5.3180	* 9.8855	*
14	* 0.4065	* 0.4024	* 0.3704	* 0.2787	* 0.2218	* 0.1730	*	*
	* 4.3663	* 4.4221	* 4.8582	* 6.0768	* 7.6451	* 9.8899	*	*
15	* 0.2065	* 0.2060	* 0.1875	* 0.1242	* F-SUB-Q			
	* 7.8724	* 7.9345	* 8.7059	* 13.2061	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5292	* 0.6066	* 0.7221	* 0.6260	* 0.7297	* 0.6346	* 0.6590	* 0.3435
	* 5.0803	* 4.7784	* 3.8468	* 4.3120	* 3.6953	* 4.2989	* 4.2059	* 7.1434
9	* 0.6066	* 0.7072	* 0.6448	* 0.7251	* 0.6276	* 0.6276	* 0.6513	* 0.3393
	* 4.7784	* 4.1087	* 4.2851	* 3.7722	* 4.3194	* 4.3849	* 4.2817	* 7.2871
10	* 0.7221	* 0.6441	* 0.5877	* 0.6208	* 0.7305	* 0.6234	* 0.5987	* 0.3045
	* 3.8468	* 4.2879	* 4.8466	* 4.5138	* 3.9195	* 4.5885	* 4.7189	* 8.0820
11	* 0.6260	* 0.7247	* 0.6206	* 0.7179	* 0.6338	* 0.6690	* 0.4443	* 0.2078
	* 4.3120	* 3.7736	* 4.5159	* 4.1533	* 4.7086	* 4.4550	* 6.1593	* 12.2569
12	* 0.7297	* 0.6274	* 0.7304	* 0.6335	* 0.5767	* 0.5989	* 0.3540	*
	* 3.6953	* 4.3200	* 3.9204	* 4.7107	* 4.6778	* 4.5875	* 7.3182	*
13	* 0.6346	* 0.6277	* 0.6237	* 0.6690	* 0.5989	* 0.5260	* 0.2675	*
	* 4.2989	* 4.3846	* 4.5866	* 4.4550	* 4.5871	* 5.1483	* 9.3315	*
14	* 0.6590	* 0.6515	* 0.5989	* 0.4445	* 0.3540	* 0.2675	*	*
	* 4.2059	* 4.2807	* 4.7176	* 6.1581	* 7.3139	* 9.3324	*	*
15	* 0.3435	* 0.3396	* 0.3046	* 0.2049	F-SUB-Q			
	* 7.1434	* 7.2799	* 8.0810	* 12.2326	M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3607	* 1.4251	* 1.6906	* 1.4460	* 1.7328	* 1.5989	* 1.7696	* 0.8406
	* 2.2523	* 2.1786	* 1.7469	* 2.0038	* 1.6690	* 1.8339	* 1.6757	* 3.1145
9	* 1.4251	* 1.7003	* 1.5659	* 1.7171	* 1.5308	* 1.6096	* 1.7544	* 0.8352
	* 2.1786	* 1.8109	* 1.8786	* 1.7003	* 1.9179	* 1.8367	* 1.6858	* 3.1344
10	* 1.6906	* 1.5645	* 1.3880	* 1.4730	* 1.7603	* 1.5738	* 1.6366	* 0.7501
	* 1.7469	* 1.8802	* 2.1812	* 2.0378	* 1.7335	* 1.9486	* 1.8439	* 3.4855
11	* 1.4460	* 1.7162	* 1.4725	* 1.7702	* 1.5463	* 1.7040	* 1.0978	* 0.5115
	* 2.0038	* 1.7009	* 2.0387	* 1.7839	* 2.0579	* 1.8642	* 2.6649	* 5.2854
12	* 1.7328	* 1.5303	* 1.7602	* 1.5456	* 1.5249	* 1.6677	* 0.8676	*
	* 1.6690	* 1.9182	* 1.7335	* 2.0589	* 1.9423	* 1.8114	* 3.1803	*
13	* 1.5989	* 1.6100	* 1.5749	* 1.7041	* 1.6678	* 1.4679	* 0.6753	*
	* 1.8339	* 1.8363	* 1.9475	* 1.8641	* 1.8112	* 2.0270	* 3.9407	*
14	* 1.7696	* 1.7549	* 1.6371	* 1.0983	* 0.8671	* 0.6753	*	*
	* 1.6757	* 1.6854	* 1.8433	* 2.6642	* 3.1794	* 3.9411	*	*
15	* 0.8406	* 0.8359	* 0.7503	* 0.5049	F-SUB-Q			
	* 3.1145	* 3.1330	* 3.4848	* 5.2696	M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6728	* 1.6215	* 1.6133	* 1.6332	* 1.7104	* 1.9255	* 1.9303	* 0.9654
	* 1.9629	* 2.0019	* 1.8789	* 1.8310	* 1.7480	* 1.5693	* 1.5624	* 2.7563
9	* 1.6215	* 1.7314	* 1.8137	* 1.7072	* 1.8391	* 1.9439	* 1.9340	* 0.9707
	* 2.0019	* 1.8215	* 1.7088	* 1.7722	* 1.6761	* 1.5633	* 1.5655	* 2.7573
10	* 1.6133	* 1.8111	* 1.6667	* 1.7134	* 1.8207	* 1.8938	* 1.9045	* 0.8950
	* 1.8789	* 1.7123	* 1.8586	* 1.8272	* 1.7177	* 1.6664	* 1.6305	* 3.0075
11	* 1.6332	* 1.7064	* 1.7126	* 1.8119	* 1.8442	* 1.8938	* 1.3175	* 0.6230
	* 1.8310	* 1.7729	* 1.8281	* 1.8040	* 1.7831	* 1.7264	* 2.2944	* 4.4848
12	* 1.7104	* 1.8391	* 1.8205	* 1.8433	* 1.8925	* 1.8642	* 1.0086	*
	* 1.7480	* 1.6762	* 1.7176	* 1.7836	* 1.6806	* 1.7109	* 2.8360	*
13	* 1.9255	* 1.9444	* 1.8952	* 1.8938	* 1.8646	* 1.8134	* 0.8340	*
	* 1.5693	* 1.5629	* 1.6653	* 1.7264	* 1.7105	* 1.7204	* 3.3134	*
14	* 1.9303	* 1.9345	* 1.9053	* 1.3181	* 1.0079	* 0.8339	*	*
	* 1.5624	* 1.5652	* 1.6298	* 2.2936	* 2.8356	* 3.3138	*	*
15	* 0.9654	* 0.9715	* 0.8953	* 0.6176	* F-SUB-Q			
	* 2.7563	* 2.7561	* 3.0066	* 4.4512	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7918	* 1.7174	* 1.7123	* 1.6951	* 1.8568	* 2.0950	* 2.1193	* 0.9997
	* 1.8943	* 1.9851	* 1.8368	* 1.8124	* 1.6604	* 1.4768	* 1.4566	* 2.7244
9	* 1.7174	* 1.8597	* 1.9276	* 1.8251	* 1.9713	* 2.1199	* 2.1260	* 1.0133
	* 1.9851	* 1.7432	* 1.6558	* 1.7182	* 1.6076	* 1.4694	* 1.4590	* 2.7085
10	* 1.7123	* 1.9244	* 1.7764	* 1.8225	* 1.9935	* 2.0515	* 2.1109	* 0.9367
	* 1.8368	* 1.6597	* 1.7916	* 1.7867	* 1.6171	* 1.5759	* 1.5101	* 2.9528
11	* 1.6951	* 1.8242	* 1.8215	* 1.9626	* 1.9911	* 2.0854	* 1.3933	* 0.6554
	* 1.8124	* 1.7191	* 1.7878	* 1.7150	* 1.6975	* 1.6175	* 2.2335	* 4.3886
12	* 1.8568	* 1.9713	* 1.9934	* 1.9900	* 2.0634	* 2.0540	* 1.0555	*
	* 1.6604	* 1.6076	* 1.6169	* 1.6981	* 1.5883	* 1.6073	* 2.8031	*
13	* 2.0950	* 2.1205	* 2.0534	* 2.0854	* 2.0544	* 2.0392	* 0.8867	*
	* 1.4768	* 1.4690	* 1.5745	* 1.6175	* 1.6070	* 1.5832	* 3.2270	*
14	* 2.1193	* 2.1266	* 2.1120	* 1.3940	* 1.0546	* 0.8866	*	*
	* 1.4566	* 1.4587	* 1.5094	* 2.2326	* 2.8031	* 3.2274	*	*
15	* 0.9997	* 1.0142	* 0.9371	* 0.6483	* F-SUB-Q			
	* 2.7244	* 2.7071	* 2.9518	* 4.3655	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7971	* 1.7200	* 1.7289	* 1.6941	* 1.8963	* 2.1404	* 2.1848	* 1.0142
	* 1.9554	* 2.0518	* 1.8840	* 1.8690	* 1.6767	* 1.4899	* 1.4566	* 2.7764
9	* 1.7200	* 1.8812	* 1.9319	* 1.8582	* 1.9972	* 2.1665	* 2.1922	* 1.0292
	* 2.0518	* 1.7850	* 1.7068	* 1.7453	* 1.6337	* 1.4823	* 1.4588	* 2.7548
10	* 1.7289	* 1.9284	* 1.7803	* 1.8459	* 2.0500	* 2.0873	* 2.1836	* 0.9549
	* 1.8840	* 1.7113	* 1.8505	* 1.8256	* 1.6257	* 1.5850	* 1.5029	* 2.9936
11	* 1.6941	* 1.8571	* 1.8449	* 2.0144	* 2.0305	* 2.1535	* 1.4244	* 0.6660
	* 1.8690	* 1.7462	* 1.8268	* 1.7309	* 1.7223	* 1.6213	* 2.2458	* 4.4444
12	* 1.8963	* 1.9972	* 2.0499	* 2.0292	* 2.1148	* 2.1245	* 1.0768	
	* 1.6767	* 1.6337	* 1.6255	* 1.7229	* 1.5981	* 1.6105	* 2.8520	
13	* 2.1404	* 2.1674	* 2.0895	* 2.1535	* 2.1249	* 2.1284	* 0.9107	
	* 1.4899	* 1.4819	* 1.5834	* 1.6213	* 1.6102	* 1.5732	* 3.2653	
14	* 2.1848	* 2.1929	* 2.1848	* 1.4251	* 1.0758	* 0.9106		
	* 1.4566	* 1.4584	* 1.5022	* 2.2450	* 2.8523	* 3.2658		
15	* 1.0142	* 1.0302	* 0.9553	* 0.6576	* F-SUB-Q			
	* 2.7764	* 2.7533	* 2.9926	* 4.4290	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7658	* 1.6892	* 1.7057	* 1.6678	* 1.8869	* 2.1337	* 2.1883	* 1.0146
	* 2.0513	* 2.1526	* 1.9730	* 1.9609	* 1.7368	* 1.5372	* 1.4966	* 2.8654
9	* 1.6892	* 1.8570	* 1.8992	* 1.8456	* 1.9811	* 2.1623	* 2.1963	* 1.0288
	* 2.1526	* 1.8694	* 1.7904	* 1.8183	* 1.7015	* 1.5282	* 1.4983	* 2.8416
10	* 1.7057	* 1.8955	* 1.7505	* 1.8348	* 2.0494	* 2.0819	* 2.1907	* 0.9586
	* 1.9730	* 1.7954	* 1.9434	* 1.9028	* 1.6862	* 1.6387	* 1.5434	* 3.0725
11	* 1.6678	* 1.8444	* 1.8339	* 2.0111	* 2.0241	* 2.1592	* 1.4303	* 0.6665
	* 1.9609	* 1.8194	* 1.9040	* 1.7996	* 1.7954	* 1.6770	* 2.3158	* 4.5950
12	* 1.8869	* 1.9811	* 2.0492	* 2.0234	* 2.1223	* 2.1336	* 1.0815	
	* 1.7368	* 1.7015	* 1.6859	* 1.7965	* 1.6614	* 1.6735	* 2.9657	
13	* 2.1337	* 2.1632	* 2.0843	* 2.1592	* 2.1339	* 2.1497	* 0.9188	
	* 1.5372	* 1.5276	* 1.6370	* 1.6771	* 1.6732	* 1.6267	* 3.3885	
14	* 2.1883	* 2.1970	* 2.1919	* 1.4309	* 1.0804	* 0.9186		
	* 1.4966	* 1.4978	* 1.5427	* 2.3151	* 2.9663	* 3.3891		
15	* 1.0146	* 1.0298	* 0.9589	* 0.6581	* F-SUB-Q			
	* 2.8654	* 2.8399	* 3.0717	* 4.5794	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7351	* 1.6578	* 1.6856	* 1.6437	* 1.8779	* 2.1235	* 2.1894	* 0.9986
	* 2.1481	* 2.2521	* 2.0860	* 2.0809	* 1.8200	* 1.6067	* 1.5556	* 3.0270
9	* 1.6578	* 1.8344	* 1.8680	* 1.8341	* 1.9603	* 2.1531	* 2.1971	* 1.0146
	* 2.2521	* 1.9778	* 1.9011	* 1.9184	* 1.7961	* 1.5970	* 1.5581	* 2.9996
10	* 1.6856	* 1.8642	* 1.7214	* 1.8117	* 2.0458	* 2.0713	* 2.1925	* 0.9437
	* 2.0860	* 1.9067	* 2.0668	* 2.0214	* 1.7688	* 1.7178	* 1.6078	* 3.2541
11	* 1.6437	* 1.8329	* 1.8106	* 2.0030	* 2.0099	* 2.1589	* 1.4103	* 0.6547
	* 2.0809	* 1.9196	* 2.0229	* 1.8721	* 1.8690	* 1.7375	* 2.4549	* 4.8888
12	* 1.8779	* 1.9603	* 2.0455	* 2.0085	* 2.1226	* 2.1363	* 1.0650	*
	* 1.8200	* 1.7959	* 1.7685	* 1.8702	* 1.7332	* 1.7401	* 3.1397	*
13	* 2.1235	* 2.1540	* 2.0737	* 2.1588	* 2.1366	* 2.1632	* 0.9069	*
	* 1.6067	* 1.5964	* 1.7160	* 1.7375	* 1.7399	* 1.6915	* 3.5970	*
14	* 2.1894	* 2.1978	* 2.1937	* 1.4109	* 1.0638	* 0.9067	*	*
	* 1.5556	* 1.5576	* 1.6070	* 2.4543	* 3.1407	* 3.5977	*	*
15	* 0.9986	* 1.0156	* 0.9439	* 0.6441	* F-SUB-Q			
	* 3.0270	* 2.9978	* 3.2534	* 4.8894	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6882	* 1.6118	* 1.6449	* 1.6036	* 1.8436	* 2.0867	* 2.1581	* 0.9777
	* 2.3011	* 2.4167	* 2.2599	* 2.2571	* 1.9569	* 1.7219	* 1.6617	* 3.2568
9	* 1.6118	* 1.7908	* 1.8190	* 1.7983	* 1.9186	* 2.1174	* 2.1660	* 0.9939
	* 2.4167	* 2.1444	* 2.0646	* 2.0739	* 1.9391	* 1.7111	* 1.6649	* 3.2275
10	* 1.6449	* 1.8152	* 1.6763	* 1.7729	* 2.0131	* 2.0354	* 2.1620	* 0.9250
	* 2.2599	* 2.0711	* 2.2471	* 2.1903	* 1.9037	* 1.8453	* 1.7199	* 3.5026
11	* 1.6036	* 1.7970	* 1.7717	* 1.9676	* 1.9730	* 2.1275	* 1.3838	* 0.6405
	* 2.2570	* 2.0753	* 2.1921	* 1.9815	* 1.9797	* 1.8319	* 2.6087	* 5.2791
12	* 1.8436	* 1.9185	* 2.0129	* 1.9716	* 2.0943	* 2.1076	* 1.0441	*
	* 1.9569	* 1.9389	* 1.9033	* 1.9811	* 1.8375	* 1.8366	* 3.3289	*
13	* 2.0867	* 2.1183	* 2.0378	* 2.1273	* 2.1078	* 2.1420	* 0.8909	*
	* 1.7219	* 1.7103	* 1.8432	* 1.8320	* 1.8364	* 1.7912	* 3.8405	*
14	* 2.1581	* 2.1667	* 2.1631	* 1.3842	* 1.0429	* 0.8907	*	*
	* 1.6617	* 1.6644	* 1.7190	* 2.6082	* 3.3302	* 3.8413	*	*
15	* 0.9777	* 0.9949	* 0.9251	* 0.6292	* F-SUB-Q			
	* 3.2568	* 3.2255	* 3.5021	* 5.2874	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6414	* 1.5655	* 1.6054	* 1.5624	* 1.8081	* 2.0457	* 2.1231	* 0.9514
	* 2.5189	* 2.6341	* 2.4778	* 2.4741	* 2.1268	* 1.8718	* 1.8001	* 3.5519
9	* 1.5655	* 1.7480	* 1.7704	* 1.7618	* 1.8736	* 2.0766	* 2.1305	* 0.9683
	* 2.6341	* 2.3424	* 2.2716	* 2.2673	* 2.1199	* 1.8599	* 1.8041	* 3.5179
10	* 1.6054	* 1.7660	* 1.6310	* 1.7309	* 1.9776	* 1.9946	* 2.1270	* 0.9005
	* 2.4778	* 2.2789	* 2.4757	* 2.3755	* 2.0741	* 2.0106	* 1.8655	* 3.8222
11	* 1.5624	* 1.7605	* 1.7297	* 1.9300	* 1.9315	* 2.0919	* 1.3490	* 0.6230
	* 2.4741	* 2.2689	* 2.3770	* 2.1371	* 2.1392	* 1.9700	* 2.8114	* 5.7682
12	* 1.8081	* 1.8736	* 1.9773	* 1.9301	* 2.0600	* 2.0741	* 1.0172	*
	* 2.1268	* 2.1196	* 2.0736	* 2.1408	* 1.9794	* 1.9737	* 3.6084	*
13	* 2.0457	* 2.0776	* 1.9971	* 2.0918	* 2.0743	* 2.1140	* 0.8686	*
	* 1.8718	* 1.8591	* 2.0082	* 1.9702	* 1.9735	* 1.9151	* 4.1522	*
14	* 2.1231	* 2.1312	* 2.1281	* 1.3494	* 1.0159	* 0.8684	*	*
	* 1.8001	* 1.8036	* 1.8647	* 2.8111	* 3.6101	* 4.1531	*	*
15	* 0.9514	* 0.9693	* 0.9006	* 0.6111	* F-SUB-Q			
	* 3.5519	* 3.5158	* 3.8220	* 5.7856	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5675	* 1.4944	* 1.5280	* 1.4950	* 1.7286	* 1.9642	* 2.0353	* 0.9286
	* 2.7921	* 2.9207	* 2.7377	* 2.7122	* 2.3300	* 2.0454	* 1.9709	* 3.8217
9	* 1.4944	* 1.6649	* 1.6915	* 1.6820	* 1.7977	* 1.9954	* 2.0430	* 0.9418
	* 2.9207	* 2.6186	* 2.5125	* 2.4905	* 2.3144	* 2.0298	* 1.9735	* 3.7877
10	* 1.5280	* 1.6861	* 1.5591	* 1.6720	* 1.8933	* 1.9159	* 2.0407	* 0.8816
	* 2.7377	* 2.5206	* 2.7350	* 2.6222	* 2.2724	* 2.1908	* 2.0339	* 4.0767
11	* 1.4950	* 1.6807	* 1.6710	* 1.8486	* 1.8624	* 2.0063	* 1.3209	* 0.6098
	* 2.7122	* 2.4923	* 2.6241	* 2.3794	* 2.3589	* 2.1876	* 3.0445	* 6.1291
12	* 1.7286	* 1.7977	* 1.8931	* 1.8616	* 1.9837	* 1.9910	* 0.9961	*
	* 2.3300	* 2.3142	* 2.2719	* 2.3600	* 2.2077	* 2.2063	* 3.9478	*
13	* 1.9642	* 1.9963	* 1.9183	* 2.0061	* 1.9911	* 2.0319	* 0.8532	*
	* 2.0454	* 2.0289	* 2.1883	* 2.1877	* 2.2062	* 2.1359	* 4.5285	*
14	* 2.0353	* 2.0436	* 2.0417	* 1.3211	* 0.9948	* 0.8530	*	*
	* 1.9710	* 1.9729	* 2.0330	* 3.0443	* 3.9499	* 4.5296	*	*
15	* 0.9286	* 0.9427	* 0.8816	* 0.5995	* F-SUB-Q			
	* 3.8217	* 3.7856	* 4.0769	* 6.1343	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5233	* 1.4506	* 1.4947	* 1.4545	* 1.6973	* 1.9237	* 2.0042	* 0.8915
	* 3.0891	* 3.2379	* 2.9126	* 2.9071	* 2.4717	* 2.1684	* 2.0763	* 4.1112
9	* 1.4506	* 1.6285	* 1.6468	* 1.6505	* 1.7517	* 1.9547	* 2.0113	* 0.9076
	* 3.2379	* 2.7930	* 2.6868	* 2.6573	* 2.4808	* 2.1541	* 2.0817	* 4.0708
10	* 1.4947	* 1.6409	* 1.5155	* 1.6180	* 1.8614	* 1.8749	* 2.0086	* 0.8456
	* 2.9126	* 2.6958	* 2.9290	* 2.8349	* 2.4196	* 2.3385	* 2.1561	* 4.4182
11	* 1.4545	* 1.6491	* 1.6167	* 1.8138	* 1.8121	* 1.9729	* 1.2701	* 0.5841
	* 2.9071	* 2.6593	* 2.8374	* 2.6062	* 2.6052	* 2.3873	* 3.3786	* 6.6719
12	* 1.6973	* 1.7516	* 1.8611	* 1.8106	* 1.9481	* 1.9593	* 0.9552	*
	* 2.4717	* 2.4806	* 2.4191	* 2.6073	* 2.4221	* 2.4055	* 4.4014	*
13	* 1.9237	* 1.9557	* 1.8773	* 1.9727	* 1.9594	* 2.0061	* 0.8176	*
	* 2.1684	* 2.1531	* 2.3357	* 2.3876	* 2.4054	* 2.3357	* 5.0918	*
14	* 2.0042	* 2.0119	* 2.0096	* 1.2703	* 0.9539	* 0.8174	*	*
	* 2.0763	* 2.0811	* 2.1551	* 3.3785	* 4.4040	* 5.0931	*	*
15	* 0.8915	* 0.9085	* 0.8456	* 0.5716	* F-SUB-Q			
	* 4.1112	* 4.0683	* 4.4186	* 6.7077	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4616	* 1.3912	* 1.4370	* 1.3976	* 1.6377	* 1.8568	* 1.9385	* 0.8591
	* 3.1236	* 3.2634	* 3.1118	* 3.1220	* 2.6759	* 2.3449	* 2.2400	* 4.4436
9	* 1.3912	* 1.5661	* 1.5816	* 1.5912	* 1.6862	* 1.8880	* 1.9455	* 0.8748
	* 3.2634	* 2.9070	* 2.8827	* 2.8570	* 2.6949	* 2.3287	* 2.2463	* 4.3994
10	* 1.4370	* 1.5758	* 1.4551	* 1.5576	* 1.7983	* 1.8095	* 1.9431	* 0.8157
	* 3.1118	* 2.8926	* 3.1269	* 2.9658	* 2.6065	* 2.5329	* 2.3271	* 4.7705
11	* 1.3976	* 1.5899	* 1.5564	* 1.7513	* 1.7476	* 1.9079	* 1.2270	* 0.5631
	* 3.1220	* 2.8594	* 2.9682	* 2.6801	* 2.6956	* 2.4773	* 3.5395	* 7.2186
12	* 1.6377	* 1.6861	* 1.7980	* 1.7461	* 1.8854	* 1.8959	* 0.9214	*
	* 2.6759	* 2.6946	* 2.6059	* 2.6979	* 2.5639	* 2.5194	* 4.6383	*
13	* 1.8568	* 1.8889	* 1.8119	* 1.9076	* 1.8959	* 1.9454	* 0.7896	*
	* 2.3449	* 2.3277	* 2.5298	* 2.4777	* 2.5194	* 2.4871	* 5.4369	*
14	* 1.9385	* 1.9461	* 1.9441	* 1.2271	* 0.9201	* 0.7894	*	*
	* 2.2400	* 2.2457	* 2.3261	* 3.5397	* 4.6413	* 5.4385	*	*
15	* 0.8591	* 0.8756	* 0.8156	* 0.5504	* F-SUB-Q			
	* 4.4436	* 4.3967	* 4.7712	* 7.2664	* M-SUB-Q			



C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3866	* 1.3192	* 1.3597	* 1.3276	* 1.5549	* 1.7697	* 1.8456	* 0.8294 *
	* 3.1637	* 3.3066	* 3.0300	* 3.0340	* 2.6100	* 2.3052	* 2.2114	* 4.3683 *
9	* 1.3192	* 1.4825	* 1.5009	* 1.5089	* 1.6055	* 1.8002	* 1.8523	* 0.8419 *
	* 3.3066	* 2.8997	* 2.7984	* 2.7783	* 2.6223	* 2.2912	* 2.2199	* 4.3399 *
10	* 1.3597	* 1.4953	* 1.3831	* 1.4927	* 1.7094	* 1.7246	* 1.8510	* 0.7895 *
	* 3.0300	* 2.8082	* 3.0474	* 2.9510	* 2.5636	* 2.5031	* 2.3171	* 4.7027 *
11	* 1.3276	* 1.5076	* 1.4917	* 1.6639	* 1.6714	* 1.8164	* 1.1875	* 0.5448 *
	* 3.0340	* 2.7806	* 2.9536	* 2.7124	* 2.7047	* 2.5042	* 3.5182	* 7.1968 *
12	* 1.5549	* 1.6054	* 1.7091	* 1.6706	* 1.8014	* 1.8063	* 0.8920 *	
	* 2.6100	* 2.6223	* 2.5631	* 2.7061	* 2.5868	* 2.5474	* 4.6170 *	
13	* 1.7697	* 1.8011	* 1.7268	* 1.8161	* 1.8063	* 1.8563	* 0.7665 *	
	* 2.3052	* 2.2902	* 2.5001	* 2.5046	* 2.5474	* 2.5140	* 5.4036 *	
14	* 1.8456	* 1.8528	* 1.8518	* 1.1876	* 0.8907	* 0.7662 *		
	* 2.2114	* 2.2193	* 2.3162	* 3.5185	* 4.6203	* 5.4053 *		
15	* 0.8294	* 0.8428	* 0.7893	* 0.5336	* F-SUB-Q			
	* 4.3683	* 4.3373	* 4.7037	* 7.2279	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3354	* 1.2691	* 1.3177	* 1.2788	* 1.5113	* 1.7161	* 1.7992	* 0.7884 *
	* 3.0167	* 3.1463	* 2.9002	* 2.9242	* 2.4944	* 2.2066	* 2.1062	* 4.2634 *
9	* 1.2691	* 1.4362	* 1.4469	* 1.4657	* 1.5486	* 1.7467	* 1.8056	* 0.8036 *
	* 3.1463	* 2.7712	* 2.6903	* 2.6632	* 2.5225	* 2.1922	* 2.1146	* 4.2271 *
10	* 1.3177	* 1.4413	* 1.3326	* 1.4301	* 1.6634	* 1.6713	* 1.8036	* 0.7502 *
	* 2.9002	* 2.7001	* 2.9323	* 2.8579	* 2.4467	* 2.3967	* 2.2072	* 4.5994 *
11	* 1.2788	* 1.4643	* 1.4289	* 1.6183	* 1.6102	* 1.7677	* 1.1311	* 0.5169 *
	* 2.9242	* 2.6655	* 2.8609	* 2.6028	* 2.6284	* 2.4043	* 3.4268	* 7.0433 *
12	* 1.5113	* 1.5485	* 1.6631	* 1.6086	* 1.7511	* 1.7595	* 0.8471 *	
	* 2.4944	* 2.5224	* 2.4462	* 2.6310	* 2.4952	* 2.4412	* 4.4857 *	
13	* 1.7161	* 1.7476	* 1.6736	* 1.7674	* 1.7595	* 1.8142	* 0.7277 *	
	* 2.2066	* 2.1912	* 2.3937	* 2.4048	* 2.4413	* 2.3972	* 5.2338 *	
14	* 1.7992	* 1.8062	* 1.8044	* 1.1311	* 0.8458	* 0.7275 *		
	* 2.1062	* 2.1140	* 2.2064	* 3.4274	* 4.4893	* 5.2355 *		
15	* 0.7884	* 0.8045	* 0.7500	* 0.5039	* F-SUB-Q			
	* 4.2634	* 4.2244	* 4.6005	* 7.1080	* M-SUB-Q			

# C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2747	* 1.2106	* 1.2613	* 1.2214	* 1.4499	* 1.6471	* 1.7315	* 0.7520 *
	* 2.7593	* 2.8815	* 2.6811	* 2.7251	* 2.3401	* 2.0832	* 1.9822	* 4.0125 *
9	* 1.2106	* 1.3743	* 1.3818	* 1.4052	* 1.4813	* 1.6769	* 1.7374	* 0.7672 *
	* 2.8815	* 2.5563	* 2.4969	* 2.4762	* 2.3690	* 2.0675	* 1.9890	* 3.9724 *
10	* 1.2613	* 1.3763	* 1.2731	* 1.3680	* 1.5978	* 1.6030	* 1.7354	* 0.7160 *
	* 2.6811	* 2.5062	* 2.7211	* 2.6275	* 2.2878	* 2.2514	* 2.0679	* 4.3128 *
11	* 1.2214	* 1.4039	* 1.3668	* 1.5535	* 1.5427	* 1.6993	* 1.0807	* 0.4926 *
	* 2.7251	* 2.4785	* 2.6297	* 2.3670	* 2.3927	* 2.1823	* 3.1385	* 6.5626 *
12	* 1.4499	* 1.4812	* 1.5975	* 1.5411	* 1.6848	* 1.6926	* 0.8085	*
	* 2.3401	* 2.3689	* 2.2874	* 2.3951	* 2.2677	* 2.2175	* 4.1108	*
13	* 1.6471	* 1.6778	* 1.6054	* 1.6990	* 1.6925	* 1.7504	* 0.6952	*
	* 2.0832	* 2.0666	* 2.2485	* 2.1828	* 2.2176	* 2.1745	* 4.8000	*
14	* 1.7315	* 1.7379	* 1.7362	* 1.0808	* 0.8072	* 0.6950	*	
	* 1.9822	* 1.9885	* 2.0671	* 3.1391	* 4.1143	* 4.8016	*	
15	* 0.7520	* 0.7680	* 0.7158	* 0.4796	F-SUB-Q			
	* 4.0125	* 3.9700	* 4.3143	* 6.6319	M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2124	* 1.1508	* 1.2006	* 1.1620	* 1.3826	* 1.5716	* 1.6541	* 0.7189 *
	* 2.5420	* 2.6544	* 2.4347	* 2.4792	* 2.1268	* 1.8920	* 1.7987	* 3.6517 *
9	* 1.1508	* 1.3080	* 1.3145	* 1.3391	* 1.4111	* 1.6010	* 1.6599	* 0.7331 *
	* 2.6544	* 2.3161	* 2.2652	* 2.2473	* 2.1506	* 1.8757	* 1.8040	* 3.6134 *
10	* 1.2006	* 1.3091	* 1.2117	* 1.3033	* 1.5247	* 1.5294	* 1.6581	* 0.6854 *
	* 2.4347	* 2.2739	* 2.4678	* 2.4113	* 2.0722	* 2.0390	* 1.8707	* 3.9106 *
11	* 1.1620	* 1.3378	* 1.3021	* 1.4820	* 1.4708	* 1.6229	* 1.0354	* 0.4714 *
	* 2.4792	* 2.2492	* 2.4140	* 2.1824	* 2.2049	* 2.0102	* 2.8767	* 5.9385 *
12	* 1.3826	* 1.4110	* 1.5244	* 1.4693	* 1.6106	* 1.6174	* 0.7737	*
	* 2.1268	* 2.1505	* 2.0719	* 2.2064	* 2.0899	* 2.0479	* 3.7951	*
13	* 1.5716	* 1.6019	* 1.5317	* 1.6226	* 1.6173	* 1.6747	* 0.6660	*
	* 1.8920	* 1.8748	* 2.0362	* 2.0106	* 2.0480	* 2.0015	* 4.4265	*
14	* 1.6541	* 1.6605	* 1.6588	* 1.0354	* 0.7724	* 0.6658	*	
	* 1.7987	* 1.8035	* 1.8700	* 2.8774	* 3.7985	* 4.4280	*	
15	* 0.7189	* 0.7338	* 0.6851	* 0.4586	F-SUB-Q			
	* 3.6517	* 3.6112	* 3.9121	* 6.0054	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1463	* 1.0880	* 1.1329	* 1.0995	* 1.3058	* 1.4883	* 1.5647	* 0.6897 *
	* 2.5414	* 2.6547	* 2.4343	* 2.4771	* 2.1305	* 1.8900	* 1.7991	* 3.6191 *
9	* 1.0880	* 1.2341	* 1.2426	* 1.2642	* 1.3363	* 1.5166	* 1.5702	* 0.7009 *
	* 2.6547	* 2.3086	* 2.2569	* 2.2440	* 2.1416	* 1.8713	* 1.8031	* 3.5853 *
10	* 1.1329	* 1.2375	* 1.1465	* 1.2428	* 1.4411	* 1.4483	* 1.5692	* 0.6585 *
	* 2.4343	* 2.2656	* 2.4571	* 2.3943	* 2.0676	* 2.0291	* 1.8637	* 3.8552 *
11	* 1.0995	* 1.2629	* 1.2418	* 1.4000	* 1.3989	* 1.5357	* 0.9949	* 0.4528 *
	* 2.4771	* 2.2464	* 2.3967	* 2.1849	* 2.1870	* 2.0112	* 2.8374	* 5.8394 *
12	* 1.3058	* 1.3362	* 1.4408	* 1.3980	* 1.5277	* 1.5309	* 0.7439	*
	* 2.1305	* 2.1424	* 2.0675	* 2.1885	* 2.0898	* 2.0502	* 3.7469	*
13	* 1.4883	* 1.5175	* 1.4504	* 1.5354	* 1.5308	* 1.5864	* 0.6416	*
	* 1.8900	* 1.8704	* 2.0265	* 2.0117	* 2.0503	* 2.0070	* 4.3754	*
14	* 1.5647	* 1.5708	* 1.5699	* 0.9948	* 0.7426	* 0.6414	*	
	* 1.7991	* 1.8026	* 1.8631	* 2.8381	* 3.7505	* 4.3771	*	
15	* 0.6897	* 0.7017	* 0.6583	* 0.4419	F-SUB-Q			
	* 3.6191	* 3.5832	* 3.8569	* 5.8874	M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1026	* 1.0457	* 1.0969	* 1.0560	* 1.2646	* 1.4357	* 1.5177	* 0.6505
	* 2.3262	* 2.4277	* 2.2189	* 2.2796	* 1.9483	* 1.7348	* 1.6430	* 3.4053
9	* 1.0457	* 1.1948	* 1.1957	* 1.2246	* 1.2833	* 1.4636	* 1.5229	* 0.6642
	* 2.4277	* 2.0960	* 2.0652	* 2.0445	* 1.9672	* 1.7155	* 1.6460	* 3.3608
10	* 1.0969	* 1.1905	* 1.1014	* 1.1856	* 1.3961	* 1.3954	* 1.5207	* 0.6206
	* 2.2189	* 2.0736	* 2.2510	* 2.1974	* 1.8814	* 1.8559	* 1.6961	* 3.6257
11	* 1.0560	* 1.2234	* 1.1845	* 1.3559	* 1.3401	* 1.4869	* 0.9400	* 0.4262
	* 2.2796	* 2.0464	* 2.2000	* 1.9961	* 2.0180	* 1.8345	* 2.6306	* 5.4742
12	* 1.2646	* 1.2832	* 1.3958	* 1.3386	* 1.4756	* 1.4828	* 0.7008	
	* 1.9483	* 1.9675	* 1.8811	* 2.0195	* 1.8992	* 1.8672	* 3.5262	
13	* 1.4357	* 1.4644	* 1.3976	* 1.4866	* 1.4827	* 1.5398	* 0.6033	
	* 1.7348	* 1.7146	* 1.8533	* 1.8349	* 1.8674	* 1.8216	* 4.1113	
14	* 1.5177	* 1.5234	* 1.5214	* 0.9399	* 0.6996	* 0.6031		
	* 1.6430	* 1.6456	* 1.6955	* 2.6312	* 3.5296	* 4.1128		
15	* 0.6505	* 0.6649	* 0.6203	* 0.4139	F-SUB-Q			
	* 3.4053	* 3.3589	* 3.6273	* 5.5471	M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0513	* 0.9967	* 1.0462	* 1.0057	* 1.2049	* 1.3675	* 1.4463	* 0.6178
	* 2.1458	* 2.2534	* 2.0772	* 2.1440	* 1.8342	* 1.6341	* 1.5474	* 3.2301
9	* 0.9967	* 1.1400	* 1.1400	* 1.1669	* 1.2210	* 1.3941	* 1.4510	* 0.6309
	* 2.2534	* 1.9502	* 1.9302	* 1.9147	* 1.8461	* 1.6139	* 1.5490	* 3.1838
10	* 1.0462	* 1.1350	* 1.0488	* 1.1282	* 1.3295	* 1.3282	* 1.4484	* 0.5894
	* 2.0772	* 1.9381	* 2.1029	* 2.0554	* 1.7589	* 1.7386	* 1.5895	* 3.4267
11	* 1.0057	* 1.1657	* 1.1270	* 1.2911	* 1.2747	* 1.4157	* 0.8943	* 0.4048
	* 2.1440	* 1.9164	* 2.0578	* 1.8531	* 1.8792	* 1.7012	* 2.4648	* 5.1455
12	* 1.2049	* 1.2209	* 1.3292	* 1.2734	* 1.4056	* 1.4117	* 0.6657	*
	* 1.8342	* 1.8464	* 1.7583	* 1.8812	* 1.7631	* 1.7322	* 3.2806	*
13	* 1.3675	* 1.3950	* 1.3303	* 1.4154	* 1.4116	* 1.4661	* 0.5727	*
	* 1.6341	* 1.6130	* 1.7360	* 1.7016	* 1.7323	* 1.6969	* 3.8491	*
14	* 1.4463	* 1.4515	* 1.4490	* 0.8942	* 0.6645	* 0.5725	*	*
	* 1.5474	* 1.5486	* 1.5890	* 2.4654	* 3.2839	* 3.8506	*	*
15	* 0.6178	* 0.6315	* 0.5892	* 0.3928	* F-SUB-Q			
	* 3.2301	* 3.1820	* 3.4284	* 5.2171	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9919	* 0.9406	* 0.9801	* 0.9484	* 1.1248	* 1.2816	* 1.3468	* 0.5907
	* 2.0643	* 2.1447	* 2.0062	* 2.0654	* 1.7872	* 1.5860	* 1.5115	* 3.0887
9	* 0.9406	* 1.0685	* 1.0749	* 1.0894	* 1.1482	* 1.3064	* 1.3514	* 0.6005
	* 2.1447	* 1.8696	* 1.8485	* 1.8540	* 1.7763	* 1.5647	* 1.5118	* 3.0528
10	* 0.9801	* 1.0703	* 0.9883	* 1.0677	* 1.2385	* 1.2450	* 1.3480	* 0.5640
	* 2.0062	* 1.8560	* 2.0108	* 1.9551	* 1.7011	* 1.6761	* 1.5445	* 3.2600
11	* 0.9484	* 1.0882	* 1.0669	* 1.2038	* 1.2023	* 1.3186	* 0.8562	* 0.3882
	* 2.0654	* 1.8560	* 1.9570	* 1.7974	* 1.7890	* 1.6533	* 2.3055	* 4.8569
12	* 1.1248	* 1.1481	* 1.2382	* 1.2015	* 1.3150	* 1.3146	* 0.6378	*
	* 1.7872	* 1.7766	* 1.7004	* 1.7903	* 1.6904	* 1.6757	* 3.0987	*
13	* 1.2816	* 1.3072	* 1.2468	* 1.3183	* 1.3145	* 1.3600	* 0.5486	*
	* 1.5860	* 1.5639	* 1.6738	* 1.6537	* 1.6758	* 1.6391	* 3.6171	*
14	* 1.3468	* 1.3518	* 1.3486	* 0.8561	* 0.6368	* 0.5484	*	*
	* 1.5115	* 1.5114	* 1.5440	* 2.3062	* 3.1015	* 3.6186	*	*
15	* 0.5907	* 0.6011	* 0.5638	* 0.3783	* F-SUB-Q			
	* 3.0887	* 3.0509	* 3.2618	* 4.9024	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9513	* 0.9023	* 0.9435	* 0.9120	* 1.0728	* 1.2191	* 1.2777	* 0.5531
	* 1.9334	* 2.0251	* 1.9112	* 1.9758	* 1.7276	* 1.5372	* 1.4693	* 3.0499
9	* 0.9023	* 1.0250	* 1.0329	* 1.0414	* 1.0935	* 1.2414	* 1.2812	* 0.5642
	* 2.0251	* 1.7758	* 1.7618	* 1.7771	* 1.7111	* 1.5163	* 1.4694	* 3.0045
10	* 0.9435	* 1.0285	* 0.9459	* 1.0111	* 1.1765	* 1.1816	* 1.2740	* 0.5259
	* 1.9112	* 1.7690	* 1.9186	* 1.8721	* 1.6361	* 1.6178	* 1.4993	* 3.2267
11	* 0.9120	* 1.0403	* 1.0101	* 1.1461	* 1.1370	* 1.2489	* 0.8001	* 0.3620
	* 1.9758	* 1.7789	* 1.8739	* 1.7104	* 1.7235	* 1.5784	* 2.2521	* 4.7808
12	* 1.0728	* 1.0934	* 1.1762	* 1.1357	* 1.2479	* 1.2450	* 0.5948	
	* 1.7276	* 1.7113	* 1.6355	* 1.7254	* 1.6380	* 1.6199	* 3.0339	
13	* 1.2191	* 1.2421	* 1.1834	* 1.2486	* 1.2449	* 1.2816	* 0.5081	
	* 1.5372	* 1.5156	* 1.6156	* 1.5788	* 1.6200	* 1.5982	* 3.5999	
14	* 1.2777	* 1.2816	* 1.2744	* 0.8000	* 0.5938	* 0.5080		
	* 1.4693	* 1.4690	* 1.4988	* 2.2527	* 3.0370	* 3.6013		
15	* 0.5531	* 0.5648	* 0.5256	* 0.3514	* F-SUB-Q			
	* 3.0499	* 3.0026	* 3.2286	* 4.8463	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8766	* 0.8429	* 0.8894	* 0.8665	* 0.9833	* 1.1138	* 1.1615	* 0.5184
	* 1.9416	* 1.9978	* 1.8891	* 1.9378	* 1.7627	* 1.5741	* 1.5122	* 3.0532
9	* 0.8429	* 0.9458	* 0.9610	* 0.9634	* 1.0087	* 1.1323	* 1.1632	* 0.5275
	* 1.9978	* 1.7855	* 1.7635	* 1.7849	* 1.7292	* 1.5545	* 1.5135	* 3.0172
10	* 0.8894	* 0.9571	* 0.8744	* 0.9404	* 1.0734	* 1.0739	* 1.1470	* 0.4868
	* 1.8891	* 1.7702	* 1.9336	* 1.8647	* 1.6704	* 1.6587	* 1.5523	* 3.2681
11	* 0.8665	* 0.9624	* 0.9395	* 1.0487	* 1.0465	* 1.1352	* 0.7367	* 0.3323
	* 1.9378	* 1.7868	* 1.8665	* 1.7132	* 1.7317	* 1.6043	* 2.2744	* 4.8670
12	* 0.9833	* 1.0086	* 1.0732	* 1.0454	* 1.1433	* 1.1349	* 0.5539	
	* 1.7627	* 1.7295	* 1.6699	* 1.7336	* 1.6364	* 1.6302	* 3.0086	
13	* 1.1138	* 1.1329	* 1.0754	* 1.1349	* 1.1348	* 1.1479	* 0.4655	
	* 1.5741	* 1.5538	* 1.6566	* 1.6047	* 1.6303	* 1.6388	* 3.6215	
14	* 1.1615	* 1.1635	* 1.1473	* 0.7366	* 0.5530	* 0.4653		
	* 1.5122	* 1.5132	* 1.5519	* 2.2752	* 3.0115	* 3.6229		
15	* 0.5184	* 0.5280	* 0.4865	* 0.3223	* F-SUB-Q			
	* 3.0532	* 3.0156	* 3.2702	* 4.9376	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.7087	* 0.7279	* 0.8970	* 0.7548	* 0.9574	* 0.8967	* 1.0327	* 0.4456 *
	* 2.2528	* 2.1799	* 1.7639	* 2.1290	* 1.6994	* 1.8510	* 1.6095	* 3.3821 *
9	* 0.7279	* 0.8994	* 0.8027	* 0.9357	* 0.8170	* 0.9098	* 1.0247	* 0.4507 *
	* 2.1799	* 1.7649	* 1.9847	* 1.7245	* 2.0075	* 1.8290	* 1.6262	* 3.3606 *
10	* 0.8970	* 0.8009	* 0.7085	* 0.7996	* 1.0014	* 0.8717	* 0.9557	* 0.4076 *
	* 1.7639	* 1.9871	* 2.2599	* 2.0889	* 1.6729	* 1.9447	* 1.7616	* 3.7108 *
11	* 0.7548	* 0.9348	* 0.7990	* 1.0049	* 0.8597	* 0.9934	* 0.6138	* 0.2727 *
	* 2.1290	* 1.7263	* 2.0905	* 1.6834	* 1.9795	* 1.7244	* 2.5756	* 5.6307 *
12	* 0.9574	* 0.8169	* 1.0012	* 0.8591	* 0.9348	* 1.0174	* 0.4795	*
	* 1.6994	* 2.0091	* 1.6733	* 1.9809	* 1.8779	* 1.7173	* 3.2827	*
13	* 0.8967	* 0.9102	* 0.8728	* 0.9932	* 1.0172	* 0.9146	* 0.3800	*
	* 1.8509	* 1.8283	* 1.9423	* 1.7247	* 1.7176	* 1.9291	* 4.1778	*
14	* 1.0327	* 1.0250	* 0.9559	* 0.6136	* 0.4787	* 0.3798	*	
	* 1.6095	* 1.6258	* 1.7615	* 2.5766	* 3.2854	* 4.1795	*	
15	* 0.4456	* 0.4511	* 0.4073	* 0.2646	* F-SUB-Q			
	* 3.3821	* 3.3590	* 3.7133	* 5.7090	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.2750	* 0.2995	* 0.3592	* 0.3152	* 0.3767	* 0.3350	* 0.3586	* 0.1817
	* 5.4523	* 5.0010	* 4.1569	* 4.8073	* 4.0582	* 4.6694	* 4.3663	* 7.8724
9	* 0.2995	* 0.3514	* 0.3156	* 0.3683	* 0.3217	* 0.3376	* 0.3549	* 0.1811
	* 5.0010	* 4.2531	* 4.7712	* 4.1148	* 4.7996	* 4.6479	* 4.4230	* 7.9384
10	* 0.3592	* 0.3149	* 0.2907	* 0.3257	* 0.3863	* 0.3296	* 0.3263	* 0.1648
	* 4.1569	* 4.7801	* 5.2261	* 4.8326	* 4.0556	* 4.8168	* 4.8581	* 8.7001
11	* 0.3152	* 0.3679	* 0.3255	* 0.3823	* 0.3361	* 0.3674	* 0.2453	* 0.1109
	* 4.8073	* 4.1192	* 4.8358	* 4.1289	* 4.7598	* 4.3837	* 6.0740	* 13.1483
12	* 0.3767	* 0.3214	* 0.3862	* 0.3359	* 0.3423	* 0.3549	* 0.1950	
	* 4.0582	* 4.8030	* 4.0570	* 4.7635	* 4.8087	* 4.6309	* 7.6416	
13	* 0.3350	* 0.3377	* 0.3298	* 0.3673	* 0.3548	* 0.3118	* 0.1518	
	* 4.6694	* 4.6465	* 4.8135	* 4.3846	* 4.6319	* 5.3180	* 9.8855	
14	* 0.3586	* 0.3549	* 0.3263	* 0.2452	* 0.1948	* 0.1518	*	
	* 4.3663	* 4.4221	* 4.8582	* 6.0768	* 7.6451	* 9.8899	*	
15	* 0.1817	* 0.1812	* 0.1647	* 0.1087	* F-SUB-Q			
	* 7.8724	* 7.9345	* 8.7059	* 13.2061	* M-SUB-Q			

C1C26 Core Operating Limits Report

TABLE A-5

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	4.0341	3.9672	3.1411	3.9431	3.2308	4.1181	3.6954	6.5284
9*	3.9672	3.1918	3.8360	3.1960	4.0115	4.1824	3.7242	6.6163
10*	3.1411	3.8376	4.1836	3.9731	3.2211	4.0662	3.9588	7.2010
11*	3.9431	3.1971	3.9739	3.2017	3.8777	3.4055	5.0591	10.1414
12*	3.2308	4.0131	3.2214	3.8787	3.9269	3.5266	5.8079	
13*	4.1182	4.1827	4.0659	3.4055	3.5263	3.9527	7.3676	
14*	3.6954	3.7236	3.9581	5.0584	5.8040	7.3683		
15 *	6.5284	6.6140	7.2008	10.1042				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.8688	1.8727	1.4725	1.8791	1.5072	1.8315	1.5200	2.9045
9*	1.8727	1.4732	1.7395	1.4846	1.8246	1.8364	1.5275	2.9237
10*	1.4725	1.7401	1.9601	1.8577	1.4721	1.7771	1.6025	3.1814
11*	1.8791	1.4852	1.8581	1.4401	1.7771	1.4850	2.2648	4.4456
12*	1.5072	1.8253	1.4723	1.7778	1.7204	1.4512	2.6085	
13*	1.8315	1.8363	1.7761	1.4850	1.4510	1.6226	3.2067	
14*	1.5200	1.5272	1.6022	2.2643	2.6075	3.2070		
15 *	2.9045	2.9228	3.1810	4.4245				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.6381	1.6903	1.5847	1.7193	1.5885	1.5817	1.4312	2.6044
9*	1.6903	1.5014	1.5697	1.5366	1.5927	1.5737	1.4271	2.5870
10*	1.5847	1.5708	1.6958	1.6539	1.4667	1.5452	1.4209	2.7531
11*	1.7193	1.5373	1.6544	1.4508	1.5528	1.3744	1.9543	3.7832
12*	1.5885	1.5928	1.4669	1.5534	1.4904	1.3647	2.3311	
13*	1.5817	1.5737	1.5441	1.3745	1.3644	1.3737	2.7032	
14*	1.4312	1.4269	1.4204	1.9538	2.3305	2.7035		
15 *	2.6044	2.5863	2.7525	3.7480				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5681	1.6316	1.5254	1.6879	1.4932	1.4758	1.3180	2.5570
9*	1.6316	1.4284	1.5077	1.4737	1.5121	1.4593	1.3122	2.5196
10*	1.5254	1.5093	1.6228	1.5847	1.3662	1.4611	1.3014	2.6799
11*	1.6879	1.4744	1.5853	1.3655	1.4642	1.2709	1.8853	3.6851
12*	1.4932	1.5122	1.3662	1.4649	1.3935	1.2648	2.2839	
13*	1.4758	1.4591	1.4605	1.2709	1.2645	1.2454	2.6094	
14*	1.3180	1.3120	1.3009	1.8847	2.2838	2.6097		
15 *	2.5570	2.5187	2.6793	3.6595				

C1C26 Core Operating Limits Report

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.5953	1.6635	1.5398	1.7117	1.4787	1.4566	1.2902	2.5609
9*	1.6635	1.4345	1.5254	1.4680	1.5077	1.4379	1.2835	2.5196
10*	1.5398	1.5272	1.6426	1.5929	1.3495	1.4541	1.2689	2.6686
11*	1.7117	1.4686	1.5936	1.3535	1.4586	1.2496	1.8781	3.7032
12*	1.4787	1.5077	1.3495	1.4590	1.3720	1.2426	2.2897	
13*	1.4566	1.4376	1.4532	1.2496	1.2423	1.2114	2.6003	
14*	1.2902	1.2832	1.2685	1.8776	2.2898	2.6007		
15 *	2.5609	2.5186	2.6680	3.6843				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.6479	1.7198	1.5854	1.7699	1.5078	1.4776	1.3033	2.6071
9*	1.7198	1.4748	1.5744	1.5010	1.5396	1.4563	1.2960	2.5669
10*	1.5854	1.5765	1.6966	1.6261	1.3671	1.4747	1.2775	2.7058
11*	1.7699	1.5016	1.6266	1.3776	1.4847	1.2647	1.8962	3.7682
12*	1.5078	1.5396	1.3672	1.4854	1.3896	1.2608	2.3356	
13*	1.4776	1.4559	1.4730	1.2648	1.2606	1.2206	2.6448	
14*	1.3033	1.2957	1.2770	1.8957	2.3359	2.6452		
15 *	2.6071	2.5658	2.7054	3.7495				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.7130	1.7923	1.6423	1.8408	1.5452	1.5097	1.3251	2.7092
9*	1.7922	1.5267	1.6355	1.5433	1.5862	1.4865	1.3175	2.6616
10*	1.6423	1.6379	1.7641	1.6782	1.3936	1.5102	1.2975	2.8100
11*	1.8408	1.5441	1.6791	1.4088	1.5196	1.2854	1.9605	3.9269
12*	1.5452	1.5862	1.3937	1.5202	1.4107	1.2789	2.4204	
13*	1.5097	1.4861	1.5092	1.2855	1.2787	1.2351	2.7431	
14*	1.3251	1.3172	1.2970	1.9601	2.4210	2.7436		
15 *	2.7092	2.6604	2.8098	3.9213				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.8201	1.9048	1.7371	1.9470	1.6164	1.5723	1.3761	2.8462
9*	1.9048	1.6129	1.7300	1.6208	1.6648	1.5470	1.3683	2.7949
10*	1.7371	1.7327	1.8663	1.7661	1.4551	1.5790	1.3473	2.9498
11*	1.9470	1.6217	1.7671	1.4763	1.5906	1.3396	2.0544	4.1378
12*	1.6164	1.6648	1.4552	1.5915	1.4676	1.3325	2.5456	
13*	1.5723	1.5466	1.5778	1.3397	1.3324	1.2795	2.8796	
14*	1.3761	1.3679	1.3467	2.0542	2.5463	2.8802		
15 *	2.8462	2.7935	2.9498	4.1381				



C1C26 Core Operating Limits Report

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.9585	2.0458	1.8524	2.0777	1.7048	1.6538	1.4426	3.0280
9*	2.0458	1.7173	1.8459	1.7169	1.7654	1.6265	1.4346	2.9698
10*	1.8524	1.8489	1.9921	1.8793	1.5364	1.6680	1.4134	3.1387
11*	2.0777	1.7178	1.8804	1.5656	1.6865	1.4135	2.1853	4.4177
12*	1.7048	1.7655	1.5365	1.6875	1.5547	1.4083	2.7204	
13*	1.6538	1.6260	1.6666	1.4136	1.4082	1.3464	3.0774	
14*	1.4426	1.4342	1.4129	2.1851	2.7214	3.0781		
15 *	3.0280	2.9683	3.1389	4.4243				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	2.1134	2.2017	1.9950	2.2359	1.8420	1.7782	1.5534	3.1877
9*	2.2017	1.8603	2.0000	1.8650	1.9066	1.7489	1.5453	3.1423
10*	1.9950	2.0031	2.1551	2.0322	1.6727	1.7997	1.5254	3.3148
11*	2.2359	1.8661	2.0332	1.7077	1.8308	1.5395	2.3217	4.6805
12*	1.8420	1.9066	1.6728	1.8314	1.6923	1.5374	2.9071	
13*	1.7782	1.7484	1.7982	1.5397	1.5373	1.4664	3.2910	
14*	1.5534	1.5449	1.5249	2.3217	2.9084	3.2918		
15 *	3.1877	3.1409	3.3153	4.6772				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	2.2134	2.3072	2.0716	2.3304	1.9218	1.8565	1.6132	3.4024
9*	2.3072	1.9325	2.0859	1.9476	2.0111	1.8274	1.6063	3.3413
10*	2.0716	2.0893	2.2504	2.1607	1.7635	1.8903	1.5924	3.5387
11*	2.3304	1.9487	2.1620	1.8111	1.9492	1.6258	2.4964	5.0260
12*	1.9218	2.0112	1.7636	1.9504	1.7947	1.6246	3.1537	
13*	1.8565	1.8268	1.8886	1.6260	1.6245	1.5482	3.5742	
14*	1.6132	1.6059	1.5918	2.4965	3.1554	3.5751		
15 *	3.4024	3.3396	3.5394	5.0452				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	2.3179	2.4077	2.1560	2.4335	2.0143	1.9672	1.7058	3.6030
9*	2.4077	2.0176	2.1829	2.0353	2.1142	1.9360	1.6992	3.5406
10*	2.1560	2.1864	2.3523	2.2628	1.8701	2.0090	1.6870	3.7503
11*	2.4335	2.0367	2.2643	1.9097	2.0752	1.7276	2.6545	5.2875
12*	2.0143	2.1144	1.8703	2.0765	1.9151	1.7309	3.3436	
13*	1.9672	1.9354	2.0072	1.7279	1.7309	1.6511	3.8247	
14*	1.7058	1.6988	1.6865	2.6547	3.3456	3.8258		
15 *	3.6030	3.5392	3.7515	5.3136				

C1C26 Core Operating Limits Report

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
	*****							
8*	2.2809	2.3708	2.1279	2.3928	1.9974	1.9432	1.6921	3.5444
9*	2.3708	1.9873	2.1469	2.0113	2.0918	1.9153	1.6877	3.4977
10*	2.1279	2.1506	2.3120	2.2348	1.8538	1.9906	1.6837	3.7017
11*	2.3928	2.0126	2.2363	1.9015	2.0419	1.7246	2.5995	5.2912
12*	1.9974	2.0920	1.8540	2.0428	1.9542	1.7474	3.3433	
13*	1.9432	1.9147	1.9888	1.7249	1.7474	1.7032	3.8621	
14*	1.6921	1.6873	1.6831	2.5998	3.3455	3.8633		
15 *	3.5444	3.4960	3.7029	5.3050				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
	*****							
8*	2.2067	2.2949	2.0436	2.3063	1.9194	1.8735	1.6232	3.4886
9*	2.2949	1.9072	2.0690	1.9232	2.0246	1.8444	1.6184	3.4274
10*	2.0436	2.0727	2.2300	2.1561	1.7915	1.9236	1.6175	3.6381
11*	2.3063	1.9245	2.1576	1.8317	2.0021	1.6685	2.5657	5.1821
12*	1.9194	2.0249	1.7911	2.0036	1.8893	1.6881	3.2970	
13*	1.8735	1.8438	1.9217	1.6688	1.6882	1.6374	3.8172	
14*	1.6232	1.6180	1.6170	2.5661	3.2993	3.8184		
15 *	3.4886	3.4256	3.6394	5.2209				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
	*****							
8*	2.0917	2.1733	1.9302	2.1862	1.8092	1.7681	1.5275	3.2946
9*	2.1733	1.8039	1.9623	1.8193	1.9122	1.7397	1.5226	3.2322
10*	1.9302	1.9660	2.1141	2.0439	1.6783	1.8114	1.5186	3.4264
11*	2.1862	1.8205	2.0454	1.7289	1.8781	1.5622	2.4081	4.9060
12*	1.8092	1.9124	1.6785	1.8796	1.7803	1.5820	3.1019	
13*	1.7681	1.7391	1.8095	1.5626	1.5820	1.5310	3.5704	
14*	1.5275	1.5223	1.5181	2.4086	3.1044	3.5716		
15 *	3.2946	3.2306	3.4279	4.9493				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
	*****							
8*	1.9856	2.0653	1.8338	2.0791	1.7110	1.6663	1.4378	3.1156
9*	2.0653	1.7108	1.8628	1.7221	1.8075	1.6379	1.4327	3.0573
10*	1.8338	1.8664	2.0077	1.9317	1.5775	1.7047	1.4263	3.2326
11*	2.0791	1.7234	1.9332	1.6264	1.7649	1.4642	2.2596	4.6343
12*	1.7110	1.8077	1.5778	1.7664	1.6634	1.4819	2.9153	
13*	1.6663	1.6373	1.7029	1.4646	1.4820	1.4276	3.3476	
14*	1.4378	1.4323	1.4259	2.2602	2.9176	3.3488		
15 *	3.1156	3.0557	3.2342	4.6785				

C1C26 Core Operating Limits Report

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.9054	1.9837	1.7668	1.9990	1.6425	1.5906	1.3738	2.9528
9*	1.9837	1.6451	1.7887	1.6539	1.7284	1.5619	1.3683	2.9056
10*	1.7668	1.7923	1.9281	1.8453	1.5059	1.6251	1.3597	3.0557
11*	1.9990	1.6552	1.8468	1.5526	1.6707	1.3932	2.1267	4.3864
12*	1.6425	1.7286	1.5062	1.6716	1.5719	1.4072	2.7414	
13*	1.5906	1.5614	1.6234	1.3935	1.4073	1.3495	3.1361	
14*	1.3738	1.3680	1.3593	2.1272	2.7438	3.1372		
15 *	2.9528	2.9041	3.0573	4.4150				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.7996	1.8811	1.6664	1.9016	1.5462	1.4985	1.2873	2.8614
9*	1.8811	1.5500	1.6952	1.5564	1.6386	1.4703	1.2821	2.8019
10*	1.6664	1.6988	1.8310	1.7478	1.4104	1.5313	1.2733	2.9615
11*	1.9016	1.5576	1.7493	1.4572	1.5819	1.3019	2.0477	4.2574
12*	1.5462	1.6387	1.4107	1.5833	1.4602	1.3108	2.6442	
13*	1.4985	1.4697	1.5295	1.3022	1.3109	1.2504	3.0231	
14*	1.2873	1.2818	1.2729	2.0482	2.6465	3.0242		
15 *	2.8614	2.8005	2.9631	4.3069				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.7210	1.8037	1.5974	1.8278	1.4879	1.4389	1.2353	2.7734
9*	1.8037	1.4830	1.6232	1.4904	1.5760	1.4108	1.2300	2.7144
10*	1.5974	1.6268	1.7562	1.6737	1.3511	1.4690	1.2200	2.8681
11*	1.8278	1.4917	1.6751	1.3935	1.5161	1.2452	1.9683	4.1146
12*	1.4879	1.5762	1.3514	1.5176	1.3888	1.2521	2.5477	
13*	1.4389	1.4102	1.4672	1.2455	1.2522	1.1909	2.9106	
14*	1.2353	1.2297	1.2196	1.9688	2.5500	2.9116		
15 *	2.7734	2.7130	2.8697	4.1651				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.6813	1.7630	1.5734	1.7875	1.4646	1.4123	1.2200	2.6837
9*	1.7630	1.4572	1.5852	1.4691	1.5391	1.3845	1.2145	2.6389
10*	1.5734	1.5888	1.7154	1.6356	1.3346	1.4415	1.2046	2.7728
11*	1.7875	1.4704	1.6371	1.3689	1.4803	1.2284	1.8959	3.9662
12*	1.4646	1.5393	1.3349	1.4812	1.3597	1.2347	2.4529	
13*	1.4123	1.3840	1.4398	1.2287	1.2348	1.1748	2.8025	
14*	1.2200	1.2142	1.2043	1.8964	2.4549	2.8036		
15 *	2.6837	2.6374	2.7744	3.9967				

C1C26 Core Operating Limits Report

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.6298	1.7091	1.5225	1.7249	1.4228	1.3758	1.1916	2.6641
9*	1.7091	1.4106	1.5310	1.4257	1.4966	1.3498	1.1869	2.6119
10*	1.5225	1.5345	1.6614	1.5919	1.2988	1.4075	1.1810	2.7677
11*	1.7249	1.4269	1.5933	1.3347	1.4482	1.2017	1.8863	3.9639
12*	1.4228	1.4969	1.2991	1.4495	1.3244	1.2076	2.4427	
13*	1.3758	1.3493	1.4058	1.2020	1.2077	1.1518	2.8150	
14*	1.1916	1.1866	1.1806	1.8869	2.4450	2.8161		
15 *	2.6641	2.6106	2.7695	4.0117				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.6588	1.7164	1.5229	1.6983	1.4492	1.4069	1.2241	2.6630
9*	1.7164	1.4308	1.5421	1.4409	1.5152	1.3829	1.2210	2.6208
10*	1.5229	1.5455	1.6846	1.6001	1.3274	1.4488	1.2258	2.8061
11*	1.6983	1.4422	1.6015	1.3511	1.4678	1.2343	1.9170	4.0656
12*	1.4492	1.5154	1.3277	1.4691	1.3486	1.2375	2.4586	
13*	1.4069	1.3825	1.4473	1.2346	1.2376	1.2003	2.8879	
14*	1.2241	1.2207	1.2255	1.9177	2.4608	2.8890		
15 *	2.6630	2.6197	2.8081	4.1177				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	1.9329	1.8827	1.4120	1.8534	1.3816	1.6408	1.2911	2.9293
9*	1.8827	1.4059	1.7291	1.3837	1.7439	1.6143	1.2998	2.9001
10*	1.4120	1.7305	1.9591	1.7823	1.3296	1.6609	1.3849	3.1691
11*	1.8534	1.3850	1.7835	1.3246	1.6791	1.3219	2.1667	4.6993
12*	1.3816	1.7452	1.3299	1.6801	1.5528	1.2944	2.6820	
13*	1.6408	1.6138	1.6592	1.3222	1.2947	1.4354	3.3528	
14*	1.2911	1.2995	1.3848	2.1676	2.6840	3.3542		
15 *	2.9293	2.8989	3.1716	4.7570				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24  
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
*****	*****	*****	*****	*****	*****	*****	*****	*****
8*	4.6271	4.2631	3.2768	4.1300	3.2417	4.0586	3.4466	6.7309
9*	4.2631	3.3418	4.0888	3.2568	4.1022	4.0255	3.4801	6.7644
10*	3.2768	4.0948	4.4606	4.0680	3.1888	4.0745	3.7628	7.3429
11*	4.1300	3.2599	4.0705	3.2189	3.9750	3.3221	5.0440	10.8845
12*	3.2417	4.1050	3.1897	3.9777	3.9393	3.4460	6.1716	
13*	4.0586	4.0248	4.0724	3.3229	3.4468	3.9222	7.8679	
14*	3.4466	3.4795	3.7631	5.0466	6.1740	7.8714		
15 *	6.7309	6.7616	7.3485	10.9147				

C1C26 Core Operating Limits Report

TABLE A-6

F-DEL-H & M-DEL-H VALUES - POWER ESCALATION

AT 100% POWER, 4 EFPD								
	H	G	F	E	D	C	B	A
8	* 1.2070	* 1.1671	* 1.2028	* 1.1607	* 1.2685	* 1.3876	* 1.4410	* 0.6851
	* 1.4481	* 1.5117	* 1.4712	* 1.4889	* 1.3668	* 1.2614	* 1.2336	* 2.4129
9	* 1.1671	* 1.2884	* 1.2914	* 1.2788	* 1.3093	* 1.4076	* 1.4451	* 0.6971
	* 1.5117	* 1.3882	* 1.3554	* 1.3722	* 1.3291	* 1.2491	* 1.2324	* 2.3810
10	* 1.2028	* 1.2887	* 1.1944	* 1.2402	* 1.3744	* 1.3561	* 1.4447	* 0.6496
	* 1.4712	* 1.3591	* 1.4629	* 1.4373	* 1.3039	* 1.3290	* 1.2411	* 2.5778
11	* 1.1607	* 1.2777	* 1.2393	* 1.3707	* 1.3375	* 1.4463	* 0.9564	* 0.4596
	* 1.4889	* 1.3732	* 1.4381	* 1.3014	* 1.3288	* 1.2655	* 1.8447	* 3.6743
12	* 1.2685	* 1.3091	* 1.3741	* 1.3364	* 1.3969	* 1.4275	* 0.7379	*
	* 1.3668	* 1.3292	* 1.3041	* 1.3298	* 1.2693	* 1.2729	* 2.3358	*
13	* 1.3876	* 1.4081	* 1.3574	* 1.4461	* 1.4275	* 1.4320	* 0.6253	*
	* 1.2614	* 1.2487	* 1.3277	* 1.2657	* 1.2728	* 1.2602	* 2.7207	*
14	* 1.4410	* 1.4454	* 1.4452	* 0.9564	* 0.7368	* 0.6251	*	*
	* 1.2336	* 1.2322	* 1.2408	* 1.8440	* 2.3383	* 2.7212	*	*
15	* 0.6851	* 0.6976	* 0.6494	* 0.4499	* F-DEL-H			
	* 2.4129	* 2.3790	* 2.5769	* 3.7334	* M-DEL-H			

AT 75% POWER, 4 EFPD								
	H	G	F	E	D	C	B	A
8	* 1.1925	* 1.1519	* 1.1875	* 1.1491	* 1.2737	* 1.4072	* 1.4596	* 0.6830
	* 1.7539	* 1.8342	* 1.6094	* 1.6976	* 1.5564	* 1.4219	* 1.3871	* 2.7359
9	* 1.1519	* 1.2761	* 1.2837	* 1.2721	* 1.3160	* 1.4278	* 1.4637	* 0.6945
	* 1.8342	* 1.6337	* 1.5557	* 1.5832	* 1.5136	* 1.4091	* 1.3929	* 2.7057
10	* 1.1875	* 1.2810	* 1.1852	* 1.2389	* 1.3828	* 1.3722	* 1.4612	* 0.6465
	* 1.6094	* 1.5601	* 1.6966	* 1.6656	* 1.5376	* 1.5023	* 1.4130	* 2.9542
11	* 1.1491	* 1.2710	* 1.2380	* 1.3747	* 1.3478	* 1.4575	* 0.9583	* 0.4536
	* 1.6976	* 1.5841	* 1.6666	* 1.5945	* 1.6199	* 1.5047	* 2.1810	* 4.2822
12	* 1.2737	* 1.3159	* 1.3825	* 1.3467	* 1.4130	* 1.4385	* 0.7338	*
	* 1.5564	* 1.5137	* 1.5373	* 1.6211	* 1.5156	* 1.5115	* 2.8170	*
13	* 1.4072	* 1.4284	* 1.3737	* 1.4573	* 1.4386	* 1.4453	* 0.6211	*
	* 1.4219	* 1.4086	* 1.5009	* 1.5048	* 1.5114	* 1.4882	* 3.2893	*
14	* 1.4596	* 1.4641	* 1.4617	* 0.9584	* 0.7328	* 0.6209	*	*
	* 1.3871	* 1.3925	* 1.4123	* 2.1796	* 2.8196	* 3.2898	*	*
15	* 0.6830	* 0.6951	* 0.6463	* 0.4443	* F-DEL-H			
	* 2.7359	* 2.7033	* 2.9523	* 4.3376	* M-DEL-H			

C1C26 Core Operating Limits Report

TABLE A-6 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - POWER ESCALATION

AT 50% POWER, 4 EFPD								
	H	G	F	E	D	C	B	A
8	* 1.1744	* 1.1332	* 1.1695	* 1.1354	* 1.2801	* 1.4280	* 1.4801	* 0.6824
	* 1.6544	* 1.8231	* 1.5755	* 1.6614	* 1.4469	* 1.3336	* 1.3224	* 2.6765
9	* 1.1332	* 1.2619	* 1.2726	* 1.2640	* 1.3220	* 1.4492	* 1.4842	* 0.6934
	* 1.8231	* 1.6169	* 1.5216	* 1.5562	* 1.4660	* 1.3248	* 1.3532	* 2.6532
10	* 1.1695	* 1.2697	* 1.1729	* 1.2361	* 1.3910	* 1.3898	* 1.4797	* 0.6446
	* 1.5755	* 1.5255	* 1.6602	* 1.6298	* 1.4806	* 1.4302	* 1.3810	* 2.9103
11	* 1.1354	* 1.2628	* 1.2352	* 1.3782	* 1.3578	* 1.4693	* 0.9613	* 0.4485
	* 1.6614	* 1.5571	* 1.6309	* 1.5405	* 1.5344	* 1.4555	* 2.1577	* 4.2945
12	* 1.2801	* 1.3220	* 1.3907	* 1.3567	* 1.4305	* 1.4508	* 0.7309	*
	* 1.4469	* 1.4660	* 1.4802	* 1.5353	* 1.4222	* 1.4870	* 2.7422	*
13	* 1.4280	* 1.4498	* 1.3914	* 1.4691	* 1.4509	* 1.4614	* 0.6182	*
	* 1.3336	* 1.3244	* 1.4288	* 1.4555	* 1.4868	* 1.4380	* 3.1876	*
14	* 1.4801	* 1.4846	* 1.4803	* 0.9615	* 0.7300	* 0.6181	*	*
	* 1.3224	* 1.3527	* 1.3801	* 2.1561	* 2.7444	* 3.1880	*	*
15	* 0.6824	* 0.6941	* 0.6446	* 0.4394	* F-DEL-H			
	* 2.6765	* 2.6507	* 2.9081	* 4.3414	* M-DEL-H			

AT 30% POWER, 4 EFPD								
	H	G	F	E	D	C	B	A
8	* 1.1563	* 1.1148	* 1.1528	* 1.1248	* 1.2859	* 1.4466	* 1.4991	* 0.6826
	* 1.6544	* 1.8231	* 1.5755	* 1.6614	* 1.4469	* 1.3336	* 1.3224	* 2.6765
9	* 1.1148	* 1.2476	* 1.2623	* 1.2566	* 1.3271	* 1.4682	* 1.5032	* 0.6932
	* 1.8231	* 1.6169	* 1.5216	* 1.5562	* 1.4660	* 1.3248	* 1.3532	* 2.6532
10	* 1.1528	* 1.2580	* 1.1606	* 1.2331	* 1.3981	* 1.4054	* 1.4968	* 0.6437
	* 1.5755	* 1.5255	* 1.6602	* 1.6298	* 1.4806	* 1.4302	* 1.3810	* 2.9103
11	* 1.1248	* 1.2556	* 1.2322	* 1.3811	* 1.3664	* 1.4799	* 0.9647	* 0.4442
	* 1.6614	* 1.5571	* 1.6309	* 1.5405	* 1.5344	* 1.4555	* 2.1577	* 4.2945
12	* 1.2859	* 1.3270	* 1.3980	* 1.3653	* 1.4464	* 1.4623	* 0.7291	*
	* 1.4469	* 1.4660	* 1.4802	* 1.5353	* 1.4222	* 1.4870	* 2.7422	*
13	* 1.4466	* 1.4689	* 1.4071	* 1.4798	* 1.4624	* 1.4767	* 0.6164	*
	* 1.3336	* 1.3244	* 1.4288	* 1.4555	* 1.4868	* 1.4380	* 3.1876	*
14	* 1.4991	* 1.5036	* 1.4975	* 0.9649	* 0.7282	* 0.6162	*	*
	* 1.3224	* 1.3527	* 1.3801	* 2.1561	* 2.7444	* 3.1880	*	*
15	* 0.6826	* 0.6939	* 0.6437	* 0.4354	* F-DEL-H			
	* 2.6765	* 2.6507	* 2.9081	* 4.3414	* M-DEL-H			