



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 22, 2020

Mr. Bryan C. Hanson
Senior Vice President
Exelon Generation Company, LLC
President and Chief Nuclear Officer (CNO)
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2 – CORRECTION
OF LICENSE AMENDMENT NOS. 333 AND 311 FOR DELETION OF E-BAR
DEFINITION AND REVISION TO REACTOR COOLANT SYSTEM SPECIFIC
ACTIVITY TECHNICAL SPECIFICATIONS (EPID L- 2019- LLA-0102)

Dear Mr. Hanson:

By letter dated February 28, 2020 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML19337D035), the U.S. Nuclear Regulatory Commission issued Amendment No. 333 to Renewed Facility Operating License No. DPR-53 and Amendment No. 311 to Renewed Facility Operating License No. DPR-69 for the Calvert Cliffs Nuclear Power Plant, Units 1 and 2 (Calvert Cliffs), respectively. The amendments were in response to the license amendment request by Exelon Generation Company, LLC dated May 6, 2019 (ADAMS Accession No. ML19127A076). The amendments revised the Calvert Cliffs, Units 1 and 2, Technical Specification (TS) requirements relating to reactor coolant system activity limits.

When these amendments were issued, the abbreviation for microcuries per gram was incorrectly written on replacement TS page 3.4.15-2. The issued replacement page incorrectly abbreviated microcuries per gram as $\mu\text{Ci/gm}$. The correct abbreviation is $\mu\text{Ci/gm}$.

The corrected Calvert Cliffs TS page 3.4.15-2 is enclosed. Please remove current page 3.4.15-2 and insert corrected page 3.4.15-2, which is applicable to both Units 1 and 2. The other TS pages issued as part of Amendment Nos. 333 and 331 were not affected by this error.

If you have any questions, please contact me at (301) 415-2781 or by e-mail to Michael.Marshall@nrc.gov.

Sincerely,

/RA/

Michael L. Marshall, Jr., Senior Project Manager
Plant Licensing Branch I
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

Enclosure:
Corrected TS page 3.4.15-2

cc: Listserv

ENCLOSURE

CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2

CORRECTED TS PAGE 3.4.15-2

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. DOSE EQUIVALENT XE-133 > 630 μ Ci/gm.	-----NOTE----- LC0 3.0.4.c is applicable. -----	
	B.1 Restore DOSE EQUIVALENT XE-133 to within limit.	48 hours
C. Required Action and associated Completion Time of Condition A or B not met. <u>OR</u> DOSE EQUIVALENT I-131 > 30 μ Ci/gm.	C.1 Be in MODE 3	6 hours
	<u>AND</u> C.2 Be in MODE 5	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.15.1 Verify reactor coolant DOSE EQUIVALENT XE-133 specific activity \leq 630 μ Ci/gm.	In accordance with the Surveillance Frequency Control Program

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2 – CORRECTION
OF LICENSE AMENDMENT NOS. 333 AND 311 FOR DELETION OF E-BAR
DEFINITION AND REVISION TO REACTOR COOLANT SYSTEM SPECIFIC
ACTIVITY TECHNICAL SPECIFICATIONS (EPID L- 2019- LLA-0102)
DATED JUNE 22, 2020

DISTRIBUTION:

PUBLIC

PM File Copy

RidsNrrDorLpl1 Resource

RidsNrrLALRonewicz Resource

RidsRgn1MailCenter Resource

RidsNrrPMCalvertCliffs Resource

ADAMS Accession No.: ML20167A041

OFFICE	NRC/NRR/DORL/LPL1/PM	/NRC/NRR/DORL/LPL1/LA	NRC/NRR/DORL/LPL1/BC
NAME	MMarshall	LRonewicz	JDanna
DATE	06/15/2020	06/15/2020	06/22/2020
OFFICE	NRC/NRR/DORL/LPL1/PM		
NAME	MMarshall		
DATE	06/22/2020		

OFFICIAL RECORD COPY