



June 18, 2020

10 CFR 50.90
Docket No. 50-443
SBK-L-20081

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Seabrook Station

Withdrawal of Relief Request SG-1, Proposed Alternative in Accordance with 10 CFR
50.55a(z)(1), Use of Code Case OMN-13 with 2012 Edition of the OM Code

References:

1. NextEra Energy Seabrook, LLC letter SBK-L-20017 "Relief Request SG-1, Proposed Alternative in Accordance in with 10 CFR 50.55a(z)(1), Use of Code Case OMN-13 with 2012 Edition of the OM Code," March 20, 2020 (ML#20080J159)

In Reference 1, NextEra Energy Seabrook, LLC (NextEra) submitted a relief request to allow the use of American Society of Mechanical Engineers (ASME) approved Code Case (CC) OMN-13, "Performance-Based Requirements for Extending Snubber Inservice Visual Examination Interval at LWR Power Plants," Revision 2. At the time of submittal of Reference 1, CC OMN-13 was only applicable to ASME OM Code 1995 Edition through 2011 Addenda. The fourth interval of the Seabrook Station Inservice Test Program (IST) will comply with the ASME OM Code, 2012 Edition.


Regulatory Guide 1.192, Revision 3, "Operation and Maintenance Code Case Acceptability, ASME OM Code", published in the Federal Register on March 16, 2020, lists the Code Cases that the U.S. Nuclear Regulatory Commission (NRC) has approved for use as voluntary alternatives to the mandatory ASME OM Code provisions, which includes endorsement of CC OMN-13.

Due to the issuance of Regulatory Guide 1.192, Revision 3, this relief request is no longer required. NextEra hereby withdraws the relief request.

Should you have any questions regarding this information, please contact me at (603) 773-7932.

Sincerely,

NextEra Energy Seabrook, LLC

A handwritten signature in cursive script, appearing to read "Kenneth J. Browne", is written over a horizontal line.

Kenneth J. Browne
Safety Assurance and Learning Site Director
NextEra Energy Seabrook, LLC

cc

NRC Region I Administrator
NRC Project Manager
NRC Senior Resident Inspector