

From: Cotton, Karen
Sent: Tuesday, July 7, 2020 12:18 PM
To: naira@dhec.sc.gov
Subject: Request for State Comments
Attachments: State comments Catawba Pressure Temperature limits LARcted.docx

Anuradha,

Hello,

I am Karen Cotton-Gross, the new PM for Catawba Nuclear Station. Please find attached a request for state comments. The original email's Federal Register Notice information is corrected. Please let me know if you have comments,

Best,

Karen

Hearing Identifier: NRR_DRMA
Email Number: 665

Mail Envelope Properties (SA9PR09MB54868FF248C56338E895118985660)

Subject: Request for State Comments
Sent Date: 7/7/2020 12:18:18 PM
Received Date: 7/7/2020 12:18:18 PM
From: Cotton, Karen

Created By: Karen.Cotton@nrc.gov

Recipients:
"naira@dhec.sc.gov" <naira@dhec.sc.gov>
Tracking Status: None

Post Office: SA9PR09MB5486.namprd09.prod.outlook.com

Files	Size	Date & Time	
MESSAGE	271	7/7/2020 12:18:18 PM	
State comments Catawba Pressure Temperature limits LARcted.docx			14503

Options
Priority: Normal
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:

Pursuant to 10 CFR 50.91(b), "State Consultation", I am notifying you that the NRC staff is currently processing an amendment for the Catawba Nuclear Power Station, Unit No. 1. The NRC staff has determined that the amendment request involves no significant hazards consideration. The analysis on the issue of no significant hazards consideration is published in the *Federal Register* as shown in the table.

Plant	EPID No.	Accession #	FR Page	Description
Catawba	L-2019-0141	ML19183A038, as supplemented by ML20044C924	84 FR 59657 November 05, 2019	The proposed amendment revises the Catawba, Unit 1, Technical Specification (TS) 3.4.3, "RCS Pressure and Temperature (P/T) Limits," to reflect an update to the P/T limit curves in Figures 3.4.3-1 (Unit 1 only) and 3.4.3-2 (Unit 1 only). The proposed change will also reflect that the revised Catawba, Unit 1 P/T limit curves in TS 3.4.3 are applicable until 42.7 effective full power years (EFPY). Although the proposed change only impacts Catawba, Unit 1, the TS are common to both units.

You may contact me if you have any comments on this amendment. Please verify that you have received no comments.

Thanks,

Karen Cotton-Gross