



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION I
2100 RENAISSANCE BOULEVARD, SUITE 100
KING OF PRUSSIA, PENNSYLVANIA 19406-2713

November 10, 2020

Mr. Bryan C. Hanson
Senior Vice President
Exelon Generation Company, LLC
President and Chief Nuclear Officer
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: R. E. GINNA NUCLEAR POWER PLANT, LLC – INTEGRATED INSPECTION
REPORT 05000244/2020003

Dear Mr. Hanson:

On September 30, 2020, the U.S. Nuclear Regulatory Commission (NRC) completed an inspection at R. E. Ginna Nuclear Power Plant, LLC. On October 16, 2020, the NRC inspectors discussed the results of this inspection with Mr. Paul Swift, Site Vice President and other members of your staff. The results of this inspection are documented in the enclosed report.

No findings or violations of more than minor significance were identified during this inspection.

This letter, its enclosure, and your response (if any) will be made available for public inspection and copying at <http://www.nrc.gov/reading-rm/adams.html> and at the NRC Public Document Room in accordance with Title 10 of the *Code of Federal Regulations* 2.390, "Public Inspections, Exemptions, Requests for Withholding."

Sincerely,

X /RA/

Signed by: Erin E. Carfang
Erin E. Carfang, Chief
Reactor Projects Branch 1
Division of Reactor Projects

Docket No. 05000244
License No. DPR-18

Enclosure:
As stated

cc w/ encl: Distribution via LISTSERV®

SUBJECT: R. E. GINNA NUCLEAR POWER PLANT, LLC – INTEGRATED INSPECTION
REPORT 05000244/2020003 DATED NOVEMBER 10, 2020

DISTRIBUTION: (via E-mail)
DLew, RA (R1ORAMAIL RESOURCE)
RLorson, DRA (R1ORAMAIL RESOURCE)
DCollins, DRP (R1DRPMAIL RESOURCE)
BPham, DRP (R1DRPMAIL RESOURCE)
JYerokun, DRS (R1DRSMAIL RESOURCE)
PKrohn, DRS (R1DRSMAIL RESOURCE)
ECarfang, DRP
CLally, DRP
CSwisher, DRP
JSchussler, DRP, SRI
SMonarque, DRP, RI
KTennity, DRP
RSkokowski, RI, OEDO
RidsNrrPMREGinna Resource
RidsNrrDorlLpl1 Resource
ROPReports Resource

DOCUMENT NAME: <https://usnrc.sharepoint.com/teams/Region-I-Branch-1/Shared Documents/Inspection Reports/GN/Word Final Report 2020-003.docx>

ADAMS ACCESSION NUMBER: ML20315A368

<input checked="" type="checkbox"/> SUNSI Review		<input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Sensitive		<input checked="" type="checkbox"/> Publicly Available <input type="checkbox"/> Non-Publicly Available	
OFFICE	R1/DRP	R1/DRP	R1/DRP		
NAME	Jschussler/via email	CLally/via email	ECarfang/via email		
DATE	11/09/2020	11/09/2020	11/10/2020		

OFFICIAL RECORD COPY

U.S. NUCLEAR REGULATORY COMMISSION
Inspection Report

Docket Number: 05000244

License Number: DPR-18

Report Number: 05000244/2020003

Enterprise Identifier: I-2020-003-0041

Licensee: Exelon Generation Company, LLC

Facility: R. E. Ginna Nuclear Power Plant, LLC

Location: Ontario, New York

Inspection Dates: July 1, 2020 to September 30, 2020

Inspectors: J. Schussler, Senior Resident Inspector
S. Monarque, Resident Inspector
J. DeBoer, Reactor Inspector
S. Elkhiamy, Operations Engineer
J. Rady, Emergency Preparedness Inspector
J. Schoppy, Senior Reactor Inspector
S. Shaffer, Senior Health Physicist

Approved By: Erin E. Carfang, Chief
Reactor Projects Branch 1
Division of Reactor Projects

Enclosure

SUMMARY

The U.S. Nuclear Regulatory Commission (NRC) continued monitoring the licensee's performance by conducting an integrated inspection at R. E. Ginna Nuclear Power Plant, LLC, in accordance with the Reactor Oversight Process. The Reactor Oversight Process is the NRC's program for overseeing the safe operation of commercial nuclear power reactors. Refer to <https://www.nrc.gov/reactors/operating/oversight.html> for more information.

List of Findings and Violations

No findings or violations of more than minor significance were identified.

Additional Tracking Items

None.

PLANT STATUS

Ginna began the inspection period at 100 percent power. The unit remained at, or near, 100 percent power for the entire inspection period.

INSPECTION SCOPES

Inspections were conducted using the appropriate portions of the inspection procedures (IPs) in effect at the beginning of the inspection unless otherwise noted. Currently approved IPs with their attached revision histories are located on the public website at <http://www.nrc.gov/reading-rm/doc-collections/insp-manual/inspection-procedure/index.html>. Samples were declared complete when the IP requirements most appropriate to the inspection activity were met consistent with Inspection Manual Chapter (IMC) 2515, "Light-Water Reactor Inspection Program - Operations Phase." The inspectors reviewed selected procedures and records, observed activities, and interviewed personnel to assess licensee performance and compliance with Commission rules and regulations, license conditions, site procedures, and standards. Starting on March 20, 2020, in response to the National Emergency declared by the President of the United States on the public health risks of the coronavirus (COVID-19), resident and regional inspectors were directed to begin telework and to remotely access licensee information using available technology. During this time the resident inspectors performed periodic site visits each week, increasing the amount of time on site as local COVID-19 conditions permitted. As part of their onsite activities, resident inspectors conducted plant status activities as described in IMC 2515, Appendix D; observed risk significant activities; and completed on site portions of IPs. In addition, resident and regional baseline inspections were evaluated to determine if all or portion of the objectives and requirements stated in the IP could be performed remotely. If the inspections could be performed remotely, they were conducted per the applicable IP. In some cases, portions of an IP were completed remotely and on site. The inspections documented below met the objectives and requirements for completion of the IP.

REACTOR SAFETY

71111.04 - Equipment Alignment

Partial Walkdown Sample (IP Section 03.01) (1 Sample)

The inspectors evaluated system configurations during partial walkdowns of the following systems/trains:

- (1) 'B' service water system alignment following scheduled surveillance testing
September 29, 2020

71111.05 - Fire Protection

Fire Area Walkdown and Inspection Sample (IP Section 03.01) (4 Samples)

The inspectors evaluated the implementation of the fire protection program by conducting a walkdown and performing a review to verify program compliance, equipment functionality, material condition, and operational readiness of the following fire areas:

- (1) Turbine building main feedwater pump room on July 23, 2020
- (2) Control room air handling room on August 6, 2020

- (3) Walkdown of fire piping systems S13, S24, S12, S24, and S38 on September 24, 2020
- (4) Technical support center on September 25, 2020

71111.06 - Flood Protection Measures

Inspection Activities - Internal Flooding (IP Section 03.01) (1 Sample)

The inspectors evaluated internal flooding mitigation protections of:

- (1) Door gaskets to 'B' battery and 'B' emergency diesel generator rooms on July 22, 2020

71111.07A - Heat Sink Performance

Annual Review (IP Section 03.01) (1 Sample)

The inspectors evaluated readiness and performance of:

- (1) Residual heat recovery 'B' heat exchanger on August 21, 2020

71111.07T - Heat Sink Performance

Triennial Review (IP Section 03.02) (4 Samples)

The inspectors evaluated heat exchanger/sink performance on the following on August 21, 2020:

- (1) 'B' emergency diesel generator lube oil cooler heat exchanger, cooled by service water
- (2) 'B' emergency diesel generator jacket water heat exchanger, cooled by service water
- (3) 'B' spent fuel pool heat exchanger, cooled by service water
- (4) 'B' containment recirculating fan cooler heat exchanger, cooled by service water

71111.11Q - Licensed Operator Regualification Program and Licensed Operator Performance

Licensed Operator Performance in the Actual Plant/Main Control Room (IP Section 03.01) (1 Sample)

- (1) The inspectors observed and evaluated licensed operator performance and procedure use and adherence in the main control room following an eight inch fire water pipe fitting failure that caused water to partly fill the condenser pit on September 3, 2020 and observed reactor power reduction for a planned turbine driven auxiliary feedwater surveillance and test performance on September 22, 2020

Licensed Operator Regualification Training/Examinations (IP Section 03.02) (1 Sample)

- (1) The inspectors observed and evaluated licensed operator performance in the simulator during licensed operator re-qualification training on September 3, 2020. The training involved a scenario that contained, but was not limited to, a chemical volume control system leak in the reactor coolant letdown line, a loss of one offsite circuit, a steam generator tube leak, and safety injection pump failures.

71111.12 - Maintenance Effectiveness

Maintenance Effectiveness (IP Section 03.01) (3 Samples)

The inspectors evaluated the effectiveness of maintenance to ensure the following structures, systems, and components remain capable of performing their intended function:

- (1) 'D' standby auxiliary feedwater system on August 7, 2020
- (2) Alternating current and direct current distribution system, breaker 52/MMC1G1 failure to transfer bus 18 480v loads to safety related equipment, maintenance rule action plan on August 14, 2020
- (3) Service air compressor system 11/12, maintenance rule action plan on September 28, 2020

71111.13 - Maintenance Risk Assessments and Emergent Work Control

Risk Assessment and Management Sample (IP Section 03.01) (8 Samples)

The inspectors evaluated the accuracy and completeness of risk assessments for the following planned and emergent work activities to ensure configuration changes and appropriate work controls were addressed:

- (1) Elevated risk, (yellow), during planned maintenance of 'B' emergency diesel generator air roll and replacement of 'B' battery room door gasket on July 1, 2020
- (2) Elevated risk, (yellow), during planned maintenance of service air compressor, dryer, and relief valves on July 6, 2020
- (3) Elevated risk, (yellow), during planned maintenance of 'C' standby auxiliary feedwater pump system on August 11, 2020
- (4) Elevated risk, (yellow), during planned quarterly testing of 'A' residual heat removal pump on September 1, 2020
- (5) Elevated risk, (green), during unplanned maintenance of 'B' motor driven auxiliary feedwater lube oil cooler service water system flush on September 14, 2020
- (6) Elevated risk, (green), during unplanned maintenance of turbine driven auxiliary feedwater steam admission line visual inspection for pipe integrity on September 25, 2020
- (7) Elevated risk, (green), during unplanned maintenance of fire system S04 pipe failure and associated replacement on September 25, 2020
- (8) Elevated risk, (action green), during planned maintenance of the 'B' control room emergency air treatment system cooling system on September 28, 2020

71111.15 - Operability Determinations and Functionality Assessments

Operability Determination or Functionality Assessment (IP Section 03.01) (3 Samples)

The inspectors evaluated the licensee's justifications and actions associated with the following operability determinations and functionality assessments:

- (1) OPEVAL-20-004 microprocessor rod position indication subsystem 1 DC power supply failure PS2 on August 20, 2020
- (2) 'A' steam generator level transmitter 461 instrument deviation on August 24, 2020
- (3) Service water hanger SWU-164 loose turnbuckle on September 22, 2020

71111.17T - Evaluations of Changes, Tests, and Experiments

Sample Selection (IP Section 02.01) (28 Samples)

The inspectors reviewed the following evaluations, screenings, and/or applicability determinations for 10 CFR 50.59 from September 14 through September 18, 2020.

- (1) A-2018-007, P-15.54, Diesel air compressor procedure to start, stop, ensure correct configuration control and monitor the compressors, dated February 1, 2018
- (2) A-2018-049, Increase the residual heat removal pump motor bearing oil temperature operating temperature range, dated September 12, 2018
- (3) A-2018-051, Raise spent fuel pool pump/motor temperature limits, dated September 19, 2018
- (4) A-2018-069, Revise acceptance criteria of alternate reactor coolant system injection system flow test, dated December 14, 2018
- (5) A-2019-048, Low greenhouse water level, dated July 29, 2019
- (6) A-2019-064, Technical specification basis change to clarify allowed duration of emergency diesel generator operation while parallel to the grid, dated October 22, 2019
- (7) A-2020-074, Allow reactor coolant system loop fill with refueling water purification pump, dated April 17, 2020
- (8) B-2017-049, NFPA 805 Modification to reduce likelihood of spurious actuation of standby auxiliary feedwater valves, dated March 23, 2018
- (9) B-2018-002, Auxiliary building high energy line break requirements, dated January 23, 2018
- (10) B-2018-005, Tornado missile protection structural barriers, dated February 14, 2018
- (11) B-2018-020, Guidance for withdrawal rates after prolonged 'D' bank insertion in R.E. Ginna Cycle 40, dated April 20, 2018
- (12) B-2018-052, Equivalent change to allow use of either element of dual element RTD TE-410A for reactor coolant loop 'B' leg temperature, dated October 17, 2018
- (13) B-2018-053, Manipulator crane overload/underload setpoints increase to +/- 200lbs, dated October 22, 2018
- (14) B-2018-055, Permanent scaffolds inside containment for temporary lead shielding, dated October 24, 2018
- (15) B-2019-007, TSB change to revise B 3.8.9 and B 3.8.10 for minimum DC system voltage to be 129 VDC, dated February 26, 2019
- (16) B-2019-009, MSSV setpoint tolerance change, dated March 11, 2020
- (17) B-2019-014, Turbine driven auxiliary feedwater instrumentation upgrade, dated June 26, 2019

- (18) B-2019-015, Newly identified SSCs in scope of license renewal, section 18.1.3 update, dated April 3, 2019
- (19) B-2019-040, Permanently maintain the open phase in an alarm only configuration in accordance with Revision 3 of the NEI Voluntary Industry Initiative, dated December 12, 2019
- (20) B-2020-007, Design change to resolve resonant condition on turbine driven auxiliary feedwater pump turbine, dated May 11, 2020
- (21) B-2020-013, Disconnect pressurizer heater 28, dated May 10, 2020
- (22) B-2020-0014, Swap F12 and H13 CET trains, dated May 10, 2020
- (23) B-2020-0015, PCTCC to defeat the zirconium guide tube trip function in PT-34.0, dated May 8, 2020
- (24) C-2017-004, Change valve 9080 from normal closed to normal open, dated December 1, 2017
- (25) C-2018-001, Retire AVT area radiation monitors R-23, R-24, R-25, R27 and R-28, dated May 17, 2018
- (26) C-2018-002, Remove all remaining intake heaters from the intake structure, dated June 21, 2018
- (27) C-2018-004, AMSAC Actuation Logic (STP-O-R-21 Test interval Extension – Technical Requirements Manual change: TSR 3.4.3.6 change required frequency from 18 months to 36 months, dated October 19, 2018
- (28) C-2019-001, Compensatory measure to tagout 738A switch and allow local operation only, dated March 18, 2019

71111.19 - Post-Maintenance Testing

Post-Maintenance Test Sample (IP Section 03.01) (6 Samples)

The inspectors evaluated the following post maintenance test activities to verify system operability and functionality:

- (1) Inservice test for residual heat removal suction valves, motor operated valve 851, following planned maintenance on July 7, 2020
- (2) Operational testing of the service air compressor, dryer, and relief valves, following planned maintenance on July 16, 2020
- (3) 'C' standby auxiliary feedwater pump, comprehensive test, valve and modification, following planned maintenance on July 16, 2020
- (4) NFPA 805 diesel generator operational test, following planned maintenance on August 26, 2020
- (5) Standby auxiliary feed water pump diesel generator operational test, following planned maintenance on August 27, 2020
- (6) Operational testing of the instrument air compressor and relief valve, following planned maintenance on September 8, 2020

71111.22 - Surveillance Testing

The inspectors evaluated the following surveillance tests:

Surveillance Tests (other) (IP Section 03.01) (4 Samples)

- (1) STP-O-36Q-D, 'D' standby auxiliary feedwater pump quarterly test on July 28, 2020
- (2) STP-O-12.2, 'B' emergency diesel generator monthly test on August 28, 2020

- (3) STP-O-R-20, 'B' emergency diesel generator auto start undervoltage logic test on September 30, 2020
- (4) STP-O-16QT, auxiliary feedwater turbine driven pump quarterly test on September 30, 2020

Inservice Testing (IP Section 03.01) (1 Sample)

- (1) STP-O-3-COMP-B, 'B' containment spray pump comprehensive test on September 15, 2020

FLEX Testing (IP Section 03.02) (1 Sample)

- (1) STP-O-40.1C, beyond design basis flex pump PBD01C periodic test on September 10, 2020

71114.02 - Alert and Notification System Testing

Inspection Review (IP Section 02.01-02.04) (1 Sample)

- (1) The inspectors evaluated Exelon's maintenance and testing of the Ginna alert and notification system on July 27–30, 2020, for the period of July 2018 through June 2020

71114.03 - Emergency Response Organization Staffing and Augmentation System

Inspection Review (IP Section 02.01-02.02) (1 Sample)

- (1) The inspectors evaluated the readiness of Exelon's Emergency Preparedness Organization on July 27–30, 2020

71114.04 - Emergency Action Level and Emergency Plan Changes

Inspection Review (IP Section 02.01-02.03) (1 Sample)

- (1) The inspectors evaluated the following submitted Emergency Action Level and Emergency Plan changes onsite on July 27–30, 2020. The NRC notes that this evaluation does not constitute NRC approval.
 - Evaluation No.: 19-65, EP-AA-1000, Exelon Nuclear Standardized Radiological Emergency Plan, Revision 32
 - Evaluation No.: 19-84, EP-AA-1000, Exelon Nuclear Standardized Radiological Emergency Plan, Revision 33
 - Evaluation No.: 19-89, EP-AA-1012, Exelon Nuclear Radiological Emergency Plan Annex for Ginna Station, Revision 8
 - Evaluation No.: 19-90, EP-AA-1012, Addendum 1, Rev 1, R. E. Ginna Nuclear Power Plant On-Shift Staffing Technical Basis, Revision 1

71114.05 - Maintenance of Emergency Preparedness

Inspection Review (IP Section 02.01 - 02.11) (1 Sample)

- (1) The inspectors evaluated the maintenance of the emergency preparedness program on July 27–30, 2020, for the period of July 2018 through June 2020

71114.06 - Drill Evaluation

Select Emergency Preparedness Drills and/or Training for Observation (IP Section 03.01) (1 Sample)

- (1) The inspectors evaluated an emergency drill in the simulator control room and emergency offsite facility involving an Alert, Site Area Emergency, and General Emergency declaration due to a scenario which contained, but was not limited to, a loss of reactor vessel inventory affecting fuel clad with containment challenged on July 14, 2020

Drill/Training Evolution Observation (IP Section 03.02) (1 Sample)

- (1) The inspectors evaluated a simulator drill involving an Unusual Event, Alert, Site Area Emergency, and General Emergency declaration due to a scenario which contained, but as not limited to, a loss of coolant accident and a loss of reactor coolant system barrier with a potential containment barrier on August 25, 2020

RADIATION SAFETY

71124.08 - Radioactive Solid Waste Processing & Radioactive Material Handling, Storage, & Transportation

Radioactive Material Storage (IP Section 03.01) (2 Samples)

- (1) Inspectors evaluated the licensee's performance in controlling, labeling and securing radioactive materials in the radioactive waste yard east
- (2) Inspectors evaluated the licensee's performance in controlling, labelling and securing radioactive materials in the steam generator mausoleum

Radioactive Waste System Walkdown (IP Section 03.02) (2 Samples)

- (1) Inspectors walked down accessible portions of the solid radioactive waste handling system and evaluated system configuration and functionality
- (2) Inspectors walked down accessible portions of the liquid radioactive waste systems and evaluated system configuration and functionality

Waste Characterization and Classification (IP Section 03.03) (2 Samples)

- (1) The inspectors evaluated the licensee's characterization and classification of radioactive waste in spent resin sample identification number 2019-227SA analyzed on October 15, 2019

- (2) The inspectors evaluated the licensee's characterization and classification of radioactive waste in dry active waste sample identification number 2018-189SA analyzed on December 11, 2018

Shipment Preparation (IP Section 03.04) (1 Sample)

- (1) The inspectors reviewed the records for shipment packaging, surveying, labeling, placarding, vehicle surveys, emergency instructions, manifests, and shipping papers provided to the driver

Shipping Records (IP Section 03.05) (4 Samples)

The inspectors evaluated the following non-excepted radioactive material shipments through a record review:

- (1) The inspectors reviewed the shipping records for shipment 2018-054 shipped on August 23, 2018
- (2) The inspectors reviewed the shipping records for shipment 2018-092 shipped on November 9, 2018
- (3) The inspectors reviewed the shipping records for shipment 2019-020 shipped on March 25, 2019
- (4) The inspectors reviewed the shipping records for shipment 2019-049 shipped on July 31, 2019

OTHER ACTIVITIES – BASELINE

71151 - Performance Indicator Verification

The inspectors verified licensee performance indicators submittals listed below:

EP01: Drill/Exercise Performance (IP Section 02.12) (1 Sample)

- (1) Submitted data from April 1, 2019 - March 31, 2020

EP02: ERO Drill Participation (IP Section 02.13) (1 Sample)

- (1) Submitted data from April 1, 2019 - March 31, 2020

EP03: Alert & Notification System Reliability (IP Section 02.14) (1 Sample)

- (1) Submitted data from April 1, 2019 - March 31, 2020

MS06: Emergency AC Power Systems (IP Section 02.05) (1 Sample)

- (1) Submitted data from July 1, 2019 - June 30, 2020

MS07: High Pressure Injection Systems (IP Section 02.06) (1 Sample)

- (1) Submitted data from July 1, 2019 - June 30, 2020

MS08: Heat Removal Systems (IP Section 02.07) (1 Sample)

- (1) Submitted data from July 1, 2019 - June 30, 2020

MS09: Residual Heat Removal Systems (IP Section 02.08) (1 Sample)

- (1) Submitted data from July 1, 2019 - June 30, 2020

MS10: Cooling Water Support Systems (IP Section 02.09) (1 Sample)

- (1) Submitted data from July 1, 2019 - June 30, 2020

OR01: Occupational Exposure Control Effectiveness Sample (IP Section 02.15) (1 Sample)

- (1) The inspectors reviewed licensee submittals for the occupational radiological occurrences PI for the fourth quarter 2019 through the third quarter of 2020

PR01: Radiological Effluent Technical Specifications/Offsite Dose Calculation Manual
Radiological Effluent Occurrences (RETS/ODCM) Radiological Effluent Occurrences Sample
(IP Section 02.16) (1 Sample)

- (1) The inspectors reviewed licensee submittals for the radiological effluent TS/ODCM radiological effluent occurrence PI for the fourth quarter 2019 through the third quarter of 2020

71152 - Problem Identification and Resolution

Annual Follow-up of Selected Issues (IP Section 02.03) (1 Sample)

The inspectors reviewed the licensee's implementation of its corrective action program related to the following issues:

- (1) Control room emergency air treatment system, IR 04351801, on September 10, 2020

INSPECTION RESULTS

Observation: 'B' Control room emergency air treatment system filter failure	71152
<p>The inspectors reviewed Exelon's corrective action program evaluation, work orders, extent of condition reviews, and corrective actions associated with the 'B' train of the control room emergency air treatment system charcoal filter efficiency failure. Exelon entered this issue into their corrective action program as IR 04351801, specifically the charcoal filter efficiency results for the 'B' train of the control room emergency air treatment system were below the Technical Specification 3.7.9 surveillance requirements, detailed in section 5.5.10. The inspectors assessed Exelon's problem identification threshold, causal analysis, prioritization, and timeliness of corrective actions to determine whether Exelon had taken timely and appropriate corrective actions.</p> <p>The inspectors observed that Exelon performed a thorough review of the issue and determined the cause of the sample efficiency failure to meet the acceptance criteria was due to contamination of the sample. Exelon's immediate corrective actions were to declare the system inoperable and enter the applicable technical specification action statement. Exelon</p>	

completed evacuation of the existing charcoal and replaced the charcoal particulate with new material. Additional corrective actions are long term and appear to be appropriate and commensurate with the significance which include increased sample quantity and a review of the efficiency acceptance criteria.

Exelon also performed additional testing of the removed charcoal to aid in determining the failure cause. These samples were determined to meet acceptance criteria. Through the corrective action program evaluation document, Exelon concluded the removed charcoal would have met the efficiency requirements and the error was either contamination during testing or sample retrieval. Furthermore, Exelon notes specific conclusion of cause is unlikely because the samples are destroyed during the testing process.

The inspectors independently reviewed the testing data, requirements, and methodology. At the time of Exelon's immediate correction actions, the inspectors observed the in-field activities to replace the charcoal particulate. During this time, the inspectors also observed how Exelon accomplished the sample retrieval process. Additionally, the inspectors reviewed work orders and efficiency trends dating back to 2007 to identify adverse trends. Lastly, the inspectors independently reviewed Exelon's conclusion and technical basis that the efficiency of the removed charcoal would have met performance requirements outlined in the plant's technical specification. The inspectors determined that Exelon's actions in identifying and resolving the issue was appropriate and timely and commensurate with the safety significance. The inspectors independently evaluated the deficiencies noted above for significance in accordance with the guidance in IMC 0612, Appendix B, "Issue Screening," and Appendix E, "Examples of Minor Issues." The inspectors determined that none of the conditions were deficiencies of greater than minor significance and, therefore, are not subject to enforcement action in accordance with the NRC's Enforcement Policy.

EXIT MEETINGS AND DEBRIEFS

The inspectors verified no proprietary information was retained or documented in this report.

- On July 30, 2020, the inspectors presented the Emergency Preparedness Program inspection results to Mr. Paul Swift, Site Vice President and other members of the licensee staff.
- On August 21, 2020, the inspectors presented the Triennial Heat Sink inspection results to Mr. Paul Swift, Site Vice President and other members of the licensee staff.
- On September 18, 2020, the inspectors presented the Triennial 50.59 Team inspection results to Mr. Paul Swift, Site Vice President and other members of the licensee staff.
- On October 16, 2020, the inspectors presented the integrated inspection results to Mr. Paul Swift, Site Vice President and other members of the licensee staff.

DOCUMENTS REVIEWED

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71111.04	Procedures	STP-O-30.8	Service Water System Valve Position Verification	Revision 002
71111.05	Corrective Action Documents Resulting from Inspection	AR 04372590	Corrosion at Threaded Fitting downstream of Diesel Generator Preaction System S13 Isolation Valve V-5230	09/28/2020
		AR 04372603	Corrosion at Threaded Fitting Upstream of 5216K	09/28/2020
71111.06	Work Orders	C93709104	Perform Visual Inspection/Replacement - Door Neoprene Gaskets (B Train)	06/29/2020
71111.07A	Work Orders	C93690133	EAC02B Clean, Inspect, and Eddy Current Tube Side of Heat Exchanger	03/25/2020
71111.07T	Miscellaneous	ER-AA-340-1002	EDG "B" Jacket Water Heat Exchanger Inspection Report	11/26/2018
71111.12	Corrective Action Documents	AR 04341255	AOV4270 and AOV 4272 did not close during testing	05/05/2020
		AR 04344709	SAC trip on Motor Overload	05/20/2020
71111.15	Corrective Action Documents	AR 04358711	A Steam Generator level Transmitter LT-461 deviation	07/24/2020
	Work Orders	C93451228	Contingency Repair/Replace Steam Generator Level Transmitter	07/24/2020
71111.17T	Corrective Action Documents	AR 04034735	50.59 Self Assessment Screen not Performed within 90 days	07/24/2017
		AR 04056448	AD-AA-101-F-01 not filled correctly	09/27/2017
		AR 04057261	Follow up actions from 50.59 inspection	09/29/2017
		AR 04092244	'A' Auxiliary feed water pump motor high temp during test	01/10/2018
		AR 04214360	Entered ER-SC.3 due to screenhouse level lowering 6 inches	01/27/2019
		AR 04226929	NRC identified 50.59 screen/eval not performed for 738A OP	03/06/2019
		AR 04347695	Pipe blockage upstream of 4516	06/03/2020
	Corrective Action Documents Resulting from Inspection	AR 04370151	NRC 50.59 Inspection non-conformance not entered into CAP	09/17/2020
		IR 04370150	NRC 50.59 Inspection lack design control for CETS	09/17/20
	Procedures	LS-AA-104-1000	Exelon 50.59 Resource Manual	Revision 14
71111.19	Corrective Action Documents Resulting from Inspection	AR 0435999	WO C93690133 field copy data not transferred to Master	07/30/2020
		AR 04364457	NRC Identified - Fuel Oil Weepage found on KDG08	08/20/2020

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
	Procedures	STP-O-2.3.3	Inservice Test of RHR Suction Valves	Revision 00001
		STP-O-36-COMP-C	Standby Auxiliary Feedwater Pump C - Comprehensive Test	Revision 021
		STP-O-40.4	SAFW Diesel Generator (KDG08) Run Test	Revision 012
		STP-O-40.5	NFPA Diesel Generator (KDG09) Run Test	Revision 011
	Work Orders	699555	Replace service air filter to demineralizer mixed bed resin vessels (FSA02)	07/06/2020
		C93665383	Stroke the following Valves 7001D, 7001I, 7001J, 7001P, 7001T, 7000D, 7000E, 7000F, 7000G	07/06/2020
		C93686385	Replace Motor for 851B RHR Pump Suction Valve from Containment Sump B	04/08/2020
		C93708985	Perform Instrument Air Compressor CIA02C Maintenance	07/23/2020
		C93710361	Service Air Compressor Receiver Relief Valves	7/6/2020
		C93711063	Annual Preventive Maintenance for Service Air Compressor Dryer (TSA01A and TSA01B)	07/06/2020
		C93711915	Perform Service Air Dryer Annual or 4 Year Preventive Maintenance	07/06/2020
		C93714754	Annual Maintenance on Diesel Generator KDG09 650 Kw Load Run	8/18/2020
		C93714763	Annual Maintenance on SAFW DG KDG08 and 650 kw Load Run	08/17/2020
		C93747333	Perform Corrective Maintenance on SMB-00 Motor Operator for OP/851B Pump Suction	4/8/2020
		C93749868	Perform Repairs o OP/851B RHR Pump Suction Valve Actuator and Control Circuitry	5/3/2020
		C93750631	RV-8302 Swap Out with Pre-Tested Spare and Test Removed Valve	07/24/2020
71111.22	Procedures	STP-O-36Q-D	Standby Auxiliary Feedwater Pump D - Quarterly	Revision 020
		STP-O-R-20	Diesel Generator B - Auto Start Undervoltage Logic Test	Revision 007
71114.02	Corrective Action Documents	AR 04180998	Siren 82 indicated a communication issue on evening poll	10/07/2018
		AR 04317551	Siren 18 indicated a no response during evening poll	02/13/2020
	Miscellaneous	Design Report	R. E. Ginna Nuclear Power Station Site-Specific Offsite	February 26,

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
			Radiological Emergency Preparedness Alert and Notification System Quality Assurance	1986
71114.03	Miscellaneous	EP-AA-1000	Exelon Nuclear Standardized Radiological Emergency Plan	Revision 33
		EP-AA-1012	Exelon Nuclear Radiological Emergency Plan Annex for Ginna Station	Revision 8
		EP-AA-1012 Addendum 1	R. E. Ginna Nuclear Power Plant On-Shift Staffing Technical Basis	Revision 1
71114.04	Miscellaneous	EP-AA-120-1001	10 CFR 50.54(q) Change Evaluation	Revision 10
71114.05	Corrective Action Documents	AR 04214466	150 foot wind direction weather vane damaged	01/28/2019
		AR 04248782	OCCRP computer sign on = 12 minutes impact	05/14/2019
	Corrective Action Documents Resulting from Inspection	AR 04359748	NRC EP program inspection - EP equipment removed from either procedure	07/29/2020
	Miscellaneous	EP-AA-121-F-12	Ginna Equipment Matrix	Revision 1