Tier / Group	Randomly Selected K/A	Reason for Rejection
1 / 1 Q #9	295021 AA1.06	There is no tie between loss of SDC and Drywell Temperature. Replace with 295021 AA1.02, Ability to operate and/or monitor the following as the apply to LOSS OF SHUTDOWN COLLING: RHR/Shutdown Cooling
2 / 1 Q #29	205000 K4.01	On the LGS Suppressed KA list. Replaced with 205000 K4.02 High Pressure Isolation
2 / 1 Q #33	211000 K5.02	SLC system oversampled in Tier/Group. Concept of Chugging unknown at LGS. Consider for Suppressed KA list. Replaced #33 with 215004 K5.03, Changing Detector Position.
2 / 1 Q #46	262002 A1.02	On the LGS suppressed KA List. Replaced #46 with 262002 K4.01, Transfer from Preferred Power to Alternate Power Supplies.
2 / 1 Q #50	300000 K6.03	Oversampled system and K1 for Tier/Group. Effect that a loss of temperature indication would have on instrument air system is limited. Replaced #50 with 300000 K%.01 Air Compressors
2 / 1 Q #53	400000 K1.01	Oversampled System for Tier/Group. Replaced with 263000 K1.02, D.C. Battery Charger and Battery.
2 / 1 Q #44	261000 K4.05	Overlap with Q #18 Replaced with 261000 K4.01
2 / 2 Q #62	268000 A2.01	Draft exam review, two implausible distractors. Could not write good question for this K/A. Replaced with 226001 A2.11
3 Q #96	2.2.14	Draft exam review, two implausible distractors. Could not write good question for this K/A. Replaced with Generic 2.1.35