

From: Kim, James
Sent: Tuesday, March 2, 2021 3:32 PM
To: Duke, Paul R.
Cc: Thomas, Brian J.; Danna, James
Subject: Acceptance Review - Salem 1 and 2 - Salem 1 and 2 - Adopt TSTF-569, Revision of Response Time Testing Definition (EPID: L-2021-LLA-0017)

Mr. Duke,

By letter dated February 16, 2021 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML21047A238), Public Service Enterprise Group Nuclear, LCC (PSEG, the licensee) submitted a license amendment request for Salem Generating Station Units 1 and 2 (Salem) to adopt TSTF-569, "Revise Response Time Testing Definition." The proposed amendment revises the TS Definitions for Engineered Safety Feature (ESF) Response Time and Reactor Trip System (RTS) Response Time.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

The NRC staff has estimated that this licensing request will take approximately 120 hours to complete. The NRC staff expect to complete this review in approximately 12 months, which is March 2022. If there are emergent complexities or challenges in our review that would cause changes to the initial forecasted completion date or significant changes in the forecasted hours, the reasons for the changes, along with the new estimates, will be communicated during the routine interactions with the assigned project manager.

These estimates are based on the NRC staff's initial review of the application and they could change, due to several factors including requests for additional information, unanticipated addition of scope to the review, and review by NRC advisory committees or hearing-related activities. Additional delay may occur if the submittal is provided to the NRC in advance or in parallel with industry program initiatives or pilot applications.

If you have any question, please contact me, James Kim, at James.Kim@nrc.gov or 301-415-4125.

James Kim, Project Manager
Branch 1, Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission

Hearing Identifier: NRR_DRMA
Email Number: 1048

Mail Envelope Properties (DM6PR09MB50487ECBE350F253233EEE48E4999)

Subject: Acceptance Review - Salem 1 and 2 - Salem 1 and 2 - Adopt TSTF-569,
Revision of Response Time Testing Definition (EPID: L-2021-LLA-0017)
Sent Date: 3/2/2021 3:31:47 PM
Received Date: 3/2/2021 3:31:00 PM
From: Kim, James

Created By: James.Kim@nrc.gov

Recipients:
"Thomas, Brian J." <Brian.Thomas@pseg.com>
Tracking Status: None
"Danna, James" <James.Danna@nrc.gov>
Tracking Status: None
"Duke, Paul R." <Paul.Duke@pseg.com>
Tracking Status: None

Post Office: DM6PR09MB5048.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	2510	3/2/2021 3:31:00 PM

Options
Priority: Normal
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date: