



Inspecting Risk-Informed Initiatives

Antonios M. Zoulis

Branch Chief

PRA Oversight Branch

Division of Risk Assessment

Office of Nuclear Reactor Regulation

Vision



Inspection Key Principles



Oversight and Inspection

Surveillance Testing

- Risk-informed samples (14–22/year).
- Verifies structures, systems, and components (SSCs) remain capable of performing their intended safety functions.

Risk-Informed Completion Times

- Risk-informed samples (14–24/year).
- Verifies that appropriate risk assessments, work controls, and risk management actions are implemented.

10 CFR 50.69

- One-time inspection of program implementation after NRC approval received.
- Risk-informed samples (8–10/year).
- Verifies SSCs remain capable of performing their intended safety functions.