



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

March 24, 2021

LICENSEE: Indiana Michigan Power Company, LLC

FACILITY: Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF MARCH 19, 2021, WITH INDIANA MICHIGAN POWER COMPANY REGARDING CONTAINMENT WATER LEVEL CHANNELS FOR DONALD C. COOK NUCLEAR PLANT, UNIT NOS. 1 AND 2 (EPID L-2021-LRM-0033)

On March 19, 2021, a Category I public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Indiana Michigan Power Company (I&M, the licensee) via teleconference. The purpose of the meeting was to discuss planned license amendment requests (LARs) for the Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2 (CNP), related to identifying a third channel for the Containment Water Level Function in Technical Specification (TS) 3.3.3., "Post Accident Monitoring (PAM) Instrumentation." The meeting notice and agenda dated March 8, 2021, are available in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML21077A100 and I&M's meeting handout is available at ADAMS Accession No. ML21077A010. A list of attendees is enclosed.

The licensee indicated that potential license amendments would be needed to identify a third channel for the Containment Water Level Function in TS 3.3.3. The third channel would be comprised of a combination of existing Containment Sump level indication and Containment water level switches. The potential LAR would most likely be permanent change to the licensing bases. The licensee indicated that both Unit 1 and 2 currently have one of the channels inoperable. Historically, repairs schedules can have a very long lead time and at times cannot be performed while operating. As such, meeting the 7-day shutdown Action statement for TS 3.3.3. would currently be a challenge.

I&M currently plans to submit the LAR request soon.

No members of the public participated in the meeting. No regulatory decisions were made at this meeting.

Please direct any inquiries to me at 301-415-2855, or Scott.Wall@nrc.gov.

Sincerely,

/RA/

Scott P. Wall, Senior Project Manager
Plant Licensing Branch III
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

Enclosure: List of Attendees

cc: Listserv

LIST OF ATTENDEES

MARCH 19, 2021, PUBLIC MEETING WITH I&M

DONALD C. COOK NUCLEAR PLANT, UNIT NOS. 1 AND 2

PLANNED LICENSE AMENDMENT REQUEST RELATED TO

CONTAINMENT WATER LEVEL CHANNELS

Name	Organization
Scott Wall	Nuclear Regulatory Commission (NRC)
Brian Wittick	NRC
Victor Cusumano	NRC
Michael Waters	NRC
DaBin Ki	NRC
Tarico Sweat	NRC
Gursharan Singh	NRC
Hang Vu	NRC
Jesse Seymour	NRC
Heather Jones	NRC
Douglas Bollock	NRC
David Beaulieu	NRC
Jackie Harvey	NRC
Michael Scarpello	Indiana Michigan Power Company (I&M)
Helen Levendosky	I&M
Brad Culwell	I&M
Rennie Ramirez	I&M
Amanda Britton	I&M
Fao Sanni	I&M
Eric Beltz	I&M

SUBJECT: SUMMARY OF MARCH 19, 2021, WITH INDIANA MICHIGAN POWER
COMPANY REGARDING CONTAINMENT WATER LEVEL CHANNELS FOR
DONALD C. COOK NUCLEAR PLANT, UNIT NOS. 1 AND 2
(EPID L-2021-LRM-0033) DATED MARCH 24, 2021

DISTRIBUTION:

PUBLIC

PM File Copy

RidsNrrLASRohrer Resource

RidsRgn3mailCenter Resource

RidsAcrr_MailCTR Resource

RidsNrrPmDCCook Resource

RidsNrrDorlLpl3 Resource

RidsNrrDnrlNphp Resource

RidsNrrDorl Resource

RidsOpaMail Resource

PMNS Resource

ADAMS Accession No. ML21082A005

***via e-mail**

OFFICE	NRR/DORL/LPL3/PM*	NRR/DORL/LPL3/LA*	NRR/DORL/LPL3/BC*	NRR/DORL/LPL3/PM*
NAME	SWall	SRohrer	NSalgado	SWall
DATE	03/24/2021	03/24/2021	03/24/2021	03/24/2021

OFFICIAL RECORD COPY