

UFSAR Revision 30.0

 An AEP Company	INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT	Revision: 29.0 Table: 8.7-1 Page: 1 of 2
---	---	--

STATION BLACKOUT EQUIPMENT LIST

Comp No.	Component Description
BATT-AB	Plant Battery AB
BATT-CD	Plant Battery CD
BLP-110	Steam Generator OME 3-1 Channel IV RPS Input Narrow Range Level Transmitter
BLP-111	Steam Generator OME 3-1 Channel II RPS Input Narrow Range Level Transmitter
BLP-112	Steam Generator OME 3-1 Channel III RPS Input Narrow Range Level Transmitter
BLP-120	Steam Generator OME 3-2 Channel IV RPS Input Narrow Range Level Transmitter
BLP-121	Steam Generator OME 3-2 Channel I RPS Input Narrow Range Level Transmitter
BLP-122	Steam Generator OME 3-2 Channel III RPS Input Narrow Range Level Transmitter
BLP-130	Steam Generator OME 3-3 Channel IV RPS Input Narrow Range Level Transmitter
BLP-131	Steam Generator OME 3-3 Channel I RPS Input Narrow Range Level Transmitter
BLP-132	Steam Generator OME 3-3 Channel III RPS Input Narrow Range Level Transmitter
BLP-140	Steam Generator OME 3-4 Channel IV RPS Input Narrow Range Level Transmitter
BLP-141	Steam Generator OME 3-4 Channel II RPS Input Narrow Range Level Transmitter
BLP-142	Steam Generator OME 3-4 Channel III RPS Input Narrow Range Level Transmitter
CRID-I	120 VAC CRID Channel I Distribution Panel
CRID-II	120 VAC CRID Channel II Distribution Panel
CRID-III	120 VAC CRID Channel III Distribution Panel
CRID-IV	120 VAC CRID Channel IV Distribution Panel
FFI-210	AFW to Steam Generator OME 3-1 Flow Indicator Transmitter
FFI-220	AFW to Steam Generator OME 3-2 Flow Indicator Transmitter
FFI-230	AFW to Steam Generator OME 3-3 Flow Indicator Transmitter

UFSAR Revision 30.0

 <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p>	<p align="center">INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p>	<p>Revision: 29.0 Table: 8.7-1 Page: 2 of 2</p>
--	---	---

STATION BLACKOUT EQUIPMENT LIST

Comp No.	Component Description
FFI-240	AFW to Steam Generator OME 3-4 Flow Indicator Transmitter
MCM-221	Main Steam Lead#2 to Auxiliary Feedwater Pump Turbine Shutoff Valve
MCM-231	Main Steam Lead#3 to Auxiliary Feedwater Pump Turbine Shutoff Valve
FMO-211	TDAFW Pump PP-4 Discharge to Steam Generator OME 3-1 Control Valve
FMO-221	TDAFW Pump PP-4 Discharge to Steam Generator OME 3-2 Control Valve
FMO-231	TDAFW Pump PP-4 Discharge to Steam Generator OME 3-3 Control Valve
FMO-241	TDAFW Pump PP-4 Discharge to Steam Generator OME 3-4 Control Valve
NPS-110	Reactor Vessel Train "A" Wide Range Pressure Transmitter
NPS-111	Reactor Vessel Train "B" Wide Range Pressure Transmitter
TK-32	Condensate Storage Tank
C-261	Condensate Storage Tank to and from Condensers Shutoff Valve
MRV-213	Steam Generator OME 3-1 PORV
MRV-223	Steam Generator OME 3-2 PORV
MRV-233	Steam Generator OME 3-3 PORV
MRV-243	Steam Generator OME 3-4 PORV
NTR-210	Reactor Coolant Loop#1 Cold Leg Wide Range Temperature Recorder Thermal Sensor
NTR-230	Reactor Coolant Loop#3 Cold Leg Wide Range Temperature Recorder Thermal Sensor
PP-4	Turbine Driven Auxiliary Feedwater Pump
QCM-350	Reactor Coolant Pump Seal Water Return Train "B" Containment Isolation Valve
BATT-N	Train "N" Plant Battery
1/2 BATLIT	Specified Station Blackout Emergency Battery Lighting Units