



# Point Beach GL 2004-02 Resolution Update

NextEra Energy Point Beach, LLC  
(NextEra)

May 18, 2021



# Meeting Agenda


- **Overview of plant layout and strainer configuration**
- **Previous Generic Letter (GL) 2004-02 submittal and NRC audit**
- **Resolution options evaluation**
- **Overview of risk-informed resolution approach**
- **Content of submittal**
- **Submittal schedule**

# Meeting Objectives


- **Communicate current Point Beach plan for GL 2004-02 response**
- **Obtain staff feedback on the overall risk-informed resolution path for Point Beach**
- **Identify areas of concern from the NRC on the approach**

# Point Beach Plant Layout


- **Westinghouse 2-loop pressurized water reactor (PWR) with large dry containment**
- **Two redundant emergency core cooling system (ECCS) and containment spray (CS) trains**
  - Each train has a high-head safety injection (SI) pump, residual heat removal (RHR) pump, and CS pump
  - During recirculation, the CS and SI pumps take suction from the RHR pump discharge





# Sump Strainer Arrangement



Unit 1



Unit 2



- PCI Sure-Flow strainers
- Vertical disk modules around a core tube
- Surface area of 1904.6 ft<sup>2</sup> per train

# Background

- **Previous GL Response submitted to the NRC in 2017 (ML17363A253)**
  - Used NEI 04-07 Section 6 alternate break methodology
  - Required exemption from single failure requirement for Region II breaks
- **NRC performed an audit of the submittal in January 2019**
- **NRC issued an audit report on December 2, 2019 with several questions**
- **Point Beach was able to address all technical questions from the audit report except for Mineral Wool cassettes having a lower destruction pressure than assumed**

# Resolution Options Evaluation for GL 2004-02 Closeout

- **NextEra conducted an alternative analysis for Point Beach to determine the best path for closeout of GL 2004-02**
- **Nine options were evaluated, including different levels of modification to the resistance temperature detector (RTD) bypass line piping and/or insulation (e.g., mineral wool and Cal-Sil), use of a different resolution method, and upgrades to sump strainers**
- **The selected option was the use of a risk-informed resolution approach**
  - Accepted resolution methodology with precedence by South Texas Project (STP) and Vogtle
  - The risk-informed approach addresses the NRC concerns in the audit report
  - Overall risk increase due to debris effects is expected to be in Region III of Regulatory Guide (RG) 1.174
  - Minimizes radiation dose associated with physical changes
  - Minimizes outage impacts

# Highlights of Changes to Overall Approach

- **NextEra plans to use a risk-informed approach for Point Beach based on conditional failure probability (CFP) similar to Vogtle**
- **Debris generation analysis will be revised to evaluate Mineral Wool debris using a ZOI size of 5.4D**
  - Mineral wool insulation is similar to K-Wool, which is classified as unjacketed mineral wool with wire mesh reinforcement in NEI 04-07
  - K-Wool went through air jet impact testing and was assigned a ZOI size of 5.4D per NEI 04-07 SE
  - Mineral Wool insulation at Point Beach has a more robust casing than K-Wool
    - Tested K-Wool had wire mesh lining and fabric cover
    - Mineral Wool insulation at Point Beach is encapsulated in stainless steel cassettes
- **BADGER models will be rerun to update debris loads for both units**
- **No significant updates to other deterministic analyses (e.g., debris transport, water level, etc.) or testing are anticipated**



# Event Selection for Risk Quantification

- **Risk quantification will consider the following events**
  - Small, medium, and large LOCAs due to:
    - Pipe breaks
    - Failure of non-piping components
    - Water hammer
  - Secondary side breaks inside containment that result in a consequential LOCA that requires sump recirculation
  - Fire-induced RCP seal LOCAs
  - Seismically-induced LOCAs
- **Based on preliminary evaluations of these initiating events, it is expected that only large LOCAs and secondary side breaks will contribute to the risk associated with LOCA-generated debris**


# Secondary Side Breaks

- **Secondary side breaks will be addressed using a bounding approach**
  - Secondary side breaks inside containment can generate a significant quantity of debris (although the ZOI would be smaller than an equivalent primary side break)
  - ECCS recirculation may be necessary for secondary side breaks due to a stuck open power operated relief valve (PORV) or a scenario that requires feed and bleed
  - Strainer flow rate limited by capacity of PORVs
  - Internal events PRA model will be used to quantify the change in core damage frequency ( $\Delta$ CDF) and change in large early release frequency ( $\Delta$ LERF) by taking the differences in CDF and LERF between the following two scenarios:
    - The strainers always fail when required for secondary side breaks
    - The strainers never fail when required for secondary side breaks
  - Preliminary results indicate that the risk is within RG 1.174 Region III

# Seismically-Induced LOCAs

- **Seismically-induced LOCAs will be addressed using the Point Beach individual plant examination of external events (IPEEE)**
  - Large LOCAs were screened out in the IPEEE at a HCLPF (high confidence of low probability of failure) of 0.3g
  - Small LOCAs were evaluated in the IPEEE and demonstrated not to be a significant risk contributor
  - Because large LOCAs have a lower conditional probability of occurrence, they would also be an insignificant contributor to risk
  - This conclusion is supported for the GSI-191 application because many large LOCAs would not generate enough debris to cause strainer failure
    - Only a fraction of seismically-induced large LOCAs would contribute to strainer performance risk
- **Based on this assessment, the risk contribution of seismically-induced LOCAs on strainer performance is judged to be negligible for Point Beach and screened from more detailed evaluation**

# Overview of Point Beach Risk-Informed Approach



# Failure Criteria

- **NARWHAL software will be used to evaluate each of the postulated breaks against the following failure criteria**
  - Strainer head loss exceeds pump NPSH margin or strainer structural margin
    - Breaks that generate and transport more debris of any one type than tested are assumed to fail
  - Gas voids from degasification or flashing exceed pump limits
  - Penetrated debris exceeds in-vessel fuel blockage and boron precipitation limits
    - In-vessel evaluation and acceptance criteria will follow latest NRC review guidance
- **Bounding analysis for the following failure criteria have been performed outside of NARWHAL**
  - Upstream blockage prevents water from reaching sump
  - Pumps fail due to air intrusion from vortexing
  - Penetrated debris exceeds ex-vessel wear and blockage limits

# Risk Quantification

- **NARWHAL will be used to calculate CFPs based on:**
  - The definition of small (<2”), medium (2”-6”), and large (>6”) LOCAs
  - The fraction of breaks that pass and fail within each size category for various pump configurations
  - The LOCA frequency allocated across welds using the top-down approach
- **PRA model will be used to determine the functional failure probability (FFP) for relevant equipment lineups**
  - All pumps available, single RHR/CS train failure, single RHR train failure, etc.
- **$\Delta$ CDF will be calculated outside the PRA model using the initiating event (LOCA) frequency, CFP, and FFP:**

$$\Delta CDF = IEF * \sum_{j=0}^{j=X} CFP_j * FFP_j$$

- **$\Delta$ LERF will be calculated outside the PRA model based on:**
  - $\Delta$ CDF
  - Conditional large early release probability (CLERP) calculated using relevant LERF sequences from the PRA model

# Uncertainty Evaluation

- **Following the guidance in NUREG-1855, uncertainty evaluation will address:**
  - Parametric uncertainty
  - Model uncertainty
  - Completeness uncertainty
- **Parametric uncertainty will quantify uncertainty associated with input parameters that are not conservative or bounding (e.g., mean LOCA frequency values)**
- **Model uncertainty will quantify uncertainty associated with models that are not consensus models (e.g., continuum break model) by running a sensitivity case with an alternative model (e.g., DEGB only model)**
- **Completeness uncertainty will be qualitatively evaluated**

# Sensitivity Analysis

- **Sensitivity analysis will be performed for input parameters by varying one parameter at a time to determine its impact on the overall results**
- **Parameters will be varied through a range of values selected based on the value used in base case NARWHAL model**
  - If base case value already skewed in conservative direction, min [max] value will be assumed to be 10% lower [higher]
  - If available, design limits of an input parameter will be used
  - Otherwise, the min [max] value will be assumed to be 25% lower [higher] than the base case value
- **Sensitivity analysis will be used to gain insights on which parameters have the most significant effect on the model**



# Submittal Content and Schedule

- **Submittal will address the five principles from RG 1.174**
- **Submittal will include the following enclosures**
  - Enclosure 1: License amendment request (LAR) for implementation of risk-informed approach to address debris effects
  - Enclosure 2: Request for exemption from 10 CFR 50.46(a)(1) for the use of risk-informed approach to address debris effects
  - Enclosure 3: Updated GL 2004-02 responses following the NRC content guide (revision bars will be shown for technical changes from the 2017 GL submittal)
  - Enclosure 4: Risk quantification and sensitivity and uncertainty analyses
  - Enclosure 5: Defense-in-depth measures and safety margin
- **Submittal Schedule**
  - Complete analyses: October 2021
  - Submittal updates: December 2021
  - Submittal to the NRC: Spring 2022

# Point Beach PRA Model Status

- **Internal events PRA model developed and maintained in accordance with ASME/ANS PRA standard and RG 1.200, Revision 2**
- **Recent applications**
  - TS Initiative 5.b - SFCP
  - 10 CFR 50.69
  - NFPA-805
- **A preliminary assessment of the open peer review facts and observations (F&Os) indicates they will have no significant impact on the risk-informed resolution of GL 2004-02**
- **A preliminary review of relevant PRA model assumptions indicate that none of the assumptions are key sources of uncertainty with respect to the risk-informed resolution of GL 2004-02**



**Questions?**