

# Alternative Licensing Strategy - Overview

## Risk Informed Analysis of Loss of Coolant Accident Induced Fuel Fragmentation, Relocation, and Dispersal


Fred Smith  
EPRI - Technical Executive

NRC Pre-submittal Meeting  
June 2, 2021  
Webcast




# Issue Statement

- Enhancements to fuel safety, reliability, efficiency and economics are critical to the industry, now and into the future
- Evolutionary fuel designs and materials have enabled increases in discharge burnup limits and uranium enrichments over the past several decades
  - Burnup limit currently at 62 GWd/MTU (rod average)
  - Enrichment limit currently at 5 weight percent U-235
- Generic issue for increasing burnup limit Fuel Fragmentation, Relocation, and Dispersal (FFRD) with fuel rod burst/rupture during design basis accidents (Ref: SECY-15-0148)



# Risk Informed Analysis of LOCA induced FFRD

- Based on existing process – RG-1.174
- Small increase in Core Damage Frequency ( $<10^{-6}$ ) and Large Early Release Fraction ( $<10^{-7}$ )
  - Small Break – No cladding rupture for high burnup fuel
  - Large Break – Credit Plant Shutdown (Leak Before Break) prior to LOCA
  - Ensure overlap addresses Intermediate Break
  - Feasibility evaluations show lower risk than the target criteria by factor of 10 (regulatory margin)
- Defense in Depth/Safety Margins
  - Seven Principles for Defense in Depth addressed
  - Maintained with combination of SB-LOCA analysis results and Leak Before Break mitigation for LB-LOCA
  - Evaluation of fuel dispersal impacts provides a backup strategy



# EPRI Docketed Topical Report

## Supporting Reports

- Risk Informed LOCA Induced FFRD Evaluation

- Evaluation of impact on CDF and LERF

- Inputs

- PWR Small /Intermediate Break LOCA /Cladding Rupture Results
      - Leak Before Break Large/Intermediate Break Results
        - Human Reliability Assessment of Operator Actions
        - Break Spectrum Failure Frequency Validation
      - Other Inputs – Internally Documented
        - Conditional Containment Failure Probability
        - ECCS degradation frequency
        - Fuel Relocation Frequency – FFR
        - FFRD Frequency (If necessary)
        - Fleet Capacity Factors
    - Uncertainty Evaluation

- Analysis and Results

- Design Margin Assessment

- Inputs

- Fuel Relocation Evaluation
    - FFRD Consequences (if necessary)
      - Eq Impact
      - Criticality Impact

- Results

- Defense-in-Depth

- Inputs

- FFRD Consequences (if necessary)

- Results

- Applicability Requirements

Site Specific Submittals

Vendor Specific Small/Intermediate  
LOCA/Cladding Rupture Results

Vendor Specific Methodology Topical Updates

x-LPR Fracture Mechanics Analysis  
Intermediate/Large Piping Ruptures

Vendor Specific Fuel Relocation Evaluation

If rupture not precluded: Dispersal  
Consequences Analysis  
Dispersal Model  
DBA Source Term  
Criticality Analysis  
Coolability

A blue-tinted photograph of four people standing in a row. From left to right: a man with curly hair and glasses wearing a white lab coat; a man with glasses and a mustache wearing a white lab coat and safety glasses; a woman wearing a white hard hat and a dark shirt; and a man with glasses and a beard wearing a light blue button-down shirt. They are all smiling and looking towards the camera. The background is a solid blue color.

Together...Shaping the Future of Electricity

FULL SPECTRUM and FSLOCA trademarks or registered trademarks of Westinghouse Electric Company LLC, its affiliates and/or its subsidiaries in the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.

# Westinghouse Approach for SBLOCA Rupture Calculations to Support EPRI Alternative Licensing Strategy

Jeffrey Kobelak

Fellow Engineer

Westinghouse Electric Company

June 2021

# Background

## FULL SPECTRUM LOCA

- The **FULL SPECTRUM™ LOCA (FSLOCA™)** evaluation model (EM) is the latest advancement in Westinghouse analysis technology
  - WCOBRA/TRAC-TF2 is the T/H system code licensed as part of the FSLOCA EM
  - PAD5 code provides steady-state fuel rod calculations
- The FSLOCA EM is NRC-approved to analyze the full spectrum of break sizes using a single best-estimate code
  - Currently approved for Westinghouse-designed 3-Loop and 4-Loop plants
- The methodology demonstrates with high probability that the acceptance criteria will not be exceeded in a design basis LOCA scenario



# Background


## Incremental Burnup Extension

- Incremental burnup extension for Westinghouse (and Combustion Engineering) fuel designs was submitted to the NRC in December 2020
  - Increases fuel rod average burnup limit to ~68 GWd/MTU
- Various WCOBRA/TRAC-TF2 code models were updated for analysis of higher burnup fuel
- Method was developed to assess cladding rupture for higher burnup fuel on the core periphery under LOCA conditions using WCOBRA/TRAC-TF2



**Code and method used for SBLOCA rupture calculations to support EPRI will build on FSLOCA EM and Incremental BU submittals**


# Illustration of LOCA Cladding Temperature Response versus Break Size



# EPRI Alternate Licensing Strategy

## Preliminary Scoping Calculations

- FSLOCA EM is well-aligned with EPRI alternate licensing strategy
- Westinghouse has completed exploratory work indicating that burst may be precluded for high burnup fuel under SBLOCA and IBLOCA conditions
- Approach and results will be formalized to support EPRI submittal to NRC



# EPRI Alternate Licensing Strategy

## Westinghouse Plan

- **Step 1:** Establish bounding nuclear design envelope
  - Nuclear designs will cover various fuel designs, fuel arrays, and operating strategies
- **Step 2:** Develop bounding fuel rod design data
  - Include conservatism to ensure that plant-specific operation falls within analysis envelope
- **Step 3:** Generate bounding PWR / ECCS model
  - Updates will be made to a relatively limiting model to address PWR and ECCS design differences with first-order impact on LOCA transient results

**Applicability of various envelopes would have to be confirmed for implementation, or plant-specific calculations would be required**

# EPRI Alternate Licensing Strategy

## Westinghouse Plan

- **Step 4:** Address phenomena related to high burnup fuel rod response within the FSLOCA methodology / WCOBRA/TRAC-TF2 code as appropriate
  - Transient fission gas release
  - Potential for pre-burst axial fuel relocation
- **Step 5:** Execute cladding rupture calculations
  - Objective is to demonstrate no cladding rupture occurs for breaks smaller than threshold defined by EPRI

# Expected Ranges of Applicability


- Westinghouse-designed 2-Loop, 3-Loop, & 4-Loop PWRs
  - 2-Loop extension of the FSLOCA EM has been completed and will be available to the NRC in advance of any EPRI submittal
- Westinghouse 14x14 and 17x17 fuel assembly designs, at a minimum
  - Extension to other designs / classes could be accomplished via supplement
- Westinghouse cladding and fuel materials intended for high burnup operation



# NRC meeting – EPRI FFRD Strategy

John H. Strumpell, General Manager, US Fuel R&D

Web Conference, June 2, 2022



## Framatome Supports the Industry FFRD Solution 100%

Framatome is partnering with the industry initiative led by NEI and EPRI to develop an alternative licensing strategy to address FFRD in PWR reactors

- Framatome views the alternative licensing approach as a precedent setting, constructive approach that will fully support safe, competitive energy production
- Framatome will leverage licensed SBLOCA codes and methods to evaluate the effects of FFRD for fuel with burnups greater than 62 GWd/mTU

**Specific details of EPRI support will link to Framatome proprietary methods and is being disclosed through official channels**



# xLPR Analysis of Intermediate/Large Piping Ruptures

## LOCA Frequency Estimates and Time Between Leakage and Rupture

Craig Harrington  
Technical Executive


Nate Glunt  
Senior Technical Leader

NRC Public Meeting -EPRI Report on FFRD Licensing Strategy  
June 2, 2021



# Introduction

- “The approach would be supported by the application of the **Extremely Low Probability of Rupture (xLPR)** leak-before-break (LBB) analysis tool, developed jointly by EPRI and the NRC Office of Nuclear Regulatory Research for Large Break- (LB) LOCAs. This tool could be used within this generic methodology to **inform the probability of LB-LOCAs and that LB-LOCAs may be detected in sufficient time to allow for reactor shutdown before a reactor coolant system (RCS) piping rupture occurs.** This approach facilitates the demonstration of no fuel rod burst (that is, no FFRD) and estimates the changes in CDF.”
  - From: [Alternative Licensing Approaches for Higher Burnup Fuel: A Scoping Study on Deterministic and Risk- Informed Alternatives Supporting Fuel Discharge Burnup Extension.](#) EPRI, Palo Alto, CA: 2020. 3002018457.



# xLPR Work Scope

- **Objective:** Perform Probabilistic Fracture Mechanics (PFM) evaluation using xLPR to calculate the probabilities of Loss-of-Coolant-Accidents (LOCAs) as a function of line size
  - Use xLPR to benchmark NUREG-1829, Vol. 1, *“Estimating Loss-of-Coolant Accident (LOCA) Frequencies Through the Elicitation Process”*
    - Validate (or replace) NUREG-1829 LOCA frequency estimates for use in high burnup fuel licensing
  - Evaluate the time between detectable leakage and rupture to further inform the fuels licensing effort
- **Approach:** Project to be performed in phases
  - Phase 1 consists of a PFM evaluation of two line sizes as a proof-of-concept and to develop methodology for possible expansion to other line sizes
  - Phase 2 will expand the study to a variety of line sizes



# Phase 1 Proof-of-Concept Study

- Focus on the following:
  1. **Methodology** for using xLPR to evaluate the probability of LOCAs as a function of line size
  2. Estimation of the frequency of LOCA events
  3. Statistics on time between detectable leakage and unstable pipe rupture
- Two lines for initial evaluations were selected considering:
  - xLPR computational abilities
  - NUREG-1829 LOCA frequency insights (*smaller lines have higher frequency of rupture*)
  - Line size (*mid-range of greatest interest*)
  - Input availability
  - Degradation mechanisms (*i.e., fatigue and primary water stress corrosion cracking (PWSCC)*)
- Scope is limited to Pressurized Water Reactors (PWRs)



# Lines Selected for Evaluation

- Emphasis was placed on lines in the 6-10 in. (DN 150-250) range, as this range is of particular interest for FFRD
- Available input sources reviewed to identify lines for which xLPR inputs were readily available
  - Licensee submittals in NRC ADAMS
  - EPRI reports
  - xLPR documentation
- It was determined that of the two lines evaluated, one should be susceptible to PWSCC and the other only susceptible to fatigue since the population of dissimilar-metal welds is small

## Stainless Steel Weld

- NPS 6 (DN 150)
- NUREG-1829 category:
  - Direct Volume Injection
- Represented by [Westinghouse Safety Injection](#)
- Population includes both hot leg and cold leg temperature locations

## Alloy 82/182 Weld

- NPS 12 (DN 300) SCH 140 or 160, resulting in ~10 in. (250 mm) ID
- NUREG-1829 Category:
  - High Pressure Safety Injection
- Represented by [CE Safety Injection/Accumulator](#)
- Cold leg temperature
  - Unmitigated at most plants

# Summary of Cases Evaluated

- Base cases for each line include
  - Initial postulated flaws
  - Fatigue and PWSCC crack growth (where applicable)
  - Seismic occurrences
  - 80-years of service life
  - Inservice inspection and leak rate detection not initially credited, but included in base case inputs
- Sensitivity cases were defined considering both inputs known to have influence on xLPR results and assumptions made during input development
  - Geometry
  - Increased loading
  - Increased earthquake probability
  - Crack initiation
  - Alternate WRS Profile
  - Multiple initial flaws
  - Mitigation

# Initial Results

- Runs are nearing completion for the two lines selected for Phase 1
- Loading and WRS sensitivity cases have shown the highest importance
- As expected, LOCA frequencies are higher for lines susceptible to PWSCC
  - When fatigue is the only active degradation mechanism the frequency of occurrence of leakage/rupture is extremely low
- Results show rupture frequencies on similar order of magnitude or lower than NUREG-1829 LOCA frequencies
  - Results are conservative as inservice inspection and leak rate detection were not credited
- Time between detectable leakage and rupture data also show notable margin (>1 year) between leak rates of 1 and 10 gpm and rupture

# Summary

- xLPR is being used to estimate probabilities of rupture, for comparison with LOCA frequency estimates presented in NUREG-1829
  - Initial analysis cases
    - Stainless Steel Weld – NPS 6 (DN 150)
    - Alloy 82/182 Weld – NPS 12 (DN 300) *w/ ID of ~10 in. (250 mm)*
- Results suggest the NUREG-1829 LOCA frequencies are conservative
  - It is noted that NUREG-1829 expert elicitation considered degradation mechanisms in addition to those modeled in these xLPR analyses
- A methodology has been established that is able (*with some refinements*) to evaluate LOCA probabilities and time between leakage and rupture for other PWR lines



A blue-tinted photograph of four people standing in a row. From left to right: a man with curly hair and glasses in a lab coat; a man with glasses in a lab coat; a woman wearing a hard hat and safety glasses in a lab coat; and a man with glasses and a beard in a light blue button-down shirt. They are all smiling and looking towards the camera. The background is a solid blue color.

# Together...Shaping the Future of Electricity

# Risk-Informed Analysis of LOCA-Induced Fuel Fragmentation, Relocation and Dispersal

## Risk Assessment for High Burnup Fuel

Storm Kauffman  
MPR Associates, Inc.

NRC Pre-Application Meeting  
June 2, 2021



# Outline

- Objective
- Topical Report
- Risk-Informed LOCA-Induced FFRD Methodology
- Technical Basis for Methodology
- Human Reliability Analysis
- Defense in Depth and Safety Margins
- Conclusion – Key Takeaways

# Objective for Industry Initiative


Demonstrate that fuel fragmentation, relocation, and dispersal of fuel with peak rod average burnups in the range 62 to 75 GWd/MTU caused by LOCA events is of sufficiently low risk that it does not need to be included in the design-basis analyses of LOCA consequences, as currently performed to satisfy 10 CFR 50.46

Not intended to justify:

- Changes to safety-related Systems, Structures and Components requirements
- Relaxation of conditions for operation

# Topical Report


- Topical Report to be submitted to NRC
  - Assess justification for burnup limit extensions for PWRs
  - Minimize need for licensee-specific analysis
  - $\Delta$ CDF estimates ( $\Delta$ LERF if needed)
  - Uncertainties
  - Defense-in-depth
  - Safety margins



RG 1.174 - Figure 2.  
Principles of risk-informed integrated decision making


# Risk-Informed LOCA-Induced FFRD Methodology

- RG 1.174 approach; address RG 1.200
- Supporting analyses
  - LOCA analyses to determine break size threshold for rod burst
  - xLPR to assess:
    - Initiating event frequency
    - Time for operator response
- Probabilistic Risk Assessment (PRA) goal
  - Determine  $\Delta$  CDF for LOCAs with potential to induce FFRD
  - If  $\Delta$  CDF  $< 10^{-7}/\text{ry}$ , no calculation of total CDF is required
    - Individual plant CDF not a constraint
    - Determination of  $\Delta$  LERF and containment failure probability analysis may not be required if  $\Delta$  CDF is below RG 1.174 criteria



# Technical Basis for Methodology

- Larger breaks are very low frequency
  - xLPR predicts large breaks presaged by detectable leakage
  - Use xLPR to predict:
    - Frequency
    - Time from detectable rate before rupture occurs




NUREG-1829, Vol 2, PWR part of Figure 1

# Technical Basis for Methodology

## ■ LOCA-induced FFRD

- Does not affect LOCA PRA of record for individual plants
- LOCAs already included in individual plant PRA
  - A portion of these LOCAs is assessed for FFRD risk
- $\Delta$ CDF for LOCAs is in addition to existing plant CDF:
  - Cannot reduce CDF
- Details of PRA may differ from that of individual plants:
  - Event trees: simplified and different top events
  - Initiating event frequency (IEF) based on xLPR and NUREG-1829
  - Assess operator response by Human Reliability Analysis (HRA)





# Human Reliability Analysis

- HRA methodology considers human error probability, dependency, time available for action, training, procedures, etc.
- Consistent with industry practice
  - Slow flaw progression allows time for operator recognition and response
  - Considerable time available for operator detection of leak
  - RG 1.45 criteria – multiple means to detect 1 gpm within one hour
  - Technical Specifications Limiting Condition for Operation for unidentified leakage
  - Plant procedures for troubleshooting/responding to increased unidentified leakage
  - Response to alarm indications of unidentified leakage

# Defense in Depth and Safety Margins

## Defense in Depth

- Maintain existing layers of defense
- Design features unaffected
- Preserve system redundancy, independence and diversity
- Assess defense against potential common cause failures
- Evaluate impact on effectiveness of the multiple fission product barriers
- Assess defense against human errors
- Retain existing plant's design criteria

## Safety Margins

- Maintain sufficient safety margin
- No reduction in required safety system performance specifications

**Address criteria of RG 1.174**

# Conclusion – Key Takeaways

- Proposed licensing basis change:

*“Fuel fragmentation, relocation, and dispersal of fuel with peak rod average burnups in the range 62 to 75 GWd/MTU caused by LOCA events is of sufficiently low risk that it does not need to be included in the design-basis analyses of LOCA consequences, as currently performed to satisfy 10 CFR 50.46.”*

- Risk-informed application of RG 1.174 to LOCA-induced FFRD

- Low probability event – NUREG-1829 / xLPR
- xLPR – validates time for operator detection of leak and response
- Defense in depth maintained – requirements for safety equipment not relaxed
- Safety margins maintained – requirements for safety margins not relaxed

A blue-tinted photograph of four people, two men and two women, standing in a row. They are all wearing white lab coats with the EPRI logo on the left chest. The man on the far left has curly hair and glasses. The man next to him has short dark hair and glasses. The woman next to him is wearing a white hard hat and has short dark hair. The man on the far right has a beard and glasses. They are all smiling and looking towards the camera. The background is a solid blue color.

# Together...Shaping the Future of Electricity

# Alternative Licensing Strategy

## Submittal Schedule

Fred Smith  
EPRI – Technical Executive

NRC Pre-Application Meeting  
June 2, 2021



## EPRI Docketed Topical Report

### ▪ Risk Informed LOCA Induced FFRD Evaluation

- Evaluation of impact on CDF and LERF
  - Inputs
    - PWR Small /Intermediate Break LOCA /Cladding Rupture Results
    - Leak Before Break Large/Intermediate Break Results
      - Human Reliability Assessment of Operator Actions
      - Break Spectrum Failure Frequency Validation
    - Other Inputs – Internally Documented
      - Conditional Containment Failure Probability
      - ECCS degradation frequency
      - Fuel Relocation Frequency – FFR
      - FFRD Frequency (If necessary)
      - Fleet Capacity Factors
    - Uncertainty Evaluation
  - Analysis and Results
- Design Margin Assessment
  - Inputs
    - Fuel Relocation Evaluation
    - FFRD Consequences (if necessary)
      - Eq Impact
      - Criticality Impact
  - Results
- Defense-in-Depth
  - Inputs
    - FFRD Consequences (if necessary)
  - Results
- Applicability Requirements

Site Specific Submittals

## Supporting Reports

Vendor Specific Small/Intermediate  
LOCA/Cladding Rupture Results

Vendor Specific Methodology Topical Updates

x-LPR Fracture Mechanics Analysis  
Intermediate/Large Piping Ruptures

Vendor Specific Fuel Relocation Evaluation

**If rupture not precluded:** Dispersal  
Consequences Analysis

Dispersal Model

DBA Source Term

Criticality Analysis

Coolability

# Planned Submittal

- Schedule 4<sup>th</sup> quarter 2022
  - Risk Informed LOCA induced FFRD Evaluation
    - Vendor Specific LOCA Evaluations
    - xLPR Fracture Mechanics Analysis
    - Consequence Analysis - If cladding rupture is NOT precluded
  - Vendor Specific Methodology Updates

A blue-tinted photograph of four people, likely EPRI staff, standing in a row. From left to right: a man with curly hair and glasses wearing a white lab coat; a man with glasses and a mustache wearing a white lab coat; a woman wearing a white hard hat and a dark shirt; and a man with glasses and a beard wearing a light blue button-down shirt. They are all smiling and looking towards the camera. The text "Together...Shaping the Future of Electricity" is overlaid in white in the center.

Together...Shaping the Future of Electricity