



Energy Harbor Nuclear Corp.
Beaver Valley Power Station
P. O. Box 4
Shippingport, PA 15077

John J. Grabnar
Site Vice President, Beaver Valley Nuclear

724-682-5234

May 21, 2020
L-21-137

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

SUBJECT:
Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Cycle 28 Core Operating Limits Report

Pursuant to the requirements of Beaver Valley Power Station, Unit No. 1 Technical Specification 5.6.3, "CORE OPERATING LIMITS REPORT (COLR)," Energy Harbor Nuclear Corp. hereby submits the COLR for Cycle 28. Technical Specification 5.6.3.d requires, in part, that the COLR be provided to the Nuclear Regulatory Commission upon issuance for each reload cycle, including any midcycle revisions or supplements. The Cycle 28 COLR was made effective on April 23, 2021.

There are no regulatory commitments contained in this submittal. If there are any questions, or if additional information is required, please contact Mr. Phil H. Lashley, Manager - Fleet Licensing, at (330) 696-7208.

Sincerely,

Grabnar, John 19072
Site Vice President, Beaver Valley
I am approving this document
May 21 2021 1:00 PM

DocuSign

John J. Grabnar

Enclosure:
Beaver Valley Power Station, Unit No. 1, Core Operating Limits Report, Cycle 28

cc: NRC Region I Administrator
NRC Resident Inspector
NRC Project Manager
Director BRP/DEP
Site BRP/DEP Representative

Enclosure
L-21-137

Beaver Valley Power Station, Unit No. 1,
Core Operating Limits Report, Cycle 28
(16 pages follow)

5.0 ADMINISTRATIVE CONTROLS

5.1 Core Operating Limits Report

This Core Operating Limits Report provides the cycle specific parameter limits developed in accordance with the NRC approved methodologies specified in Technical Specification Administrative Control 5.6.3.

5.1.1 SL 2.1.1 Reactor Core Safety Limits

See Figure 5.1-1.

5.1.2 SHUTDOWN MARGIN (SDM)

- a. In MODES 1, 2, 3, and 4, SHUTDOWN MARGIN shall be $\geq 1.77\% \Delta k/k$.⁽¹⁾
- b. Prior to manually blocking the Low Pressurizer Pressure Safety Injection Signal, the Reactor Coolant System shall be borated to \geq the MODE 5 boron concentration and shall remain \geq this boron concentration at all times when this signal is blocked.
- c. In MODE 5, SHUTDOWN MARGIN shall be $\geq 1.0\% \Delta k/k$.

5.1.3 LCO 3.1.3 Moderator Temperature Coefficient (MTC)

- a. Upper Limit - MTC shall be maintained within the acceptable operation limit specified in Technical Specification Figure 3.1.3-1.
- b. Lower Limit - MTC shall be maintained less negative than $-4.4 \times 10^{-4} \Delta k/k/^{\circ}F$ at RATED THERMAL POWER.
- c. 300 ppm Surveillance Limit: $(-37 \text{ pcm}/^{\circ}F)$
- d. The revised predicted near-EOL 300 ppm MTC shall be calculated using Figure 5.1-5 and the following algorithm from Reference 11 :

Revised Predicted MTC = Predicted MTC* + AFD Correction** + Predictive Correction***

where,

* Predicted MTC is calculated from Figure 5.1-5 at the burnup corresponding to the measurement of 300 ppm at RTP conditions,

** AFD Correction is the more negative value of :

$$\{0 \text{ pcm}/^{\circ}F \text{ or } (\Delta AFD * AFD \text{ Sensitivity})\}$$

where: ΔAFD is the measured AFD minus the predicted AFD from an incore flux map taken at or near the burnup corresponding to 300 ppm.

and

$$AFD \text{ Sensitivity} = 0.10 \text{ pcm}/^{\circ}F / \Delta AFD$$

***Predictive Correction is $-3 \text{ pcm}/^{\circ}F$.

(1) The MODE 1 and MODE 2 with $k_{eff} \geq 1.0$ SDM requirements are included to address SDM requirements (e.g., MODE 1 Required Actions to verify SDM) that are not within the applicability of LCO 3.1.1, SHUTDOWN MARGIN (SDM).

5.1 Core Operating Limits Report

If the revised predicted MTC is less negative than the SR 3.1.3.2 limit (COLR 5.1.3.c) and all of the benchmark data contained in the surveillance procedure are met, then an MTC measurement, in accordance with SR 3.1.3.2, is not required.

- e. 60 ppm Surveillance Limit: (- 42.5 pcm/°F)

5.1.4 LCO 3.1.5 Shutdown Bank Insertion Limits

The Shutdown Banks shall be withdrawn to at least 225 steps.⁽²⁾

5.1.5 LCO 3.1.6 Control Bank Insertion Limits

- Control Banks A and B shall be withdrawn to at least 225 steps.⁽²⁾
- Control Banks C and D shall be limited in physical insertion as shown in Figure 5.1-2.⁽²⁾
- Sequence Limits - The sequence of withdrawal shall be A, B, C and D bank, in that order.
- Overlap Limits⁽²⁾ - Overlap shall be such that step 129 on banks A, B, and C corresponds to step 1 on the following bank. When C bank is fully withdrawn, these limits are verified by confirming D bank is withdrawn at least to a position equal to the all-rods-out position minus 128 steps.

5.1.6 LCO 3.2.1 Heat Flux Hot Channel Factor ($F_Q(Z)$)

The Heat Flux Hot Channel Factor - $F_Q(Z)$ limit is defined by:

$$F_Q(Z) \leq \left[\frac{CFQ}{P} \right] * K(Z) \quad \text{for } P > 0.5$$

$$F_Q(Z) \leq \left[\frac{CFQ}{0.5} \right] * K(Z) \quad \text{for } P \leq 0.5$$

Where: $CFQ = 2.40$ $P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$

$K(Z)$ = the function obtained from Figure 5.1-3.

$$F_Q^C(Z) = F_Q^M(Z) * 1.0815^{\$}$$

$$F_Q^W(Z) = F_Q^C(Z) * W(Z)$$

(2) As indicated by the group demand counter

\$ An additional uncertainty is to be applied if the number of measured thimbles for the moveable incore detector system is less than 75% of the total number of thimbles. If there are less than 75% of the total number of thimbles and at least 50% of the total number of thimbles measured, an additional uncertainty of $(0.01)^{(3-T/12.5)}$ is added to the measurement uncertainty, 1.05, where T is the total number of measured thimbles. This adjusted measurement uncertainty is then multiplied by 1.03 to obtain the total uncertainty to be applied. At least three measured thimbles per core quadrant are also required.

5.1 Core Operating Limits Report

The W(Z) values are provided in Table 5.1-1 and 5.1-2. The W(Z) values in Table 5.1-1 were generated assuming that they will be used for full power surveillance. The W(Z) values in Table 5.1-2 were generated assuming that they will be used for a part power surveillance during initial cycle startup following the refueling outage. When a part power surveillance is performed, the W(Z) values should be multiplied by the factor 1/P, when $P > 0.5$. When $P \leq 0.5$, the W(Z) values should be multiplied by the factor 1/(0.5), or 2.0. This is consistent with the adjustment in the $F_Q(Z)$ limit at part power conditions.

The $F_Q(Z)$ penalty function, applied when the analytic $F_Q(Z)$ function increases from one monthly measurement to the next, is provided in Table 5.1-3.

5.1.7 LCO 3.2.2 Nuclear Enthalpy Rise Hot Channel Factor ($F_{\Delta H}^N$)

$$F_{\Delta H}^N \leq CF_{\Delta H} * (1 + PF_{\Delta H} (1-P))^{\$}$$

Where: $CF_{\Delta H}$ = Value listed in Table 5.1-4

$$PF_{\Delta H} = 0.3$$

$$P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$$

5.1.8 LCO 3.2.3 Axial Flux Difference (AFD)

The AFD acceptable operation limits are provided in Figure 5.1-4.

5.1.9 LCO 3.3.1 Reactor Trip System Instrumentation - Overtemperature and Overpower ΔT Parameter Values from Table Notations 1 and 2a. Overtemperature ΔT Setpoint Parameter Values:

<u>Parameter</u>	<u>Value</u>
Overtemperature ΔT reactor trip setpoint	$K1 \leq 1.242$
Overtemperature ΔT reactor trip setpoint Tavg coefficient	$K2 \geq 0.0183/^{\circ}\text{F}$
Overtemperature ΔT reactor trip setpoint pressure coefficient	$K3 \geq 0.001/\text{psia}$
Tavg at RATED THERMAL POWER	$T' \leq 577.9^{\circ}\text{F}^{(1)}$

$\$$ An additional uncertainty is to be applied if the number of measured thimbles for the moveable incore detector system is less than 75% of the total number of thimbles. If there are less than 75% of the total number of thimbles and at least 50% of the total number of thimbles measured, an additional uncertainty of $(0.01) * (3 - T/12.5)$ is added to the standard uncertainty on $FN_{\Delta H}$ of 1.04, where T is the total number of measured thimbles. At least three measured thimbles per core quadrant are also required.

(1) T' represents the cycle-specific Full Power Tavg value used in core design.

5.1 Core Operating Limits Report

Nominal pressurizer pressure	$P' \geq 2250$ psia
Measured reactor vessel average temperature lead/lag time constants	$\tau_1 \geq 30$ secs $\tau_2 \leq 4$ secs
Measured reactor vessel ΔT lag time constant	$\tau_4 \leq 6$ secs
Measured reactor vessel average temperature lag time constant	$\tau_5 \leq 2$ secs

$f(\Delta I)$ is a function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) For $q_t - q_b$ between -37% and +15%, $f(\Delta I) = 0$ (where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER).
- (ii) For each percent that the magnitude of $(q_t - q_b)$ exceeds -37%, the ΔT trip setpoint shall be automatically reduced by 2.52% of its value at RATED THERMAL POWER.
- (iii) For each percent that the magnitude of $(q_t - q_b)$ exceeds +15%, the ΔT trip setpoint shall be automatically reduced by 1.47% of its value at RATED THERMAL POWER.

b. Overpower ΔT Setpoint Parameter Values:

<u>Parameter</u>	<u>Value</u>
Overpower ΔT reactor trip setpoint	$K4 \leq 1.085$
Overpower ΔT reactor trip setpoint Tav _g rate/lag coefficient	$K5 \geq 0.02/^{\circ}\text{F}$ for increasing average temperature $K5 = 0/^{\circ}\text{F}$ for decreasing average temperature
Overpower ΔT reactor trip setpoint Tav _g heatup coefficient	$K6 \geq 0.0021/^{\circ}\text{F}$ for $T > T''$ $K6 = 0/^{\circ}\text{F}$ for $T \leq T''$
Tav _g at RATED THERMAL POWER	$T'' \leq 577.9^{\circ}\text{F}^{(2)}$
Measured reactor vessel average temperature rate/lag time constant	$\tau_3 \geq 10$ secs
Measured reactor vessel ΔT lag time constant	$\tau_4 \leq 6$ secs
Measured reactor vessel average temperature lag time constant	$\tau_5 \leq 2$ secs

- (2) T'' represents the cycle-specific Full Power Tav_g value used in core design.

5.1 Core Operating Limits Report

5.1.10 LCO 3.4.1, RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits

<u>Parameter</u>	<u>Indicated Value</u>
Reactor Coolant System T _{avg}	T _{avg} ≤ 581.5°F ⁽¹⁾
Pressurizer Pressure	Pressure ≥ 2218 psia ⁽²⁾
Reactor Coolant System Total Flow Rate	Flow ≥ Value listed in Table 5.1-4 ⁽³⁾

5.1.11 LCO 3.9.1 Boron Concentration (MODE 6)

The boron concentration of the Reactor Coolant System, the refueling canal, and the refueling cavity shall be maintained ≥ 2400 ppm. This value includes a 50 ppm conservative allowance for uncertainties.

-
- (1) The Reactor Coolant System (RCS) indicated T_{avg} value is determined by adding the appropriate allowances for rod control operation and verification via control board indication (3.6°F) to the cycle specific full power T_{avg} used in the core design.
 - (2) The pressurizer pressure value includes allowances for pressurizer pressure control operation and verification via control board indication.
 - (3) The RCS total flow rate includes allowances for normalization of the cold leg elbow taps with a beginning of cycle precision RCS flow calorimetric measurement and verification on a periodic basis via control board indication.

5.1 Core Operating Limits Report

5.1.12 References

1. WCAP-9272-P-A, "WESTINGHOUSE RELOAD SAFETY EVALUATION METHODOLOGY," July 1985 (Westinghouse Proprietary).
2. WCAP-8745-P-A, "Design Bases for the Thermal Overpower ΔT and Thermal Overtemperature ΔT Trip Functions," September 1986.
3. WCAP-12945-P-A, Volume 1 (Revision 2) and Volumes 2 through 5 (Revision 1), "Code Qualification Document for Best Estimate LOCA Analysis," March 1998 (Westinghouse Proprietary).
4. WCAP-10216-P-A, Revision 1A, "Relaxation of Constant Axial Offset Control-F_Q Surveillance Technical Specification," February 1994.
5. WCAP-14565-P-A, "VIPRE-01 Modeling and Qualification for Pressurized Water Reactor Non-LOCA Thermal-Hydraulic Safety Analysis," October 1999.
6. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," April 1995 (Westinghouse Proprietary).
7. WCAP-15025-P-A, "Modified WRB-2 Correlation, WRB-2M, for Predicting Critical Heat Flux in 17x17 Rod Bundles with Modified LPD Mixing Vane Grids," April 1999.
8. Caldon, Inc. Engineering Report-80P, "Improving Thermal Power Accuracy and Plant Safety While Increasing Operating Power Level Using the LEFM[√]™ System," Revision 0, March 1997.
9. Caldon, Inc. Engineering Report-160P, "Supplement to Topical Report ER-80P: Basis for a Power Uprate With the LEFM[√]™ System," Revision 0, May 2000.
10. WCAP-16009-P-A, "Realistic Large Break LOCA Evaluation Methodology Using Automated Statistical Treatment of Uncertainty Method (ASTRUM)," Revision 0, January 2005.
11. WCAP-13749-P-A, "Safety Evaluation Supporting the Conditional Exemption of the Most Negative EOL Moderator Temperature Coefficient Measurement," March 1997 (Westinghouse Proprietary).
12. WCAP-16045-P-A, "Qualification of the Two-Dimensional Transport Code PARAGON," August 2004.
13. WCAP-16045-P-A, Addendum 1-A, "Qualification of the NEXUS Nuclear Data Methodology," August 2007.
14. WCAP-12610-P-A & CENPD-404-P-A, Addendum 1-A, "Optimized ZIRLO™," July 2006.




Figure 5.1-1 (Page 1 of 1)

REACTOR CORE SAFETY LIMIT
THREE LOOP OPERATION
(Technical Specification Safety Limit 2.1.1)




Figure 5.1-2 (Page 1 of 1)

CONTROL ROD INSERTION LIMITS




Figure 5.1-3 (Page 1 of 1)

F_{QT} NORMALIZED OPERATING ENVELOPE, $K(Z)$




Figure 5.1-4 (Page 1 of 1)

AXIAL FLUX DIFFERENCE LIMITS AS A FUNCTION OF
PERCENT OF RATED THERMAL POWER FOR RAOC




Figure 5.1-5 (Page 1 of 1)

HOT FULL POWER PREDICTED
MODERATOR TEMPERATURE COEFFICIENT
AS A FUNCTION OF CYCLE BURNUP
WHEN 300 PPM IS ACHIEVED

Table 5.1-1 (Page 1 of 2)
F_Q Surveillance W(Z) Function versus Burnup at 100% RTP

Exclusion Zone	Axial Point	Elevation (feet)	150 MWD/MTU	3000 MWD/MTU	8000 MWD/MTU	12000 MWD/MTU	16000 MWD/MTU
*	1	12.08	1.0000	1.0000	1.0000	1.0000	1.0000
*	2	11.88	1.0000	1.0000	1.0000	1.0000	1.0000
*	3	11.68	1.0000	1.0000	1.0000	1.0000	1.0000
*	4	11.47	1.0000	1.0000	1.0000	1.0000	1.0000
*	5	11.27	1.0000	1.0000	1.0000	1.0000	1.0000
*	6	11.07	1.0000	1.0000	1.0000	1.0000	1.0000
*	7	10.87	1.0000	1.0000	1.0000	1.0000	1.0000
	8	10.67	1.1076	1.1582	1.2370	1.2366	1.2096
	9	10.47	1.1026	1.1559	1.2339	1.2303	1.2038
	10	10.27	1.0971	1.1516	1.2283	1.2227	1.1974
	11	10.07	1.1026	1.1496	1.2209	1.2142	1.1937
	12	9.86	1.1079	1.1470	1.2125	1.2051	1.1953
	13	9.66	1.1128	1.1446	1.2034	1.1956	1.2019
	14	9.46	1.1142	1.1413	1.2009	1.1873	1.2078
	15	9.26	1.1122	1.1355	1.2002	1.1829	1.2099
	16	9.06	1.1141	1.1369	1.1988	1.1777	1.2171
	17	8.86	1.1206	1.1373	1.1960	1.1742	1.2185
	18	8.66	1.1306	1.1408	1.1973	1.1779	1.2238
	19	8.46	1.1380	1.1466	1.2006	1.1855	1.2342
	20	8.25	1.1440	1.1504	1.2017	1.1907	1.2423
	21	8.05	1.1487	1.1529	1.2009	1.1939	1.2475
	22	7.85	1.1523	1.1544	1.1988	1.1955	1.2508
	23	7.65	1.1535	1.1536	1.1946	1.1950	1.2514
	24	7.45	1.1536	1.1520	1.1892	1.1932	1.2505
	25	7.25	1.1521	1.1484	1.1813	1.1887	1.2459
	26	7.05	1.1500	1.1444	1.1723	1.1825	1.2389
	27	6.84	1.1470	1.1395	1.1629	1.1758	1.2310
	28	6.64	1.1423	1.1331	1.1521	1.1678	1.2216
	29	6.44	1.1369	1.1260	1.1417	1.1586	1.2103
	30	6.24	1.1312	1.1180	1.1345	1.1482	1.1971
	31	6.04	1.1242	1.1131	1.1262	1.1370	1.1828
	32	5.84	1.1196	1.1084	1.1173	1.1260	1.1677

Note: Top and Bottom 10% Excluded

Table 5.1-1 (Page 2 of 2)
F_Q Surveillance W(Z) Function versus Burnup at 100% RTP

Exclusion Zone	Axial Point	Elevation (feet)	150 MWD/MTU	3000 MWD/MTU	8000 MWD/MTU	12000 MWD/MTU	16000 MWD/MTU
	33	5.64	1.1180	1.1033	1.1078	1.1187	1.1512
	34	5.44	1.1173	1.1021	1.1005	1.1102	1.1373
	35	5.23	1.1169	1.1025	1.0960	1.1049	1.1343
	36	5.03	1.1170	1.1056	1.0930	1.1011	1.1292
	37	4.83	1.1217	1.1101	1.0912	1.0970	1.1238
	38	4.63	1.1273	1.1142	1.0889	1.0926	1.1176
	39	4.43	1.1326	1.1180	1.0865	1.0881	1.1109
	40	4.23	1.1373	1.1221	1.0840	1.0833	1.1040
	41	4.03	1.1416	1.1274	1.0816	1.0804	1.0971
	42	3.83	1.1458	1.1324	1.0788	1.0804	1.0885
	43	3.62	1.1513	1.1371	1.0754	1.0802	1.0841
	44	3.42	1.1570	1.1414	1.0748	1.0800	1.0819
	45	3.22	1.1620	1.1452	1.0762	1.0799	1.0794
	46	3.02	1.1672	1.1496	1.0767	1.0796	1.0763
	47	2.82	1.1829	1.1605	1.0864	1.0828	1.0778
	48	2.62	1.2045	1.1814	1.1033	1.0949	1.0883
	49	2.42	1.2250	1.2055	1.1201	1.1101	1.1022
	50	2.21	1.2460	1.2294	1.1378	1.1253	1.1159
	51	2.01	1.2672	1.2535	1.1552	1.1397	1.1286
	52	1.81	1.2881	1.2773	1.1722	1.1536	1.1405
	53	1.61	1.3074	1.2993	1.1884	1.1667	1.1521
	54	1.41	1.3249	1.3192	1.2031	1.1787	1.1628
*	55	1.21	1.0000	1.0000	1.0000	1.0000	1.0000
*	56	1.01	1.0000	1.0000	1.0000	1.0000	1.0000
*	57	0.81	1.0000	1.0000	1.0000	1.0000	1.0000
*	58	0.60	1.0000	1.0000	1.0000	1.0000	1.0000
*	59	0.40	1.0000	1.0000	1.0000	1.0000	1.0000
*	60	0.20	1.0000	1.0000	1.0000	1.0000	1.0000
*	61	0.00	1.0000	1.0000	1.0000	1.0000	1.0000

Note: Top and Bottom 10% Excluded

Table 5.1-2 (Page 1 of 2)
F_Q Surveillance W(Z) Function versus Burnup at 75% RTP

Exclusion Zone	Axial Point	Elevation (feet)	75% RTP
*	1	12.08	1.0000
*	2	11.88	1.0000
*	3	11.68	1.0000
*	4	11.47	1.0000
*	5	11.27	1.0000
*	6	11.07	1.0000
*	7	10.87	1.0000
	8	10.67	1.2103
	9	10.47	1.1908
	10	10.27	1.1698
	11	10.07	1.1571
	12	9.86	1.1447
	13	9.66	1.1364
	14	9.46	1.1210
	15	9.26	1.1062
	16	9.06	1.0929
	17	8.86	1.0932
	18	8.66	1.0935
	19	8.46	1.0903
	20	8.25	1.0908
	21	8.05	1.0898
	22	7.85	1.0897
	23	7.65	1.0875
	24	7.45	1.0857
	25	7.25	1.0822
	26	7.05	1.0806
	27	6.84	1.0769
	28	6.64	1.0736
	29	6.44	1.0688
	30	6.24	1.0655
	31	6.04	1.0592
	32	5.84	1.0572

Note: Top and Bottom 10% Excluded

Table 5.1-2 (Page 2 of 2)
F_Q Surveillance W(Z) Function versus Burnup at 75% RTP

Exclusion Zone	Axial Point	Elevation (feet)	75% RTP
	33	5.64	1.0582
	34	5.44	1.0596
	35	5.23	1.0629
	36	5.03	1.0640
	37	4.83	1.0715
	38	4.63	1.0793
	39	4.43	1.0882
	40	4.23	1.0944
	41	4.03	1.1030
	42	3.83	1.1113
	43	3.62	1.1200
	44	3.42	1.1298
	45	3.22	1.1382
	46	3.02	1.1484
	47	2.82	1.1667
	48	2.62	1.1926
	49	2.42	1.2152
	50	2.21	1.2390
	51	2.01	1.2645
	52	1.81	1.2899
	53	1.61	1.3140
	54	1.41	1.3357
*	55	1.21	1.0000
*	56	1.01	1.0000
*	57	0.81	1.0000
*	58	0.60	1.0000
*	59	0.40	1.0000
*	60	0.20	1.0000
*	61	0.00	1.0000

Note: Top and Bottom 10% Excluded

Table 5.1-3
F_Q(Z) Penalty Factor versus Burnup

Cycle Burnup (MWD/MTU)	F _Q (Z) Penalty Factor
> 0	1.0200

Note: The Penalty Factor, to be applied to F_Q(Z) in accordance with Technical Specification Surveillance Requirement (SR) 3.2.1.2, is the maximum factor by which F_Q(Z) is expected to increase over a 39 Effective Full Power Day (EFPD) interval (surveillance interval of 31 EFPD plus the maximum allowable extension not to exceed 25% of the surveillance interval per Technical Specification SR 3.0.2) starting from the burnup at which the F_Q(Z) was determined.

Table 5.1-4
F_{ΔH} Limit versus Minimum Measured Flow

Minimum Measured Flow (MMF) (gpm)	F _{ΔH} Limit
MMF ≥ 279,731	1.62
279,731 > MMF ≥ 278,348	1.61
278,348 > MMF ≥ 277,499	1.60