

June 2, 2021

Docket No.: 50-366

NL-21-0528

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Edwin I. Hatch Nuclear Plant – Unit 2
Inservice Inspection Program Owner's Activity Report (OAR-1) for Outage 2R26

Ladies and Gentlemen:

The Edwin I. Hatch Nuclear Plant Unit 2 OAR-1 for the 2R26 Refueling Outage is provided as an Enclosure to this letter, in accordance with ASME Section XI, Article IWA-6200 and ASME Section XI Code Case N-532-5. This Enclosure includes Table 1, "Items with Flaws or Relevant Conditions that Required Evaluation for Continued Service," which lists evaluations performed for continued service, and Table 2, "Abstract of Repair / Replacement Activities Required for Continued Service," which lists repair/replacement activities.

This report is for the second period of the 5th Inservice Inspection Interval (Interval 5, Period 2, Outage 2)

This letter contains no NRC commitments. If you have any questions, please contact Jamie Coleman at 205.992.6611.

Respectfully submitted,

Cheryl A. Gayheart
Regulatory Affairs Director

CAG/dsp/cbg

Enclosure: 2R26 Form OAR-1 Owner's Activity Report

cc: Regional Administrator, Region II
NRR Project Manager – Hatch
Senior Resident Inspector – Hatch
RType: CHA02.004

Edwin I. Hatch Nuclear Plant – Unit 2
Inservice Inspection Program Owner's Activity Report (OAR-1) for Outage 2R26

Enclosure

2R26 Form OAR-1 Owner's Activity Report

Form OAR-1 – Owner's Activity Report

Report Number 2-5-2-2 (Unit 2, 5th Interval, 2nd period, 2nd Report)

Plant Edwin I. Hatch Nuclear Plant -11028 Hatch Parkway North, Baxley, GA 31513 (Bin 63010)

Unit No. 2 Commercial Service Date 09/05/1979 Refueling Outage No. H2R26
(if applicable)

Applicable Inspection Interval 5th
(1st, 2nd, 3rd, 4th, other)

Applicable Inspection Period 2nd
(1st, 2nd, 3rd)

Edition and Addenda of Section XI Applicable to the Inspection Plans 2007 Edition through the 2008 Addenda

Volume 1 - 02/03/2021 (Version 5.0), Volume 2 - 01/20/2021 (Version 3.0),
Volume 3 - 02/06/2019 (Version 2.0), Volume 4 - 01/20/2021 (Version 4.0),
Volume 5 - 02/02/2021 (Version 3.0) Outage Selection Plan Revision 1 – 1/27/21, Outage
Selection Plan (scope change 001) – 2/11/21, Outage Selection Plan (scope change 002) –
3/3/21

Date and Revision of Inspection Plans

Edition and Addenda of Section XI Applicable to Repair/Replacement Activities (If different than the Inspection Plans) Same

Code Cases Used for Inspection and Evaluation: N-532-5, N-648-2, N-716-1, N-702, N-805
(if applicable)

CERTIFICATE OF CONFORMANCE

I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion of H2R26 conform to the requirements of ASME Code, Section XI. (Refueling Outage Number)

Signed [Signature] Engineering Support Sr Mgr Date 5/18/21
Owner or Owner's Designee Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by The Hartford Steam Boiler Inspection and Insurance Company of Hartford, CT have inspected the items described in this Owner's Activity Report and state that, to the best of my knowledge and belief, the Owner has performed all activities represented by this report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair/replacement activities and evaluation described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 15391 NI GA 1321
Inspector's Signature National Board, State, Province, and Endorsements
Date 6/01/2021

Table 1 – Items with Flaws or Relevant Conditions that Required Evaluation for Continued Service
Edwin I. Hatch Nuclear Plant – Unit 2 (Cycle 26)

Examination Category and Item Number	Item Description	Evaluation Description
None	None	None

Table 2 – Abstract of Repairs, Replacement or Corrective Measures Required for Continue Service

Edwin I. Hatch Nuclear Plant – Unit 2 (Cycle 26)

Code Class	Item Description	Description of Work	Date Completed	R&R Work Order
2	10' RHR piping	Replacement of piping between 2E11F073B and 2E11F075B due to pin hole leak	2/21/21	SNC1039571