



Michael J. Yox
Regulatory Affairs Director
Vogtle 3 & 4

7825 River Road
Waynesboro, GA 30830
706-848-6459 tel

JUN 04 2021

Docket No.: 52-025

ND-21-0551
10 CFR 52.99(c)(1)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Southern Nuclear Operating Company
Vogtle Electric Generating Plant Unit 3
ITAAC Closure Notification on Completion of ITAAC 2.3.04.05 [Index Number 332]

Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 2.3.04.05 [Index Number 332]. This ITAAC confirms the retrievability of Fire Protection System pump displays in the Main Control Room. The closure process for this ITAAC is based on the guidance described in Nuclear Energy Institute (NEI) 08-01, "Industry Guideline for the ITAAC Closure Process under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Kelli Roberts at 706-848-6991.

Respectfully submitted,

A handwritten signature in black ink, appearing to read "Michael J. Yox", written over a horizontal line.

Michael J. Yox
Regulatory Affairs Director Vogtle 3 & 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3
Completion of ITAAC 2.3.04.05 [Index Number 332]

MJY/RLB/sfr

To:

Southern Nuclear Operating Company/ Georgia Power Company

Mr. Peter P. Sena III

Mr. D. L. McKinney

Mr. M. D. Meier

Mr. G. Chick

Mr. S. Stimac

Mr. P. Martino

Mr. M. J. Yox

Mr. A. S. Parton

Ms. K. A. Roberts

Mr. C. T. Defnall

Mr. C. E. Morrow

Mr. J. M. Fisher

Mr. R. L. Beilke

Mr. S. Leighty

Ms. A. C. Chamberlain

Mr. J. C. Haswell

Document Services RTYPE: VND.LI.L06

File AR.01.02.06

cc:

Nuclear Regulatory Commission

Ms. M. Bailey

Mr. M. King

Mr. G. Bowman

Ms. A. Veil

Mr. C. P. Patel

Mr. G. J. Khouri

Mr. C. J. Even

Mr. B. J. Kemker

Ms. N. C. Coover

Mr. C. Welch

Mr. J. Gaslevic

Mr. O. Lopez-Santiago

Mr. G. Armstrong

Mr. M. Webb

Mr. T. Fredette

Mr. C. Santos

Mr. B. Davis

Mr. J. Vasquez

Mr. J. Eargle

Mr. E. Davidson

Mr. T. Fanelli

Ms. K. McCurry

Mr. J. Parent

Mr. B. Griman

Oglethorpe Power Corporation

Mr. R. B. Brinkman
Mr. E. Rasmussen

Municipal Electric Authority of Georgia

Mr. J. E. Fuller
Mr. S. M. Jackson

Dalton Utilities

Mr. T. Bundros

Westinghouse Electric Company, LLC

Dr. L. Oriani
Mr. D. C. Durham
Mr. M. M. Corletti
Mr. Z. S. Harper
Mr. J. L. Coward

Other

Mr. S. W. Kline, *Bechtel Power Corporation*
Ms. L. Matis, *Tetra Tech NUS, Inc.*
Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*
Mr. S. Roetger, *Georgia Public Service Commission*
Mr. R. L. Trokey, *Georgia Public Service Commission*
Mr. K. C. Greene, *Troutman Sanders*
Mr. S. Blanton, *Balch Bingham*

U.S. Nuclear Regulatory Commission
ND-21-0551 Enclosure
Page 1 of 4

**Southern Nuclear Operating Company
ND-21-0551
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3
Completion of ITAAC 2.3.04.05 [Index Number 332]**

ITAAC Statement

Design Commitment

5. Displays of the parameters identified in Table 2.3.4-1 can be retrieved in the MCR.

Inspections, Tests, Analyses

Inspection will be performed for retrievability of the parameters in the MCR.

Acceptance Criteria

The displays identified in Table 2.3.4-1 can be retrieved in the MCR.

ITAAC Determination Basis

An inspection was performed to verify the retrievability of the Vogtle Electric Generating Plant (VEGP) Unit 3 Fire Protection System (FPS) plant parameters in the Main Control Room (MCR). The inspection for retrievability confirmed that the displays of the parameters identified in Combined License (COL) Appendix C Table 2.3.4-1 (Attachment A) can be retrieved in the MCR.

The inspection was performed in accordance with the Unit 3 FPS component test work order (Reference 1) for FPS pump indication verifications, and visually confirmed that when each of the displays of parameters identified in Attachment A was summoned at a MCR workstation, the summoned plant parameter appeared on a display monitor at that MCR workstation. The results of the FPS component test work order are summarized in Reference 2.

The Unit 3 component test results are documented in References 1 and 2 and confirm that the VEGP Unit 3 plant parameter displays listed in Attachment A can be retrieved in the MCR. References 1 and 2 are available for NRC inspection as part of Unit 3 ITAAC 2.3.04.05 Completion Package (Reference 3).

ITAAC Finding Review

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all ITAAC findings pertaining to the subject ITAAC and associated corrective actions. This review found there are no relevant ITAAC findings associated with the ITAAC. The ITAAC completion review is documented in the ITAAC Completion Package for ITAAC 2.3.04.05 (Reference 3) and is available for NRC review.

ITAAC Completion Statement

Based on the above information, SNC hereby notifies the NRC that ITAAC 2.3.04.05 was performed for VEGP Unit 3 and that the prescribed acceptance criteria are met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

References (available for NRC inspection)

1. Work Order SNC921200, FPS Displays Retrievability in MCR Verification Test - ITAAC:SV3-2.3.04.05, Revision 0
2. ITAAC Technical Report SV3-FPS-ITR-800332, Unit 3 FPS Displays Retrievability in MCR Verification Test: ITAAC 2.3.04.05, Revision 0
3. 2.3.04.05-U3-CP-Rev 0, ITAAC Completion Package

Attachment A

*Excerpt from COL Appendix C Table 2.3.4-1

*Table 2.3.4-1		
*Equipment Name	*Tag No.	*Display
Motor-driven Fire Pump	FPS-MP-01A	Yes (Run Status)
Diesel-driven Fire Pump	FPS-MP-01B	Yes (Run Status)
Jockey Pump	FPS-MP-02	Yes (Run Status)