



PM-102508
Revision: 0

Public Meeting Presentation

Draft Regulatory Guide DG-1361

May 13, 2021

Copyright 2021 by NuScale Power, LLC.



Presenter

Patrick Conley
Engineering Programs

Comments on DG-1361

- Align RG with the scope and intent of 10 CFR 50.49
- Endorse EPRI's Equipment Qualification Reference Manual (Revision 1, September, 2010)
- Allow use of conservatively established and acceptable activation energies values and clarify the need for traceable reports
- Eliminate discussion related to inverse temperature effects
- Clarify the joint logo and RG apply to these two scenarios:
 - RG 1.89 to endorse the use of IEEE 323-1974 as acceptable to meeting the joint logo, and
 - RG 1.89 to endorse the joint logo as meeting the requirements for IEEE 323-1974

Acronyms

DG	Draft Guide
EPRI	Electric Power Research Institute
IEEE	Institute of Electrical and Electronics Engineers
RG	Regulatory Guide

Portland Office

6650 SW Redwood Lane,
Suite 210
Portland, OR 97224
971.371.1592

Corvallis Office

1100 NE Circle Blvd., Suite 200
Corvallis, OR 97330
541.360.0500

Rockville Office

11333 Woodglen Ave., Suite 205
Rockville, MD 20852
301.770.0472

Richland Office

1933 Jadwin Ave., Suite 130
Richland, WA 99354
541.360.0500

Charlotte Office

2815 Coliseum Centre Drive,
Suite 230
Charlotte, NC 28217
980.349.4804



<http://www.nuscalepower.com>

Twitter: @NuScale_Power

