

14.2 UNACCEPTABLE SAFETY RESULTS FOR ABNORMAL OPERATIONAL TRANSIENTS

1. The release of radioactive material to the environs to such an extent that the limits of 10 CFR 20 are exceeded.
2. Any fuel failure calculated as a result of the transient.
3. Nuclear system stress in excess of that allowed for transients by applicable industry codes.