



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 5, 2022

Ms. Cheryl A. Gayheart
Regulatory Affairs Director
Southern Nuclear Operating Company
3535 Colonnade Parkway
Birmingham, AL 35243

SUBJECT: JOSEPH M. FARLEY NUCLEAR PLANT, UNITS 1 AND 2, AND VOGTLE
ELECTRIC GENERATING PLANT, UNITS 1 AND 2 - ISSUANCE OF
AMENDMENTS REGARDING REVISION TO TECHNICAL SPECIFICATIONS
TO ADOPT TSTF-577, "REVISED FREQUENCIES FOR STEAM GENERATOR
TUBE INSPECTIONS" (EPID L-2021-LLA-0163)

Dear Ms. Gayheart:

The U.S. Nuclear Regulatory Commission (the Commission) has issued the enclosed Amendment No. 238 to Renewed Facility Operating License No. NPF-2 and Amendment No. 235 to Renewed Facility Operating License No. NPF-8 for the Joseph M. Farley Nuclear Plant (Farley), Units 1 and 2, respectively; and Amendment No. 211 to Renewed Facility Operating License NPF-68 and Amendment No. 194 to Renewed Facility Operating License NPF-81 for the Vogtle Electric Generating Plant (Vogtle), Units 1 and 2, respectively. The amendments consist of changes to the License and Technical Specifications (TSs) in response to your application dated September 17, 2021, as supplemented October 21, 2021.

The amendments would revise the TSs to adopt Technical Specifications Task Force (TSTF) Traveler TSTF-577, Revision 1, "Revised Frequencies for Steam Generator Tube Inspections."

Copies of the related Safety Evaluations are also enclosed. A Notice of Issuance will be included in the Commission's monthly *Federal Register* notice.

If you have questions, you can contact me at 301-415-3100 or John.Lamb@nrc.gov.

Sincerely,

/RA/

John G. Lamb, Senior Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-348, 50-364, 50-424,
and 50-425

Enclosures:

1. Amendment No. 238 to NPF-2
2. Amendment No. 235 to NPF-8
3. Amendment No. 211 to NPF-68
4. Amendment No. 194 to NPF-81
5. Safety Evaluation for Farley
6. Safety Evaluation for Vogtle

cc w/encls: Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

ALABAMA POWER COMPANY

DOCKET NO. 50-348

JOSEPH M. FARLEY NUCLEAR PLANT, UNIT 1

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 238
Renewed License No. NPF-2

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern Nuclear Operating Company, Inc. (Southern Nuclear), dated September 17, 2021, as supplemented on October 21, 2021, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-2 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 238, are hereby incorporated in the renewed license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Michael T. Markley, Chief
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Renewed Operating License
and Technical Specifications

Date of Issuance: January 5, 2022



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

ALABAMA POWER COMPANY

DOCKET NO. 50-364

JOSEPH M. FARLEY NUCLEAR PLANT, UNIT 2

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 235
Renewed License No. NPF-8

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern Nuclear Operating Company, Inc. (Southern Nuclear), dated September 17, 2021, as supplemented on October 21, 2021, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-8 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 235, are hereby incorporated in the renewed license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Michael T. Markley, Chief
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Renewed Operating License
and Technical Specifications

Date of Issuance: January 5, 2022

ATTACHMENT
TO LICENSE AMENDMENT NO. 238
JOSEPH M. FARLEY NUCLEAR PLANT, UNIT 1
RENEWED FACILITY OPERATING LICENSE NO. NPF-2
DOCKET NO. 50-348

AND
TO LICENSE AMENDMENT NO. 235
JOSEPH M. FARLEY NUCLEAR PLANT, UNIT 2
RENEWED FACILITY OPERATING LICENSE NO. NPF-8
DOCKET NO. 50-364

Replace the following pages of the Licenses and the Appendix A Technical Specifications (TSs) with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove Pages

License

License No. NPF-2, page 4
License No. NPF-8, page 3

TSs

5.5-5
5.5-7
5.5-8
5.6-6

Insert Pages

License

License No. NPF-2, page 4
License No. NPF-8, page 3

TSs

5.5-5
5.5-7
5.5-8
5.6-6
5.6-7

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 238, are hereby incorporated in the renewed license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications.

(3) Additional Conditions

The matters specified in the following conditions shall be completed to the satisfaction of the Commission within the stated time periods following the Issuance of the renewed license or within the operational restrictions indicated. The removal of these conditions shall be made by an amendment to the renewed license supported by a favorable evaluation by the Commission.

- a. Southern Nuclear shall not operate the reactor in Operational Modes 1 and 2 with less than three reactor coolant pumps in operation.
- b. Deleted per Amendment 13
- c. Deleted per Amendment 2
- d. Deleted per Amendment 2
- e. Deleted per Amendment 152
Deleted per Amendment 2
- f. Deleted per Amendment 158
- g. Southern Nuclear shall maintain a secondary water chemistry monitoring program to inhibit steam generator tube degradation. This program shall include:
 - 1) Identification of a sampling schedule for the critical parameters and control points for these parameters;
 - 2) Identification of the procedures used to quantify parameters that are critical to control points;
 - 3) Identification of process sampling points;
 - 4) A procedure for the recording and management of data;
 - 5) Procedures defining corrective actions for off control point chemistry conditions; and

- (2) Alabama Power Company, pursuant to Section 103 of the Act and 10 CFR Part 50, "Licensing of Production and Utilization Facilities," to possess but not operate the facility at the designated location in Houston County, Alabama in accordance with the procedures and limitations set forth in this renewed license.
- (3) Southern Nuclear, pursuant to the Act and 10 CFR Part 70, to receive, possess and use at any time special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Safety Analysis Report, as supplemented and amended;
- (4) Southern Nuclear, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (5) Southern Nuclear, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use in amounts as required any byproducts, source or special nuclear material without restriction to chemical or physical form for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (6) Southern Nuclear, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.

C. This renewed license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporate below:

(1) Maximum Power Level

Southern Nuclear is authorized to operate the facility at reactor core power levels not in excess of 2821 megawatts thermal.

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 235, are hereby incorporated in the renewed license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications.

- (3) Delete per Amendment 144
- (4) Delete Per Amendment 149
- (5) Delete per Amend 144

5.5 Programs and Manuals

5.5.7 Reactor Coolant Pump Flywheel Inspection Program (continued)

- b. A surface examination (magnetic particle and/or liquid penetrant) of exposed surfaces of the disassembled flywheel.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Reactor Coolant Pump Flywheel Inspection Program.

5.5.8 Not Used

5.5.9 Steam Generator (SG) Program

An SG Program shall be established and implemented to ensure that SG tube integrity is maintained. In addition, the SG Program shall include the following:

- a. Provisions for condition monitoring assessments. Condition monitoring

(continued)

5.5 Programs and Manuals

5.5.9 Steam Generator SG Program (continued)

- c. Provisions for SG tube plugging criteria. Tubes found by inservice inspection to contain flaws with a depth equal to or exceeding 40% of the nominal tube wall thickness shall be plugged.
- d. Provisions for SG tube inspections. Periodic SG tube inspections shall be performed. The number and portions of the tubes inspected and methods of inspection shall be performed with the objective of detecting flaws of any type (e.g., volumetric flaws, axial and circumferential cracks) that may be present along the length of the tube, from the tube-to-tubesheet weld at the tube inlet to the tube-to-tubesheet weld at the tube outlet, and that may satisfy the applicable tube plugging criteria. The tube-to-tubesheet weld is not part of the tube. In addition to meeting the requirements of d.1, d.2, and d.3 below, the inspection scope, inspection methods, and inspection intervals shall be such as to ensure that SG tube integrity is maintained until the next SG inspection. A degradation assessment shall be performed to determine the type and location of flaws to which the tubes may be susceptible and, based on this assessment, to determine which inspection methods need to be employed and at what locations.
 - 1. Inspect 100% of the tubes in each SG during the first refueling outage following SG installation.
 - 2. After the first refueling outage following SG installation, inspect 100% of the tubes in each SG at least every 96 effective full power months, which defines the inspection period.
 - 3. If crack indications are found in any SG tube, then the next inspection for each affected and potentially affected SG for the degradation mechanism that caused the crack indication shall be at the next refueling outage. If definitive information, such as from examination of a pulled tube, diagnostic non-destructive testing, or engineering evaluation indicates that a crack-like indication is not associated with a crack(s), then the indication need not be treated as a crack.
- e. Provisions for monitoring operational primary to secondary LEAKAGE.

(continued)

5.5 Programs and Manuals

5.5.10 Secondary Water Chemistry Program

This program provides controls for monitoring secondary water chemistry to inhibit SG tube degradation. The program shall include:

- a. Identification of a sampling schedule for the critical variables and control points for these variables;
- b. Identification of the procedures used to measure the values of the critical variables;
- c. Identification of process sampling points, which shall include monitoring the condenser hotwells for evidence of condenser in leakage;
- d. Procedures for the recording and management of data;

(continued)

5.6 Reporting Requirements

5.6.7 EDG Failure Report

If an individual emergency diesel generator (EDG) experiences four or more valid failures in the last 25 demands, these failures shall be reported within 30 days. Reports on EDG failures shall include a description of the failures, underlying causes, and corrective actions taken per the Emergency Diesel Generator Reliability Monitoring Program.

5.6.8 PAM Report

When a report is required by Condition B or F of LCO 3.3.3, "Post Accident Monitoring (PAM) Instrumentation," a report shall be submitted within the following 14 days. The report shall outline the preplanned alternate method of monitoring, the cause of the inoperability, and the plans and schedule for restoring the instrumentation channels of the Function to OPERABLE status.

5.6.9 Deleted

5.6.10 Steam Generator (SG) Tube Inspection Report

A report shall be submitted within 180 days after the initial entry into MODE 4 following completion of an inspection performed in accordance with the Specification 5.5.9, "Steam Generator (SG) Program." The report shall include:

- a. The scope of inspections performed on each SG;
- b. The nondestructive examination techniques utilized for tubes with increased degradation susceptibility;
- c. For each degradation mechanism found:
 1. The nondestructive examination techniques utilized;
 2. The location, orientation (if linear), measured size (if available), and voltage response for each indication. For tube wear at support structures less than 20 percent through-wall, only the total number of indications needs to be reported;
 3. A description of the condition monitoring assessment and results, including the margin to the tube integrity performance criteria and comparison with the margin predicted to exist at the inspection by the previous forward-looking tube integrity assessment; and
 4. The number of tubes plugged during the inspection outage.

(continued)

5.6 Reporting Requirements

5.6.10 Steam Generator (SG) Tube Inspection Report (continued)

- d. An analysis summary of the tube integrity conditions predicted to exist at the next scheduled inspection (the forward-looking tube integrity assessment) relative to the applicable performance criteria, including the analysis methodology, inputs, and results;
- e. The number and percentage of tubes plugged to date, and the effective plugging percentage in each SG; and
- f. The results of any SG secondary side inspections.

5.6.11 Alternate AC (AAC) Source Out of Service Report

The NRC shall be notified if the AAC source is out of service for greater than 10 days.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

GEORGIA POWER COMPANY

OGLETHORPE POWER CORPORATION

MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA

CITY OF DALTON, GEORGIA

DOCKET NO. 50-424

VOGTLE ELECTRIC GENERATING PLANT, UNIT 1

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 211
Renewed License No. NPF-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Vogtle Electric Generating Plant, Unit 1 (the facility) Renewed Facility Operating License No. NPF-68 filed by the Southern Nuclear Operating Company, Inc. (the licensee), acting for itself, Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia (the owners), dated September 17, 2021, as supplemented on October 21, 2021, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-68 is hereby amended to read as follows:

Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 211, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Michael T. Markley, Chief
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Changes to License No. NPF-68
and the Technical Specifications

Date of Issuance: January 5, 2022



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

GEORGIA POWER COMPANY

OGLETHORPE POWER CORPORATION

MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA

CITY OF DALTON, GEORGIA

DOCKET NO. 50-425

VOGTLE ELECTRIC GENERATING PLANT, UNIT 2

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 194
Renewed License No. NPF-81

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Vogtle Electric Generating Plant, Unit 2 (the facility) Renewed Facility Operating License No. NPF-81 filed by the Southern Nuclear Operating Company, Inc. (the licensee), acting for itself, Georgia Power Company Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia (the owners), dated September 17, 2021, as supplemented on October 21, 2021, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-81 is hereby amended to read as follows:

Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 194, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Michael T. Markley, Chief
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Changes to License No. NPF-81
and the Technical Specifications

Date of Issuance: January 5, 2022

ATTACHMENT
TO LICENSE AMENDMENT NO. 211
VOGTLE ELECTRIC GENERATING PLANT, UNIT 1
RENEWED FACILITY OPERATING LICENSE NO. NPF-68
DOCKET NO. 50-424

AND
TO LICENSE AMENDMENT NO. 194
VOGTLE ELECTRIC GENERATING PLANT, UNIT 2
RENEWED FACILITY OPERATING LICENSE NO. NPF-81
DOCKET NO. 50-425

Replace the following pages of the Licenses and the Appendix A Technical Specifications (TSs) with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove Pages

License

License No. NPF-68, page 4
License No. NPF-81, page 3

TSs

5.5-7
5.5-8
5.5-9
5.5-10
5.5-11
5.6-6

Insert Pages

License

License No. NPF-68, page 4
License No. NPF-81, page 3

TSs

5.5-7
5.5-8
5.5-9
5.5-10

5.6-6
5.6-7

(1) Maximum Power Level

Southern Nuclear is authorized to operate the facility at reactor core power levels not in excess of 3625.6 megawatts thermal (100 percent power) in accordance with the conditions specified herein.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 211, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

(3) Southern Nuclear Operating Company shall be capable of establishing containment hydrogen monitoring within 90 minutes of initiating safety injection following a loss of coolant accident.

(4) Deleted

(5) Deleted

(6) Deleted

(7) Deleted

(8) Deleted

(9) Deleted

(10) Mitigation Strategy License Condition

The licensee shall develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

(a) Fire fighting response strategy with the following elements:

1. Pre-defined coordinated fire response strategy and guidance
2. Assessment of mutual aid fire fighting assets
3. Designated staging areas for equipment and materials
4. Command and control
5. Training and response personnel

(b) Operations to mitigate fuel damage considering the following:

1. Protection and use of personnel assets
2. Communications
3. Minimizing fire spread
4. Procedures for Implementing integrated fire response strategy
5. Identification of readily-available pre-staged equipment
6. Training on integrated fire response strategy

- (2) Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia, pursuant to the Act and 10 CFR Part 50, to possess but not operate the facility at the designated location in Burke County, Georgia, in accordance with the procedures and limitations set forth in this license;
- (3) Southern Nuclear, pursuant to the Act and 10 CFR Part 70, to receive, possess, and use at any time special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Safety Analysis Report, as supplemented and amended;
- (4) Southern Nuclear, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to receive, possess, and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (5) Southern Nuclear, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components;
- (6) Southern Nuclear, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility authorized herein.

C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter 1 and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect, and is subject to the additional conditions specified or incorporated below.

(1) Maximum Power Level

Southern Nuclear is authorized to operate the facility at reactor core power levels not in excess of 3625.6 megawatts thermal (100 percent power) in accordance with the conditions specified herein.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 194 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

The Surveillance requirements (SRs) contained in the Appendix A Technical Specifications and listed below are not required to be performed immediately upon implementation of Amendment No. 74. The SRs listed below shall be

5.5 Programs and Manuals (continued)

5.5.9 Steam Generator (SG) Program

An SG Program shall be established and implemented to ensure that SG tube integrity is maintained. In addition, the SG Program shall include the following:

- a. Provisions for condition monitoring assessments. Condition monitoring assessment means an evaluation of the “as found” condition of the tubing with respect to the performance criteria for structural integrity and accident induced leakage. The “as found” condition refers to the condition of the tubing during an SG inspection outage, as determined from the inservice inspection results or by other means, prior to the plugging of tubes. Condition monitoring assessments shall be conducted during each outage during which the SG tubes are inspected or plugged to confirm that the performance criteria are being met.
- b. Performance criteria for SG tube integrity. SG tube integrity shall be maintained by meeting the performance criteria for tube structural integrity, accident induced leakage, and operational LEAKAGE.
 1. Structural integrity performance criterion: All in-service SG tubes shall retain structural integrity over the full range of normal operating conditions (including startup, operation in the power range, hot standby, and cool down), all anticipated transients included in the design specification, and design basis accidents. This includes retaining a safety factor of 3.0 against burst under normal steady state full power operation primary-to-secondary pressure differential and a safety factor of 1.4 against burst applied to the design basis accident primary-to-secondary pressure differentials. Apart from the above requirements, additional loading conditions associated with the design basis accidents, or combination of accidents in accordance with the design and licensing basis, shall also be evaluated to determine if the associated loads contribute significantly to burst or collapse. In the assessment of tube integrity, those loads that do significantly affect burst or collapse shall be determined and assessed in combination with the loads due to pressure with a safety factor of 1.2 on the combined primary loads and 1.0 on axial secondary loads.

(continued)

5.5 Programs and Manuals

5.5.9 Steam Generator (SG) Program (continued)

2. Accident induced leakage performance criterion: The primary to secondary accident induced leakage rate for any design basis accident, other than a SG tube rupture, shall not exceed the leakage rate assumed in the accident analysis in terms of total leakage rate for all SGs and leakage rate for an individual SG. Leakage is not to exceed 1 gpm per SG.
3. The operational LEAKAGE performance criterion is specified in LCO 3.4.13, "RCS Operational LEAKAGE."

- c. Provisions for SG tube plugging criteria. Tubes found by inservice inspection to contain flaws with a depth equal to or exceeding 40% of the nominal tube wall thickness shall be plugged.

The following alternate tube plugging criteria shall be applied as an alternative to the 40% depth based criteria:

Tubes with service-induced flaws located greater than 15.2 inches below the top of the tubesheet do not require plugging. Tubes with service-induced flaws located in the portion of the tube from the top of the tubesheet to 15.2 inches below the top of the tubesheet shall be plugged upon detection.

- d. Provisions for SG tube inspections. Periodic SG tube inspections shall be performed. The number and portions of the tubes inspected and methods of inspection shall be performed with the objective of detecting flaws of any type (e.g., volumetric flaws, axial and circumferential cracks) that may be present along the length of the tube, from the tube-to-tubesheet weld at the tube inlet to the tube-to-tubesheet weld at the tube outlet except for any portions of the tube that are exempt from inspection by alternate repair criteria, and that may satisfy the applicable tube plugging criteria. The tube-to-tubesheet weld is not part of the tube. In addition to meeting the requirements of d.1, d.2, and d.3 below, the inspection scope, inspection methods, and inspection intervals shall be such as to ensure that SG tube integrity is maintained until the next SG inspection. A degradation assessment shall be performed to determine the type and location of flaws to which the tubes may be susceptible and, based on this assessment, to determine which inspection methods need to be employed and at what locations.

(continued)

5.5 Programs and Manuals

5.5.9 Steam Generator (SG) Program (continued)

1. Inspect 100% of the tubes in each SG during the first refueling outage following SG installation.
 2. After the first refueling outage following SG installation, inspect 100% of the tubes in each SG at least every 54 effective full power months, which defines the inspection period. If none of the SG tubes have ever experienced cracking other than in regions that are exempt from inspection by alternate repair criteria and the SG inspection was performed with enhanced probes, the inspection period may be extended to 72 effective full power months. Enhanced probes have a capability to detect flaws of any type equivalent to or better than array probe technology. The enhanced probes shall be used from the tube-to-tubesheet weld at the tube inlet to the tube-to-tubesheet weld at the tube outlet except any portions of the tube that are exempt from inspection by alternate repair criteria. If there are regions where enhanced probes cannot be used, the tube inspection techniques shall be capable of detecting all forms of existing and potential degradation in that region.
 3. If crack indications are found in portions of the SG tube excluding any region that is exempt from inspection by alternate repair criteria, then the next inspection for each affected and potentially affected SG for the degradation mechanism that caused the crack indication shall be at the next refueling outage, but may be deferred to the following refueling outage if the 100% inspection of all SGs was performed with enhanced probes as described in paragraph d.2. If definitive information, such as from examination of a pulled tube, diagnostic nondestructive testing, or engineering evaluation indicates that a crack-like indication is not associated with a crack(s), then the indication need not be treated as a crack.
- e. Provisions for monitoring operational primary to secondary LEAKAGE.

(continued)

5.5 Programs and Manuals

5.5.10 Secondary Water Chemistry Program

This program provides controls for monitoring secondary water chemistry to inhibit SG tube degradation. The program shall include:

(continued)

5.6 Reporting Requirements

5.6.9 Deleted.

5.6.10 Steam Generator Tube Inspection Report

A report shall be submitted within 180 days after the initial entry into MODE 4 following completion of an inspection performed in accordance with the Specification 5.5.9, "Steam Generator (SG) Program." The report shall include:

- a. The scope of inspections performed on each SG;
- b. The nondestructive examination techniques utilized for tubes with increased degradation susceptibility;
- c. For each degradation mechanism found:
 - 1. The nondestructive examination techniques utilized;
 - 2. The location, orientation (if linear), measured size (if available), and voltage response for each indication. For tube wear at support structures less than 20 percent through-wall, only the total number of indications needs to be reported;
 - 3. A description of the condition monitoring assessment and results, including the margin to the tube integrity performance criteria and comparison with the margin predicted to exist at the inspection by the previous forward-looking tube integrity assessment; and
 - 4. The number of tubes plugged during the inspection outage.
- d. An analysis summary of the tube integrity conditions predicted to exist at the next scheduled inspection (the forward-looking tube integrity assessment) relative to the applicable performance criteria, including the analysis methodology, inputs, and results;
- e. The number and percentage of tubes plugged to date, and the effective plugging percentage in each SG;
- f. The results of any SG secondary side inspections;
- g. The primary to secondary LEAKAGE rate observed in each SG (if it is not practical to assign the LEAKAGE to an individual SG, the entire primary to secondary LEAKAGE should be conservatively assumed to be from one SG) during the cycle preceding the inspection which is the subject of the report;

(continued)

5.6 Reporting Requirements

5.6.10 Steam Generator Tube Inspection Report (continued)

- h. The calculated accident induced leakage rate from the portion of the tubes below 15.2 inches from the top of the tubesheet for the most limiting accident in the most limiting SG. In addition, if the calculated accident induced leakage rate from the most limiting accident is less than 2.48 times the maximum operational primary to secondary leakage rate, the report should describe how it was determined; and
 - i. The results of monitoring for tube axial displacement (slippage). If slippage is discovered, the implications of the discovery and corrective action shall be provided.
-
-



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO

JOSEPH M. FARLEY NUCLEAR PLANT, UNITS 1 AND 2

AMENDMENT NO. 238 TO RENEWED FACILITY OPERATING LICENSE NPF-2

AMENDMENT NO. 235 TO RENEWED FACILITY OPERATING LICENSE NPF-8

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

DOCKET NOS. 50-348, AND 50-364

1.0 INTRODUCTION

By application dated September 17, 2021 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML21263A223), as supplemented by letter dated October 21, 2021 (ADAMS Accession No. ML21298A244, Southern Nuclear Operating Company (SNC, the licensee) submitted a license amendment request (LAR) for the Joseph M. Farley Nuclear Plant (Farley), Units 1 and 2.

In its application, SNC requested that the U.S. Nuclear Regulatory Commission (NRC, the Commission) process the proposed amendment under the Consolidated Line Item Improvement Process (CLIIP). The proposed changes would revise the Farley "Steam Generator (SG) Program" and "Steam Generator (SG) Tube Inspection Report" technical specifications (TSs) based on Technical Specifications Task Force (TSTF) Traveler TSTF-577, Revision 1, "Revised Frequencies for Steam Generator Tube Inspections" (TSTF-577) (ADAMS Accession No. ML21060B434), and the associated NRC staff safety evaluation (SE) of TSTF-577 (ADAMS Accession No. ML21098A188).

The tubes within an SG function as an integral part of the reactor coolant pressure boundary and, in addition, isolate fission products in the primary coolant from the secondary coolant and the environment. SG tube integrity means that the tubes are capable of performing this safety function in accordance with the plant design and licensing basis.

The current Farley, Units 1 and 2, SG TS requirements are based on TSTF-510, "Revision to Steam Generator Program Inspection Frequencies and Tube Sample Selection" (ADAMS Accession No. ML110610350). The Farley, Units 1 and 2, SG tubes are made from Thermally Treated Alloy 690 (Alloy 690TT).

The supplemental letter dated October 21, 2021, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination as published in the *Federal Register* on November 2, 2021 (86 FR 60485).

1.1 Proposed TS Changes to Adopt TSTF-577

In accordance with NRC staff-approved TSTF-577, the licensee proposed changes that would revise Farley TS 5.5.9, "Steam Generator (SG) Program," and TS 5.6.10, "Steam Generator (SG) Tube Inspection Report." Specifically, the licensee proposed the following changes to adopt TSTF-577:

TS 5.5.9, "Steam Generator (SG) Program":

- The introductory paragraph to TS 5.5.9 would be revised by replacing "steam generator" with "SG" in a couple instances.
- TS 5.5.9.d.2 would be revised by deleting the requirement to base inspection frequency on the more restrictive metric between either the effective full power months (EFPM) or refueling outage and to use just the EFPM metric.
- TS 5.5.9.d.2 would be revised by deleting the requirement to inspect 100 percent of the tubes during each period in paragraphs d.2.a, d.2.b, d.2.c, and d.2.d (144, 120, 96, and 72 EFPM, respectively) and by adding the requirement to inspect 100 percent of the tubes in each SG at least every 96 EFPM.
- TS 5.5.9.d.2 would be revised by deleting the allowance to extend the inspection period by up to 3 EFPM and by deleting the discussion of prorating inspections.
- TS 5.5.9.d.3 would be revised by replacing "shall not exceed 24 effective full power months or one refueling outage (whichever results in more frequent inspections)" with "shall be at the next refueling outage."

TS 5.6.10, "Steam Generator (SG) Tube Inspection Report":

- Existing reporting requirement b. would be renumbered as c. and be revised by editorial and punctuation changes.
- New reporting requirement b. would be added to require the nondestructive examination (NDE) techniques utilized for tubes with increased degradation susceptibility to be reported.
- Existing reporting requirement c. would be renumbered as c.1. and be revised by editorial and punctuation changes.
- Existing reporting requirement d. would be renumbered as c.2. and be revised to note that the location, orientation (if linear), measured size (if available), and voltage response do not need to be reported for tube wear indications at support structures that are less than 20 percent through-wall. However, the total number of tube wear indications at support structures that are less than 20 percent through-wall would be reported.
- New reporting requirement d. would be added to require an analysis summary of the tube integrity conditions predicted to exist at the next scheduled inspection relative to the applicable performance criteria, including the analysis, methodology, inputs, and results.

- Existing reporting requirement e. would be renumbered as c.4 and be revised by editorial and punctuation changes.
- Existing reporting requirement f. would be renumbered as e. and be revised by editorial and punctuation changes.
- New reporting requirement f. would be added to require the results of any SG secondary side inspections to be reported.
- Existing reporting requirement g. would be renumbered as c.3. and be revised to add the requirements to report a description of the condition monitoring assessment, the margin to the tube integrity performance criteria, and a comparison with the margin predicted to exist at the inspection by the previous forward-looking tube integrity assessment. In addition, the requirement to report the results of tube pulls and in-situ testing would be deleted.

1.2 Additional Proposed TS Changes

In addition to the changes proposed consistent with the traveler discussed in Section 1.1, SNC proposed the following variations.

1.2.1 Editorial Variations

The licensee identified one variation for Farley, Units 1 and 2. SNC noted that Farley TS 5.6.10 references the title of TS 5.5.9, "Steam Generator (SG) Program," without placing the title within quotation marks. For consistency with TSTF-577 and the Standard Technical Specifications, a change is proposed to place the title within quotation marks.

2.0 REGULATORY EVALUATION

The regulations in Title 10 of the *Code of Federal Regulations* (10 CFR) paragraph 50.36(c)(5), "Administrative controls," state that "[a]dministrative controls are the provisions relating to organization and management, procedures, recordkeeping, review and audit, and reporting necessary to assure operation of the facility in a safe manner. Each licensee shall submit any reports to the Commission pursuant to approved technical specifications as specified in [10 CFR] 50.4." Technical Specification Section 5.0, "Administrative Controls," requires that a SG Program be established and implemented to ensure that SG tube integrity is maintained. Programs established by the licensee, including the SG Program, are listed in the administrative controls section of the TS to operate the facility in a safe manner.

The NRC staff's guidance for the review of TSs is in NUREG-0800, "Standard Review Plan [SRP] for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR [Light-Water Reactor] Edition," Chapter 16.0, "Technical Specifications," Revision 3, dated March 2010 (ADAMS Accession No. ML100351425).

As described therein, as part of the regulatory standardization effort, the NRC staff has prepared Standard Technical Specifications (STSs) for each of the LWR nuclear designs. Accordingly, the NRC staff's review includes consideration of whether the proposed changes are consistent with NUREG-1431,¹ as modified by NRC-approved travelers.

TSTF-577 revised the STSs related to SG tube inspections and SG tube inspection reporting requirements. The NRC approved TSTF-577, under the CLIIP on April 14, 2021 (ADAMS Package Accession No. ML21099A086).

3.0 TECHNICAL EVALUATION

3.1 Proposed TS Changes to Adopt TSTF-577

The NRC staff compared the licensee's proposed TS changes in Section 1.1 of this SE against the changes approved in TSTF-577. In accordance with SRP Chapter 16.0, the NRC staff determined that the STS changes approved in TSTF-577 are applicable because Farley is a Pressurized-Water Reactor (PWR) design plant, and the NRC staff approved the TSTF-577 changes for PWR designs. The NRC staff finds that the licensee's proposed changes to the Farley, Units 1 and 2, TSs in Section 1.1 of this SE are consistent with those found acceptable in the NRC staff review of TSTF-577.

In the SE of TSTF-577, the NRC staff concluded that the TSTF-577 changes to STS 5.5.9, "Steam Generator (SG) Program," and STS 5.6.7, "Steam Generator Tube Inspection Report," were acceptable because, as discussed in Section 3.0 of that SE, they continued to ensure SG tube integrity and, therefore, protected the public health and safety. In particular, the structural integrity performance criterion and accident-induced leakage performance criterion (explained in STS 5.5.9.b, Items 1 and 2, respectively) will continue to be met with the proposed revised SG inspection intervals (maximum allowable time between SG inspections) and inspection periods (maximum allowable time between 100 percent of SG tubes inspections). Additionally, the proposed changes to the reporting requirements will provide more detailed and consistent information to the NRC. Therefore, the NRC staff found that the proposed changes to the SG program and inspection reporting requirements were acceptable because they continued to meet the requirements of 10 CFR 50.36(c)(5) by providing administrative controls necessary to assure operation of the facility in a safe manner. For these same reasons, the NRC staff concludes that the corresponding proposed changes to the Farley, Units 1 and 2, TSs in Section 1.1 of this SE, which incorporate the changes made in TSTF-577, continue to meet the requirements of 10 CFR 50.36(c)(5).

3.2 Additional Proposed TS Changes

3.2.1 Editorial

SNC identified one variation. The licensee noted that Farley, Units 1 and 2, TS 5.6.10 references the title of TS 5.5.9, "Steam Generator (SG) Program," without placing the title within quotation marks. The NRC staff finds that placing the title within quotation marks is acceptable because it is administrative in nature, consistent with the STS, and does not substantively alter TS requirements. The NRC staff also noted that Farley uses different numbering than the STS

¹ U.S. Nuclear Regulatory Commission, "Standard Technical Specifications, Westinghouse Plants," NUREG-1431, Volume 1, "Specifications," and Volume 2, "Bases," Revision 5, September 2021 (ADAMS Accession Nos. ML21259A155 and ML21259A159, respectively).

on which TSTF-577 was based. Specifically, Farley uses TS 5.6.10 for “Steam Generator (SG) Tube Inspection Report” and the TSTF-577 uses TS 5.6.7. The NRC staff finds that the different TS numbering is acceptable because it does not substantively alter TS requirements.

3.3 TS Change Consistency

The NRC staff reviewed the proposed TS changes for technical clarity and consistency with the existing requirements for customary terminology and formatting. The NRC staff finds that the proposed changes are consistent with Chapter 16.0 of the SRP and are, therefore, acceptable.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Alabama State officials were notified on November 18, 2021, of the proposed issuance of the amendments. On November 19, 2021, the State official indicated the State of Alabama has no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendment relates, in part, to changes in recordkeeping, reporting, or administrative procedures or requirements. The amendment also relates, in part, to changing requirements with respect to the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration (86 FR 60485 dated November 2, 2021), and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9) and 10 CFR 51.22(c)(10). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) there is reasonable assurance that such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Charley Peabody, Jr., NRR/DSS

Date: January 5, 2022



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO

VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2

AMENDMENT NO. 211 TO RENEWED FACILITY OPERATING LICENSE NPF-68

AMENDMENT NO. 194 TO RENEWED FACILITY OPERATING LICENSE NPF-81

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

DOCKET NOS. 50-424, AND 50-425

1.0 INTRODUCTION

By application dated September 17, 2021 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML21263A223), as supplemented by letter dated October 21, 2021 (ADAMS Accession No. ML21298A244, Southern Nuclear Operating Company (SNC, the licensee) submitted a license amendment request (LAR) for the Vogtle Electric Generating Plant (Vogtle), Units 1 and 2.

In its application, SNC requested that the U.S. Nuclear Regulatory Commission (NRC, the Commission) process the proposed amendment under the Consolidated Line Item Improvement Process (CLIIP). The proposed changes would revise the Vogtle "Steam Generator (SG) Program" and the "Steam Generator Tube Inspection Report" technical specifications (TSs) based on Technical Specifications Task Force (TSTF) Traveler TSTF-577, Revision 1, "Revised Frequencies for Steam Generator Tube Inspections" (TSTF-577) (ADAMS Accession No. ML21060B434), and the associated NRC staff safety evaluation (SE) of TSTF-577 (ADAMS Accession No. ML21098A188).

The tubes within an SG function as an integral part of the reactor coolant pressure boundary and, in addition, isolate fission products in the primary coolant from the secondary coolant and the environment. SG tube integrity means that the tubes are capable of performing this safety function in accordance with the plant design and licensing basis.

The current Vogtle, Units 1 and 2, SG TS requirements are based on TSTF-510, "Revision to Steam Generator Program Inspection Frequencies and Tube Sample Selection" (ADAMS Accession No. ML110610350). The Vogtle, Units 1 and 2, SG tubes are made from Thermally Treated Alloy 600 (Alloy 600TT).

The supplemental letter dated October 21, 2021, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination as published in the *Federal Register* on November 2, 2021 (86 FR 60485).

1.1 Proposed TS Changes to Adopt TSTF-577

In accordance with NRC staff-approved TSTF-577, the licensee proposed changes that would revise Vogtle, Units 1 and 2, TS 5.5.9, "Steam Generator (SG) Program," and TS 5.6.10, "Steam Generator Tube Inspection Report." Specifically, the licensee proposed the following changes to adopt TSTF-577:

TS 5.5.9, "Steam Generator (SG) Program":

- TS 5.5.9 introductory paragraph and paragraph b.1 would be revised by replacing "steam generator" with "SG" in a few instances.
- TS 5.5.9.d would be revised by adding a phrase regarding portions of the tube that are exempt from inspection by alternate repair criteria that replaces information that specifies distance from the top of the tubesheet.
- TS 5.5.9.d.2 would be revised by changing the requirement to inspect 100 percent of the tubes at periods of 120, 96, and 72 effective full power months (EFPM) to 54 EFPM. A 72 EFPM inspection period would be permitted if none of the SG tubes have ever experienced cracking (not including regions exempt from inspection by alternate repair criteria) and the SG inspection was performed with enhanced probes. A description of the enhanced probe inspection would be added.
- TS 5.5.9.d.2 would be revised by deleting the requirement to base inspection frequency on the more restrictive metric between either the EFPM or refueling outage and to use just the EFPM metric.
- TS 5.5.9.d.2 would be revised by deleting the allowance to extend the inspection period by 3 months and by deleting the discussion of prorating inspections.
- TS 5.5.9.d.3 would be revised by replacing "shall not exceed 24 effective full power months or one refueling outage (whichever results in more frequent inspections)" with "shall be at the next refueling outage."
- TS 5.5.9.d.3 would be revised by adding a phrase regarding portions of the tube that are exempt from inspection by alternate repair criteria that replaces the phrase, "not excluded above." An additional phrase would be added that permits deferring SG inspections after cracking indications are found if the 100 percent inspection of all SGs was performed with enhanced probes.

TS 5.6.10, "Steam Generator Tube Inspection Report":

- Existing reporting requirement b. would be renumbered as c. and be revised by editorial and punctuation changes.

- New reporting requirement b. would be added to require the nondestructive examination (NDE) techniques utilized for tubes with increased degradation susceptibility to be reported.
- Existing reporting requirement c. would be renumbered as c.1. and be revised by editorial and punctuation changes.
- Existing reporting requirement d. would be renumbered as c.2. and be revised to note that the location, orientation (if linear), measured size (if available), and voltage response do not need to be reported for tube wear indications at support structures that are less than 20 percent through-wall. However, the total number of tube wear indications at support structures that are less than 20 percent through-wall would be reported.
- New reporting requirement d. would be added to require an analysis summary of the tube integrity conditions predicted to exist at the next scheduled inspection relative to the applicable performance criteria, including the analysis, methodology, inputs, and results.
- Existing reporting requirement e. would be renumbered as c.4. and be revised by editorial and punctuation changes.
- Existing reporting requirement f. would be renumbered as e. and be revised by editorial and punctuation changes.
- New reporting requirement f. would be added to require the results of any SG secondary side inspections to be reported.
- Existing reporting requirement g. would be renumbered as c.3. and be revised to add the requirements to report a description of the condition monitoring assessment, the margin to the tube integrity performance criteria, and a comparison with the margin predicted to exist at the inspection by the previous forward-looking tube integrity assessment. In addition, the requirement to report the results of tube pulls and in-situ testing would be deleted.
- Existing reporting requirements h., i., and j. would be renumbered to g., h., and i., respectively and be revised by editorial and punctuation changes.

1.2 Additional Proposed TS Changes

In addition to the changes proposed consistent with the traveler discussed in Section 1.1, the licensee proposed the following variations.

1.2.1 Editorial Variations

The licensee noted that Vogtle, Units 1 and 2, TS 5.6.10 references the title of TS 5.5.9, "Steam Generator (SG) Program," without placing the title within quotation marks. For consistency with TSTF-577 and the Standard Technical Specifications, a change is proposed to place the title within quotation marks.

1.2.2 Other Variations

SNC noted that the Vogtle, Units 1 and 2, SG Program TSs currently contain a provision for an alternate tube plugging criteria. The description of the alternate tube plugging criteria in the proposed change is equivalent to the description in the current TSs.

2.0 REGULATORY EVALUATION

The regulations in Title 10 of the *Code of Federal Regulations* (10 CFR) paragraph 50.36(c)(5), "Administrative controls," state that "[a]dministrative controls are the provisions relating to organization and management, procedures, recordkeeping, review and audit, and reporting necessary to assure operation of the facility in a safe manner. Each licensee shall submit any reports to the Commission pursuant to approved technical specifications as specified in [10 CFR] 50.4." Technical Specification Section 5.0, "Administrative Controls," requires that a SG Program be established and implemented to ensure that SG tube integrity is maintained. Programs established by the licensee, including the SG Program, are listed in the administrative controls section of the TS to operate the facility in a safe manner.

The NRC staff's guidance for the review of TSs is in NUREG-0800, "Standard Review Plan [SRP] for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR [Light-Water Reactor] Edition," Chapter 16.0, "Technical Specifications," Revision 3, dated March 2010 (ADAMS Accession No. ML100351425). As described therein, as part of the regulatory standardization effort, the NRC staff has prepared Standard Technical Specifications (STSs) for each of the LWR nuclear designs. Accordingly, the NRC staff's review includes consideration of whether the proposed changes are consistent with NUREG-1431,² as modified by NRC-approved travelers.

TSTF-577 revised the STSs related to SG tube inspections and SG tube inspection reporting requirements. The NRC approved TSTF-577, under the CLIIP on April 14, 2021 (ADAMS Package Accession No. ML21099A086).

3.0 TECHNICAL EVALUATION

3.1 Proposed TS Changes to Adopt TSTF-577

The NRC staff compared the licensee's proposed TS changes in Section 1.1 of this SE against the changes approved in TSTF-577. In accordance with SRP Chapter 16.0, the NRC staff determined that the STS changes approved in TSTF-577 are applicable, because Vogtle, Units 1 and 2, are a pressurized-water reactor (PWR) design plant and the NRC staff approved the TSTF-577 changes for PWR designs. The NRC staff finds that SNC's proposed changes to the Vogtle, Units 1 and 2, TSs in Section 1.1 of this SE are consistent with those found acceptable in the NRC staff review of TSTF-577.

In the SE of TSTF-577, the NRC staff concluded that the TSTF-577 changes to STS 5.5.9, "Steam Generator (SG) Program," and STS 5.6.7, "Steam Generator Tube Inspection Report," were acceptable because, as discussed in Section 3.0 of that SE, they continued to ensure SG

² U.S. Nuclear Regulatory Commission, "Standard Technical Specifications, Westinghouse Plants," NUREG-1431, Volume 1, "Specifications," and Volume 2, "Bases," Revision 5, September 2021 (ADAMS Accession Nos. ML21259A155 and ML21259A159, respectively).

tube integrity and, therefore, protected the public health and safety. In particular, the structural integrity performance criterion and accident-induced leakage performance criterion (explained in STS 5.5.9.b, items 1 and 2, respectively) will continue to be met with the proposed revised SG inspection intervals (maximum allowable time between SG inspections) and inspection periods (maximum allowable time between 100 percent of SG tubes inspections). Additionally, the proposed changes to the reporting requirements will provide more detailed and consistent information to the NRC. Therefore, the NRC staff found that the proposed changes to the SG program and inspection reporting requirements were acceptable because they continued to meet the requirements of 10 CFR 50.36(c)(5) by providing administrative controls necessary to assure operation of the facility in a safe manner. For these same reasons, the NRC staff concludes that the corresponding proposed changes to the Vogtle, Units 1 and 2, TSs in Section 1.1 of this SE, which incorporate the changes made in TSTF-577, continue to meet the requirements of 10 CFR 50.36(c)(5).

3.2 Additional Proposed TS Changes

3.2.1 Editorial

The licensee noted that Vogtle, Units 1 and 2, TS 5.6.10 references the title of TS 5.5.9, "Steam Generator (SG) Program," without placing the title within quotation marks. The NRC staff finds that placing the title within quotation marks is acceptable because it is administrative in nature, consistent with the STS, and does not substantively alter TS requirements. The NRC staff also noted that Vogtle uses different numbering than the STS on which TSTF-577 was based. Specifically, Vogtle uses TS 5.6.10 for "Steam Generator Tube Inspection Report," and the TSTF-577 uses TS 5.6.7. The NRC staff finds that the different TS numbering is acceptable because it does not substantively alter TS requirements.

3.2.2 Other Variations

The licensee noted that the Vogtle, Units 1 and 2, SG Program TSs currently contain a provision for an alternate tube plugging criteria. The description of the alternate tube plugging criteria in the proposed change is equivalent to the description in the current TSs.

The current Vogtle, Units 1 and 2, TS that addresses alternate tube plugging criteria (i.e., TS 5.5.9.c.) reflects NRC-approved changes contained in Amendment No. 167 and Amendment No. 149 for the Vogtle, Units 1 and 2, respectively (ADAMS Accession No. ML12216A056). As part of the request to adopt TSTF-577, the licensee did not propose any changes to these criteria. Therefore, the NRC staff considers the variation as information for awareness purposes, rather than a variation from the traveler or a change to the plant-specific TSs.

3.3 TS Change Consistency

The NRC staff reviewed the proposed TS changes for technical clarity and consistency with the existing requirements for customary terminology and formatting. The NRC staff finds that the proposed changes are consistent with Chapter 16.0 of the SRP and are therefore acceptable.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Georgia State officials were notified on November 18, 2021, of the proposed issuance of the amendments. On November 18, 2021, the State official indicated the State of Georgia has no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendment relates, in part, to changes in recordkeeping, reporting, or administrative procedures or requirements. The amendment also relates, in part, to changing requirements with respect to the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration (86 FR 60485 dated November 2, 2021), and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9) and 10 CFR 51.22(c)(10). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) there is reasonable assurance that such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Charley Peabody, Jr., NRR/DSS

Date: January 5, 2022

SUBJECT: JOSEPH M. FARLEY NUCLEAR PLANT, UNITS 1 AND 2; AND VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS REGARDING REVISION TO TECHNICAL SPECIFICATIONS TO ADOPT TSTF-577, "REVISED FREQUENCIES FOR STEAM GENERATOR TUBE INSPECTIONS" (EPID L-2021-LLA-0163) DATED JANUARY 5, 2021

DISTRIBUTION:

Public

LPL2-1 R/F

RidsNrrLAKGoldstein Resource

RidsNrrDorlLpl2-1 Resource

RidsNrrDnrlNcsg Resource

RidsACRS_MailCTR Resource

RidsNrrPMVogtle Resource (hard copy)

RidsRgn2MailCenter Resource

RidsNrrDssStsb Resource

ADAMS Accession No.: ML21316A055

OFFICE	NRR/DORL/LPL2-1/PM	NRR/DORL/LPL2-1/LA	NRR/DSS/STSB/BC	OGC – NLO
NAME	JLamb	KGoldstein	NJordan (MHamm for)	CKreuzberger
DATE	11/10/2021	12/13/2021	11/9/2021	12/8/2021
OFFICE	NRR/DORL/LPL2-1/BC	NRR/DORL/LPL2-1/PM		
NAME	MMarkley	JLamb		
DATE	1/5/2022	1/5/2022		

OFFICIAL RECORD COPY