



Sequoyah Nuclear Plant, Post Office Box 2000, Soddy Daisy, Tennessee 37384

September 22, 2021

10 CFR 50.73

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Sequoyah Nuclear Plant, Units 1 and 2
Renewed Facility Operating License Nos. DPR-77 and DPR-79
NRC Docket Nos. 50-327 and 50-328

Subject: **Licensee Event Reports 50-327/2021-002-00, Ice Bed Inoperable Due to Exceeding Surveillance Requirement Frequency and 50-328/2021-001-00, Ice Bed Inoperable Due to Exceeding Surveillance Requirement Frequency**

The enclosed licensee event reports provide details concerning inoperable Unit 1 and Unit 2 ice beds due to exceeding the Frequency specified by Surveillance Requirement 3.6.12.1. These events are being reported, in accordance with 10 CFR 50.73(a)(2)(v), as events or conditions that could have prevented the fulfillment of a safety function of structures or systems that are needed to: (C) control the release of radioactive material and (D) mitigate the consequences of an accident.

There are no regulatory commitments contained in this letter. Should you have any questions concerning this submittal, please contact Mr. Jeffrey Sowa, Site Licensing Manager, at (423) 843-8129.

Respectfully,

Marshall, Thomas B.  Digitally signed by Marshall, Thomas B.
Date: 2021.09.22 12:53:11 -04'00'

Thomas Marshall
Site Vice President
Sequoyah Nuclear Plant

Enclosures: Licensee Event Report 50-327/2021-002-00
Licensee Event Report 50-328/2021-001-00
cc: NRC Regional Administrator – Region II
NRC Senior Resident Inspector – Sequoyah Nuclear Plant