



December 27, 2021

L-2021-220  
10 CFR 50.36  
10 CFR 50.55a

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Re: St. Lucie Unit 2  
Docket No. 50-389  
In-Service Inspection Program  
ISI Fourth Interval - Third Period SL2-26  
Owner's Activity Report (OAR-1)

Enclosed is the Owner's Activity Report, Form OAR-1, for the St. Lucie Unit 2 SL2-26 refueling outage. The OAR-1 report is prepared, certified, and submitted upon completion of each refueling outage. The SL2-26 refueling outage ended on September 30, 2021.

Should you have any questions regarding this submittal, please contact me at (772) 467-7435.

Sincerely,

A handwritten signature in black ink, appearing to read 'Wyatt Godes', is written over a light blue horizontal line.

Wyatt Godes  
Licensing Manager  
St. Lucie Plant

WG/rcs

Attachment: SL2-26 Refueling Outage OAR-1 Owner's Activity Report

cc: NRC Region II Administrator  
NRC Site Resident Inspector

## FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: ISI-PSL-SL2-26-2021

Plant: St. Lucie Nuclear Power Plant Unit 2  
6501 South Ocean Drive  
Jensen Beach, Florida 34957

Commercial Service Date: August 8, 1983 Refueling Outage No.: SL2-26Current Inspection Interval: ISI-Fourth Interval, IWE-Third IntervalCurrent Inspection Period: ISI – First Outage Third Period, IWE – First Outage Second Period

Edition and Addenda of Section XI applicable to the inspection plan: ISI Fourth Interval and IWE Third Interval - 2007  
Edition through 2008 Addenda


Date and Revision of inspection plan: ISI – Fourth Interval August 13, 2020 Rev. 3  
IWE – July 15, 2018, Rev. 0

Edition and Addenda of Section XI applicable to repairs and replacements, if different than the inspection plan: Same

Code Cases Used: N-513-4, N-532-5, N-652-2, N-722-1, N-729-6

## CERTIFICATE OF CONFORMANCE


I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion of SL2-26 conform to the requirements of Section XI.

Signed  Lauren Kestenbaum, Programs Engineering Manager Date 12/21/21  
Owner or Owner's Designee, Title

## CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by Hartford Steam Boiler Inspection and Insurance Company of Connecticut have inspected the items described in this Owner's Activity Report, and state that, to the best of my knowledge and belief, the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair/replacement activities and evaluation described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

 Commissions NB 14084 B, I, N, R  
Inspector's Signature (National Board Number and Endorsements)  
Date 12/21/2021

FORM OAR-1 OWNER'S ACTIVITY REPORT

---

TABLE 1 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE		
Examination Category and Item Number	Item Description	Evaluation Description
None	None	None

## FORM OAR-1 OWNER'S ACTIVITY REPORT

**TABLE 2**  
**ABSTRACT REPAIR/REPLACEMENT ACTIVITIES REQUIRED FOR CONTINUED SERVICE**

<b>Code Class</b>	<b>Item Description</b>	<b>Description of Work</b>	<b>Date Completed</b>	<b>Repair / Replacement Plan Number</b>
3	CW-72	REPLACE DRAIN COUPLING BY WELDING PER EC 296390	12/13/21	SL2-21034
2	SI-556	REMOVE FLAW PURSUANT TO EC 296694	12/21/21	SL2-21043
2	V15328	REPLACE VALVE DISC	12/16/21	SL2-21045