

**St. Lucie SLRA: Breakout Questions**

SLRA Section: B.2.3.17 Outdoor and Large Atmospheric Metallic Storage Tanks  
TRP: 29

Note: Breakout Questions are provided to the applicant and will be incorporated into the publicly-available audit report.

Technical Reviewer	Tony Gardner	01/03/2022
Technical Branch Chief	Steve Bloom	
Breakout Session	Date/Time	To be filled in by PM

Applicant Staff	NRC staff
To be filled out by PM during breakout	

Question Number	SLRA Section	SLRA Page	Background / Issue (As applicable/needed)	Discussion Question / Request	Outcome of Discussion
1	B.2.3.17	Page B-154 and Page B-155	The preventive maintenance activities include diver inspections performed at a refueling outage interval and a drained tank inspection performed at an interval of every 6 <sup>th</sup> refueling outage. The drained tank inspection will continue to inspect for galvanic corrosion cells between the SS piping, and manway flanges and the aluminum tank. Additionally, the relief request for the ISI inspection (ML19115A281) states that the hands-on inspection is done at an interval of every 3 <sup>rd</sup> refueling outage.	This exception is not consistent with the relief request for the ISI inspection (ML19115A281). Possible rewording is needed to clarify that the inspection frequency for B.2.3.17 is based on the approved ISI inspection relief request.	