

**PSL SLRA: Breakout Questions**

SLRA Section 2.4 – Structural Scoping and Screening

Note: Breakout Questions are provided to the applicant and will be incorporated into the publicly-available audit report.

<b>Technical Reviewer</b>	Bryce Lehman	12/17/21
<b>Technical Branch Chief</b>	Joseph Colaccino	12/20/21
<b>Breakout Session</b>	<i>Date/Time</i>	<i>To be filled in by PM</i>

<b>Applicant Staff</b>	<b>NRC staff</b>
<i>To be filled out by PM during breakout</i>	

<b>Question Number</b>	<b>SLRA Section</b>	<b>SLRA Page</b>	<b>Background / Issue (As applicable/needed)</b>	<b>Discussion Question / Request</b>	<b>Outcome of Discussion</b>
1	2.4.9	2.4-20	SLRA Section 2.4.9 notes that water enters the intake structure and passes through stationary and traveling screens.  SLRA Table 2.4-9 shows the structural scoping results for the intake structure but does not list intake screens as a component receiving an AMR. It also does not list 'filter' as an intended function for any of the components in the table.	Explain if the intake screens are within in the scope of SLR. If they are not within scope provide a technical justification. If they are in-scope, identify the AMR that addresses these components.	