

Oconee SLRA Breakout Questions

SLRA Section 3.1.2.2.6.1 and AMR Item 3.1.1-019, and Letdown Coolers

#	SLRA Section	SLRA Page	Question / Issue	Why are we asking?
1	3.1.2.2.6	3-27	The further evaluation is for PWR SS bottom mounted instrument guide tubes exposed to reactor coolant. The SLRA states that this component is not applicable to Oconee. Staff could not locate another AMR item(s) that were used in lieu of 3.1.1-019, or an explanation why bottom mounted guide tubes are not applicable to Oconee because it is a B&W design.	Other B&W designed Units have not dispositioned these items as NA.
2	Oconee Letdown Coolers		It is the staff's understanding that the Letdown Coolers for Oconee, will be included in a supplement as a result of recent breakout discussions. Staff's understanding is that the Coolers will be periodically replaced. Please provide a brief overview on how the periodicity of the replacements will be established?	The question is related to determining the practicality of the proposed replacement interval for the Coolers in the event it is determined that they will be periodically replaced vs managing the aging affects.