



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

February 17, 2022

Mr. Steven M. Snider  
Site Vice President  
Duke Energy Carolinas, LLC  
7800 Rochester Highway  
Seneca, SC 29672-0752

SUBJECT: OCONEE NUCLEAR STATION – CLOSEOUT OF BULLETIN 2012-01,  
“DESIGN VULNERABILITY IN ELECTRIC POWER SYSTEM”

Dear Mr. Snider:

The purpose of this letter is to inform you that the U.S. Nuclear Regulatory Commission (NRC) staff has verified that Duke Energy Carolinas, LLC (the licensee) has provided the necessary information requested in NRC’s Bulletin (BL) 2012-01, “Design Vulnerability in Electric Power System,” dated July 27, 2012 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML12074A115), for Oconee Nuclear Station, Units 1, 2, and 3 (Oconee). The NRC staff has completed its review of this information and has closed out BL 2012-01 for Oconee.

The NRC issued BL 2012-01 on July 27, 2012, to all holders of operating licenses and combined licenses for nuclear power reactors, except those who have permanently ceased operation and have certified that fuel has been removed from the reactor vessel. The Bulletin requested information about each facility’s electric power system designs that would allow the NRC staff to verify the system’s capability to address open phase conditions. Specifically, the NRC requested licensees to:

- describe how the protection scheme for engineered safety features buses (Class 1E for current operating plants or non-Class 1E for passive plants) is designed to detect and automatically respond to a single-phase open circuit condition or high impedance ground fault condition on offsite power circuits or another power source; and
- describe the operating configuration of engineered safety features buses (Class 1E for current operating plants or non-Class 1E for passive plants) at power (i.e., normal operating condition).

By letter dated October 23, 2012 (ADAMS Accession No. ML12300A426), the licensee provided its response to BL 2012-01 for Oconee. By letter dated February 3, 2014 (ADAMS Accession No. ML14035A453), the licensee provided supplemental information for this facility in response to an NRC staff request for additional information issued on December 20, 2013 (ADAMS Accession No. ML13351A314).

By letters dated October 9, 2013, and March 16, 2015 (ADAMS Accession Nos. ML13333A147 and ML15075A454, respectively), the Nuclear Energy Institute (NEI) submitted a voluntary industry initiative to address open phase conditions at nuclear power plants. The NEI letter

dated March 16, 2015, stated, in part: “The initiative is a formal commitment by the companies that operate nuclear power plants to follow a specific policy or plan of action. The initiative calls for a proactive plan and schedule for addressing potential design vulnerabilities to the open phase condition.”

To evaluate the adequacy of the open phase isolation systems designs, the NRC staff issued Temporary Instruction (TI) 2515/194, “Inspection of the Licensees’ Implementation of Industry Initiative Associated with the Open Phase Condition Design Vulnerabilities in Electric Power Systems (NRC Bulletin 2012-01),” dated October 31, 2017 (ADAMS Accession No. ML17137A416), which provided temporary inspection instructions for the purpose of verifying that licensees appropriately implemented the NEI voluntary industry initiative dated March 16, 2015. The NRC staff piloted the use of TI 2515/194 by inspecting four nuclear power plants with four distinct open phase isolation system designs. A summary of the NRC staff’s preliminary observations and issues needing additional clarity were discussed with industry representatives in two public meetings conducted on September 19, 2018, and October 17, 2018. The meeting summaries can be found in ADAMS under Package Accession Nos. ML18268A342 and ML18309A226, respectively.

By letter dated June 6, 2019 (ADAMS Accession No. ML19163A176), NEI submitted Revision 3 of the voluntary industry initiative to include an option for plants to perform a risk evaluation under certain boundary conditions to support manual response to an open phase condition. NEI also submitted NEI 19-02, “Guidance for Assessing Open Phase Condition Implementation Using Risk Insights” on June 20, 2019 (ADAMS Accession No. ML19172A086). On August 18, 2020, the NRC staff issued Revision 2 of TI 2515/194 (ADAMS Accession No. ML20230A328), which provided temporary inspection instructions for the purpose of verifying that licensees appropriately implemented Revision 3 of the NEI voluntary industry initiative. The revision accounted for changes reflected in Revision 3 of the NEI voluntary initiative.

In October 2019, the NRC staff performed inspections at Oconee using TI 2515/194 dated October 31, 2017. In September 2021, the NRC staff performed inspections at Oconee using TI 2515/194 Revision 2. These inspections at Oconee were performed to verify the licensee’s implementation of the voluntary industry initiative at this facility. To address the open phase condition design vulnerability issue at this facility, the licensee implemented open phase isolation system plant modifications, which provide detection and alarm in the control room, and necessary plant procedures that allow operators to diagnose and take manual action to mitigate an open phase condition. The NRC inspection reports listed below document the results of the TI 2515/194 inspections.

- Oconee Nuclear Station – Temporary Instruction 2515/194 Inspection Report 05000269/2019013 and 05000270/2019013 and 05000287/2019013, dated November 14, 2019 (ADAMS Accession No. ML19318G943)
- Oconee Nuclear Station – Integrated Inspection Report 05000269/2021003 and 05000270/2021003 and 05000287/2021003, dated October 28, 2021 (ADAMS Accession No. ML21301A125)

The NRC staff reviewed the information submitted by the licensee and the results of the TI 2515/194 inspections for Oconee. No findings nor exceptions were identified. Based on the above, the NRC staff concludes that the licensee provided the necessary information requested in BL 2012-01 and has completed the implementation of its open phase isolation system. Therefore, the NRC staff closes BL 2012-01 for Oconee.

S. Snider

- 3 -

If you have any questions, please contact me at 301-415-1009 or [Shawn.Williams@nrc.gov](mailto:Shawn.Williams@nrc.gov) .

Sincerely,

Shawn A. Williams, Project Manager  
Plant Licensing Branch II-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, 50-287

cc: Listserv

SUBJECT: OCONEE NUCLEAR STATION – CLOSEOUT OF BULLETIN 2012-01,  
 “DESIGN VULNERABILITY IN ELECTRIC POWER SYSTEM”  
 DATED FEBRUARY 17, 2022

**DISTRIBUTION:**

PUBLIC  
 PM File Copy  
 RidsNrrLAKGoldstein Resource  
 RidsNrrLAKEntz Resource  
 RidsRgn2MailCenter Resource  
 RidsACRS\_MailCTR Resource  
 RidsNrrDexEEEEB Resource  
 RidsNrrDorlLpl2-1 Resource  
 RidsNrrDraApob Resource  
 RidsNrrDroloeb Resource  
 RidsNrrPMOconee Resource

WMorton, NRR  
 KNguyen, NRR  
 VGoel, NRR  
 RRodriguez, NRR  
 SWilliams, NRR  
 AZoulis, NRR  
 LRegner, NRR  
 MMarkley, NRR

**ADAMS Accession No.: ML22045A024**

OFFICE	NRR/DORL/LPL2-1/PM	NRR/DORL/LPL2-1/LA	NRR/DEX/EEEEB/BC
NAME	SWilliams	KGoldstein	WMorton
DATE	02/16/2022	02/16/2022	02/09/2022
OFFICE	NRR/DRA/APOB/BC	NRR/DRO/IOEB/BC	NRR/DORL/LPL2-1/BC
NAME	AZoulis	LRegner	MMarkley
DATE	02/15/2022	02/16/2022	02/16/2022
OFFICE	NRR/DORL/LPL2-1/PM		
NAME	SWilliams		
DATE	02/17/2022		

**OFFICIAL RECORD COPY**