



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

February 25, 2022

LICENSEE: Energy Harbor Nuclear Corp.

FACILITY: Beaver Valley Power Station, Units 1 and 2

SUBJECT: SUMMARY OF THE FEBRUARY 15, 2021, MEETING WITH ENERGY HARBOR NUCLEAR CORP. REGARDING THE LICENSE AMENDMENT REQUEST RELATED TO REVISING TECHNICAL SPECIFICATION 5.6.3 "CORE OPERATING LIMITS REPORT" (COLR) (EPID L-2021-LLA-0075)

On February 15, 2021, a public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) staff and the representatives of Beaver Valley Power Station (the licensee) using Microsoft Teams meeting. The purpose of the meeting was to clarify questions the NRC had regarding the licensee's response (Agencywide Documents Access and Management System (ADAMS) at Accession No. ML21300A359) to the NRC's request for additional information (RAI) (ADAMS Accession No. ML21259A164). The meeting notice dated January 25, 2022, is available ADAMS Accession No. ML22013B283. A list of attendees is provided as an enclosure to this letter.

In the meeting, Energy Harbor clarified that the venturi-based feedwater flow measurements provided in the licensee's RAI response were not adjusted to match the Leading Edge Flow Meter (LEFM) during the one-year analysis window. The licensee explained that the venturi-based feedwater flow measurements from the plant computer are to be used by operators to calculate calorimetric power when the LEFM is out of service.

The NRC questions were resolved during the meeting and the licensee was not asked to submit any documentation.

Members of the public were not in attendance. Public meeting feedback forms were not received.

Please direct any inquiries to me at 301-415-8004 or Sujata.Goetz@nrc.gov

/RA/

Sujata Goetz, Project Manager
Plant Licensing Branch I
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-314

Enclosure:
List of Attendees

cc: Listserv

LIST OF ATTENDEES

CLARIFICATION MEETING WITH ENERGY HARBOR NUCLEAR CORP. REGARDING
TECHNICAL SPECIFICATION 5.6.3 "CORE OPERATING LIMITS REPORT (COLR) AT
BEAVER VALLEY POWER STATION UNITS 1 AND 2
FEBRUARY 15, 2021

<u>Name</u>	<u>Affiliation</u>
Sue Goetz	U.S. Nuclear Regulatory Commission (NRC)
Josh Kaizer	NRC
Ravi Grover	NRC
Jeremy Dean	NRC
Richard Stattel	NRC
James Danna	NRC
Phil Lashley	Energy Harbor
Sean Padgett	Energy Harbor
Curt Ciocca	Energy Harbor
Gary Cacciani	Energy Harbor
Dave McCreary	Energy Harbor
Chris Lord	Energy Harbor
David Hwang	Energy Harbor
Larry Winkler	Pennsylvania Department of Environmental Protection

SUBJECT: SUMMARY OF THE FEBRUARY 15, 2021, MEETING WITH ENERGY HARBOR NUCLEAR CORP. REGARDING THE LICENSE AMENDMENT REQUEST RELATED TO REVISING TECHNICAL SPECIFICATION 5.6.3 "CORE OPERATING LIMITS REPORT" (COLR) (EPID L-2021-LLA-0075) DATED FEBRUARY 25, 2022

DISTRIBUTION:

PUBLIC

PM File Copy

RidsNrrPMBeaver Valley Resource

RidsNrrDorlLpl1 Resource

RidsNrrLAKZelenock Resource

RidsACRS_MailCTR Resource

RidsRgn1MailCenter Resource

RidsNrrDorl Resource

SGoetz, NRR

JKaiser, NRR

ADAMS Accession No.: ML22053A298

OFFICE	NRR/DORL/LPL1/PM	NRR/DORL/LPL1/LA	NRR/DORL/LPL1/BC	NRR/DORL/LPL1/PM
NAME	SGoetz	KZeletznock	JDanna	SGoetz
DATE	02/22/2022	02/24/2022	2/25/2022	2/25/2022

OFFICIAL RECORD COPY