



Jamie M. Coleman
Regulatory Affairs
Vogtle 3 & 4

7825 River Road
Waynesboro, GA 307520
706-848-6926 tel

Docket No.: 52-025

APR 13 2022

ND-22-0228
10 CFR 52.99(c)(1)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Southern Nuclear Operating Company
Vogtle Electric Generating Plant Unit 3
ITAAC Closure Notification on Completion of ITAAC 3.2.00.05 [Index Number 752]

Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 3.2.00.05 [Index 752]. This ITAAC confirms that the Remote Shutdown Workstation (RSW) includes a reactor operator workstation(s) from which licensed operators perform remote shutdown operations. The closure process for this ITAAC is based on the guidance described in NEI 08-01, "Industry Guideline for the ITAAC Closure Process under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Kelli Roberts at 706-848-6991.

Respectfully submitted,

A handwritten signature in black ink that reads "Jamie Coleman". The signature is fluid and cursive, with the first name "Jamie" and last name "Coleman" clearly distinguishable.

Jamie M. Coleman
Regulatory Affairs Director Vogtle 3 & 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3
Completion of ITAAC 3.2.00.05 [Index Number 752]

JMC/MSV/sfr

To:

Southern Nuclear Operating Company/ Georgia Power Company

Mr. Peter P. Sena III

Mr. D. L. McKinney

Mr. H. Nieh

Mr. G. Chick

Mr. S. Stimac

Mr. P. Martino

Mr. J.B. Williams

Mr. A. S. Parton

Ms. K. A. Roberts

Ms. J.M. Coleman

Mr. C. T. Defnall

Mr. C. E. Morrow

Mr. K. J. Drudy

Mr. J. M. Fisher

Mr. R. L. Beilke

Mr. S. Leighty

Ms. A. C. Chamberlain

Mr. J. C. Haswell

Document Services RTYPE: VND.LI.L06

File AR.01.02.06

Nuclear Regulatory Commission

Ms. M. Bailey

Mr. M. King

Mr. G. Bowman

Ms. A. Veil

Mr. C. P. Patel

Mr. G. J. Khouri

Mr. C. J. Even

Mr. B. J. Kemker

Ms. N. C. Covert

Mr. C. Welch

Mr. J. Gaslevic

Mr. O. Lopez-Santiago

Mr. G. Armstrong

Mr. M. Webb

Mr. T. Fredette

Mr. C. Santos

Mr. B. Davis

Mr. J. Vasquez

Mr. J. Eargle

Mr. T. Fanelli

Ms. K. McCurry

Mr. J. Parent

Mr. B. Griman

Mr. V. Hall

Oglethorpe Power Corporation

Mr. R. B. Brinkman
Mr. E. Rasmussen

Municipal Electric Authority of Georgia

Mr. J. E. Fuller
Mr. S. M. Jackson

Dalton Utilities

Mr. T. Bundros

Westinghouse Electric Company, LLC

Dr. L. Oriani
Mr. D. C. Durham
Mr. M. M. Corletti
Mr. Z. S. Harper
Ms. S.L. Zwack

Other

Mr. S. W. Kline, *Bechtel Power Corporation*
Ms. L. Matis, *Tetra Tech NUS, Inc.*
Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*
Mr. S. Roetger, *Georgia Public Service Commission*
Mr. R. L. Trokey, *Georgia Public Service Commission*
Mr. K. C. Greene, *Troutman Sanders*
Mr. S. Blanton, *Balch Bingham*

**Southern Nuclear Operating Company
ND-22-0228
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3
Completion of ITAAC 3.2.00.05 [Index Number 752]**

ITAAC Statement

Design Commitment

5. The RSW includes reactor operator workstation(s) from which licensed operators perform remote shutdown operations.

Inspections/Tests/Analyses

An inspection of the RSW will be performed.

Acceptance Criteria

The RSW includes reactor operator workstation(s).

ITAAC Determination Basis

An inspection of the Remote Shutdown Workstation (RSW) was performed to verify that the RSW includes a reactor operator workstation(s) from which licensed operators perform remote shutdown operations.

The inspection utilized approved construction drawings to perform walkdown inspections of the Unit 3 RSW reactor operator workstation(s). The walkdown inspections compared the as-built reactor operator workstation(s) with Reference 1 and 2 construction drawings to confirm that the RSW includes a reactor operator workstation(s).

The Unit 3 walkdown inspection results are documented the Principal Closure Document SV3-OCS-ITR-800752 (Reference 3) supporting the ITAAC 3.2.00.05 Completion Package (Reference 4) and confirmed that the RSW includes a reactor operator workstation(s).

References 1 through 3 are available for NRC inspection as part of ITAAC 3.2.00.05 Completion Package (Reference 4).

ITAAC Finding Review

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all findings pertaining to the subject ITAAC and associated corrective actions. This review found there are no relevant ITAAC findings associated with this ITAAC.

The ITAAC completion review is documented in the ITAAC Completion Package for ITAAC 3.2.00.05 (Reference 4) and is available for NRC review.

ITAAC Completion Statement

Based on the above information, SNC hereby notifies the NRC that ITAAC 3.2.00.05 was performed for VEGP Unit 3 and that the prescribed acceptance criteria were met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

References (available for NRC inspection)

1. SV3-JC01-V1-100, Rev.2, "AP1000 Remote Shutdown Room Layout Top View" (Security Related Information)
2. SV3-JC01-V1-120, Rev.3, "AP1000 Remote Shutdown Workstation Panel Layout"
3. Unit 3 Principal Closure Document SV3-OCS-ITR-800752 Rev 0 "Unit 3 HFE Remote Shutdown Workstation Reactor Operator Workstation(s): ITAAC 3.2.00.05" (NRC Index Number 752)
4. 3.2.00.05-U3-CP-Rev0, ITAAC Completion Package