

April 13, 2022

10 CFR 50.55a

RS-22-054

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555-0001Quad Cities Nuclear Power Station, Units 1 and 2  
Renewed Facility Operating License Nos. DPR-29 and DPR-30  
NRC Docket Nos. 50-254 and 50-265Subject: Withdrawal of Relief Request RV-10 Associated with the Sixth Inservice  
Testing Interval

- References:
1. Letter from P.R. Simpson (Constellation Energy Generation, LLC) to U.S. Nuclear Regulatory Commission, " Submittal of Relief Requests Associated with the Sixth Inservice Testing Interval," dated February 17, 2022 (ML22048B569)
  2. Email from R. Kuntz (U.S. Nuclear Regulatory Commission) to R. Steinman (Constellation Energy Generation, LLC), Subject: Quad Cities Nuclear Power Station, Units 1 and 2 – Acceptance of Alternative RV-10 related to Code Case OMN-26, MOV Testing (EPID: L-2022-LLR-0019), dated March 9, 2022 (ML22068A151)

On February 17, 2022, Constellation Energy Generation, LLC (CEG) submitted a request for approval of seven proposed relief requests associated with the Sixth 10-Year Inservice Testing (IST) Program Interval for Quad Cities Nuclear Power Station (QCNPS). Relief Request RV-10, "Adopt ASME OM Code Case OMN-26, 'Alternative Risk-Informed and Margin Based Rules for Inservice Testing of Motor Operated Valves'," was included in Reference 1. The March 3, 2022, publication of the Federal Register contained the final rule updating the list of approved OM Code Cases. Effective April 4, 2022, Code Case OMN-26, referenced as the basis for relief request RV-10, is an approved OM Code Case. As a result, CEG has decided to withdraw the proposed relief request and is no longer seeking NRC review and approval of RV-10, which had been accepted for review on March 9, 2022 (Reference 2).

This withdrawal applies only to relief request RV-10. CEG requests that the NRC continue to review of the remaining six relief requests included in Reference 1.

April 13, 2022  
U.S. Nuclear Regulatory Commission  
Page 2

There are no regulatory commitments contained within this letter. Should you have any questions concerning this letter, please contact Ms. Rebecca L. Steinman at 630-657-2831.

Respectfully,

A handwritten signature in black ink, appearing to read "Patrick R. Simpson", with a long horizontal flourish extending to the right.

Patrick R. Simpson  
Sr. Manager Licensing  
Constellation Energy Generation, LLC

cc: Regional Administrator – NRC Region III  
NRC Senior Resident Inspector – Quad Cities Nuclear Power Station