

Docket No.: 52-025

**APR 22 2022**

ND-22-0285  
10 CFR 52.99(c)(1)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Unit 3  
ITAAC Closure Notification on Completion of ITAAC 3.2.00.09 [Index Number 758]


Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 3.2.00.09 [Index Number 758]. This ITAAC confirms that the capability for local control and monitoring from selected locations throughout the plant exists. The closure process for this ITAAC is based on the guidance described in Nuclear Energy Institute (NEI) 08-01, "Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Kelli Roberts at 706-848-6991.

Respectfully submitted,



Jamie M. Coleman  
Regulatory Affairs Director Vogtle 3 & 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion of ITAAC 3.2.00.09 [Index Number 758]

JMC/RLB/sfr

**To:**

**Southern Nuclear Operating Company/ Georgia Power Company**

Mr. Peter P. Sena III  
Mr. D. L. McKinney  
Mr. H. Nieh  
Mr. G. Chick  
Mr. S. Stimac  
Mr. P. Martino  
Mr. J. B. Williams  
Mr. A. S. Parton  
Ms. K. A. Roberts  
Ms. J.M. Coleman  
Mr. C. T. Defnall  
Mr. C. E. Morrow  
Mr. K. J. Drudy  
Mr. J. M. Fisher  
Mr. R. L. Beilke  
Mr. S. Leighty  
Ms. A. C. Chamberlain  
Mr. J. C. Haswell  
Document Services RTYPE: VND.LI.L06  
File AR.01.02.06

**cc:**

**Nuclear Regulatory Commission**

Ms. M. Bailey  
Mr. M. King  
Mr. G. Bowman  
Ms. A. Veil  
Mr. C. P. Patel  
Mr. G. J. Khouri  
Mr. C. J. Even  
Mr. B. J. Kemker  
Ms. N. C. Coover  
Mr. C. Welch  
Mr. J. Gaslevic  
Mr. O. Lopez-Santiago  
Mr. G. Armstrong  
Mr. M. Webb  
Mr. T. Fredette  
Mr. C. Santos  
Mr. B. Davis  
Mr. J. Vasquez  
Mr. J. Eargle  
Ms. K. McCurry  
Mr. J. Parent  
Mr. B. Griman  
Mr. V. Hall

**Oglethorpe Power Corporation**

Mr. R. B. Brinkman  
Mr. E. Rasmussen

**Municipal Electric Authority of Georgia**

Mr. J. E. Fuller  
Mr. S. M. Jackson

**Dalton Utilities**

Mr. T. Bundros

**Westinghouse Electric Company, LLC**

Dr. L. Oriani  
Mr. D. C. Durham  
Mr. M. M. Corletti  
Mr. Z. S. Harper  
Ms. S. L. Zwack

**Other**

Mr. S. W. Kline, *Bechtel Power Corporation*  
Ms. L. Matis, *Tetra Tech NUS, Inc.*  
Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*  
Mr. S. Roetger, *Georgia Public Service Commission*  
Mr. R. L. Trokey, *Georgia Public Service Commission*  
Mr. K. C. Greene, *Troutman Sanders*  
Mr. S. Blanton, *Balch Bingham*

U.S. Nuclear Regulatory Commission  
ND-22-0285 Enclosure  
Page 1 of 3

**Southern Nuclear Operating Company  
ND-22-0285  
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion of ITAAC 3.2.00.09 [Index Number 758]**

## **ITAAC Statement**

### **Design Commitment**

9. The capability to access displays and controls is provided (controls as assigned by the MCR operators) for local control and monitoring from selected locations throughout the plant.

### **Inspections/Tests/Analyses**

An inspection of the local control and monitoring capability is provided.

### **Acceptance Criteria**

The capability for local control and monitoring from selected locations throughout the plant exists.

## **ITAAC Determination Basis**

An inspection was performed to demonstrate that the capability to access displays and controls is provided (controls as assigned by the MCR operators) for local control and monitoring from selected locations throughout the plant.

An inspection was performed in accordance with Unit 3 component test work order listed in Reference 1. The component test package work order directed monitoring and controlling plant components at six different local control stations. The local control stations are the Primary Sampling System Room, Radiological Chemistry Lab, Radiological Waste Corridor, Operator Work Area, Annex Building Conference Room, and Turbine and Outside Operator Conference Room. A system was selected at each local control station, indications were verified to be available, and component controls were manipulated and component operation was verified.

The completed Unit 3 component test results are summarized in Reference 1 and confirm that the capability for local control and monitoring from selected locations throughout the plant exists.

Reference 1 is available for NRC inspection as part of the ITAAC 3.2.00.09 Completion Package (Reference 2).

## **ITAAC Finding Review**

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all findings pertaining to the subject ITAAC and associated corrective actions. This review found there were no relevant ITAAC findings associated with this ITAAC. The ITAAC completion review is documented in the ITAAC Completion Package for ITAAC 3.2.00.09 (Reference 2) and is available for NRC review.

## **ITAAC Completion Statement**

Based on the above information, SNC hereby notifies the NRC that ITAAC 3.2.00.09 was performed for VEGP Unit 3 and that the prescribed acceptance criteria was met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

**References (available for NRC inspection)**

1. SV3-HSI-ITR-800758, Unit 3 Capability to Access Plant Displays and Controls ITAAC  
3.2.00.09, Rev 0
2. 3.2.00.09-U3-CP-Rev 0, ITAAC Completion Package