

FAQ 22-02: Diablo Canyon Scram

Plant: Diablo Canyon Power Plant Unit 2
Date of Event: 10/15/2021
Submittal Date: May 23, 2022
Licensee Contact: James Morris **Tel/email:** James.morris@pge.com
NRC Contact: Ayesha Athar **Tel/email:** Ayesha.athar@nrc.gov

Performance Indicator: IE 04, Unplanned Scrams with Complications

Site-Specific FAQ (see Appendix D)? (X) Yes or () No

FAQ to Become Effective (X) when approved.

Question Section

NEI 99-02 Guidance needing interpretation:

Page 24, lines 26-29

Page H-4, lines 26-32

Page H-5, lines 35 to 40

Event or circumstances requiring guidance interpretation:

On October 15, 2021, at 17:49 Pacific Daylight Time, DCPP Unit 2 was operating at 90 percent power. While diagnosing a potential tube leak in FWH 2-5B, the reactor was manually tripped in accordance with plant procedures due to increasing water level in the feedwater heater. The Operations crews responded to this event in accordance with plant operating procedures. There were no inoperable Technical Specification structures, systems, or components that contributed to the event.

Following the reactor trip, all safety-related equipment operated as designed. The auxiliary feedwater system (AFW) started as expected.

This FAQ focuses on the flowchart question pertaining Main Feedwater availability and recovery using approved plant procedures during the scram response.

Based on Figure 2, "IE04 Unplanned Scrams with Complications – Flowchart," on Page 29 of NEI 99-02, "Regulatory Assessment Performance Indicator Guideline," Revision 7, 5 of the 6 criteria for "no complications" are clear and not the subject of this FAQ:

- the control rods fully inserted
- the turbine tripped
- power was not lost to any Emergency Safeguards Features (ESF) bus
- a Safety Injection signal was not received
- the scram response procedure was completed without entering another Emergency Operating Procedure (EOP)

Event Timeline, DCPP Unit 2, October 15, 2021 (All Times PDT):

17:12 Ramp completed at 1050 MW to support isolating and bypassing FWHs 2-5B & 2-

FAQ 22-02: Diablo Canyon Scram

6B

17:20 Isolation activities commenced for FWH 2-5B & 2-6B

17:40 Isolation of condensate inlet to FWH 2-6B completed

17:49:35 Manual reactor trip Initiated due to level in FWH 2-5B being out-of-sight high per annunciator response procedure AR PK10-21

17:49:41 Main steam isolation valves (MSIVs) manually closed per annunciator response procedure AR PK10-21

19:06 Main condenser vacuum broken per annunciator response procedure AR PK10-21

20:36 Secured condensate and booster pump sets per annunciator response procedure AR PK10-21

NRC POSITION:

The resident inspectors and RIV maintain that the October 15th trip of Unit 2 at Diablo Canyon Power Plant should be considered an "Unplanned Scram with Complications" due to the inability of the operations crew to start a Main Feedwater pump and feed the Steam Generators with the Main Feedwater System. This inability to feed the Steam Generators with the Main Feedwater System was not due to a design feature or procedural prohibition. The damage to the Feedwater heater 2-5B required closing of the MSIVs, thus rendering the steam-driven Main Feedwater Pumps unavailable due to loss of motive force (main steam).

The operations staff would not have been able to start and operate main feedwater pumps using EOP FR-H.1, "Response to Loss of Secondary Heat Sink," Step 7, because the MSIVs were closed. The MSIVs were closed as a result of the severe tube leak in FWH 2-5B, which the station had been unable to isolate while the unit was online. Therefore, the unavailability of the Main Feedwater Pumps was a consequence of the failure of the main feedwater system (FWH 2-5B tube failure), not a design feature or a procedural prohibition.

If the conditions to feed with main feedwater pumps are not met, the condensate/condensate booster pumps are used to feed one steam generator, per EOP FR-H.1. This requires reduction of the pressure in one SG to below the condensate booster pump shutoff head (to approximately 480 psig), and is therefore a less desirable method than feeding the steam generators using the main feedwater pumps. The main feedwater pumps are a vital component of the main feedwater system. The discussion of reducing the secondary system below the injection capabilities of the condensate and condensate booster pump does not constitute equivalency of restoring the main feedwater system. The ability to use condensate/booster pumps to feed steam generators under extreme cases where main feedwater and auxiliary feedwater are no longer available is a common Westinghouse design. Despite the common nature of the method, this path is not discussed in the NEI 99-02, Revision 7, guidance as an acceptable means toward considering main feedwater available.

During the October 15th scram, immediate restarting of main feedwater pumps would not have been possible using the approved emergency operating procedure. Nor would main feedwater be able to be restored within 30 minutes, as required by NEI 99-02 guidance for feedwater availability credit. Note that there is no design feature or procedural prohibition that would prevent restarting Main Feedwater after a trip; in fact, EOP FR-H.1, "Response to Loss of Secondary Heat Sink," Step 7 directs operators to place main feedwater pumps

FAQ 22-02: Diablo Canyon Scram

back in service to feed the SGs via the feedwater regulating bypass valves. Thus, the question, "Was Main Feedwater unavailable or not recoverable using approved plant procedures during the scram response?" requires an answer of, "Yes," per the guidance in NEI 99-02, Revision 7, and the October 15th trip should be designated as an "Unplanned Scram with Complications."

SITE POSITION:

Main Feedwater System Description:

The main feedwater system consists of two steam-turbine-driven feed pumps, which take suction from the condensate system and provide feedwater to each of the four SGs via a common discharge header. Unlike some Westinghouse PWRs, the DCPP main feedwater system design does not include a motor-driven pump. During normal plant shutdown conditions, the AFW system provides feed flow when the SGs are being used for secondary heat removal.

In the event of a loss of AFW following a reactor trip, secondary cooling is established using one of two methods:

- (1) Reestablish main feedwater flow via the feedwater regulating bypass valves (per EOP FR-H.1, "Response to Loss of Secondary Heat Sink," Step 7):

Main feedwater pumps are placed back in service to feed the SGs via the feedwater regulating bypass valves if certain plant criteria are met. This requires the main condenser to be available (vacuum established, at least one circulating water pump running, and MSIVs open) and the feedwater isolation signal to be reset. As noted above, the main feedwater pumps are steam-driven.

- (2) Use the condensate/condensate booster pumps to establish flow at reduced secondary pressure (per EOP FR-H.1, "Response to Loss of Secondary Heat Sink," Step 9):

If the conditions to feed with main feedwater pumps are not met, the condensate/condensate booster pumps are used to feed one SG. This requires reduction of the pressure in one SG to below the condensate booster pump shutoff head (to approximately 480 psig).

(NEI 99-02, Revision 7, Page 24, line numbers 26 to 29): "For plants with design features or procedural prohibitions that prevent restarting Main Feedwater, this question should be answered as "No" if Main Feedwater is free from damage or failure that would prevent it from performing its intended function and is available for use."

Because approved plant procedures resulted in closure of the MSIVs which prevented restarting the main feedwater pumps, the answer to this question should be no. Closure of the MSIVs would have delayed the availability of main feedwater utilizing the main feedwater pumps, however, the main feedwater system was free of damage or failure that would have prevented it from performing its function.

FAQ 22-02: Diablo Canyon Scram

(Page H-4, line numbers 26 to 32): "Since all PWR designs have an emergency Feedwater system that operates if necessary, the availability of the normal or main Feedwater systems as a backup in emergency situations can be important for managing risk following a reactor scram. This portion of the indicator is designed to assess that backup availability or ability to recover main feedwater as directed by approved plant procedures (e.g., the EOPs) on a loss of all emergency Feedwater."

The above uses "normal or Main Feedwater" but does not define what they are, nor does it specify the use of only main feedwater pumps. DCPP design includes an alternative option to providing cooling water to steam generator via electrically driven condensate booster pumps.

(Page H-5, line numbers 31 to 40): The estimated 30-minute timeframe for restart of main Feedwater was chosen based on restarting from a hot and filled condition. Since this timeframe will not be measured directly it should be an estimation developed based on the material condition of the plants systems following the reactor trip. The judgment of the on-shift licensed SRO during the reactor trip should be used in determining if this timeframe was met.

Simulator Scenario: Operations estimated that the time it would take to establish flow to one depressurized SG to allow the condensate/booster pump set to inject feedwater in accordance with EOP is approximately 33 minutes, which is consistent with the time estimate of "about 30 minutes" in the NEI 99-02, Revision 7 for establishing main feed. During this simulator scenario, it was observed that the level in the other three SGs remained above the SG dry-out criteria.

Facts:

1. Due to a FWH tube leak, the reactor was manually tripped in accordance with an annunciator response procedure.
2. The MSIVs were manually closed in accordance with annunciator response procedure.
3. Following the reactor trip, all safety-related equipment operated as designed. The AFW system started as expected. No complications were experienced during or after the reactor trip. There were no inoperable Technical Specification structures, systems, or components that contributed to the event.
4. There was no abnormal equipment condition that would have precluded the use of the main feedwater flow path. The only degradation in the feedwater system was the tube leakage experienced in Feedwater Heater equipment. This condition would not preclude the use of the main feedwater flowpath to supply feedwater to the SGs in order to maintain a heat sink.
5. The main feedwater pumps are steam-driven.
6. There are no electric-driven main feedwater pumps at DCPP.
7. At DCPP, the AFW and main feedwater pumps are the only pumps that supply the SGs with water when the SGs are at normal operating pressure.
8. The condensate booster pumps are in the main feedwater system flow path. The same water is provided to the steam generators using the same flow path as the main feedwater pumps.

FAQ 22-02: Diablo Canyon Scram

Conclusion: Based on the guidance of NEI 99-02, Revision 7, and the simulator study, the licensee concluded that the question "Was Main Feedwater unavailable or not recoverable using approved plant procedures during the scram response?" should be answered "No," either (1) because of the design features (steam driven main feedwater pumps) and procedural instructions at DCPP which directed closure of MSIVs, or (2) because of the ability to provide feedwater to one depressurized SG (to approximately 480 psig) via a condensate/condensate booster pump set within about 30 minutes utilizing plant procedures. The plant conditions did not cause an actual complication for the operations staff during the reactor trip response. Therefore, in accordance with either of the exceptions stated on page 24, page H-4, and page H-5 of NEI 99-02, Revision 7, this event should be classified as a "Normal Scram."

If licensee and NRC resident/region do not agree on the facts and circumstances, explain:

Potentially relevant FAQs:

FAQ 14-03

FAQ 14-03 discussed two ways that backup to EFW (AFW at DCPP) could have been provided, including an alternate (referred to as AFW for ANO) means to provide feedwater to SGs. A similar position is being made regarding using condensate booster pumps, as directed by DCPP procedures, to establish backup cooling via the main feedwater piping to a steam generator. The FAQ was silent on the argument for alternate means, instead agreeing that MFW could have been recovered within 30 minutes, and the trip was uncomplicated.

Response Section

Proposed Resolution of FAQ:

If appropriate, provide proposed rewording of guidance for inclusion in next revision:

PRA update required to implement this FAQ?

MSPI Basis Document update required to implement this FAQ?

Proposed NRC Response: