

From: [Wu, Angela](#)
To: [Guill, Paul E](#); [Johnson, Marieliz](#)
Cc: [Gambrell, Reese](#)
Subject: RE: RAI B2.1.9-2a ePortal
Date: Wednesday, June 01, 2022 10:10:00 AM

Paul,

Please see below for the staff's feedback:

1. Enhancement 4 in SLRA B2.1.9, in addition to Element 4, needs to also apply to "acceptance criteria (Element 6)" program element. This was implied in my previous feedback.
2. For Enhancement 4 and related SLR commitment, in the last paragraph beginning "For systems containing air/gas....", change "alternative inspections **may** include" to "alternative inspections **will** include" as was done in the other paragraphs of the enhancement.

No need to see a revised response on the ePortal for this, you can go straight to submitting the final response!

Thanks,
Angela
