



*Energy Harbor Nuclear Corp.
Davis-Besse Nuclear Power Station
5501 N. State Route 2
Oak Harbor, Ohio 43449*

Terry J. Brown
Site Vice President, Davis-Besse Nuclear

419-321-7676

June 7, 2022
L-22-136

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

SUBJECT:
Davis-Besse Nuclear Power Station, Unit No. 1
Docket No. 50-346, License No. NPF-3
Steam Generator Tube Circumferential Crack Report – Spring 2022 Refueling Outage

In accordance with Davis-Besse Nuclear Power Station (DBNPS) License Condition 2.C(7), "Steam Generator Tube Circumferential Crack Report," Energy Harbor Nuclear Corp. is required to submit an evaluation within three months following the completion of steam generator (SG) tube inservice inspection. The DBNPS SGs were replaced in 2014 with new Babcock and Wilcox Replacement Once Through Steam Generators, and as a result, DBNPS is no longer licensed to perform repair reroll. Structural and accident induced leakage integrity are evaluated analytically based on the degradation mechanism's characteristics, including circumferential extent, axial length, and percent through-wall depth. All indications of tube degradation were evaluated against the large-break loss-of-coolant accident (LBLOCA) loading for leakage integrity. All reported indications met condition monitoring criteria, and there were no indications of circumferential cracking identified, demonstrating reasonable assurance that the performance criteria for LBLOCA loading will continue to be satisfied throughout the next operating cycle. Therefore, it is bounded by current analyses, does not result in a significant increase of radionuclide release in excess of 10 CFR 100 limits, and demonstrates that adequate margin and defense-in-depth continue to be maintained. This letter satisfies License Condition 2.C(7) for evaluating that the primary-to-secondary leakage following a LBLOCA continues to be acceptable.

Davis-Besse Nuclear Power Station, Unit No. 1

L-22-136

Page 2 of 2

There are no regulatory commitments contained in this letter. If there are any questions or if additional information is required, please contact Mr. Phil H. Lashley, Manager – Fleet Licensing, at (330) 696-7208.

Sincerely,



Terry J. Brown

cc: NRC Region III Administrator
NRC Resident Inspector
NRC Project Manager
Utility Radiological Safety Board