



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

July 15, 2022

Mr. John J. Grabnar
Site Vice President
Energy Harbor Nuclear Corp.
Beaver Valley Power Station
P.O. Box 4, Route 168
Shippingport, PA 15077

SUBJECT: BEAVER VALLEY POWER STATION, UNITS 1 AND 2 – CLOSEOUT OF
BULLETIN 2012-01, "DESIGN VULNERABILITY IN ELECTRIC POWER
SYSTEM"

Dear Mr. Grabnar:

The purpose of this letter is to inform you that the U.S. Nuclear Regulatory Commission (NRC) staff has verified that Energy Harbor Nuclear Corp. (the licensee) has provided the necessary information requested in NRC's Bulletin (BL) 2012-01, "Design Vulnerability in Electric Power System," dated July 27, 2012 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML12074A115), for Beaver Valley Power Station, Units 1 and 2. The NRC staff has completed its review and this letter closes out BL 2012-01 for Beaver Valley.

The NRC issued BL 2012-01 to all holders of operating licenses and combined licenses for nuclear power reactors, except those that have permanently ceased operation and have certified that fuel has been removed from the reactor vessel. The Bulletin requested information about each facility's electric power system designs that would allow the NRC staff to verify the system's capability to address open phase conditions. Specifically, the NRC requested licensees to provide the following information:

- A description of how the protection scheme for engineered safety features buses (Class 1E for current operating plants or non-Class 1E for passive plants) is designed to detect and automatically respond to a single-phase open circuit condition or high impedance ground fault condition on offsite power circuits or another power source; and
- A description of the operating configuration of engineered safety features buses (Class 1E for current operating plants or non-Class 1E for passive plants) at power (i.e., normal operating condition).

By letter dated October 25, 2012 (ML12300A066), the licensee provided its response to BL 2012-01 for Beaver Valley. By letter dated February 3, 2014 (ML14034A055), the licensee provided supplemental information for Beaver Valley in response to an NRC staff request for additional information issued on December 20, 2013 (ML13351A314).

By letters dated October 9, 2013, and March 16, 2015 (ML13333A147 and ML15075A454, respectively), the Nuclear Energy Institute (NEI) submitted a voluntary industry initiative to address open phase conditions at nuclear power plants. The NEI letter dated March 16, 2015, stated, in part: “The initiative is a formal commitment by the companies that operate nuclear power plants to follow a specific policy or plan of action. The initiative calls for a proactive plan and schedule for addressing potential design vulnerabilities to the open phase condition.”

To evaluate the adequacy of the open phase isolation systems designs, the NRC staff issued Temporary Instruction (TI) 2515/194, “Inspection of the Licensees’ Implementation of Industry Initiative Associated with the Open Phase Condition Design Vulnerabilities in Electric Power Systems (NRC Bulletin 2012-01),” dated October 31, 2017 (ML17137A416), which provided temporary inspection instructions for the purpose of verifying that licensees appropriately implemented the NEI voluntary industry initiative dated March 16, 2015. The NRC staff piloted the use of TI 2515/194 by inspecting four nuclear power plants with four distinct open phase isolation system designs. A summary of the NRC staff’s preliminary observations and issues needing additional clarity were discussed with industry representatives in two public meetings conducted on September 19, 2018, and October 17, 2018. The meeting summaries can be found in ADAMS under Package Accession Nos. ML18268A342 and ML18309A226, respectively.

By letter dated June 6, 2019 (ML19163A176), NEI submitted Revision 3 of the voluntary industry initiative to include an option for plants to perform a risk evaluation under certain boundary conditions to support manual response to an open phase condition. NEI also submitted NEI 19-02, “Guidance for Assessing Open Phase Condition Implementation Using Risk Insights” on June 20, 2019 (ML19172A086). On August 18, 2020, the NRC staff issued Revision 2 of TI 2515/194 (ML20230A328), which provided temporary inspection instructions for the purpose of verifying that licensees appropriately implemented Revision 3 of the NEI voluntary industry initiative. The revision accounted for changes reflected in Revision 3 of the NEI voluntary initiative.

In September 2021 and June 2022, the NRC staff performed inspections at Beaver Valley using TI 2515/194 Revision 2. The inspections at Beaver Valley were performed to verify the licensee’s implementation of the voluntary industry initiative at Beaver Valley. To address the potential open phase condition design vulnerability issue at Beaver Valley, the licensee implemented open phase isolation system plant modifications, which provide detection and alarm in the control room, and necessary plant procedures that allow operators to diagnose and take manual action to mitigate an open phase condition. The NRC staff documented the results of inspections in the following reports:

- Beaver Valley Power Station, Units 1 and 2 – Temporary Instruction 2515/194 Inspection Report 05000334/2021011 and 05000412/2021011, dated October 19, 2021 (ML21292A063)
- Beaver Valley Power Station, Units 1 and 2 – Temporary Instruction 2515/194 Inspection Report 05000334/2022011 and 05000412/2022011, dated June 29, 2022 (ML22180A228)

The NRC staff reviewed the information submitted by the licensee and the results of the TI 2515/194 inspections for Beaver Valley. An exception related to risk-informed evaluation noted in inspection report dated October 21, 2021, has been resolved accordingly to the inspection report dated June 29, 2022. Based on this review, the NRC staff concludes that the licensee provided the necessary information requested in BL 2012-01 and has completed the implementation of its open phase isolation system. Therefore, the NRC staff closes BL 2012-01 for Beaver Valley.

If you have any questions, please contact me at 301-415-0680 or Brent.Ballard@nrc.gov.

Sincerely,

/RA/

Brent T. Ballard, Project Manager
Plant Licensing Branch I
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-334, 50-412

cc: Listserv

SUBJECT: BEAVER VALLEY POWER STATION, UNITS 1 AND 2 – CLOSEOUT OF
BULLETIN 2012-01, “DESIGN VULNERABILITY IN ELECTRIC POWER
SYSTEM” DATED JULY 15, 2022

DISTRIBUTION:

PUBLIC
PM File Copy
RidsNrrLAKGoldstein Resource
RidsNrrLAKZeletznock Resource
RidsRgn1MailCenter Resource
RidsACRS_MailCTR Resource
RidsNrrDexEEEEB Resource
RidsNrrDorlLpl1 Resource
RidsNrrDraApob Resource
RidsNrrDroloeb Resource
RidsNrrPMBeaverValley Resource

WMorton, NRR
KNguyen, NRR
VGoel, NRR
RRodriguez, NRR
BBallard, NRR
AZoulis, NRR
JHughey, NRR
LRegner, NRR
JDanna, NRR

ADAMS Accession No.: ML22189A184

OFFICE	NRR/DORL/LPL1/PM	NRR/DORL/LPL1/LA	NRR/DEX/EEEEB/BC
NAME	BBallard	KZeletznock	WMorton (SRay for)
DATE	07/08/2022	07/12/2022	07/05/2022
OFFICE	NRR/DRA/APOB/BC	NRR/DRO/IOEB/BC	NRR/DORL/LPL1/BC
NAME	AZoulis (JHughey for)	LRegner	JDanna
DATE	07/07/2022	07/08/2022	07/15/2022
OFFICE	NRR/DORL/LPL2-1/PM		
NAME	BBallard		
DATE	07/15/2022		

OFFICIAL RECORD COPY