

NEI 99-01 [Revision 7-DRAFT G]

Development of Emergency Action Levels for Non-Passive Reactors

Month 20XX

[THIS PAGE IS LEFT BLANK INTENTIONALLY]

NEI 99-01 [Revision 7-DRAFT G]

Nuclear Energy Institute

**Development of
Emergency Action Levels
for Non-Passive Reactors**

Month 20XX

ACKNOWLEDGMENTS

This document was prepared by the Nuclear Energy Institute Emergency Action Level (EAL) Task Force.

Tim Barton – Exelon Nuclear

Ricky Collings - Southern Nuclear

Kelly Walker – Operations Support Services

Eric White – Duke Energy

David Young - NEI

NOTICE

Neither NEI, nor any of its employees, members, supporting organizations, contractors, or consultants make any warranty, expressed or implied, or assume any legal responsibility for the accuracy or completeness of, or assume any liability for damages resulting from any use of, any information apparatus, methods, or process disclosed in this report or that such may not infringe privately owned rights.

EXECUTIVE SUMMARY

Federal regulations require a nuclear power plant licensee to develop a scheme for the classification of emergency events and conditions. This scheme is a fundamental component of an emergency plan in that it provides the defined thresholds that will allow site personnel to rapidly implement a range of pre-planned emergency response measures. An emergency classification scheme also facilitates timely decision-making by an Offsite Response Organization (ORO for implementation of precautionary or protective actions for the public.

The purpose of Nuclear Energy Institute (NEI) 99-01 is to provide guidance to nuclear power plant licensees for the development of a site-specific emergency classification scheme. The methodology has been endorsed by the U.S. Nuclear Regulatory Commission (NRC) as an acceptable method for meeting the requirements of Title 10 of the Code of Federal Regulations (10 CFR) 50.47(b)(4) and related sections of 10 CFR 50, Appendix E, and the associated planning standard evaluation elements in NUREG-0654/ FEMA-REP-1, *Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants*. Individuals responsible for developing an emergency classification scheme are strongly encouraged to review all applicable NRC requirements and guidance prior to beginning their work.

NEI 99-01 contains a set of generic Initiating Conditions (ICs), Emergency Action Levels (EALs) and fission product barrier status thresholds. It also includes supporting technical basis information, developer notes and recommended classification instructions for users. Scheme developers should implement ICs, EALs and thresholds as close as practicable to the generic material presented in this document with allowance for changes necessary to address site-specific considerations such as plant design, location, terminology, etc.

Properly implemented, the guidance in NEI 99-01 will yield a site-specific emergency classification scheme with clearly defined and readily observable EALs and thresholds. Other benefits include the development of a sound basis document, the adoption of industry-standard instructions for emergency classification (e.g., transient events, classification of multiple events, upgrading, downgrading, etc.), and incorporation of features to improve human performance. An emergency classification using this scheme will be appropriate to the risk posed to plant workers and the public and should be the same as that made by another NEI 99-01 user plant in response to a similar event.

Finally, unique State and local requirements associated with an emergency classification scheme are not reflected in this guidance. Incorporation of these requirements may be performed on a case-by-case basis in conjunction with the appropriate ORO agency. Any such changes will require a review under the applicable sections of 10 CFR 50.

[THIS PAGE IS LEFT BLANK INTENTIONALLY]

TABLE OF CONTENTS

EXECUTIVE SUMMARY.....	i
1 REGULATORY BACKGROUND.....	1
1.1 OPERATING REACTORS	1
1.2 IMMEDIATE NOTIFICATION REQUIREMENTS PER 10 CFR 50.72.....	1
1.3 INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI).....	2
1.4 SPENT FUEL POOL MONITORING INSTRUMENTATION.....	2
1.5 DECOMMISSIONING FACILITY.....	3
1.6 APPLICABILITY TO ADVANCED AND SMALL MODULAR REACTOR DESIGNS	3
2 KEY TERMINOLOGY USED IN NEI 99-01.....	5
2.1 EMERGENCY CLASSIFICATION LEVEL (ECL).....	5
2.2 INITIATING CONDITION (IC)	7
2.3 EMERGENCY ACTION LEVEL (EAL)	7
2.4 FISSION PRODUCT BARRIER THRESHOLD	7
3 DESIGN OF THE NEI 99-01 EMERGENCY CLASSIFICATION SCHEME.....	9
3.1 ASSIGNMENT OF EMERGENCY CLASSIFICATION LEVELS (ECLs)	9
3.2 TYPES OF INITIATING CONDITIONS AND EMERGENCY ACTION LEVELS.....	10
3.3 NSSS DESIGN DIFFERENCES	10
3.4 ORGANIZATION AND PRESENTATION OF GENERIC INFORMATION.....	11
3.5 IC AND EAL MODE APPLICABILITY.....	12
4 SITE-SPECIFIC SCHEME DEVELOPMENT GUIDANCE	14
4.1 GENERAL IMPLEMENTATION GUIDANCE	14
4.2 CRITICAL CHARACTERISTICS	15
4.3 INSTRUMENTATION USED FOR EALS	16
4.4 PRESENTATION OF SCHEME INFORMATION TO USERS	17
4.5 INTEGRATION OF ICS/EALS WITH PLANT PROCEDURES	18
4.6 BASIS DOCUMENT	19
4.7 EAL/THRESHOLD REFERENCES TO AOP AND EOP SETPOINTS/CRITERIA	19
4.8 DEVELOPER AND USER FEEDBACK	20
5 GUIDANCE ON MAKING EMERGENCY CLASSIFICATIONS.....	21
5.1 GENERAL CONSIDERATIONS	21
5.2 CLASSIFICATION METHODOLOGY	22

5.3	CLASSIFICATION OF MULTIPLE EVENTS AND CONDITIONS.....	22
5.4	CONSIDERATION OF MODE CHANGES DURING CLASSIFICATION	23
5.5	EMERGENCY CLASSIFICATION LEVEL DOWNGRADING AND TERMINATION	23
5.6	CLASSIFICATION OF TRANSIENT CONDITIONS	23
5.7	AFTER-THE-FACT DISCOVERY OF AN EMERGENCY EVENT OR CONDITION.....	24
5.8	RETRACTION OF THE NOTIFICATION OF AN EMERGENCY DECLARATION.....	24
6	ABNORMAL RAD LEVELS / RADIOLOGICAL EFFLUENT ICS/EALS	26
7	COLD SHUTDOWN / REFUELING SYSTEM MALFUNCTION ICS/EALS	45
8	INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI) ICS/EALS	70
9	FISSION PRODUCT BARRIER ICS/EALS	74
10	HAZARDS AND OTHER CONDITIONS AFFECTING PLANT SAFETY ICS/EALS	108
11	SYSTEM MALFUNCTION ICS/EALS	124
	APPENDIX A – ACRONYMS AND ABBREVIATIONS.....	1
	APPENDIX B – DEFINITIONS.....	3
	APPENDIX C – GUIDANCE FOR RADIATION EFFLUENT MONITOR EALS	1

DEVELOPMENT OF EMERGENCY ACTION LEVELS **FOR NON-PASSIVE REACTORS**

1 REGULATORY BACKGROUND

1.1 OPERATING REACTORS

Title 10, Code of Federal Regulations (CFR), Energy, contains the U.S. Nuclear Regulatory Commission (NRC) regulations applicable to nuclear power reactor facilities. Several of these regulations govern the development, approval and use of an emergency classification scheme. A review of the sections listed below will aid the reader in understanding the key terminology developed in Section 3.0 of this document.

- 10 CFR 50.47(a)(1)(i)
- 10 CFR 50.47(b)(4)
- 10 CFR 50.54(q)
- 10 CFR 50.72
- 10 CFR 50, Appendix E, IV.B, Assessment Actions
- 10 CFR 50, Appendix E, IV.C, Activation of Emergency Organization

The above regulations are supplemented by various regulatory guidance documents; these include:

- NSIR/DPR-ISG-01, *Interim Staff Guidance, Emergency Planning for Nuclear Power Plants*
- NUREG-0654/FEMA-REP-1, *Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants*
- NUREG-1022, *Event Reporting Guidelines: 10 CFR 50.72 and 50.73*
- Regulatory Guide 1.101, *Emergency Response Planning and Preparedness for Nuclear Power Reactors*
- Regulatory Guide 1.219, *Guidance on Making Changes to Emergency Plans for Nuclear Power Reactors*

The above list is not all-inclusive, and it is recommended that scheme developers consult with licensing/regulatory affairs personnel to identify and understand applicable requirements and guidance. Questions may also be directed to the NEI Emergency Preparedness staff.

1.2 IMMEDIATE NOTIFICATION REQUIREMENTS PER 10 CFR 50.72

There are a range of “non-emergency events” reported to the NRC in accordance with the requirements of 10 CFR 50.72, *Immediate notification requirements for operating nuclear power reactors*. Guidance concerning these reporting requirements, and example events, are provided in NUREG-1022. Certain events may require both an emergency declaration in accordance with the requirements of 10 CFR 50.47 and Appendix E, and an event notification under the provisions of 10 CFR 50.72.

1.3 INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)

The guidance in NEI 99-01 is applicable to licensees electing to use their 10 CFR 50 emergency plan to fulfill the requirements of 10 CFR 72.32 for a stand-alone ISFSI. The emergency classification levels applicable to an ISFSI are consistent with those described in 10 CFR 50, Appendix E, and NUREG 0654/FEMA-REP-1. The initiating conditions germane to a 10 CFR 72.32 emergency plan (as described in NUREG-1567) are subsumed within the classification scheme for a 10 CFR 50.47 emergency plan.

The generic ICs and EALs for an ISFSI are presented in Section 8, ISFSI ICs/EALs. IC E-HU1 covers the spectrum of credible natural and man-made events included within the scope of an ISFSI design. This IC is not applicable to installations or facilities that may process and/or repackage spent fuel (e.g., a Monitored Retrievable Storage Facility or an ISFSI at a spent fuel processing facility). In addition, appropriate aspects of IC HU1 and IC HA1 should also be included in a scheme to address a HOSTILE ACTION directed against an ISFSI.

An analysis of potential onsite and offsite consequences of accidental releases associated with the operation of an ISFSI is contained in NUREG-1140, *A Regulatory Analysis on Emergency Preparedness for Fuel Cycle and Other Radioactive Material Licensees*. NUREG-1140 concluded that the postulated worst-case accident involving an ISFSI has insignificant consequences to public health and safety. This evaluation shows that the maximum offsite dose to a member of the public due to an accidental release of radioactive materials would not exceed 1 rem Effective Dose Equivalent.

1.4 SPENT FUEL POOL MONITORING INSTRUMENTATION

On March 11, 2011, the Great East Japan Earthquake, rated a magnitude 9.0 on the Richter Scale, occurred off the coast of Honshu Island, resulting in the automatic shutdown of 11 nuclear power plants at four sites along the northeast coast of Japan, including three of six reactors at the Fukushima Dai-ichi site (the three remaining plants were shutdown for maintenance). The earthquake caused a large tsunami that is estimated to have exceeded 14 meters (46 feet) in height at the Fukushima Dai-ichi site. The earthquake and tsunami disabled most of the offsite and onsite electrical power systems, causing an extended loss of AC power that ultimately led to core damage in three reactors. While the loss of power also impaired the spent fuel pool cooling function, sufficient water inventory was maintained in the pools to preclude fuel damage.

Following a review of the Fukushima Dai-ichi accident, the NRC concluded that several measures were necessary to ensure adequate protection of public health and safety under the provisions of the backfit rule, 10 CFR 50.109(a)(4)(ii). Among them was to provide each spent fuel pool with reliable level instrumentation to significantly enhance the ability of key decision-makers to allocate resources effectively following a beyond design basis event. This conclusion led the NRC to issue Order EA-12-051, *Issuance of Order to Modify Licenses with Regard to Reliable Spent Fuel Pool Instrumentation*, on March 12, 2012, to all US nuclear plants with an operating license, construction permit, or combined construction and operating license.

NRC Order EA-12-051 states, in part, “All licensees ... shall have a reliable indication of the water level in associated spent fuel storage pools capable of supporting identification of the following pool water level conditions by trained personnel: (1) level that is adequate to support operation of the normal fuel pool cooling system, (2) level that is adequate to provide substantial radiation shielding for a person standing on the spent fuel pool operating deck, and (3) level where fuel remains covered and actions to implement make-up water addition should no longer be deferred.” To this end, all licensees must provide:

- A primary and back-up level instrument that will monitor water level from the normal level to the top of the used fuel rack in the pool;
- A display in an area accessible following a severe event; and
- Independent electrical power to each instrument channel and provide an alternate remote power connection capability.

The requirements in NRC Order EA-12-051 were eventually codified in 10 CFR 50.155, *Mitigation of beyond-design-basis events*; refer to 10 CFR 50.155(e), *Spent fuel pool monitoring*. NEI 99-01 contains three EALs that reflect the availability of the enhanced spent fuel pool level instrumentation associated with the requirements of 10 CFR 50.155. These EALs, along with associated notes, bases and developer notes, are presented in ICs AA2, AS2 and AG2.

1.5 DECOMMISSIONING FACILITY

A power reactor licensee that has submitted certifications of the permanent cessation of operations and permanent removal of all fuel from the reactor vessel, in accordance with 10 CFR 50.82(a)(1) or 10 CFR 52.110(a), may continue using the ICs and EALs in Recognition Categories A, C, I and H applicable to All Modes or the Defueled Mode. Such use may continue through the Post-Shutdown phase of decommissioning (i.e., prior to entering the Permanently Defueled phase). During this period, a licensee may use an operator aid (e.g., a wallboard) to identify those ICs and EALs that are precluded from occurring once the reactor is permanently shutdown. When evaluating changes to EALs, the licensee may also consider the examples contained in Draft Regulatory Guide (DG)-1346, *Emergency Planning for Decommissioning Nuclear Power Reactors*.¹

1.6 APPLICABILITY TO ADVANCED AND SMALL MODULAR REACTOR DESIGNS

The guidance in this document primarily addresses so-called Generation I and II plant designs – large light water reactors with non-passive safety features; however, it may be adapted to advanced non-passive designs, often referred to as Generation III designs, as well. Developers of an emergency classification scheme for an advanced non-passive reactor plant may need to propose deviations from the generic guidance to account for the differences in design features, and operating characteristics and capabilities.

The guidance in NEI 99-01 is not applicable to advanced passive light water reactor designs. An emergency classification scheme for this type of facility should be

¹ This document was under development by the NRC staff at the time NEI 99-01, Revision 7, was being developed. It is expected to be issued as Regulatory Guide 1.235.

developed in accordance with NEI 07-01, *Methodology for Development of Emergency Action Levels, Advanced Passive Light Water Reactors*.

Finally, there are significant design and operating differences between large light water reactors and Small Modular Reactors (SMRs) and other new technologies (ONTs) such as liquid-metal-cooled reactors, gas-cooled reactors, and molten-salt-cooled reactors. SMRs and ONT have design features and safety enhancements that result in slower transient response times, and relatively small and slow releases of fission products. For this reason, the guidance in NEI 99-01 is not applicable to SMR and ONT designs.

.

2 KEY TERMINOLOGY USED IN NEI 99-01

There are several key terms that appear throughout the NEI 99-01 methodology. These terms are introduced in this section to support understanding of subsequent material. As an aid to the reader, the following table is provided as an overview to illustrate the relationship of the terms to each other.

Emergency Classification Level			
Unusual Event	Alert	SAE	GE
↓	↓	↓	↓
Initiating Condition	Initiating Condition	Initiating Condition	Initiating Condition
↓	↓	↓	↓
Emergency Action Level (1) <ul style="list-style-type: none"> • Operating Mode Applicability • Notes • Basis 	Emergency Action Level (1) <ul style="list-style-type: none"> • Operating Mode Applicability • Notes • Basis 	Emergency Action Level (1) <ul style="list-style-type: none"> • Operating Mode Applicability • Notes • Basis 	Emergency Action Level (1) <ul style="list-style-type: none"> • Operating Mode Applicability • Notes • Basis
(1) - When making an emergency classification, the Shift Manager/Emergency Director must consider all information having a bearing on the proper assessment of an Initiating Condition (IC). This includes the Emergency Action Level (EAL) plus the associated Operating Mode Applicability, Notes and the informing Basis information. In the Recognition Category F matrices, EALs are referred to as Fission Product Barrier Thresholds; the thresholds serve the same function as an EAL.			

2.1 EMERGENCY CLASSIFICATION LEVEL (ECL)

One of a set of names or titles established by the US Nuclear Regulatory Commission (NRC) for grouping off-normal events or conditions according to (1) potential or actual effects or consequences, and (2) resulting onsite and offsite response actions. The emergency classification levels, in ascending order of severity, are:

- Notification of Unusual Event (NOUE)
- Alert
- Site Area Emergency (SAE)
- General Emergency (GE)

2.1.1 Notification of Unusual Event (NOUE)²

Events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant or indicate a security threat to facility protection has been

² This term is sometimes shortened to Unusual Event (UE) or other similar site-specific terminology. The terms Notification of Unusual Event, NOUE and Unusual Event are used interchangeably throughout this document

initiated. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety systems occurs.

Purpose: The purpose of this classification is to assure that the first step in future response has been carried out, to bring the operations staff to a state of readiness, and to provide systematic handling of unusual event information and decision-making.

2.1.2 Alert

Events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant or a security event that involves probable life threatening risk to site personnel or damage to site equipment because of HOSTILE ACTION. Any releases are expected to be limited to small fractions of the EPA PAG exposure levels.

Purpose: The purpose of this classification is to assure that emergency personnel are readily available to respond if the situation becomes more serious or to perform confirmatory radiation monitoring if required, and provide offsite authorities current information on plant status and parameters.

2.1.3 Site Area Emergency

Events are in progress or have occurred which involve actual or likely major failures of plant functions needed for protection of the public or HOSTILE ACTION that results in intentional damage or malicious acts; 1) toward site personnel or equipment that could lead to the likely failure of or; 2) that prevent effective access to, equipment needed for the protection of the public. Any releases are not expected to result in exposure levels which exceed EPA PAG exposure levels beyond the site boundary.

Purpose: The purpose of the Site Area Emergency declaration is to assure that emergency response centers are staffed, to assure that monitoring teams are dispatched, to assure that personnel required for evacuation of near-site areas are at duty stations if the situation becomes more serious, to provide consultation with offsite authorities, and to provide updates to the public through government authorities.

2.1.4 General Emergency (GE)

Events are in progress or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity or HOSTILE ACTION that results in an actual loss of physical control of the facility. Releases can be reasonably expected to exceed EPA PAG exposure levels offsite for more than the immediate site area.

Purpose: The purpose of the General Emergency declaration is to initiate predetermined protective actions for the public, to provide continuous assessment of information from the licensee and offsite organizational measurements, to initiate additional measures as indicated by actual or potential releases, to provide consultation with offsite authorities, and to provide updates for the public through government authorities.

2.2 INITIATING CONDITION (IC)

An event or condition that aligns with the definition of one of the four emergency classification levels by virtue of the potential or actual effects or consequences.

Discussion: An IC describes an event or condition with potential or actual effects or consequences that align with the definition of an emergency classification level. An IC can be expressed as a continuous, measurable parameter (e.g., RCS leakage), an event (e.g., an earthquake), or the status of one or more fission product barriers (e.g., loss of the RCS barrier). Considerations for the assignment of a particular Initiating Condition to an emergency classification level are discussed in Section 3.

2.3 EMERGENCY ACTION LEVEL (EAL)

A pre-determined, site-specific, observable threshold for an Initiating Condition that, when met or exceeded, places the plant in a given emergency classification level.

Discussion: EAL statements may utilize a variety of criteria including instrument readings and equipment status indications; observable events; results of calculations and analyses; entry into particular procedures; and the occurrence of natural phenomena.

2.4 FISSION PRODUCT BARRIER THRESHOLD

A pre-determined, site-specific, observable threshold indicating the loss or potential loss of a fission product barrier.

Discussion: Fission product barrier thresholds represent threats to the defense-in-depth design concept that precludes the release of radioactive fission products to the environment. This concept relies on multiple physical barriers, any one of which, if maintained intact, precludes the release of significant amounts of radioactive fission products to the environment. The primary fission product barriers are:

- Fuel Clad
- Reactor Coolant System (RCS)
- Containment

Upon determination that one or more fission product barrier thresholds have been exceeded, the combination of barrier loss and/or potential loss thresholds is compared to the fission product barrier IC/EAL criteria to determine the appropriate ECL.

In some accident sequences, a Fission Product Barrier IC threshold for a given ECL will be exceeded before an EAL presented in the Abnormal Radiation Levels / Radiological Effluent (A) Recognition Category for the same ECL. For example, conditions involving a loss the Fuel Clad and RCS Barriers with a concurrent potential loss of the Containment Barrier will lead to a General Emergency declaration. This could occur even when a concurrent radiological assessment, considering only design basis containment leakage, indicates a lower ECL (e.g., a Site Area Emergency). This aspect of the scheme ensures that proactive declarations are made in instances where there is a significant source term in containment and energy available as a motive force for a release.

In addition, the A and F IC sets work together to ensure timely emergency classifications of potential or actual releases of radioactivity from whatever source, including events involving sources not encompassed by the fission product barrier matrix (e.g., a spent fuel pool accident).

3 DESIGN OF THE NEI 99-01 EMERGENCY CLASSIFICATION SCHEME

3.1 ASSIGNMENT OF EMERGENCY CLASSIFICATION LEVELS (ECLs)

An effective emergency classification scheme must incorporate a realistic and accurate assessment of risk, both to plant workers and the public. There are obvious health and safety risks in underestimating the potential or actual threat from an event or condition; however, there are risks in overestimating the threat as well (e.g., harm that may occur during an evacuation). The NEI 99-01 emergency classification scheme attempts to strike an appropriate balance between reasonably anticipated event or condition consequences, potential accident trajectories, and risk avoidance or minimization.

The assignment of each Initiating Condition to an ECL is based on one or more of the following sources.

- Qualitative assessment of the effects and consequences of an event or condition
- Typical abnormal and emergency operating procedure setpoints and transition criteria
- Typical Technical Specification limits and controls
- Radiological Effluent Technical Specifications (RETS)/Offsite Dose Calculation Manual (ODCM) radiological release limits
- Review of selected Updated Final Safety Analysis Report (UFSAR) accident analyses
- Environmental Protection Agency (EPA) Protective Action Guidelines (PAGs)
- Industry Operating Experience
- Input from industry subject matter experts and NRC staff members

3.1.1 Risk-Informed Insights

Emergency preparedness is a defense-in-depth measure that is independent of the assessed risk from any particular accident sequence; however, the development of an effective emergency classification scheme can benefit from a review of risk-based assessment results. To that end, the development and assignment of certain ICs and EALs also considered insights from several site-specific probabilistic safety assessments (PSA - also known as probabilistic risk assessment, PRA). Some generic insights from this review included:

1. Accident sequences involving an extended loss of all AC power are significant contributors to core damage frequency at many Pressurized Water Reactors (PWRs) and Boiling Water Reactors (BWRs). For this reason, a loss of all AC power for greater than 15 minutes, with the plant at or above Hot Shutdown, was assigned an ECL of Site Area Emergency. Precursor events to a loss of all AC power were also included as an Unusual Event and an Alert.
2. For severe core damage events, uncertainties exist in phenomena important to accident progressions leading to containment failure. Because of these uncertainties, predicting the status of containment integrity may be difficult under severe accident conditions. Therefore, maintaining containment integrity alone following sequences leading to severe core damage is an insufficient basis for not escalating to a General Emergency.

3. PSAs indicated that leading contributors to latent fatalities were sequences involving a containment bypass, a large Loss of Coolant Accident (LOCA) with early containment failure, and a reactor coolant pump seal failure. A generic EAL methodology needs to be sufficiently rigorous to address these sequences in a timely fashion.

3.2 TYPES OF INITIATING CONDITIONS AND EMERGENCY ACTION LEVELS

The NEI 99-01 methodology makes use of symptom-based, barrier-based and event-based ICs and EALs. Each type is discussed below.

Symptom-based ICs and EALs are parameters or conditions that are measurable over some range using plant instrumentation (e.g., core temperature, reactor coolant level, radiological effluent, etc.). When one or more of these parameters or conditions are off-normal, reactor operators will implement procedures to identify the probable cause(s) and take corrective action.

Fission product barrier-based ICs and EALs are the subset of symptom-based EALs that refer specifically to the level of challenge to the principal barriers against the release of radioactive material from the reactor core to the environment. These barriers are the Fuel Clad, the Reactor Coolant System pressure boundary, and the Containment. The barrier-based ICs and EALs consider the level of challenge to each individual barrier - potentially lost and lost - and the total number of barriers under challenge.

Event-based ICs and EALs define a variety of specific occurrences that have potential or actual safety significance. These include natural phenomena (e.g., an earthquake) or man-made hazards such as a toxic gas release.

3.3 NSSS DESIGN DIFFERENCES

The NEI 99-01 emergency classification scheme accounts for the design differences between PWRs and BWRs by specifying EALs unique to each type of Nuclear Steam Supply System (NSSS). There are also significant design differences among PWR NSSSs; therefore, guidance is provided to aid in the development of EALs appropriate to different PWR NSSS types. In some instances, development guidance also addresses unique considerations for advanced non-passive reactor designs such as the Advanced Boiling Water Reactor (ABWR), the Advanced Pressurized Water Reactor (APWR) and the Evolutionary Power Reactor (EPR).

Developers will need to consider the relevant aspects of their plant's design and operating characteristics when converting the generic guidance of this document into a site-specific classification scheme. The goal is to maintain as much fidelity as possible to the intent of generic ICs and EALs within the constraints imposed by the plant design and operating characteristics. To this end, developers of a scheme for an advanced non-passive reactor may need to add, modify or delete some information contained in this document; these changes will be reviewed for acceptability by the NRC as part of the scheme approval process.

3.4 ORGANIZATION AND PRESENTATION OF GENERIC INFORMATION

The scheme's generic information is organized by Recognition Category in the following order.

- A - Abnormal Radiation Levels / Radiological Effluent – Section 6
- C - Cold Shutdown / Refueling System Malfunction – Section 7
- E - Independent Spent Fuel Storage Installation (ISFSI) – Section 8
- F - Fission Product Barrier – Section 9
- H - Hazards and Other Conditions Affecting Plant Safety – Section 10
- S - System Malfunction – Section 11

Each Recognition Category section contains a matrix showing the ICs and their associated emergency classification levels.

The following information and guidance is provided for each IC:

- **ECL** – the assigned emergency classification level for the IC.
- **Initiating Condition** – provides a summary description of the emergency event or condition.
- **Operating Mode Applicability** – Lists the modes during which the IC and associated EAL(s) are applicable (i.e., are to be used to classify events or conditions).
- **Example Emergency Action Level(s)** – Provides examples of reports and indications that are considered to meet the intent of the IC. Developers should address each example EAL. If the generic approach to the development of an example EAL cannot be used (e.g., an assumed instrumentation range is not available at the plant), the developer should attempt to specify an alternate means for identifying entry into the IC.

For Recognition Category F, the fission product barrier thresholds are presented in tables applicable to BWRs and PWRs and arranged by fission product barrier and the degree of barrier challenge (i.e., potential loss or loss). This presentation method shows the relationship among the thresholds and supports accurate assessments.

- **Basis** – Provides background information that explains the intent and application of the IC and EALs. In some cases, the basis also includes relevant source information and references.
- **Developer Notes** - Information that supports the development of the site-specific ICs and EALs. This may include clarifications, references, examples, instructions for calculations, etc. Developer notes should not be included in the site's emergency classification scheme basis document. Developers may elect to include information resulting from a developer note action in a basis section.

It is important to point out that NRC references to “an EAL” typically mean the Initiating Condition, the Operating Mode Applicability, the Notes (if any) the EAL(s), and the Basis (i.e., all the aspects of a given EAL).

3.5 IC AND EAL MODE APPLICABILITY

The NEI 99-01 emergency classification scheme was developed recognizing that the applicability of ICs and EALs will vary with plant mode. For example, some symptom-based ICs and EALs can be assessed only during the power operations, startup, or hot standby/shutdown modes of operation when all fission product barriers are in place, and plant instrumentation and safety systems are fully operational. In the cold shutdown and refueling modes, different symptom-based ICs and EALs will come into play to reflect the opening of systems for routine maintenance, the unavailability of some safety system components and the use of alternate instrumentation.

The following table shows which Recognition Categories are applicable in each plant mode. The ICs and EALs for a given Recognition Category are applicable in the indicated modes. In the case where a licensee’s mode descriptions contained in their current licensing basis (e.g., Technical Specifications) are not aligned with the table below, the licensee should propose an alternative mode applicability matrix for NRC review. There is no intent to require a licensee to change their mode descriptions to support an emergency classification scheme submittal.

MODE APPLICABILITY MATRIX

Mode	Recognition Category					
	A	C	E	F	H	S
Power Operations	X		X	X	X	X
Startup	X		X	X	X	X
Hot Standby	X		X	X	X	X
Hot Shutdown	X		X	X	X	X
Cold Shutdown	X	X	X		X	
Refueling	X	X	X		X	
Defueled	X	X	X		X	

Typical BWR Operating Modes

Power Operations (1):	Mode Switch in Run
Startup (2):	Mode Switch in Startup/Hot Standby or Refuel (with all vessel head bolts fully tensioned)
Hot Shutdown (3):	Mode Switch in Shutdown, Average Reactor Coolant Temperature >200 °F
Cold Shutdown (4):	Mode Switch in Shutdown, Average Reactor

Coolant Temperature ≤ 200 °F

Refueling (5): Mode Switch in Shutdown or Refuel, and one or more vessel head bolts less than fully tensioned.

Typical PWR Operating Modes

Power Operations (1): Reactor Power $> 5\%$, $K_{eff} \geq 0.99$

Startup (2): Reactor Power $\leq 5\%$, $K_{eff} \geq 0.99$

Hot Standby (3): $RCS \geq 350$ °F, $K_{eff} < 0.99$

Hot Shutdown (4): 200 °F $< RCS < 350$ °F, $K_{eff} < 0.99$

Cold Shutdown (5): $RCS < 200$ °F, $K_{eff} < 0.99$

Refueling (6): One or more vessel head closure bolts less than fully tensioned

Developers will need to incorporate the mode criteria from unit-specific Technical Specifications into their emergency classification scheme. In addition, the scheme must also include the following mode designation specific to NEI 99-01:

Defueled (None): All fuel removed from the reactor vessel (i.e., full core offload during refueling or extended outage).

4 SITE-SPECIFIC SCHEME DEVELOPMENT GUIDANCE

This section provides detailed guidance for developing a site-specific emergency classification scheme. Conceptually, the approach discussed here mirrors the approach used to prepare emergency operating procedures – each nuclear power plant converts the generic material prepared by reactor vendor owners’ groups into site-specific emergency operating procedures. Likewise, the emergency classification scheme developer will use the generic guidance in NEI 99-01 to prepare a site-specific emergency classification scheme and the associated basis document.

It is important that the NEI 99-01 emergency classification scheme be implemented as an integrated package. Selected use of portions of this guidance is strongly discouraged as it will lead to an inconsistent or incomplete emergency classification scheme that will likely not receive the necessary regulatory approval.

4.1 GENERAL IMPLEMENTATION GUIDANCE

The guidance in NEI 99-01 is not intended to be applied to plants “as-is;” however, developers should attempt to keep their site-specific schemes as close to the generic guidance as possible. The goal is to meet the intent of the generic Initiating Conditions (ICs) and Emergency Action Levels (EALs) within the context of site-specific characteristics – locale, plant design, operating features, terminology, etc. Meeting this goal will result in a shorter and less cumbersome NRC review and approval process, closer alignment with the schemes of other nuclear power plant sites and better positioning to adopt future industry-wide scheme enhancements.

When properly developed, the ICs and EALs should be unambiguous and readily assessable.

As discussed in Section 3, the generic guidance includes ICs and example EALs. It is the intent of this guidance that both be included in site-specific documents as each serves a specific purpose. The IC is the fundamental event or condition requiring a declaration. The EAL(s) is the pre-determined threshold that defines when the IC is met. If some feature of the plant location or design is not compatible with a generic IC or EAL, efforts should be made to identify an alternate IC or EAL.

If an IC or EAL includes an explicit reference to a mode dependent technical specification limit that is not applicable to the plant, then that IC and/or EAL need not be included in the site-specific scheme. In these cases, developers must provide adequate documentation to justify why the IC and/or EAL were not incorporated (i.e., sufficient detail to allow a third party to understand the decision not to incorporate the generic guidance).

Useful acronyms and abbreviations associated with the NEI 99-01 emergency classification scheme are presented in Appendix A, Acronyms and Abbreviations. Site-specific entries may be added if necessary.

Many words or terms used in the NEI 99-01 emergency classification scheme have

scheme-specific definitions. These words and terms are identified by being set in all capital letters (i.e., ALL CAPS). The definitions are presented in Appendix B, Definitions.

Below are examples of acceptable modifications to the generic guidance. These may be incorporated depending upon site developer and user preferences.

- The ICs within a Recognition Category may be placed in reverse order for presentation purposes (e.g., start with a General Emergency at the left/top of a user aid, followed by Site Area Emergency, Alert and NOUE).
- The Initiating Condition numbering may be changed.
- The first letter of a Recognition Category designation may be changed, as follows, provided the change is carried through for all the associated IC identifiers.
 - R may be used in lieu of A
 - M may be used in lieu of S

For example, the Abnormal Radiation Levels / Radiological Effluent category designator “A” (for Abnormal) may be changed to “R” (for Radiation). This means that the associated ICs would be changed to RU1, RU2, RA1, etc.

- The ICs and EALs from Recognition Categories S and C may be incorporated into a common presentation method (e.g., one table) provided that all related notes and mode applicability requirements are maintained.
- The ICs and EALs for Shift Manager/Emergency Director judgment and security-related events may be placed under separate Recognition Categories.
- The terms EAL and threshold may be used interchangeably.

All instances of the EAL “OR” logic presented under an IC (e.g., EAL #1 OR EAL #2) should be maintained in presentation methods to users.

The material in the Developer Notes section is included to assist developers with crafting correct IC and EAL statements. This material is not required to be in the final emergency classification scheme basis document.

4.2 CRITICAL CHARACTERISTICS

As discussed above, developers are encouraged to keep their site-specific schemes as close to the generic guidance as possible. When crafting the scheme, developers should satisfy themselves that certain critical characteristics have been met. These critical characteristics are listed below.

- The ICs, EALs, Operating Mode Applicability criteria, Notes and Basis information are consistent with industry guidance; while the actual wording may be different, the classification intent is maintained. With respect to Recognition Category F, a site-specific scheme must include some type of user-aid to facilitate timely and accurate classification of fission product barrier losses and/or potential losses. The user-aid logic must be consistent with the classification logic presented in Section 9.

- The ICs, EALs, Operating Mode Applicability criteria, Notes and Basis information are technically complete and accurate (i.e., they contain the information necessary to make a correct classification).
- EAL statements use objective criteria and observable values.
- ICs, EALs, Operating Mode Applicability and Note statements and formatting consider human factors and are user-friendly.
- The scheme facilitates upgrading and downgrading of the emergency classification where necessary.
- The scheme facilitates classification of multiple concurrent events or conditions.

4.3 INSTRUMENTATION USED FOR EALS

EALs should make use of appropriate instrumentation described in the emergency plan sections that address 10 CFR 50.47(b)(8) and (9), and in Chapter 7 of the site FSAR (e.g., commitments related to Regulatory Guide 1.97). Instrumentation for an EAL:

- does not have to be safety-related,
- need not be addressed by a Technical Specification or an ODCM/RETS control requirement,
- does not require an emergency power source, and
- can be used when installed for other purposes (e.g., a radiation monitor).

Scheme developers should strive to incorporate instrumentation that is reliable and routinely maintained in accordance with site programs and procedures. Alarms referenced in EAL statements should be those that are the most operationally significant for the described event or condition. In addition, instrumentation and alarms should be reasonably accessible during an event or condition.

Typically, most or all instruments supporting an EAL scheme, including those related to radiation monitoring, are installed for reasons other than compliance with emergency preparedness requirements. As a result, EAL scheme developers need to be broadly aware of the calibration and maintenance requirements for these instruments. Developers should ensure that EAL-related instrumentation is subject to periodic calibration checks and the specified EAL threshold values are within the calibrated range. Any automatic instrumentation functions that may impact an accurate EAL assessment should be considered. In addition, EAL setpoint values should not use terms such as “off-scale low” or “off-scale high” since that type of reading may not be readily differentiated from an instrument failure. Findings and violations related to EAL instrumentation issues may be located on the NRC website.

Developers should pay particular attention to radiation monitoring instrumentation and the applicable guidance in Regulatory Guide 1.97. Controls should be in place to ensure that the monitors are calibrated correctly and used in a manner supported by the range of the instruments. In addition, dose assessment models use radiation monitoring instrumentation, effluent flow monitoring instrumentation, and meteorology instrumentation, and developers should be aware of the potential impact that instrumentation issues could have on the overall effectiveness of dose assessments.

Many EALs incorporate instrumentation through reference rather than having the instrumentation specifically stated; the expectations provided above also apply to instrumentation incorporated by reference. Examples of referenced instrumentation are:

- Max safe/max normal indications
- Instrumentation assessed in EOP steps where the steps also support evaluation of EALs
- Indications related to offsite dose assessments
- Instrumentation used in decision-making criteria and tools adopted from generic BWROG and PWROG guidance that also support evaluation of EALs (e.g., Critical Safety Function Status Trees)

EALs may specify instrumentation with readout locations outside the main Control Room, if doing so is advantageous to the entire emergency classification scheme. The remote instrumentation must be able to support an EAL assessment and emergency declaration within 15 minutes of the initiating event. Instrumentation that could be used for an EAL assessment but requires additional time (i.e., beyond 15 minutes) for obtaining a reading may be proposed and the NRC will review for acceptability. If this type of instrument is included in an EAL, the Basis section should identify the anticipated elapsed time required to obtain a reading. In some cases, the advantages of using this instrumentation outweigh the timing considerations as long as the timing impact is known and documented.

4.4 PRESENTATION OF SCHEME INFORMATION TO USERS

The U.S. Nuclear Regulatory Commission (NRC) expects licensees to establish and maintain the capability to assess, classify and declare an emergency condition promptly within 15 minutes after the availability of indications to plant operators that an emergency action level has been, or may be, exceeded. When writing an emergency classification procedure and creating related user aids, the developer must determine the presentation method(s) that best supports the end users by facilitating accurate and timely emergency classification. To this end, developers should consider the following points.

- The first users of an emergency classification procedure are the operators in the Control Room. During the allowable classification time period, they may have responsibility for other critical tasks, and will likely have minimal assistance in making a classification assessment.
- As an emergency evolves, members of the Control Room staff are likely to be the first personnel to notice a change in plant conditions. They can assess the changed conditions and, when warranted, recommend a different emergency classification level to the Technical Support Center (TSC) and/or Emergency Operations Facility (EOF).
- Emergency Directors in the TSC and/or EOF will have more opportunity to focus on making an emergency classification and will probably have advisors from Operations available to help them.

Emergency classification scheme information for end users should be presented in a manner with which licensed operators are most comfortable. Developers will need to work closely with representatives from the Operations and Operations Training

Departments to develop readily usable and easily understood classification tools (e.g., a procedure and related user aids). If necessary, an alternate method for presenting emergency classification scheme information may be developed for use by Emergency Directors and/or Offsite Response Organization personnel.

A wallboard is an acceptable presentation method provided that it contains all the information necessary to make a correct emergency classification. This information includes the ICs, Operating Mode criteria, EALs and Notes. Notes may be kept with each applicable EAL or moved to a common area and referenced; a reference to a Note is acceptable as long as the information is adequately captured on the wallboard and pointed to by each applicable EAL.³ Basis information need not be included on a wallboard but it should be readily available to emergency classification decision-makers.

In some cases, it may be advantageous to develop two wallboards - one for use during power operations, startup and hot conditions, and another for cold shutdown and refueling conditions.

Alternative presentation methods for the Recognition Category F ICs and fission product barrier thresholds are acceptable and include flow charts, block diagrams, and checklist-type tables. Developers must ensure that the site-specific method addresses all possible threshold combinations and classification outcomes shown in the BWR or PWR EAL fission product barrier tables. The NRC staff considers the presentation method of the Recognition Category F information to be an important user aid and may request a change to a particular proposed method if, among other reasons, the change is necessary to promote consistency across the industry.

4.5 INTEGRATION OF ICs/EALS WITH PLANT PROCEDURES

A rigorous integration of IC and EAL references into plant operating procedures is not recommended. This approach would greatly increase the administrative controls and workload for maintaining procedures. On the other hand, performance challenges may occur if recognition of meeting an IC or EAL is based solely on the memory of a licensed operator or an Emergency Director, especially during periods of high stress.

Developers should consider placing appropriate visual cues (e.g., a step, note, caution, etc.) in plant procedures alerting the reader/user to consult the site emergency classification procedure. Visual cues could be placed in emergency operating procedures, abnormal operating procedures, alarm response procedures, and normal operating procedures that apply to cold shutdown and refueling modes. As an example, a step, note or caution could be placed at the beginning of an RCS leak abnormal operating procedure that reminds the reader that an emergency classification assessment should be performed.

³ Where appropriate, the Notes shown in the generic guidance typically include the event/condition ECL and the duration time specified in the EAL. If developers prefer to have several ICs reference a common NOTE on a wallboard display, it is acceptable to remove the ECL and time criterion and use a generic statement. For example, a common NOTE could read "The Emergency Director should declare the emergency promptly upon determining that the applicable EAL time has been exceeded or will likely be exceeded."

4.6 BASIS DOCUMENT

A basis document is an integral part of an emergency classification scheme. The material in this document supports proper emergency classification decision-making by providing informing background and development information in a readily accessible format. It can be referred to in training situations and when making an actual emergency classification, if necessary. The document is also useful for establishing configuration management controls for EP-related equipment and explaining an emergency classification to offsite authorities. The content of the basis document should include, at a minimum, the following:

- A site-specific Mode Applicability Matrix and description of operating modes, similar to that presented in section 3.5.
- A discussion of the emergency classification and declaration process reflecting the material presented in Section 5. This material may be edited as needed to align with site-specific emergency plan and implementing procedure requirements.
- Each Initiating Condition along with the associated EALs or fission product barrier thresholds, Operating Mode Applicability, Notes and Basis information.
- A listing of acronyms and defined terms, similar to that presented in Appendices A and B, respectively. This material may be edited as needed to align with site-specific characteristics.
- Any site-specific background or technical appendices that the developers believe would be useful in explaining or using elements of the emergency classification scheme.

A Basis section should not contain information that could modify the meaning or intent of the associated IC or EAL. Such information should be incorporated within the IC or EAL statements, or as an EAL Note. Information in the Basis should only clarify and inform decision-making for an emergency classification.

Basis information should be readily available to be referenced, if necessary, by the Shift Manager/Emergency Director. For example, a copy of the basis document could be maintained in the appropriate emergency response facilities.

Because the information in a basis document can affect emergency classification decision-making (e.g., the Emergency Director refers to it during an event), the NRC staff expects that changes to the basis document will be evaluated in accordance with the provisions of 10 CFR 50.54(q).

4.7 EAL/THRESHOLD REFERENCES TO AOP AND EOP SETPOINTS/CRITERIA

As reflected in the generic guidance, the criteria/values used in several EALs and fission product barrier thresholds may be drawn from a plant's AOPs and EOPs. This approach is intended to maintain good alignment between operational diagnoses and emergency classification assessments. Developers should verify that appropriate administrative controls are in place to ensure that a subsequent change to an AOP or EOP is screened to determine if an evaluation pursuant to 10 CFR 50.54(q) is required.

4.8 DEVELOPER AND USER FEEDBACK

Questions or comments concerning the material in this document may be directed to the NEI Emergency Preparedness staff, NEI EAL task force members or submitted to the Emergency Preparedness Frequently Asked Questions process.

5 GUIDANCE ON MAKING EMERGENCY CLASSIFICATIONS

5.1 GENERAL CONSIDERATIONS

When making an emergency classification, the Shift Manager/Emergency Director must consider all information having a bearing on the assessment of an Initiating Condition (IC). This includes the Emergency Action Level (EAL) plus the associated Operating Mode Applicability, Notes and Basis information. In the Recognition Category F matrices, EALs are referred to as Fission Product Barrier Thresholds; the thresholds serve the same function as an EAL.

NRC regulations require the licensee to establish and maintain the capability to assess, classify, and declare an emergency condition within 15 minutes after the availability of indications to plant operators that an emergency action level has been exceeded and to promptly declare the emergency condition as soon as possible following identification of the appropriate emergency classification level.⁴ As used here, a “plant operator” is any member of the plant staff who, by virtue of training and experience, is qualified to assess indications for validity and to compare the same to the EALs in the licensee’s emergency classification scheme (i.e., an individual qualified to make an emergency classification). For ICs and EALs that have a stipulated time duration (e.g., 15 minutes, 30 minutes, etc.), the Shift Manager/Emergency Director should not wait until the applicable time has elapsed but should declare the event as soon as it is determined that the condition has exceeded, or will likely exceed, the applicable time. When an EAL specifies a duration for an off-normal condition (e.g., some condition must exist for 15 minutes), the emergency declaration “clock” runs concurrently with the duration “clock” specified in the EAL. Once the off-normal condition has existed for the duration specified in the EAL, no further assessment of the EAL is necessary - the EAL has been exceeded and the emergency declaration should be made promptly.

All emergency classification assessments should be based upon valid indications, reports or conditions. A valid indication, report, or condition is one that has been verified through appropriate means such that there is no doubt regarding the indicator’s operability, the condition’s existence, or the report’s accuracy. For example, validation could be accomplished through an instrument channel check, response on related or redundant indicators, or direct observation by plant personnel. The validation of indications should be completed in a manner that supports timely emergency declaration.

A planned work activity that results in an expected event or condition which meets or exceeds an EAL does not warrant an emergency declaration provided that 1) the activity proceeds as planned and 2) the plant remains within the limits imposed by the operating license. Such activities include planned work to test, manipulate, repair, maintain or modify a system or component. In these cases, the controls associated with the planning, preparation and execution of the work will ensure that compliance is maintained with all aspects of the operating license provided that the activity proceeds and concludes as

⁴ For decommissioning facilities that have transitioned to the Permanently Defueled or ISFSI-Only level, emergency classification must be performed in accordance with applicable regulations and NRC-approved site-specific exemptions.

expected. Events or conditions of this type may be subject to the reporting requirements of 10 CFR 50.72.

The assessment of some EALs is based on the results of analyses that are necessary to ascertain whether a specific EAL threshold has been exceeded (e.g., dose assessments, chemistry sampling, RCS leak rate calculation, etc.); the EAL and/or the associated basis discussion will identify the necessary analysis. In these cases, the 15-minute declaration period starts with the availability of the analysis results that show the threshold to be exceeded (i.e., this is the time that the EAL information is first available). The NRC expects licensees to establish the capability to initiate and complete EAL-related analyses within a reasonable period of time (e.g., maintain the necessary expertise on-shift).

While the EALs have been developed to address a full spectrum of possible events and conditions which may warrant emergency classification, a provision for classification based on operator/management experience and judgment is still necessary. The NEI 99-01 scheme provides the Shift Manager/Emergency Director with the ability to classify events and conditions based upon judgment using EALs that are consistent with the Emergency Classification Level (ECL) definitions (refer to Category H). The Shift Manager/Emergency Director will need to determine if the effects or consequences of the event or condition reasonably meet or exceed a particular ECL definition. A similar provision is incorporated into the Fission Product Barrier Tables, i.e., judgment may be used to determine the status of a fission product barrier.

5.2 CLASSIFICATION METHODOLOGY

To make an emergency classification, the user will compare an event or condition (i.e., the relevant plant indications and reports) to an EAL(s) and determine if the EAL has been met or exceeded. The evaluation of an EAL(s) must be consistent with the related Operating Mode Applicability and Notes. If an EAL has been met or exceeded, then the IC is considered met and the associated ECL is declared in accordance with plant procedures.

5.3 CLASSIFICATION OF MULTIPLE EVENTS AND CONDITIONS

When multiple emergency events or conditions are present, the user will identify highest met or exceeded EAL and declare the appropriate ECL. For example:

- If an Alert EAL and a Site Area Emergency EAL are met, whether at one unit or at two different units, a Site Area Emergency should be declared.

There is no “additive” effect from multiple EALs meeting the same ECL. For example:

- If two Alert EALs are met, whether at one unit or at two different units, an Alert should be declared.

Related guidance concerning the classification of rapidly escalating events or conditions is provided in Regulatory Issue Summary (RIS) 2007-02, *Clarification of NRC Guidance for Emergency Notifications During Quickly Changing Events*.

5.4 CONSIDERATION OF MODE CHANGES DURING CLASSIFICATION

The mode in effect at the time that an event or condition occurred, and prior to any plant or operator response, is the mode that determines whether an IC is applicable. If an event or condition occurs, and results in a mode change before the emergency is declared, the emergency classification level is still based on the mode that existed at the time that the event or condition was initiated (and not when it was declared). Once the initial emergency declaration is made and a different mode is reached:

- The initial/original event or condition continues to be evaluated against the ICs applicable to mode in effect at the time that the event or condition occurred, and
- Any new event or condition, not related to the initial/original event or condition, is evaluated against the ICs applicable to the mode in effect at the time of the new event or condition.

For an emergency that occurs in Cold Shutdown or Refueling, escalation of the ECL for the initial/original event or condition is via ICs applicable in the Cold Shutdown or Refueling modes, even if Hot Shutdown (or a higher mode) is entered during a subsequent plant heatup. If Hot Shutdown (or a higher mode) is entered, then any new event or condition would be assessed against the ICs applicable to the mode in effect at the time of occurrence. In particular, the fission product barrier EALs are applicable only to events or conditions initiated in the Hot Shutdown mode or higher.

5.5 EMERGENCY CLASSIFICATION LEVEL DOWNGRADING AND TERMINATION

An ECL may be downgraded when the event or condition that meets the highest IC and EAL no longer exists, and other site-specific downgrading requirements are met. If downgrading the ECL is deemed appropriate, the new ECL would then be based on a lower applicable IC(s) and EAL(s). The ECL may also simply be terminated, including through entry into recovery. Scheme developers should ensure that site emergency plan implementing procedures contain adequate guidance for controlling the downgrading and termination of emergencies.

5.6 CLASSIFICATION OF TRANSIENT CONDITIONS

Many of the ICs and/or EALs contained in this document employ time-based criteria. These criteria will require that the IC/EAL conditions be present for a defined period of time before an emergency declaration is warranted. In cases where no time-based criterion is specified, it is recognized that some transient conditions may cause an EAL to be met for a brief period (e.g., a few seconds to a few minutes). The following guidance should be applied to the classification of these conditions.

EAL momentarily met during expected plant response - In instances where an EAL is briefly met during an expected (normal) plant response, such as momentarily exceeding the criteria for a challenge to a critical safety function as valves or dampers change position, an emergency declaration is not warranted provided that associated systems and components are operating as expected, and operator actions are performed in accordance with procedures.

EAL momentarily met but the condition is corrected prior to an emergency declaration – If an operator takes prompt manual action to address a condition, and the action is successful in correcting the condition prior to the emergency declaration, then the applicable EAL is not considered met and the associated emergency declaration for the condition is not required. However, an emergency declaration may still be warranted for a concurrent event or condition. Consider the following example:

At a PWR, a plant trip occurs and the auxiliary/emergency feedwater system fails to automatically start. Steam generator levels rapidly decrease and the plant enters an inadequate RCS heat removal condition – this is an Alert condition per the PWR Fission Product Barrier Table (a potential loss of the RCS barrier). If an operator manually starts the auxiliary/emergency feedwater system in accordance with an EOP step and clears the inadequate RCS heat removal condition prior to an emergency declaration, then the classification should be based on any other events or conditions that meet an EAL.

It is important to stress that the 15-minute emergency classification assessment period is not a “grace period” during which a classification may be delayed to allow the performance of a corrective action that would obviate the need to classify the event; emergency classification assessments must be deliberate and timely, with no undue delays. The provision discussed above addresses only those rapidly evolving situations where an operator can take a successful corrective action prior to the Shift Manager/Emergency Director completing the review and steps necessary to make the emergency declaration. This provision is included to ensure that any public protective actions resulting from the emergency classification are truly warranted by the plant conditions.

5.7 AFTER-THE-FACT DISCOVERY OF AN EMERGENCY EVENT OR CONDITION

In some cases, an EAL may be met but the emergency classification was not made at the time of the event or condition. This situation can occur when personnel discover that an event or condition existed which met an EAL, but no emergency was declared, and the event or condition no longer exists at the time of discovery. This may be due to the event or condition not being recognized at the time or an error that was made in the emergency classification process.

In these cases, no emergency declaration is warranted; however, the guidance contained in NUREG-1022 is applicable. Specifically, the event should be reported to the NRC in accordance with 10 CFR 50.72 within one hour of the discovery of the undeclared event or condition. The licensee should also notify appropriate State and local agencies in accordance with the agreed upon arrangements.

5.8 RETRACTION OF THE NOTIFICATION OF AN EMERGENCY DECLARATION

In some cases, a licensee may choose to retract the event notification of a declared emergency per the guidance in NUREG-1022; however, the response associated with emergency declaration remain inspectable. In addition, the Drill/Exercise Performance (DEP) opportunities from the event are counted towards the site’s DEP indicator. The success or failure of the opportunities (e.g., emergency classification and notifications)

should be determined by evaluating the information available to the plant operator at the time of the event. Even though it may provide a basis for retracting the event notification of the emergency declaration, information learned after the event has no relevance to the assessment of the opportunities.

6 ABNORMAL RAD LEVELS / RADIOLOGICAL EFFLUENT ICS/EALS

Table A-1: Recognition Category “A” Initiating Condition Matrix

UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
	AA1 Release of gaseous radioactivity resulting in offsite dose greater than 10 mrem TEDE or 50 mrem thyroid CDE. <i>Op. Modes: All</i>	AS1 Release of gaseous radioactivity resulting in offsite dose greater than 100 mrem TEDE or 500 mrem thyroid CDE. <i>Op. Modes: All</i>	AG1 Release of gaseous radioactivity resulting in offsite dose greater than 1,000 mrem TEDE or 5,000 mrem thyroid CDE. <i>Op. Modes: All</i>
AU2 UNPLANNED loss of water level above irradiated fuel. <i>Op. Modes: All</i>	AA2 Significant lowering of water level above, or damage to, irradiated fuel. <i>Op. Modes: All</i>	AS2 Spent fuel pool level at (site-specific Level 3 description). <i>Op. Modes: All</i>	AG2 Spent fuel pool level cannot be restored to at least (site-specific Level 3 description) for 60 minutes or longer. <i>Op. Modes: All</i>
AU3 Radiation levels that impede access to equipment necessary for normal plant operations, cooldown or shutdown. <i>Op. Modes: All</i>			

Table intended for use by
EAL developers.
Inclusion in licensee
documents is not required.

AU2

ECL: Notification of Unusual Event

Initiating Condition: UNPLANNED loss of water level above irradiated fuel.

Operating Mode Applicability: All

Example Emergency Action Level:

- (1) a. UNPLANNED water level drop in the REFUELING PATHWAY as indicated by ANY of the following:

(site-specific level indications).

AND

- b. UNPLANNED rise in area radiation levels as indicated by ANY of the following radiation monitors.

(site-specific list of area radiation monitors)

Basis:

This IC addresses a decrease in water level above irradiated fuel sufficient to cause elevated radiation levels. This condition could be a precursor to a more serious event and is also indicative of a minor loss in the ability to control radiation levels within the plant. It is therefore a potential degradation in the level of safety of the plant.

A water level decrease will be primarily determined by indications from available level instrumentation. Other sources of level indications may include reports from plant personnel (e.g., from a refueling crew) or video camera observations (if available). A significant drop in the water level may also cause an increase in the radiation levels of adjacent areas that can be detected by monitors in those locations.

The effects of planned evolutions should be considered. For example, a refueling bridge area radiation monitor reading may increase due to planned evolutions such as lifting of the reactor vessel head or movement of a fuel assembly. Note that this EAL is applicable only in cases where the elevated reading is due to an UNPLANNED loss of water level.

A drop in water level above irradiated fuel within the reactor vessel may be classified in accordance Recognition Category C during the Cold Shutdown and Refueling modes.

Escalation of the emergency classification level would be via IC AA2.

Developer Notes:

The “site-specific level indications” are those indications that may be used to monitor water level in the various portions of the REFUELING PATHWAY. Specify the mode applicability of a particular indication if it is not available in all modes.

The “site-specific list of area radiation monitors” should contain those area radiation monitors that would be expected to have increased readings following a decrease in water level in the site-specific REFUELING PATHWAY. In cases where a radiation monitor(s) is not available or would not provide a useful indication, consideration should be given to including alternate indications such as UNPLANNED changes in tank and/or sump levels.

Development of the EALs should consider the availability and limitations of mode-dependent, or other controlled but temporary, radiation monitors. Specify the mode applicability of a particular monitor if it is not available in all modes.

AU3

ECL: Notification of Unusual Event

Initiating Condition: Radiation levels that impede access to equipment necessary for normal plant operations, cooldown or shutdown.

Operating Mode Applicability: All

Example Emergency Action Levels: (1 or 2)

Notes:

- A dose rate reading may be obtained from a permanently installed or temporary instrument, or a survey.
- If the equipment in the listed room or area was already inoperable or out-of-service before the event occurred, then no emergency classification is warranted.

(1) Dose rate greater than 15 mR/hr in **ANY** of the following areas:

- Control Room
- Central Alarm Station
- (Other site-specific areas/rooms)

(2) An UNPLANNED event results in radiation levels that prohibit or impede access to any of the following plant rooms or areas:

(site-specific list of plant rooms or areas with entry-related mode applicability identified)

Basis:

This IC addresses elevated radiation levels in certain plant rooms/areas sufficient to preclude or impede personnel from performing actions necessary to maintain normal plant operation, or to perform a normal plant cooldown and shutdown. As such, it represents a potential degradation in the level of safety of the plant. The Shift Manager/Emergency Director should consider the cause of the increased radiation levels and determine if another IC may be applicable.

For EAL #2, an Alert declaration is warranted if entry into the affected room/area is, or may be, procedurally required during the plant operating mode in effect at the time of the elevated radiation levels. The emergency classification is not contingent upon whether entry is actually necessary at the time of the increased radiation levels. Access should be considered as impeded if extraordinary measures are necessary to facilitate entry of personnel into the affected room/area (e.g., installing temporary shielding, requiring use of non-routine protective equipment, requesting an extension in dose limits beyond normal administrative limits).

An emergency declaration is not warranted if any of the following conditions apply.

- The plant is in an operating mode different than the mode specified for the affected room/area (i.e., entry is not required during the operating mode in effect at the time of the elevated radiation levels). For example, the plant is in Mode 1 when the radiation increase

occurs, and the procedures used for normal operation, cooldown and shutdown do not require entry into the affected room until Mode 4.

- The increased radiation levels are a result of a planned activity that includes compensatory measures which address the temporary inaccessibility of a room or area (e.g., radiography, spent filter or resin transfer, etc.).
- The action for which room/area entry is required is of an administrative or record keeping nature (e.g., normal rounds or routine inspections).
- The access control measures are of a conservative or precautionary nature and would not actually prevent or impede a required action.

Depending on the nature of the event, escalation of the emergency classification level would be via an IC in Recognition Category A, C, F or S.

Developer Notes:

EAL #1

The value of 15mR/hr is derived from the GDC 19 value of 5 rem in 30 days with adjustment for expected occupancy times.

The “other site-specific areas/rooms” should include any areas or rooms requiring continuous occupancy to maintain normal plant operation, or to perform a normal cooldown and shutdown.

EAL #2

The “site-specific list of plant rooms or areas with entry-related mode applicability identified” should specify those rooms or areas that contain equipment which require a manual/local action as specified in operating procedures used for normal plant operation, cooldown and shutdown. Do not include rooms or areas in which actions of a contingent or emergency nature would be performed. (e.g., an action to address an off-normal or emergency condition such as emergency repairs, corrective measures or emergency operations). In addition, the list should specify the plant mode(s) during which entry would be required for each room or area.

The list should not include rooms or areas for which entry is required solely to perform actions of an administrative or record keeping nature (e.g., normal rounds or routine inspections).

If the equipment in the listed room or area was already inoperable, or out-of-service, before the event occurred, then no emergency should be declared since the event will have no adverse impact beyond that already allowed by Technical Specifications at the time of the event.

Rooms and areas listed in EAL #1 do not need to be included in EAL #2, including the Control Room

AA1

ECL: Alert

Initiating Condition: Release of gaseous radioactivity resulting in offsite dose greater than 10 mrem TEDE or 50 mrem thyroid CDE.

Operating Mode Applicability: All

Example Emergency Action Levels: (1 or 2)

Notes:

- The Shift/Manager/Emergency Director should declare the Alert promptly upon determining that the applicable time has been exceeded or will likely be exceeded.
 - If an ongoing release is detected and the release start time is unknown, assume that the release duration has exceeded 15 minutes.
 - Emergency classification based on dose projections assumes there is a release path to the environment. If the flow past an effluent monitor used in a dose projection is known to have stopped due to actions to isolate the release path, then the effluent monitor reading is no longer valid for classification purposes.
- (1) Dose assessment using actual meteorology indicates doses greater than 10 mrem TEDE or 50 mrem thyroid CDE at or beyond (site-specific dose receptor point).
- (2) Field survey results indicate **EITHER** of the following at or beyond (site-specific dose receptor point):
- Closed window dose rates greater than 10 mR/hr are expected to continue for 60 minutes or longer.
 - Analyses of field survey samples indicate thyroid CDE greater than 50 mrem for one hour of inhalation.

Basis:

This IC addresses a release of gaseous radioactivity that results in projected or actual offsite doses greater than 1% of the EPA PAGs. It includes both monitored and un-monitored releases. Releases of this magnitude represent an actual or potential substantial degradation of the level of safety of the plant as indicated by a radiological release that significantly exceeds regulatory limits (e.g., a significant uncontrolled release).

Radiological effluent EALs are included in a scheme to provide a basis for classifying events and conditions that cannot be readily or appropriately classified on the basis of plant conditions alone. The inclusion of both plant condition and radiological effluent EALs more fully addresses the spectrum of possible accident events and conditions.

The TEDE dose is set at 1% of the EPA PAG of 1,000 mrem while the 50 mrem thyroid CDE was established in consideration of the 1:5 ratio of the EPA PAG for TEDE and thyroid CDE.

Emergency classification based on dose projections assumes there is a release path to the environment. If the flow past an effluent monitor used in a dose projection is known to have stopped due to actions to isolate the release path, then the effluent monitor reading is no longer valid for classification purposes.

Escalation of the emergency classification level would be via IC AS1.

Developer Notes:

While this IC may not be met absent challenges to one or more fission product barriers, it provides classification diversity and may be used to classify events that would not reach the same ECL based on plant status or the fission product matrix alone. For many of the DBAs analyzed in the Updated Final Safety Analysis Report, the discriminator will not be the number of fission product barriers challenged, but rather the amount of radioactivity released to the environment.

It is important for developers to verify that the emergency response facilities responsible for performing dose projections, including the Control Room, have a reliable dose assessment capability. This means there is reasonable assurance that the facility staff can perform a dose projection if the primary method is unavailable. Examples of an acceptable backup method include the capability to perform a dose projection on a different platform (e.g., a backup computer) or through a manual calculation. A description of the backup method(s) should be included in the EAL justification submitted to the NRC for approval. Absent an acceptable backup method, the NRC may request that an EAL based on calculated effluent radiation monitor readings be added to this IC. Should that be necessary, the guidance in Appendix C, “Guidance for Radiation Effluent Monitor EALS,” should be followed.

The EPA PAGs are expressed in terms of the sum of the effective dose equivalent (EDE) and the committed effective dose equivalent (CEDE), or as the thyroid committed dose equivalent (CDE). For the purpose of these IC/EALs, the dose quantity total effective dose equivalent (TEDE), as defined in 10 CFR 20, is used in lieu of “...sum of EDE and CEDE....”.

The EPA PAG guidance provides for the use of adult thyroid dose conversion factors; however, some states have decided to base protective actions on child thyroid CDE. Nuclear power plant ICs/EALs need to be consistent with the protective action methodologies employed by the States within their EPZs. The thyroid CDE dose used in the IC and EALs should be adjusted as necessary to align with State protective action decision-making criteria.

An ORO may elect to adopt the guidance in the 2017 EPA PAG Manual (EPA-400/R-17/001, *PAG Manual: Protective Action Guides and Planning Guidance for Radiological Incidents*); however, the NRC does not require licensees to adopt this guidance in their site emergency plan. If the licensee chooses not to adopt this guidance, then the licensee and OROs should coordinate to understand what differences may result in dose projections and PARs, and how to manage those differences to ensure an appropriate emergency response. Understanding any differences in advance may avoid delays in communicating and implementing protective actions. For additional information, developers should refer to Emergency Preparedness Frequently Asked Question (EPFAQ) 2017-001, *Clarification of Implementation of the revised EPA Protective Action Guide regarding revisions to EALs*. The ADAMS Accession Number for this document is ML17199F736.

The “site-specific dose receptor point” is the distance(s) and/or locations used by the licensee to distinguish between onsite and offsite doses. The selected distance(s) and/or locations should reflect the content of the emergency plan, and the procedural methodology used to determine offsite doses and Protective Action Recommendations. The variation in selected dose receptor points means there may be some differences in the distance from the release point to the calculated dose point from site-to-site.

Although the IC references TEDE, field survey results are generally available only as a “whole body” dose rate. For this reason, the field survey EAL specifies a “closed window” survey reading.

Indications from a real-time dose projection system are not included in the generic EALs. Many licensees do not have this capability. For those that do, the capability may not be within the scope of the plant Technical Specifications. A licensee may request to include an EAL using real-time dose projection system results; approval will be considered on a case-by-case basis.

Indications from a perimeter monitoring system are not included in the generic EALs. Many licensees do not have this capability. For those that do, these monitors may not be controlled and maintained to the same level as plant equipment, or within the scope of the plant Technical Specifications. In addition, readings may be influenced by environmental or other factors. A licensee may request to include an EAL using a perimeter monitoring system; approval will be considered on a case-by-case basis.

AA2

ECL: Alert

Initiating Condition: Significant lowering of water level above, or damage to, irradiated fuel.

Operating Mode Applicability: All

Example Emergency Action Levels: (1 or 2 or 3)

- (1) Uncovery of irradiated fuel in the REFUELING PATHWAY.
- (2) Damage to irradiated fuel resulting in a release of radioactivity from the fuel as indicated by **ANY** of the following radiation monitors:

(site-specific listing of radiation monitors, and the associated readings, setpoints and/or alarms)
- (3) Lowering of spent fuel pool level to (site-specific Level 2 value).

Basis:

This IC addresses events leading to potential or actual damage to an irradiated fuel assembly, *or a significant lowering of water level within the spent fuel pool (see Developer Notes)*. These events present radiological safety challenges to plant personnel and are precursors to a release of radioactivity to the environment. As such, they represent an actual or potential substantial degradation of the level of safety of the plant.

This IC applies to irradiated fuel that is licensed for dry storage up to the point that the loaded storage cask is sealed. Once sealed, damage to a loaded cask is assessed using IC E-HU1.

EAL #1

This EAL escalates from AU2 in that the loss of level, in the affected portion of the REFUELING PATHWAY, is of sufficient magnitude to have resulted in potential or actual uncovery of irradiated fuel. Indications of irradiated fuel uncovery may include direct or indirect visual observation (e.g., reports from personnel or camera images), as well as significant changes in water and radiation levels, or other plant parameters. Computational aids may also be used (e.g., a boil-off curve). Classification of an event using this EAL should be based on the totality of available indications, reports and observations.

While an area radiation monitor could detect an increase in a dose rate due to a lowering of water level in some portion of the REFUELING PATHWAY, the reading may not be a reliable indication of whether or not the fuel is actually uncovered. To the degree possible, readings should be considered in combination with other available indications of inventory loss.

A drop in water level above irradiated fuel within the reactor vessel may be classified in accordance Recognition Category C during the Cold Shutdown and Refueling modes.

EAL #2

This EAL addresses a release of radioactive material caused by mechanical damage to irradiated fuel. Damaging events may include the dropping, bumping or binding of an assembly, or dropping a heavy load onto an assembly. A rise in readings on radiation monitors should be considered in conjunction with in-plant reports or observations of a potential fuel damaging event (e.g., a fuel handling accident).

EAL #3

Spent fuel pool water level at this value is within the lower end of the level range necessary to prevent significant dose consequences from direct gamma radiation to personnel performing operations in the vicinity of the spent fuel pool. This condition reflects a significant loss of spent fuel pool water inventory and thus it is also a precursor to a loss of the ability to adequately cool the irradiated fuel assemblies stored in the pool.

Escalation of the emergency classification level would be via ICs AS1 or AS2, or CS1.

Developer Notes:

For EAL #1

Depending upon the availability and range of instrumentation, this EAL may include specific readings indicative of uncover of a fuel assembly at known locations within the REFUELING PATHWAY (e.g., a fuel assembly at the upper limit of the fuel handling mast); consider both water and radiation level readings. Specify the mode applicability of a particular indication if it is not available in all modes. Other sources for determining uncover of irradiated fuel, such as remote cameras, may also be included.

For EAL #2

The “site-specific listing of radiation monitors, and the associated readings, setpoints and/or alarms” should contain those radiation monitors that could be used to identify damage to an irradiated fuel assembly (e.g., confirmatory of a release of fission product gases from irradiated fuel).

For EALs #1 and #2

Developers should research radiation monitor design documents or other information sources to ensure that 1) the EAL value being considered is within the usable response and display range of the instrument, and 2) there are no automatic features that may render the monitor reading invalid (e.g., an auto-purge feature triggered at a particular indication level).

It is recognized that the condition described by this IC may result in a radiation value beyond the operating or display range of the installed radiation monitor. In those cases, EAL values should be determined with a margin sufficient to ensure that an accurate monitor reading is available. For example, an EAL monitor reading might be set at 90% to 95% of the highest accurate monitor reading. This provision notwithstanding, if the estimated/calculated monitor reading is greater than approximately 110% of the highest accurate monitor reading, then developers may choose not to include the monitor as an indication and identify an alternate EAL threshold.

To further promote accurate classification, developers should consider if some combination of monitors could be specified in the EAL to build-in an appropriate level of corroboration between monitor readings into the classification assessment.

Development of the EALs should also consider the availability and limitations of mode-dependent, or other controlled but temporary, radiation monitors. Specify the mode applicability of a particular monitor if it is not available in all modes.

For EAL #3

The “site-specific Level 2 value” is usually the spent fuel pool level that is adequate to provide substantial radiation shielding for a person standing on the spent fuel pool operating deck. This site-specific level is determined in accordance with the requirements of 10 CFR 50.155 and the guidance in NEI 12-02, *Industry Guidance for Compliance with NRC Order EA-12-051, “To Modify Licenses with Regard to Reliable Spent Fuel Pool Instrumentation.”*

It is recognized that a plant may have a wide-range spent fuel pool level monitoring system that requires manual actions to place in service and/or have an indication readout location outside the Control Room (e.g., in the spent fuel storage building). While such a design may not support immediate and/or continuous level readouts in the Control Room, the instrumentation should be specified anyway as it provides some level of backup to the classification of emergency conditions affecting the spent fuel pool (albeit later than other EALs). The basis section should identify the design or operation features that affect EAL assessments (e.g., key actions required to place the instrumentation in service), including the anticipated time required for operators in the Control Room to obtain an instrument reading. Additional guidance on the use of plant instrumentation in EALs is found in Section 4.3 of this document.

AS1

ECL: Site Area Emergency

Initiating Condition: Release of gaseous radioactivity resulting in offsite dose greater than 100 mrem TEDE or 500 mrem thyroid CDE.

Operating Mode Applicability: All

Example Emergency Action Levels: (1 or 2)

Notes:

- The Shift Manager/Emergency Director should declare the Site Area Emergency promptly upon determining that the applicable time has been exceeded or will likely be exceeded.
 - If an ongoing release is detected and the release start time is unknown, assume that the release duration has exceeded 15 minutes.
 - Emergency classification based on dose projections assumes there is a release path to the environment. If the flow past an effluent monitor used in a dose projection is known to have stopped due to actions to isolate the release path, then the effluent monitor reading is no longer valid for classification purposes.
- (1) Dose assessment using actual meteorology indicates doses greater than 100 mrem TEDE or 500 mrem thyroid CDE at or beyond (site-specific dose receptor point).
- (2) Field survey results indicate **EITHER** of the following at or beyond (site-specific dose receptor point):
- Closed window dose rates greater than 100 mR/hr are expected to continue for 60 minutes or longer.
 - Analyses of field survey samples indicate thyroid CDE greater than 500 mrem for one hour of inhalation.

Basis:

This IC addresses a release of gaseous radioactivity that results in projected or actual offsite doses greater than 10% of the EPA PAGs. It includes both monitored and un-monitored releases. Releases of this magnitude are associated with the failure of plant systems needed for the protection of the public.

Radiological effluent EALs are included in a scheme to provide a basis for classifying events and conditions that cannot be readily or appropriately classified on the basis of plant conditions alone. The inclusion of both plant condition and radiological effluent EALs more fully addresses the spectrum of possible accident events and conditions.

The TEDE dose is set at 10% of the EPA PAG of 1,000 mrem while the 500 mrem thyroid CDE was established in consideration of the 1:5 ratio of the EPA PAG for TEDE and thyroid CDE.

Emergency classification based on dose projections assumes there is a release path to the environment. If the flow past an effluent monitor used in a dose projection is known to have

stopped due to actions to isolate the release path, then the effluent monitor reading is no longer valid for classification purposes.

Escalation of the emergency classification level would be via IC AG1.

Developer Notes:

While this IC may not be met absent challenges to multiple fission product barriers, it provides classification diversity and may be used to classify events that would not reach the same ECL based on plant status or the fission product matrix alone. For many of the DBAs analyzed in the Updated Final Safety Analysis Report, the discriminator will not be the number of fission product barriers challenged, but rather the amount of radioactivity released to the environment.

It is important for developers to verify that the emergency response facilities responsible for performing dose projections, including the Control Room, have a reliable dose assessment capability. This means there is reasonable assurance that the facility staff can perform a dose projection if the primary method is unavailable. Examples of an acceptable backup method include the capability to perform a dose projection on a different platform (e.g., a backup computer) or through a manual calculation. A description of the backup method(s) should be included in the EAL justification submitted to the NRC for approval. Absent an acceptable backup method, the NRC may request that an EAL based on calculated effluent radiation monitor readings be added to this IC. Should that be necessary, the guidance in Appendix C, “Guidance for Radiation Effluent Monitor EALS,” should be followed.

The EPA PAGs are expressed in terms of the sum of the effective dose equivalent (EDE) and the committed effective dose equivalent (CEDE), or as the thyroid committed dose equivalent (CDE). For the purpose of these IC/EALs, the dose quantity total effective dose equivalent (TEDE), as defined in 10 CFR 20, is used in lieu of “...sum of EDE and CEDE....”.

The EPA PAG guidance provides for the use of adult thyroid dose conversion factors; however, some states have decided to base protective actions on child thyroid CDE. Nuclear power plant ICs/EALs need to be consistent with the protective action methodologies employed by the States within their EPZs. The thyroid CDE dose used in the IC and EALs should be adjusted as necessary to align with State protective action decision-making criteria.

An ORO may elect to adopt the guidance in the 2017 EPA PAG Manual (EPA-400/R-17/001, *PAG Manual: Protective Action Guides and Planning Guidance for Radiological Incidents*); however, the NRC does not require licensees to adopt this guidance in their site emergency plan. If the licensee chooses not to adopt this guidance, then the licensee and OROs should coordinate to understand what differences may result in dose projections and PARs, and how to manage those differences to ensure an appropriate emergency response. Understanding any differences in advance may avoid delays in communicating and implementing protective actions. For additional information, developers should refer to Emergency Preparedness Frequently Asked Question (EPFAQ) 2017-001, *Clarification of Implementation of the revised EPA Protective Action Guide regarding revisions to EALs*. The ADAMS Accession Number for this document is ML17199F736.

The “site-specific dose receptor point” is the distance(s) and/or locations used by the licensee to distinguish between on-site and offsite doses. The selected distance(s) and/or locations should

reflect the content of the emergency plan, and the procedural methodology used to determine offsite doses and Protective Action Recommendations. The variation in selected dose receptor points means there may be some differences in the distance from the release point to the calculated dose point from site-to-site.

Although the IC references TEDE, field survey results are generally available only as a “whole body” dose rate. For this reason, the field survey EAL specifies a “closed window” survey reading.

Indications from a real-time dose projection system are not included in the generic EALs. Many licensees do not have this capability. For those that do, the capability may not be within the scope of the plant Technical Specifications. A licensee may request to include an EAL using real-time dose projection system results; approval will be considered on a case-by-case basis.

Indications from a perimeter monitoring system are not included in the generic EALs. Many licensees do not have this capability. For those that do, these monitors may not be controlled and maintained to the same level as plant equipment, or within the scope of the plant Technical Specifications. In addition, readings may be influenced by environmental or other factors. A licensee may request to include an EAL using a perimeter monitoring system; approval will be considered on a case-by-case basis.

AS2

ECL: Site Area Emergency

Initiating Condition: Spent fuel pool level at (site-specific Level 3 description).

Operating Mode Applicability: All

Example Emergency Action Level:

- (1) Lowering of spent fuel pool level to (site-specific Level 3 value).

Basis:

This IC addresses a significant loss of spent fuel pool inventory control and makeup capability, a condition leading to spent fuel damage. This condition entails major failures of plant functions needed for protection of the public and thus warrant a Site Area Emergency declaration.

It is recognized that this IC would likely not be met until well after another Site Area Emergency IC was met; however, it is included to provide classification diversity.

Escalation of the emergency classification level would be via IC AG1 or AG2.

Developer Notes:

The “site-specific Level 3 value” is usually that spent fuel pool level where fuel remains covered and actions to implement make-up water addition should no longer be deferred. This site-specific level is determined in accordance with the requirements of 10 CFR 50.155 and the guidance in NEI 12-02, *Industry Guidance for Compliance with NRC Order EA-12-051, “To Modify Licenses with Regard to Reliable Spent Fuel Pool Instrumentation.”*

It is recognized that a plant may have a wide-range spent fuel pool level monitoring system that requires manual actions to place in service and/or have an indication readout location outside the Control Room (e.g., in the spent fuel storage building). While such a design may not support immediate and/or continuous level readouts in the Control Room, the instrumentation should be specified anyway as it provides some level of backup to the classification of emergency conditions affecting the spent fuel pool (albeit later than other EALs). The basis section should identify the design or operation features that affect EAL assessments (e.g., key actions required to place the instrumentation in service), including the anticipated time required for operators in the Control Room to obtain an instrument reading. Additional guidance on the use of plant instrumentation in EALs is found in Section 4.3 of this document.

AG1

ECL: General Emergency

Initiating Condition: Release of gaseous radioactivity resulting in offsite dose greater than 1,000 mrem TEDE or 5,000 mrem thyroid CDE.

Operating Mode Applicability: All

Example Emergency Action Levels: (1 or 2)

Notes:

- The Shift Manager/Emergency Director should declare the General Emergency promptly upon determining that the applicable time has been exceeded or will likely be exceeded.
 - If an ongoing release is detected and the release start time is unknown, assume that the release duration has exceeded 15 minutes.
 - Emergency classification based on dose projections assumes there is a release path to the environment. If the flow past an effluent monitor used in a dose projection is known to have stopped due to actions to isolate the release path, then the effluent monitor reading is no longer valid for classification purposes.
- (1) Dose assessment using actual meteorology indicates doses greater than 1,000 mrem TEDE or 5,000 mrem thyroid CDE at or beyond (site-specific dose receptor point).
 - (2) Field survey results indicate **EITHER** of the following at or beyond (site-specific dose receptor point):
 - Closed window dose rates greater than 1,000 mR/hr are expected to continue for 60 minutes or longer.
 - Analyses of field survey samples indicate thyroid CDE greater than 5,000 mrem for one hour of inhalation.

Basis:

This IC addresses a release of gaseous radioactivity that results in projected or actual offsite doses greater than the EPA PAGs. It includes both monitored and un-monitored releases. Releases of this magnitude will require implementation of protective actions for the public.

Radiological effluent EALs are included in a scheme to provide a basis for classifying events and conditions that cannot be readily or appropriately classified on the basis of plant conditions alone. The inclusion of both plant condition and radiological effluent EALs more fully addresses the spectrum of possible accident events and conditions. In the event of a significant release, it is anticipated that a General Emergency declaration would be based on IC FG1 because either Containment Barrier Potential Loss threshold (3.A and 3.B [*BWR*] or 4.C and 4.D [*PWR*]) would be met before the EALs in this IC; nonetheless, it is prudent to have IC AG1 as a backup to ensure the General Emergency declaration.

The TEDE dose is set at the EPA PAG of 1,000 mrem while the 5,000 mrem thyroid CDE was established in consideration of the 1:5 ratio of the EPA PAG for TEDE and thyroid CDE.

Emergency classification based on dose projections assumes there is a release path to the environment. If the flow past an effluent monitor used in a dose projection is known to have stopped due to actions to isolate the release path, then the effluent monitor reading is no longer valid for classification purposes.

Developer Notes:

While this IC may not be met absent challenges to multiple fission product barriers, it provides classification diversity and may be used to classify events that would not reach the same ECL based on plant status or the fission product matrix alone. For many of the DBAs analyzed in the Updated Final Safety Analysis Report, the discriminator will not be the number of fission product barriers challenged, but rather the amount of radioactivity released to the environment.

It is important for developers to verify that the emergency response facilities responsible for performing dose projections, including the Control Room, have a reliable dose assessment capability. This means there is reasonable assurance that the facility staff can perform a dose projection if the primary method is unavailable. Examples of an acceptable backup method include the capability to perform a dose projection on a different platform (e.g., a backup computer) or through a manual calculation. A description of the backup method(s) should be included in the EAL justification submitted to the NRC for approval. Absent an acceptable backup method, the NRC may request that an EAL based on calculated effluent radiation monitor readings be added to this IC. Should that be necessary, the guidance in Appendix C, “Guidance for Radiation Effluent Monitor EALS,” should be followed.

The EPA PAGs are expressed in terms of the sum of the effective dose equivalent (EDE) and the committed effective dose equivalent (CEDE), or as the thyroid committed dose equivalent (CDE). For the purpose of these IC/EALs, the dose quantity total effective dose equivalent (TEDE), as defined in 10 CFR 20, is used in lieu of “...sum of EDE and CEDE....”.

The EPA PAG guidance provides for the use of adult thyroid dose conversion factors; however, some states have decided to base protective actions on child thyroid CDE. Nuclear power plant ICs/EALs need to be consistent with the protective action methodologies employed by the States within their EPZs. The thyroid CDE dose used in the IC and EALs should be adjusted as necessary to align with State protective action decision-making criteria.

An ORO may elect to adopt the guidance in the 2017 EPA PAG Manual (EPA-400/R-17/001, *PAG Manual: Protective Action Guides and Planning Guidance for Radiological Incidents*); however, the NRC does not require licensees to adopt this guidance in their site emergency plan. If the licensee chooses not to adopt this guidance, then the licensee and OROs should coordinate to understand what differences may result in dose projections and PARs, and how to manage those differences to ensure an appropriate emergency response. Understanding any differences in advance may avoid delays in communicating and implementing protective actions. For additional information, developers should refer to Emergency Preparedness Frequently Asked Question (EPFAQ) 2017-001, *Clarification of Implementation of the revised EPA Protective Action Guide regarding revisions to EALs*. The ADAMS Accession Number for this document is ML17199F736.

The “site-specific dose receptor point” is the distance(s) and/or locations used by the licensee to distinguish between on-site and offsite doses. The selected distance(s) and/or locations should

reflect the content of the emergency plan, and procedural methodology used to determine offsite doses and Protective Action Recommendations. The variation in selected dose receptor points means there may be some differences in the distance from the release point to the calculated dose point from site-to-site.

Although the IC references TEDE, field survey results are generally available only as a “whole body” dose rate. For this reason, the field survey EAL specifies a “closed window” survey reading.

Indications from a real-time dose projection system are not included in the generic EALs. Many licensees do not have this capability. For those that do, the capability may not be within the scope of the plant Technical Specifications. A licensee may request to include an EAL using real-time dose projection system results; approval will be considered on a case-by-case basis.

Indications from a perimeter monitoring system are not included in the generic EALs. Many licensees do not have this capability. For those that do, these monitors may not be controlled and maintained to the same level as plant equipment, or within the scope of the plant Technical Specifications. In addition, readings may be influenced by environmental or other factors. A licensee may request to include an EAL using a perimeter monitoring system; approval will be considered on a case-by-case basis.

AG2

ECL: General Emergency

Initiating Condition: Spent fuel pool level cannot be restored to at least (site-specific Level 3 description) for 60 minutes or longer.

Operating Mode Applicability: All

Example Emergency Action Level:

Note: The Shift Manager/Emergency Director should declare the General Emergency promptly upon determining that 60 minutes has been exceeded or will likely be exceeded.

- (1) Spent fuel pool level cannot be restored to at least (site-specific Level 3 value) for 60 minutes or longer.

Basis:

This IC addresses a significant loss of spent fuel pool inventory control and makeup capability leading to a prolonged uncover of spent fuel. This condition will lead to fuel damage and a radiological release to the environment.

It is recognized that this IC may be met prior to another General Emergency IC being met (e.g., AG1, FG1, SG1, or SG6); however, it is included to provide classification diversity.

Developer Notes:

The “site-specific Level 3 value” is usually that spent fuel pool level where fuel remains covered and actions to implement make-up water addition should no longer be deferred. This site-specific level is determined in accordance with the requirements of 10 CFR 50.155 and the guidance in NEI 12-02, *Industry Guidance for Compliance with NRC Order EA-12-051, “To Modify Licenses with Regard to Reliable Spent Fuel Pool Instrumentation*.

It is recognized that a plant may have a wide-range spent fuel pool level monitoring system that requires manual actions to place in service and/or have an indication readout location outside the Control Room (e.g., in the spent fuel storage building). While such a design may not support immediate and/or continuous level readouts in the Control Room, the instrumentation should be specified anyway as it provides some level of backup to the classification of emergency conditions affecting the spent fuel pool (albeit later than other EALs). The basis section should identify the design or operation features that affect EAL assessments (e.g., key actions required to place the instrumentation in service), including the anticipated time required for operators in the Control Room to obtain an instrument reading. Additional guidance on the use of plant instrumentation in EALs is found in Section 4.3 of this document.

7 COLD SHUTDOWN / REFUELING SYSTEM MALFUNCTION ICS/EALS

Table C-1: Recognition Category “C” Initiating Condition Matrix

UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
	CA1 Loss of (reactor vessel/RCS [PWR] or RPV [BWR]) inventory. <i>Op. Modes: Cold Shutdown, Refueling</i>	CS1 Loss of (reactor vessel/RCS [PWR] or RPV [BWR]) inventory affecting core decay heat removal capability. <i>Op. Modes: Cold Shutdown, Refueling</i>	CG1 Prolonged loss of core decay heat removal capability. <i>Op. Modes: Cold Shutdown, Refueling</i>
	CA2 Loss of all offsite and all onsite AC power to emergency buses for 15 minutes or longer. <i>Op. Modes: Cold Shutdown, Refueling, Defueled</i>		
CU3 Loss of all RCS temperature and (reactor vessel/RCS [PWR] or RPV [BWR]) level indication for 15 minutes or longer. <i>Op. Modes: Cold Shutdown, Refueling</i>	CA3 Inability to maintain the plant in cold shutdown. <i>Op. Modes: Cold Shutdown, Refueling</i>		
CU4 Loss of Vital DC power for 15 minutes or longer. <i>Op. Modes: Cold Shutdown, Refueling</i>			
CU5 Loss of all onsite or offsite communications capabilities. <i>Op. Modes: Cold Shutdown, Refueling, Defueled</i>			

Table intended for use by
EAL developers.
Inclusion in licensee
documents is not required.

UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CU6 Internal flooding affecting a SAFETY SYSTEM component required for the current operating mode. <i>Op. Modes: Cold Shutdown, Refueling</i>	CA6 Hazardous event affecting SAFETY SYSTEM trains required for the current operating mode. <i>Op. Modes: Cold Shutdown, Refueling</i>	CS7 Challenge to core cooling safety function with Control Room evacuated. <i>Op. Modes: Cold Shutdown, Refueling</i>	
	CA7 Control Room evacuation resulting in transfer of plant control to alternate locations. <i>Op. Modes: Cold Shutdown, Refueling</i>		

Table intended for use by
EAL developers.
Inclusion in licensee
documents is not required.

CU3

ECL: Notification of Unusual Event

Initiating Condition: Loss of all RCS temperature and (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) level indication for 15 minutes or longer.

Operating Mode Applicability: Cold Shutdown, Refueling

Example Emergency Action Level:

Note: The Shift Manager/Emergency Director should declare the Unusual Event promptly upon determining that 15 minutes has been exceeded or will likely be exceeded.

- (1) Loss of **ALL** RCS temperature and (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) level indications for 15 minutes or longer.

Basis:

This IC addresses a loss of the instrumentation needed to monitor RCS temperature and (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) level. These indications are necessary to monitor and assure core decay heat removal. During this condition, there is no immediate threat of fuel damage because the core decay heat load has been reduced since the cessation of power operation; however, because these critical parameters cannot be monitored, the condition represents a potential degradation of the level of safety of the plant.

Fifteen minutes was selected as a threshold to exclude transient or momentary losses of indication.

Escalation to an Alert would be via IC CA1 based on an inventory loss or IC CA3 based on exceeding plant configuration-specific heatup criteria.

Developer Notes:

None

CU4

ECL: Notification of Unusual Event

Initiating Condition: Loss of Vital DC power for 15 minutes or longer.

Operating Mode Applicability: Cold Shutdown, Refueling

Example Emergency Action Level:

Note: The Shift Manager/Emergency Director should declare the Unusual Event promptly upon determining that 15 minutes has been exceeded or will likely be exceeded.

- (1) Indicated voltage is less than (site-specific bus voltage value) on required Vital DC buses for 15 minutes or longer.

Basis:

This IC addresses a loss of Vital DC power which compromises the ability to monitor and control operable SAFETY SYSTEMS when the plant is in the cold shutdown or refueling mode. In these modes, the core decay heat load has been significantly reduced, and coolant system temperatures and pressures are lower; these conditions increase the time available to restore a vital DC bus to service. Thus, this condition is considered to be a potential degradation of the level of safety of the plant.

As used in this EAL, “required” means the Vital DC buses necessary to support operation of the in-service, or operable, train or trains of SAFETY SYSTEM equipment. For example, if Train A is out-of-service (inoperable) for scheduled outage maintenance work and Train B is in-service (operable), then a loss of Vital DC power affecting Train B would require the declaration of an Unusual Event. A loss of Vital DC power to Train A would not warrant an emergency classification.

Fifteen minutes was selected as a threshold to exclude transient or momentary power losses.

Depending upon the event, escalation of the emergency classification level would be via IC CA1 or CA3, or an IC in Recognition Category A.

Developer Notes:

The “site-specific bus voltage value” should be based on the minimum bus voltage necessary for adequate operation of SAFETY SYSTEM equipment. This voltage value should incorporate a margin of at least 15 minutes of operation before the onset of inability to operate those loads. This voltage is usually near the minimum voltage selected when battery sizing is performed.

CU5

ECL: Notification of Unusual Event

Initiating Condition: Loss of all onsite or offsite communications capabilities.

Operating Mode Applicability: Cold Shutdown, Refueling, Defueled

Example Emergency Action Levels: (1 or 2 or 3)

- (1) Loss of **ALL** of the following onsite communication methods:
(site-specific list of communications methods)
- (2) Loss of **ALL** of the following ORO communications methods:
(site-specific list of communications methods)
- (3) Loss of **ALL** of the following NRC communications methods:
(site-specific list of communications methods)

Basis:

This IC addresses a significant loss of on-site or offsite communications capabilities. While not a direct challenge to plant or personnel safety, this event warrants prompt notifications to OROs and the NRC.

This IC should be assessed only when extraordinary means are being utilized to make communications possible (e.g., use of non-plant, privately owned equipment, relaying of on-site information via individuals or multiple radio transmission points, individuals being sent to offsite locations, etc.).

EAL #1 addresses a total loss of the communications methods used in support of routine plant operations.

EAL #2 addresses a total loss of the communications methods used to notify all OROs of an emergency declaration. The OROs referred to here are (see Developer Notes).

EAL #3 addresses a total loss of the communications methods used to notify the NRC of an emergency declaration.

Developer Notes:

EAL #1 - The “site-specific list of communications methods” should include all communications methods used for routine plant communications (e.g., commercial or site telephones, page-party systems, radios, etc.). This listing should include installed plant equipment and components, and not items owned and maintained by individuals.

EAL #2 - The “site-specific list of communications methods” should include all communications methods used to perform initial and follow-up emergency notifications to OROs as described in

the site Emergency Plan. The listing should include installed plant equipment and components, and not items owned and maintained by individuals. Example methods are ring-down/dedicated telephone lines, commercial telephone lines, cellular telephones, radios, and satellite telephones. A method may also include electronic or internet-based communications technologies with a procedural means to determine if the message was accessed by an ORO (e.g., a read or opened receipt, or other acknowledgement that the notification message was displayed such as an independent phone call).

In the Basis section, insert the site-specific listing of the OROs requiring notification of an emergency declaration from the Control Room in accordance with the site Emergency Plan, and typically within 15 minutes.

EAL #3 – The “site-specific list of communications methods” should include all communications methods used to perform initial emergency notifications to the NRC as described in the site Emergency Plan. The listing should include installed plant equipment and components, and not items owned and maintained by individuals. These methods are typically the dedicated Emergency Notification System (ENS) telephone line and commercial telephone lines.

CU6

ECL: Notification of Unusual Event

Initiating Condition: Internal flooding affecting a SAFETY SYSTEM component required for the current operating mode.

Operating Mode Applicability: Cold Shutdown, Refueling

Example Emergency Action Level:

- (1) Internal room or area flooding of a magnitude sufficient to require manual or automatic electrical isolation of a SAFETY SYSTEM component required by Technical Specifications for the current operating mode.

Basis:

This IC addresses flooding of a building room or area that results in operators isolating power to a SAFETY SYSTEM component or causes an automatic isolation of a SAFETY SYSTEM component (e.g., a breaker or relay trip). To warrant classification, operability of the affected component must be required by Technical Specifications for the current operating mode. This event represents a potential degradation of the level of safety of the plant.

Escalation of the emergency classification level would be based on IC CA6.

Developer Notes:

Flooding is a condition where water is entering a room or area faster than available equipment is capable removing it, resulting in a rise of water level within the room or area. Developers may add this clarification or definition if it improves user understanding.

CA1

ECL: Alert

Initiating Condition: Loss of (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) inventory.

Operating Mode Applicability: Cold Shutdown, Refueling

Example Emergency Action Level: (1 or 2)

Notes:

- The Shift Manager/Emergency Director should declare the Alert promptly upon determining that 30 minutes has been exceeded or will likely be exceeded.
- An emergency declaration is not warranted if the point of the leakage is above the vessel flange since the leakage will stop at that point and core cooling will not be challenged.

- (1) Loss of (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) inventory as indicated by level less than (site-specific level).
- (2) a. (Reactor vessel/RCS [*PWR*] or RPV [*BWR*]) level cannot be (monitored [*PWR*] or determined [*BWR*]) for 30 minutes or longer.

AND

- b. **EITHER** of the following:

1. UNPLANNED increase in (site-specific sump and/or tank) levels due to a loss of (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) inventory.

OR

2. Visual observation of UNISOLABLE RCS leakage.

Basis:

This IC addresses conditions that are precursors to a loss of the ability to adequately cool irradiated fuel (i.e., a precursor to a challenge to the fuel clad barrier). This condition represents an actual or potential substantial degradation of the level of safety of the plant.

For EAL #1, a lowering of water level below (site-specific level) indicates that operator actions have not been successful in restoring and maintaining (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) water level. The heatup rate of the coolant will increase as the available water inventory is reduced. A continuing decrease in water level will lead to core uncover.

Although related, EAL #1 is concerned with the loss of RCS inventory and not the potential concurrent effects on systems needed for decay heat removal (e.g., loss of a Residual Heat Removal suction point). An increase in RCS temperature caused by a loss of decay heat removal capability is evaluated under IC CA3.

For EAL #2, the inability to monitor (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) level may be caused by instrumentation and/or power failures, or water level dropping below the range of available instrumentation. If water level cannot be (monitored [*PWR*] or determined [*BWR*]), operators may determine that an inventory loss is occurring by observing changes in sump and/or tank levels. Sump and/or tank level changes must be evaluated against other potential sources of water flow to ensure they are indicative of leakage from the (reactor vessel/RCS [*PWR*] or RPV [*BWR*]). An RCS inventory loss may also be determined by visual observation. When assessing this EAL, an emergency declaration is not warranted if the point of the leakage is above the vessel flange since the leakage will stop at that point and core cooling will not be challenged.

The 30-minute time period reflects information related to core heatup found in NUREG-1449, *Shutdown and Low-Power Operation at Commercial Nuclear Power Plants in the United States*, and supports an appropriate escalation path to a Site Area Emergency via EAL #3 of IC CS1.

If the (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) inventory level continues to lower, then escalation to Site Area Emergency would be via IC CS1.

Developer Notes:

For EAL #1 – the “site-specific level” should be based on either:

- [*BWR*] Low-Low ECCS actuation setpoint/Level 2. This setpoint was chosen because it is a standard operationally significant setpoint at which some (typically high pressure ECCS) injection systems would automatically start.
- [*PWR*] The minimum allowable level that supports operation of normally used decay heat removal systems (e.g., Residual Heat Removal or Shutdown Cooling). If multiple levels exist, specify each along with the appropriate mode or configuration dependency criteria.

For EAL #2 - The type and range of RCS level instrumentation may vary during an outage as the plant moves through various operating modes and refueling evolutions, particularly for a PWR. As appropriate to the plant design, alternate means of determining RCS level are installed to assure that the ability to monitor level within the range required by operating procedures will not be interrupted. The instrumentation range necessary to support implementation of operating procedures in the Cold Shutdown and Refueling modes may be different (e.g., narrower) than that required during modes higher than Cold Shutdown.

Enter any “site-specific sump and/or tank” levels that could be expected to increase if there were a loss of inventory (i.e., the lost inventory would enter the listed sump or tank).

CA2

ECL: Alert

Initiating Condition: Loss of all offsite and all onsite AC power to emergency buses for 15 minutes or longer.

Operating Mode Applicability: Cold Shutdown, Refueling, Defueled

Example Emergency Action Level:

Notes:

- The Shift Manager/Emergency Director should declare the Alert promptly upon determining that 15 minutes has been exceeded or will likely be exceeded.
 - Any power source, safety-related or not, is acceptable provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with ECCS and decay heat removal functions.
- (1) Loss of **ALL** offsite and **ALL** onsite AC Power to (site-specific emergency buses) for 15 minutes or longer.

Basis:

This IC addresses a total loss of AC power that compromises the performance of all SAFETY SYSTEMS requiring electric power including those necessary for emergency core cooling, containment heat removal/pressure control, spent fuel heat removal and the ultimate heat sink.

When in the cold shutdown, refueling, or defueled mode, this condition is not classified as a Site Area Emergency because of the increased time available to restore an emergency bus to service. Additional time is available due to the reduced core decay heat load, and the lower temperatures and pressures in various plant systems. Thus, when in these modes, this condition represents an actual or potential substantial degradation of the level of safety of the plant.

Any AC power source, safety-related or not, is acceptable provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with ECCS and decay heat removal functions. This includes sources that support implementation of strategies required by 10 CFR 50.155, "Mitigation of beyond-design-basis events."

Fifteen minutes was selected as a threshold to exclude transient or momentary power losses.

Escalation of the emergency classification level would be via IC CS1 or AS1.

Developer Notes:

The 15-minute EAL criterion is appropriate recognizing that the time-to-boil period can be less than 30 minutes when decay heat removal is lost under mid-loop or reduced inventory conditions.

For a power source that has multiple generators, the EAL and/or Basis section should reflect the minimum number of operating generators necessary for that source to provide adequate power to an AC emergency bus. For example, if a backup power source is comprised of two generators (i.e., two 50%-capacity generators sized to feed 1 AC emergency bus), the EAL and Basis section must specify that both generators for that source are operating.

The “site-specific emergency buses” are the buses fed by offsite or emergency AC power sources that supply power to the electrical distribution system that powers SAFETY SYSTEMS. There is typically 1 emergency bus per train of SAFETY SYSTEMS.

The EAL and/or Basis section may specify the use of a non-safety-related power source provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with decay heat removal functions. This includes sources that support implementation of strategies required by 10 CFR 50.155, “Mitigation of beyond-design-basis events.”

At multi-unit stations, the EALs may credit compensatory measures that are proceduralized. Consider capabilities such as power source cross-ties, “swing” generators, other power sources described in abnormal or emergency operating procedures, etc. Plants that have a proceduralized capability to supply offsite AC power to an affected unit via a cross-tie to a companion unit may credit this power source in the EAL provided that the planned cross-tie strategy meets the requirements of 10 CFR 50.63.

CA3

ECL: Alert

Initiating Condition: Inability to maintain the plant in cold shutdown.

Operating Mode Applicability: Cold Shutdown, Refueling

Example Emergency Action Level:

Notes:

- The Shift Manager/Emergency Director should declare the Alert promptly upon determining that the applicable time has been exceeded or will likely be exceeded.
 - When assessing the “0 minutes” Heatup Duration, a momentary UNPLANNED excursion above the Technical Specification cold shutdown temperature limit when the decay heat removal function is available does not warrant a classification.
 - If the loss of decay heat removal capability affects the reliability of RCS temperature indication, then the emergency classification should be based on estimates of RCS temperature using procedurally approved sources (e.g., a calculated heatup curve).
- (1) UNPLANNED increase in RCS temperature to greater than (site-specific Technical Specification cold shutdown temperature limit) for greater than the duration specified in the Table CA3-1, “RCS Heatup Duration Thresholds.”

Table CA3-1: RCS Heatup Duration Thresholds		
RCS Status	Containment Closure Status	Heatup Duration
Intact (but not at reduced inventory [<i>PWR</i>])	Not applicable	60 minutes*
Not intact (or at reduced inventory [<i>PWR</i>])	Established	20 minutes*
	Not Established	0 minutes
* If an RCS heat removal system is in operation within this time frame and RCS temperature is being reduced, the EAL is not applicable.		

Basis:

This IC addresses conditions involving a loss of decay heat removal capability or an addition of heat to the RCS in excess of that which can currently be removed. Either condition represents an actual or potential substantial degradation of the level of safety of the plant.

The RCS Heatup Duration Thresholds table addresses an increase in RCS temperature when CONTAINMENT CLOSURE is established but the RCS is not intact, or RCS inventory is reduced (e.g., mid-loop operation in PWRs). The 20-minute criterion was included to allow time for operator action to address the temperature increase.

The RCS Heatup Duration Thresholds table also addresses an increase in RCS temperature with the RCS intact. The status of CONTAINMENT CLOSURE is not crucial in this condition since

the intact RCS is providing a high pressure barrier to a fission product release. The 60-minute time frame should allow sufficient time to address the temperature increase without a substantial degradation in plant safety.

Finally, in the case where there is an increase in RCS temperature, the RCS is not intact or is at reduced inventory [*PWR*], and CONTAINMENT CLOSURE is not established, no heatup duration is allowed (i.e., 0 minutes). This is because 1) the evaporated reactor coolant may be released directly into the Containment atmosphere and subsequently to the environment, and 2) there is reduced reactor coolant inventory above the top of irradiated fuel. When assessing the “0 minutes” Heatup Duration, a momentary UNPLANNED excursion above the Technical Specification cold shutdown temperature limit when the decay heat removal function is available does not warrant a classification.

If the loss of decay heat removal capability affects the reliability of RCS temperature indication, then the emergency classification should be based on estimates of RCS temperature using procedurally approved sources (e.g., a calculated heatup curve).

Escalation of the emergency classification level would be via IC CS1 or AS1.

Developer Notes:

For EAL #1 – Enter the “site-specific Technical Specification cold shutdown temperature limit” where indicated. The RCS should be considered intact or not intact in accordance with site-specific criteria.

For PWRs, this IC and its associated EALs address the concerns raised by Generic Letter 88-17, *Loss of Decay Heat Removal*. A number of phenomena such as pressurization, vortexing, steam generator U-tube draining, RCS level differences when operating at a mid-loop condition, decay heat removal system design, and level instrumentation problems can lead to conditions where decay heat removal is lost and core uncover can occur. NRC analyses show that there are sequences that can cause core uncover in 15 to 20 minutes, and severe core damage within an hour after decay heat removal is lost. The allowed time frames are consistent with the guidance provided by Generic Letter 88-17 and believed to be conservative given that a low pressure Containment barrier to fission product release is established.

CA6

ECL: Alert

Initiating Condition: Hazardous event affecting two or more SAFETY SYSTEM trains.

Operating Mode Applicability: Cold Shutdown, Refueling, Defueled

Example Emergency Action Level:

- (1) a. The occurrence of **ANY** of the following hazardous events:
- Seismic event (earthquake)
 - Internal or external flooding event
 - High winds or tornado strike
 - FIRE
 - EXPLOSION
 - (site-specific hazards)
 - Other events with similar hazard characteristics as determined by the Shift Manager

AND

- b. The event has resulted in **BOTH** of the following:
1. Indications of degraded performance on a SAFETY SYSTEM train.

AND

2. **EITHER** of the following:
 - a) **VISIBLE DAMAGE** to a second SAFETY SYSTEM train.
- OR**
- b) Indications of degraded performance to a second SAFETY SYSTEM train.

Basis:

This IC addresses a hazardous event of sufficient magnitude to cause degraded performance to a SAFETY SYSTEM train with either 1) **VISIBLE DAMAGE** to a second SAFETY SYSTEM train or 2) indications of degraded performance on a second SAFETY SYSTEM train. The affected trains may be on the same SAFETY SYSTEM or different SAFETY SYSTEMS. Commercial nuclear power plant SAFETY SYSTEMS are typically comprised of two or more separate and redundant trains of equipment in accordance with site-specific design criteria. This permits a plant to respond to an event affecting a single train without compromising public health and safety from radiological events. Nonetheless, a hazardous event of sufficient magnitude to impact two SAFETY SYSTEM trains has the potential to significantly reduce the margin to a loss or potential loss of a fission product barrier, and therefore represents an actual or potential substantial degradation of the level of safety of the plant.

The “second SAFETY SYSTEM train” referenced in EAL statement (1)b.2 may be associated with the same SAFETY SYSTEM as the train experiencing the indications of degraded performance per statement (1)b.1 or a different SAFETY SYSTEM. In addition, the EAL assessment is independent of the operability status of the second train. For example, if a system train is out-of-service for maintenance at the time of the event and sustains VISIBLE DAMAGE, then an emergency declaration is warranted if another SAFETY SYSTEM train has indications of degraded performance.

The “indications of degraded performance” address damage to a SAFETY SYSTEM train that is in service/operation since indications for it will be readily available. The indications of degraded performance should be significant enough to cause concern regarding the functionality or reliability of the SAFETY SYSTEM train. It is recognized that a train may be put into service sometime after the event has occurred; in that case, the emergency classification assessment should be made at the time the train displays indications of degraded performance.

The term VISIBLE DAMAGE addresses damage to a SAFETY SYSTEM train that is not in service/operation or readily apparent through indications alone. Operators will make a determination of VISIBLE DAMAGE based on the totality of available event and damage report information. This is intended to be a brief assessment not requiring lengthy analysis or quantification of the damage.

Escalation of the emergency classification level would be via IC CS1 or AS1.

Developer Notes:

Developers may add one or more of the following paragraphs to the Basis section as applicable to the plant design.

1. An event affecting equipment common to two or more SAFETY SYSTEMS or SAFETY SYSTEM trains (i.e., there are indications of degraded performance and/or VISIBLE DAMAGE affecting the common equipment) should be classified under this IC. By affecting the functionality or reliability of multiple system trains, the loss of the common equipment effectively meets the two-train impact criteria that underlie the EALs and Basis. Examples of such equipment include a Refueling Water Storage Tank [*PWR*] or a Condensate Storage Tank [*BWR*].
2. An event affecting a single-train SAFETY SYSTEM (i.e., there are indications of degraded performance and/or VISIBLE DAMAGE affecting the one train) would not be classified under this IC because the two-train impact criteria that underlie the EALs and Basis would not be met. If an event affects a single-train SAFETY SYSTEM, then the emergency classification should be made based on plant parameters/symptoms meeting the EALs for another IC. Depending upon the circumstances, classification may also occur based on Shift Manager/Emergency Director judgement.
3. An event that affects two trains of a SAFETY SYSTEM (e.g., one train has indications of degraded performance and the other VISIBLE DAMAGE) that also has one or more additional trains should be classified under this IC. This approach maintains consistency with the two-train impact criteria that underlie the EALs and

Basis, and is warranted because the event was severe enough to affect the functionality or reliability of two trains of a SAFETY SYSTEM despite plant design criteria associated with system and system train separation and protection. Such an event may have caused other plant impacts that are not immediately apparent.

For (site-specific hazards), developers should consider including other significant, site-specific hazards to the bulleted list contained in EAL 1.a (e.g., a seiche).

CA7

ECL: Alert

Initiating Condition: Control Room evacuation resulting in transfer of plant control to alternate locations.

Operating Mode Applicability: Cold Shutdown, Refueling

Example Emergency Action Level:

- (1) An event has resulted in plant control being transferred from the Control Room to (site-specific remote shutdown panels and local control stations).

Basis:

This IC addresses an evacuation of the Control Room that results in transfer of plant control to alternate locations outside the Control Room. The loss of the ability to control the plant from the Control Room is considered to be a potential substantial degradation in the level of plant safety.

Following a Control Room evacuation, control of the plant will be transferred to alternate shutdown locations. The necessity to control the plant from outside the Control Room, in addition to responding to the event that required the evacuation of the Control Room, will present challenges to plant operators and other on-shift personnel. Activation of the ERO and emergency response facilities will assist in responding to these challenges.

Escalation of the emergency classification level would be via IC CS7.

Developer Notes:

The “site-specific remote shutdown panels and local control stations” are the panels and control stations referenced in plant procedures used to cooldown and shutdown the plant from a location(s) outside the Control Room.

CS1

ECL: Site Area Emergency

Initiating Condition: Loss of (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) inventory affecting core decay heat removal capability.

Operating Mode Applicability: Cold Shutdown, Refueling

Example Emergency Action Levels: (1 or 2 or 3)

Note: The Shift Manager/Emergency Director should declare the Site Area Emergency promptly upon determining that 30 minutes has been exceeded or will likely be exceeded.

- (1) a. CONTAINMENT CLOSURE not established.

AND

b. (RHR flow is lost and not restored within 30 minutes [*PWR*] or RPV level less than (site-specific level) [*BWR*]).
- (2) a. CONTAINMENT CLOSURE established.

AND

b. (Reactor vessel/RCS level less than (site-specific level) [*PWR*] or Adequate core cooling cannot be assured [*BWR*]).
- (3) a. (Reactor vessel/RCS [*PWR*] or RPV [*BWR*]) level cannot be (monitored [*PWR*] or determined [*BWR*]) for 30 minutes or longer.

AND

b. Core uncover is indicated by **ANY** of the following:
 - (Site-specific radiation monitor) reading greater than (site-specific value)
 - Erratic source range monitor indication [*PWR*]
 - UNPLANNED increase in (site-specific sump and/or tank) levels of sufficient magnitude to indicate core uncover
 - Visual observation of UNISOLABLE RCS leakage of sufficient magnitude to make core uncover likely
 - (Other site-specific indications)

Basis:

This IC addresses a significant loss of (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) inventory control and makeup capability. The lost inventory may be due to an RCS component failure, a loss of configuration control or prolonged boiling of reactor coolant. These conditions entail major failures of plant functions needed for protection of the public and thus warrant a Site Area Emergency declaration.

Following a prolonged loss of core decay heat removal and inventory makeup, decay heat will cause reactor coolant boiling and a further reduction in reactor vessel level. If RCS/reactor vessel level cannot be restored (or spray cooling cannot be established [*BWR*]), then fuel damage is likely.

Outage/shutdown contingency plans typically provide for re-establishing or verifying CONTAINMENT CLOSURE following a loss of heat removal or RCS inventory control functions. The difference in the specified RCS/reactor vessel levels of EALs 1.b and 2.b reflect the fact that with CONTAINMENT CLOSURE established, there is a lower potential for a fission product release to the environment.

[*P for PWR*] EAL 1.b addresses a loss of RHR flow and subsequent heatup of the RCS. The principal concern is a lowering of the loop level below that needed to provide an acceptable suction source for the operating RHR train. The loss of the suction source could result in vortexing and potential air entrainment in the RHR line, and a pump trip. Indications of this conditions include a loop level below a required minimum level, fluctuations in RHR pump motor amperage, excessive pump vibration, and no RHR flow. Thirty minutes was selected as a reasonable amount of time for plant operators to recognize the problem, secure the affected train, and place another train into service, if available.

In EAL 3.a, the 30-minute criterion is tied to a readily recognizable event start time (i.e., the total loss of ability to monitor level), and allows sufficient time to monitor, assess and correlate reactor and plant conditions to determine if core uncover has actually occurred (i.e., to account for various accident progression and instrumentation uncertainties). It also allows sufficient time for performance of actions to terminate the leakage, recover inventory control/makeup equipment, restore level monitoring, and/or establish CONTAINMENT CLOSURE if not previously established.

The inability to monitor (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) level may be caused by instrumentation and/or power failures, or water level dropping below the range of available instrumentation. If water level cannot be (monitored [*PWR*] or determined [*BWR*]), operators may determine that an inventory loss is occurring by observing changes in sump and/or tank levels. Sump and/or tank level changes must be evaluated against other potential sources of water flow to ensure they are indicative of leakage from the (reactor vessel/RCS [*PWR*] or RPV [*BWR*]). An RCS inventory loss may also be determined by visual observation.

These EALs address concerns raised by Generic Letter 88-17, *Loss of Decay Heat Removal*; SECY 91-283, *Evaluation of Shutdown and Low Power Risk Issues*; NUREG-1449, *Shutdown and Low-Power Operation at Commercial Nuclear Power Plants in the United States*; and NUMARC 91-06, *Guidelines for Industry Actions to Assess Shutdown Management*.

Escalation of the emergency classification level would be via IC AG1.

Developer Notes:

Accident analyses suggest that fuel damage may occur within one hour of uncover depending upon the amount of time since shutdown; refer to Generic Letter 88-17, SECY 91-283, NUREG-1449 and NUMARC 91-06.

The type and range of RCS level instrumentation may vary during an outage as the plant moves through various operating modes and refueling evolutions, particularly for a PWR. As appropriate to the plant design, alternate means of determining RCS level are installed to assure that the ability to monitor level within the range required by operating procedures will not be interrupted. The instrumentation range necessary to support implementation of operating procedures in the Cold Shutdown and Refueling modes may be different (e.g., narrower) than that required during modes higher than Cold Shutdown.

PWR

For EAL #1.b – The 30-minute time period reflects information related to core heatup found in NUREG-1449, *Shutdown and Low-Power Operation at Commercial Nuclear Power Plants in the United States*. The developer may replace the term RHR with the site-specific name of the system used to remove decay heat during plant shutdowns.

For EAL #2.b – The “site-specific level” should be approximately the top of active fuel. If the availability of on-scale level indication is such that this level value can be determined during some shutdown modes or conditions, but not others, then specify the mode-dependent and/or configuration states during which the level indication is applicable. If the design and operation of water level instrumentation is such that this level value cannot be determined at any time during Cold Shutdown or Refueling modes, then do not include EAL #2 (classification will be accomplished in accordance with EAL #3).

For EAL #3.b – first bullet - As water level in the reactor vessel lowers, the dose rate above the core will increase. Enter a “site-specific radiation monitor” that could be used to detect core uncover and the associated “site-specific value” indicative of core uncover. It is recognized that the condition described by this IC may result in a radiation value beyond the operating or display range of the installed radiation monitor. In those cases, EAL values should be determined with a margin sufficient to ensure that an accurate monitor reading is available. For example, an EAL monitor reading might be set at 90% to 95% of the highest accurate monitor reading. This provision notwithstanding, if the estimated/calculated monitor reading is greater than approximately 110% of the highest accurate monitor reading, then developers may choose not to include the monitor as an indication and identify an alternate EAL threshold. Alternatively, if installed radiation monitors cannot detect core uncover in the Cold Shutdown mode (RCS intact), then this indicator can be made applicable only in the Refuel Mode (vessel head removed).

To further promote accurate classification, developers should consider if some combination of monitors could be specified in the EAL to build-in an appropriate level of corroboration between monitor readings into the classification assessment.

For EAL #3.b – second bullet - Post-TMI accident studies indicated that the installed PWR nuclear instrumentation will operate erratically when the core is uncovered and that this should be used as a tool for making such determinations.

For EAL #3.b – third bullet – Enter any “site-specific sump and/or tank” levels that could be expected to change if there were a loss of RCS/reactor vessel inventory of sufficient magnitude to indicate core uncover. Specific level values may be included if desired.

For EAL #3.b – fifth bullet - Developers should determine if other reliable indicators exist to identify fuel uncover (e.g., remote viewing using cameras). The goal is to identify any unique or site-specific indications, not already used elsewhere, that will promote timely and accurate emergency classification.

BWR

For EAL #1.b – “site-specific level” is the Low-Low-Low ECCS actuation setpoint / Level 1. The BWR Low-Low-Low ECCS actuation setpoint / Level 1 was chosen because it is a standard operationally significant setpoint at which some (typically low pressure ECCS) injection systems would automatically start and attempt to restore RPV level. This is a RPV water level value that is observable below the Low-Low/Level 2 value specified in IC CA1, but significantly above the Top of Active Fuel (TOAF) threshold specified in EAL #2.

For EAL #2.b – In accordance with the BWROG EPGs/SAGs, Revision 4, under cold shutdown or refueling conditions, core cooling can be assured by either core submergence or spray cooling. Plants that do not take credit for spray cooling in cold shutdown and refueling modes should use “RPV level less than (the site-specific level associated with top of active fuel).”

For EAL #3.b – first bullet - As water level in the reactor vessel lowers, the dose rate above the core will increase. Enter a “site-specific radiation monitor” that could be used to detect core uncover and the associated “site-specific value” indicative of core uncover. It is recognized that the condition described by this IC may result in a radiation value beyond the operating or display range of the installed radiation monitor. In those cases, EAL values should be determined with a margin sufficient to ensure that an accurate monitor reading is available. For example, an EAL monitor reading might be set at 90% to 95% of the highest accurate monitor reading. This provision notwithstanding, if the estimated/calculated monitor reading is greater than approximately 110% of the highest accurate monitor reading, then developers may choose not to include the monitor as an indication and identify an alternate EAL threshold. Alternatively, if installed radiation monitors cannot detect core uncover in the Cold Shutdown mode (RCS intact), then this indicator can be made applicable only in the Refuel Mode (vessel head removed).

To further promote accurate classification, developers should consider if some combination of monitors could be specified in the EAL to build-in an appropriate level of corroboration between monitor readings into the classification assessment.

For BWRs that do not have installed radiation monitors capable of indicating core uncover, alternate site-specific level indications of core uncover should be used if available.

For EAL #3.b – second bullet - Because BWR source range monitor (SRM) nuclear instrumentation detectors are typically located below core mid-plane, this may not be a viable indicator of core uncover for BWRs.

For EAL #3.b – third bullet – Enter any “site-specific sump and/or tank” levels that could be expected to change if there were a loss of RPV inventory of sufficient magnitude to indicate core uncover. Specific level values may be included if desired.

For EAL #3.b – fifth bullet - Developers should determine if other reliable indicators exist to identify fuel uncovering (e.g., remote viewing using cameras). The goal is to identify any unique or site-specific indications, not already used elsewhere, that will promote timely and accurate emergency classification.

CS7

ECL: Site Area Emergency

Initiating Condition: Challenge to core cooling safety function with Control Room evacuated.

Operating Mode Applicability: Cold Shutdown, Refueling

Example Emergency Action Level:

- (1) a. Plant control has been transferred to locations outside the Control Room.
- AND**
- b. **EITHER** of the following Initiating Conditions is met.
- IC CA1, Loss of (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) inventory
 - IC CA3, Inability to maintain the plant in cold shutdown

Basis:

This IC addresses an evacuation of the Control Room with a concurrent challenge to the control of the core cooling safety function. The failure to control the core cooling safety function following the transfer of plant control to locations outside the Control Room is a precursor to a challenge to one or more fission product barriers within a relatively short period of time.

Plant control is “transferred” upon completion of (site-specific action or procedure step).

ICs CA1 and CA3 identify conditions associated with a loss of (reactor vessel/RCS [*PWR*] or RPV [*BWR*]) inventory or an inability to maintain the plant in cold shutdown. Both conditions indicate a challenge to the core cooling safety function sufficient to escalate the emergency classification level if there has been a concurrent evacuation of the Control Room.

Escalation of the emergency classification level would be via IC AG1.

Developer Notes:

Because adequate shutdown margin would have already been verified before entry into the Cold Shutdown mode, the subcriticality safety function is not included in the EAL. Also, this IC is not applicable in the defueled operating mode because there is sufficient control of spent fuel cooling from outside the Control Room to preclude threats to irradiated fuel with the Control Room evacuated.

The “site-specific action or procedure step” should be the procedural action/step that concludes the process to transfer plant control to remote locations such that key safety functions are controlled from locations outside the Control Room.

CG1

Initiating Condition: Prolonged loss of core decay heat removal capability.

Operating Mode Applicability: Cold Shutdown, Refueling

Example Emergency Action Level:

- (1) a. A Site Area Emergency was declared in accordance with Initiating Condition CS1, “(site-specific name of IC CS1).”

AND

- b. 60 minutes has elapsed since the Site Area Emergency was declared, with the EAL requiring the classification still met.

Basis:

This IC addresses a prolonged loss of core decay heat removal capability leading to core uncover and a challenge to the ability of containment to retain airborne fission products. Should CONTAINMENT CLOSURE not be established or the measures to establish CONTAINMENT CLOSURE be significantly challenged, there may be releases that exceed EPA PAG exposure levels offsite for more than the immediate site area; therefore, this condition represents imminent or actual substantial core degradation or melting with potential for loss of containment integrity.

Following a prolonged loss of core decay heat removal and inventory makeup, decay heat will cause reactor coolant boiling and lowering of the water level in the (reactor vessel [*PWR*] or RPV [*BWR*]). If the water level cannot be restored above the fuel (or spray cooling cannot be established [*BWR*]), then fuel damage and a release of fission products to the containment atmosphere is likely. With CONTAINMENT CLOSURE not established, there is a high potential for a direct and unmonitored release of radioactivity to the environment. If CONTAINMENT CLOSURE is established, there is still a concern that accident conditions could eventually challenge the CONTAINMENT CLOSURE measures and lead to a release.

The EAL specifies a fixed time, 60 minutes from the Site Area Emergency declaration, after which escalation to a General Emergency is required. This approach obviates the need to do time-consuming calculations (e.g., heatup rate, water inventory, and core damage) during the event. Given the range of potential initial conditions, accident trajectories, and information uncertainties that an emergency classification decision-maker may encounter, the time of 60 minutes was determined to reasonably balance the risks of a premature PAR and a late PAR. It also considers the information found in NRC Generic Letter 88-17, *Loss of Decay Heat Removal - 10 CFR 50.54(f)*; SECY 91-283, *Evaluation of Shutdown and Low Power Risk Issues*; NUREG-1449, *Shutdown and Low-Power Operation at Commercial Nuclear Power Plants in the United States*; and NUMARC 91-06, *Guidelines for Industry Actions to Assess Shutdown Management*.

This IC is backed-up by EALs in IC AG1.

Developer Notes:

As additional background on the “60 minutes” time duration chosen for this EAL, the NEI EAL task force noted that there are several variables that affect the timing of core damage and a release during the conditions covered by IC CG1. The principal ones are:

- Core/fuel burnup
- Time after shutdown
- Water level at the beginning of the event
- How much water, if any, was added before addition/injection capability was lost

The task force also considered the impacts from information uncertainties that could accompany the event, including:

- Some CONTAINMENT CLOSURE measures may be temporary and may not have remote indications
- Instrumentation for some indications may be out-of-service for scheduled maintenance or repair during the outage
- Changes in water levels may affect the availability or accuracy of some indications
- Determining the magnitude of changes to tank or sump levels may be a judgment call

8 INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI) ICS/EALS

Table E-1: Recognition Category “I” Initiating Condition Matrix

UNUSUAL EVENT

E-HU1 Damage to a loaded spent fuel cask.
Op. Modes: All

Table intended for use by
EAL developers.
Inclusion in licensee
documents is not required.

E-HU1

ECL: Notification of Unusual Event

Initiating Condition: Damage to a loaded spent fuel cask.

Operating Mode Applicability: All

Example Emergency Action Level:

Notes:

- “Normal radiation levels” means the most recent available radiation survey result at the location of a reading or as determined by licensee expertise and experience.
- The “pad boundary” is the outer edge of the reinforced concrete pad designed to bear the weight of the stored casks.

(1) A closed window survey indicates **EITHER** of the following:

- a. For a loaded spent fuel cask on the ISFSI pad - A general area dose rate greater than 10x normal radiation levels at any point along the pad boundary.

OR

- b. For a loaded spent fuel cask in transit to the ISFSI pad – A cask dose rate greater than 10x the dose rate measured at the time the cask was sealed, at approximately the same distance.

Basis:

This IC addresses an event or condition that damages a cask loaded with spent nuclear fuel. The cause of the damage could be internal (e.g., a failure caused by chemical or environmental degradation) or external (e.g., an earthquake, tornado strike or flood), including man-made causes (e.g., a dropped or tipped over cask, or an EXPLOSION). The issues of concern are the potential creation of a radioactivity release pathway to the environment, degradation of cask shielding, degradation of the loaded fuel assemblies, and configuration changes that could challenge removal the cask or spent fuel from storage. The emphasis for this classification is the degradation in the level of safety of the cask and not the magnitude of an associated dose, dose rate, or radioactivity release.

The term “cask” encompasses the following components:

- *[List of Components - See Developer Notes]*

The IC is applicable at all times after a cask has been loaded with spent nuclear fuel and sealed (welded or bolted closed), regardless of location (e.g., in the fuel building, during transit to the ISFSI, or in storage at the ISFSI). Prior to the sealing of a cask, an event involving spent fuel would be assessed against the Recognition Category A, “Abnormal Radiation Levels / Radiological Effluent,” ICs/EALs to determine if an emergency declaration is warranted.

To support the capability to make a timely emergency classification, the EAL uses confirmatory radiation readings as an indication of damage sufficient to warrant an Unusual Event declaration. This approach obviates the need for a protracted post-event damage inspection and assessment to support the emergency classification. For casks in storage, the radiation readings may be taken at locations along the pad boundary that can be safely accessed by an individual with a hand-held monitor, consistent with the site radiological and industrial safety requirements.

The “pad boundary” means the outer edge of the reinforced concrete pad designed to bear the weight of the stored casks. This boundary is inside the ISFSI Protected Area and Controlled Area.

In the case of extreme damage, radiological or other safety considerations may necessitate that a dose rate be measured at a distance greater than that specified in the EAL. The intent is for personnel to start taking radiation readings at some distance from the pad boundary or the cask and continue their approach while taking readings. If at any point during the approach the EAL is met, then no survey at a closer location is required for EAL assessment purposes.

Security-related events for an ISFSI are covered under ICs HU1 and HA1.

Developer Notes:

For (*List of Components*), enter the primary/major components used to transfer and store dry spent nuclear fuel. Depending on the technology in use, this would typically be one or more of the following:

- Bare fuel storage cask
- Storage canister
- Transfer cask
- Storage cask/module
- Concrete cask/overpack

A “bare fuel storage cask” is a heavy-walled, bolted lid metal cask into which the individual “bare” fuel assemblies are loaded; it does not incorporate a welded canister.

The multiple of 10x was determined to provide a reasonable threshold for declaring an Unusual Event (e.g., normal readings are typically in the range of 0.1 to 1 mR). A reading of greater than 10x normal radiation levels or the cask dose rate at the time of sealing is sufficient to indicate that a degradation in the level of safety of a cask may have occurred but is high enough to accommodate fluctuations in background radiation due to natural causes. Field survey results are generally available only as a “whole body” dose rate; for this reason, the EAL specifies a “closed window” survey reading.

This IC could be assessed following an observable/detectable event (e.g., an earthquake or explosion) or because of a reading from a routine survey; however, all assessments should be made using existing licensee procedures and capabilities. There is no expectation for a licensee to install additional instrumentation or change the type or frequency of routine surveys.

It should be noted that the minimum distance from the ISFSI to the nearest boundary of the controlled area must be at least 100 meters (per 10 CFR 72.106); therefore, radiation levels at the

controlled area boundary would be a small fraction of the radiation levels measured at the pad boundary.

9 FISSION PRODUCT BARRIER ICS/EALS


Table 9-F-1: Recognition Category “F” Initiating Condition Matrix

ALERT	
FA1	Any Loss or any Potential Loss of either the Fuel Clad or RCS barrier. <i>Op. Modes: Power Operation, Hot Standby, Startup, Hot Shutdown</i>
SITE AREA EMERGENCY	
FS1	Loss or Potential Loss of any two barriers. <i>Op. Modes: Power Operation, Hot Standby, Startup, Hot Shutdown</i>
GENERAL EMERGENCY	
FG1	Loss of any two barriers and Loss or Potential Loss of the third barrier. <i>Op. Modes: Power Operation, Hot Standby, Startup, Hot Shutdown</i>

See Table 9-F-2 for BWR EALs

See Table 9-F-3 for PWR EALs

Developer Note: The adjacent logic flow diagram is for use by developers and is not required for site-specific implementation; however, a site-specific scheme must include some type of user-aid to facilitate timely and accurate classification of fission product barrier losses and/or potential losses. Such aids are typically comprised of logic flow diagrams, “scoring” criteria or checkbox-type matrices. The user-aid logic must be consistent with that of the adjacent diagram.



Developer Notes

1. The logic used for these initiating conditions reflects the following considerations:
 - The Fuel Clad Barrier and the RCS Barrier are weighted more heavily than the Containment Barrier.
 - Unusual Event ICs associated with fission product barriers are addressed in Recognition Category S.
2. For accident conditions involving a radiological release, evaluation of the fission product barrier thresholds will need to be performed in conjunction with dose assessments to ensure correct and timely escalation of the emergency classification. For example, an evaluation of the fission product barrier thresholds may result in a Site Area Emergency classification while a dose assessment may indicate that an EAL for General Emergency IC AG1 has been exceeded.
3. The fission product barrier thresholds specified within a scheme are expected to reflect plant-specific design and operating characteristics. This may require that developers create different thresholds than those provided in the generic guidance.
4. Alternative presentation methods for the Recognition Category F ICs and fission product barrier thresholds are acceptable and include flow charts, block diagrams, and checklist-type tables. Developers must ensure that the site-specific method addresses all possible threshold combinations and classification outcomes shown in the BWR or PWR EAL fission product barrier tables. The NRC staff considers the presentation method of the Recognition Category F information to be an important user aid and may request a change to a particular proposed method if, among other reasons, the change is necessary to promote consistency across the industry.
5. As used in this Recognition Category, the term RCS leakage encompasses not just those types defined in Technical Specifications but also includes the loss of RCS mass to any location— inside containment, a secondary-side system (i.e., PWR steam generator tube leakage), an interfacing system, or outside of containment. The release of liquid or steam mass from the RCS due to the as-designed/expected operation of a relief valve is not considered to be RCS leakage.
6. The RCS will not be an effective fission product barrier during conditions where an AOP or EOP requires the opening of one or more RCS valves to establish and maintain a safety function. For example, if a PWR experiences a protracted loss of feedwater to the steam generators and an EOP directs operators to open a pressurizer relief valve to implement a core cooling strategy (a “feed and bleed” cooldown), then there will exist a reactor coolant flow path from the RCS to the containment. Operators cannot isolate this path without compromising the effectiveness of the strategy; therefore, the flow through the pressure relief line is UNISOLABLE. In this case, the ability of the RCS to serve as an effective barrier to a release of fission products has been eliminated and thus this condition constitutes a loss of the RCS barrier. Although captured in the definition of UNISOLABLE, developers may add clarifying wording reflecting this position in appropriate threshold bases or notes.

7. At the Site Area Emergency level, classification decision-makers should maintain cognizance of how far present conditions are from meeting a threshold that would require a General Emergency declaration. For example, if the Fuel Clad and RCS fission product barriers were both lost, then there should be frequent assessments of containment radioactive inventory and integrity. Alternatively, if both the Fuel Clad and RCS fission product barriers were potentially lost, the Shift Manager/Emergency Director would have more assurance that there was no immediate need to escalate to a General Emergency.
8. The ability to escalate to a higher emergency classification level in response to degrading conditions should be maintained. For example, a steady increase in RCS leakage would represent an increasing risk to public health and safety.

Table 9-F-2: BWR EAL Fission Product Barrier Table
Thresholds for LOSS or POTENTIAL LOSS of Barriers

FA1 ALERT Any Loss or any Potential Loss of either the Fuel Clad or RCS barrier.	FS1 SITE AREA EMERGENCY Loss or Potential Loss of any two barriers.	FG1 GENERAL EMERGENCY Loss of any two barriers and Loss or Potential Loss of the third barrier.
--	---	---

Fuel Clad Barrier		RCS Barrier		Containment Barrier	
LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS
1. Not Applicable		1. Primary Containment Pressure		1. Primary Containment Conditions	
Not Applicable	Not Applicable	A. Primary containment pressure greater than (site-specific value) due to RCS leakage.	Not Applicable	A. UNPLANNED rapid drop in primary containment pressure following primary containment pressure rise. OR B. Primary containment pressure response not consistent with LOCA conditions.	A. Primary containment pressure greater than (site-specific value). OR B. (site-specific deflagration mixture) exists inside primary containment. OR C. HCTL exceeded.
2. RPV Water Level		2. RPV Water Level		2. RPV Water Level	
A. SAG entry required.	A. RPV water level cannot be restored and maintained above (site-specific RPV water level corresponding to the top of active fuel) or cannot be	A. RPV water level cannot be restored and maintained above (site-specific RPV water level corresponding to the top of active	Not Applicable	Not Applicable	A. It cannot be determined that core debris will be retained in the RPV.

Fuel Clad Barrier		RCS Barrier		Containment Barrier	
LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS
	determined.	fuel) or cannot be determined.			
3. Not Applicable		3. RCS Leakage		3. Primary Containment Isolation Failure	
Not Applicable	Not Applicable	<p>A. UNISOLABLE break in ANY of the following: (site-specific systems with potential for high-energy line breaks).</p> <p>OR</p> <p>B. Emergency RPV Depressurization.</p>	<p>A. UNISOLABLE primary system leakage that results in exceeding EITHER of the following:</p> <ol style="list-style-type: none"> 1. Max Normal Operating Temperature. 2. Max Normal Operating Area Radiation Level. 	<p>A. UNISOLABLE direct downstream pathway to the environment exists after primary containment isolation signal.</p> <p>OR</p> <p>B. Intentional primary containment venting per EOPs/SAGs.</p> <p>OR</p> <p>C. UNISOLABLE primary system leakage that results in exceeding EITHER of the following:</p> <ol style="list-style-type: none"> 1. Max Safe Operating Temperature. 2. Max Safe Operating Area Radiation Level. 	<p>A. Dose assessment using actual meteorology indicates doses greater than 750 mrem TEDE at or beyond site boundary.</p> <p>OR</p> <p>B. Field survey results indicate closed window dose rates greater than 750 mR/hr at or beyond the site boundary that are expected to continue for 60 minutes or longer.</p>

Fuel Clad Barrier		RCS Barrier		Containment Barrier	
LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS
4. Emergency Director Judgment		4. Emergency Director Judgment		4. Emergency Director Judgment	
A. ANY condition in the opinion of the Emergency Director that indicates Loss of the Fuel Clad Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Potential Loss of the Fuel Clad Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Loss of the RCS Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Potential Loss of the RCS Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Loss of the Containment Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Potential Loss of the Containment Barrier.

**Basis Information For
BWR EAL Fission Product Barrier Table 9-F-2**

BWR FUEL CLAD BARRIER THRESHOLDS:

The Fuel Clad Barrier consists of the zircalloy or stainless steel fuel bundle tubes that contain the fuel pellets.

1. **Not Applicable** (included for numbering consistency across barrier columns)
2. **RPV Water Level**

Loss 2.A

EOPs specify the plant conditions that require entry into the Severe Accident Guidelines (SAGs). A SAG entry indicates that either adequate core cooling cannot be assured, a condition likely to involve a loss of the fuel clad barrier, or core damage has already occurred.

Potential Loss 2.A

This water level corresponds to the top of the active fuel and is used in the EOPs to indicate a challenge to core cooling.

The RPV water level threshold is the same as RCS barrier Loss threshold 2.A. Thus, this threshold indicates a Potential Loss of the Fuel Clad barrier and a Loss of the RCS barrier that appropriately escalates the emergency classification level to a Site Area Emergency.

This threshold is considered to be exceeded when, as specified in the site-specific EOPs, RPV water cannot be restored and maintained above the specified level following depressurization of the RPV (either manually, automatically or by failure of the RCS barrier) or when procedural guidance or a lack of low pressure RPV injection sources preclude Emergency RPV depressurization. EOPs allow the operator a wide choice of RPV injection sources to consider when restoring RPV water level to within prescribed limits. EOPs also specify depressurization of the RPV in order to facilitate RPV water level control with low-pressure injection sources. In some events, elevated RPV pressure may prevent restoration of RPV water level until pressure drops below the shutoff heads of available injection sources. Therefore, this Fuel Clad barrier Potential Loss is met only after either: 1) the RPV has been depressurized, or required emergency RPV depressurization has been attempted, giving the operator an opportunity to assess the capability of low-pressure injection sources to restore RPV water level or 2) no low pressure RPV injection systems are available, precluding RPV depressurization in an attempt to minimize loss of RPV inventory.

The term “cannot be restored and maintained above” means the value of RPV water level is not able to be brought above the specified limit (top of active fuel). The determination requires an evaluation of system performance and availability in relation to the RPV water level value and trend. A threshold prescribing declaration when a threshold value *cannot* be restored and maintained above a specified limit does not require immediate action simply because the current value is below the top of active fuel, but does not

permit extended operation below the limit; the threshold must be considered reached as soon as it is apparent that the top of active fuel cannot be attained.

In high-power ATWS/failure to scram events, EOPs may direct the operator to deliberately lower RPV water level to the top of active fuel in order to reduce reactor power. RPV water level is then controlled between the top of active fuel and the Minimum Steam Cooling RPV Water Level (MSCRWL). Provided RPV water level is being controlled and maintained within the procedurally specified band, this potential loss threshold is not met.

Since the loss of ability to determine if adequate core cooling is being provided presents a significant challenge to the fuel clad barrier, a potential loss of the fuel clad barrier is specified.

Developer Notes:

Loss 2.A

None

Potential Loss 2.A

The decision that "RPV water level cannot be determined" is directed by guidance given in the RPV water level control sections of the EOPs.

3. **Not Applicable** (included for numbering consistency across barrier columns)
4. **Emergency Director Judgment**

Loss 4.A

This threshold addresses any other factors that are to be used by the Shift Manager/Emergency Director in determining whether the Fuel Clad Barrier is lost.

Potential Loss 4.A

This threshold addresses any other factors that may be used by the Shift Manager/Emergency Director in determining whether the Fuel Clad Barrier is potentially lost. The Shift Manager/Emergency Director should also consider whether or not to declare the barrier potentially lost in the event that barrier status cannot be monitored.

Developer Notes:

None

BWR RCS BARRIER THRESHOLDS:

The RCS Barrier is the reactor coolant system pressure boundary and includes the RPV and all reactor coolant system piping up to and including the isolation valves.

1. Primary Containment Pressure

Loss 1.A

The (site-specific value) primary containment pressure is the drywell high pressure setpoint which indicates a LOCA by automatically initiating the ECCS or equivalent makeup system.

Developer Notes:

None

2. RPV Water Level

Loss 2.A

This water level corresponds to the top of active fuel and is used in the EOPs to indicate challenge to core cooling.

The RPV water level threshold is the same as Fuel Clad barrier Potential Loss threshold 2.A. Thus, this threshold indicates a Loss of the RCS barrier and Potential Loss of the Fuel Clad barrier and that appropriately escalates the emergency classification level to a Site Area Emergency.

This threshold is considered to be exceeded when, as specified in the site-specific EOPs, RPV water cannot be restored and maintained above the specified level following depressurization of the RPV (either manually, automatically or by failure of the RCS barrier) or when procedural guidance or a lack of low pressure RPV injection sources preclude Emergency RPV depressurization. EOPs allow the operator a wide choice of RPV injection sources to consider when restoring RPV water level to within prescribed limits. EOPs also specify depressurization of the RPV in order to facilitate RPV water level control with low-pressure injection sources. In some events, elevated RPV pressure may prevent restoration of RPV water level until pressure drops below the shutoff heads of available injection sources. Therefore, this RCS barrier Loss is met only after either: 1) the RPV has been depressurized, or required emergency RPV depressurization has been attempted, giving the operator an opportunity to assess the capability of low-pressure injection sources to restore RPV water level or 2) no low pressure RPV injection systems are available, precluding RPV depressurization in an attempt to minimize loss of RPV inventory.

The term, “cannot be restored and maintained above,” means the value of RPV water level is not able to be brought above the specified limit (top of active fuel). The determination requires an evaluation of system performance and availability in relation to the RPV water level value and trend. A threshold prescribing declaration when a threshold value *cannot* be restored and maintained above a specified limit does not

require immediate action simply because the current value is below the top of active fuel, but does not permit extended operation beyond the limit; the threshold must be considered reached as soon as it is apparent that the top of active fuel cannot be attained.

In high-power ATWS/failure to scram events, EOPs may direct the operator to deliberately lower RPV water level to the top of active fuel in order to reduce reactor power. RPV water level is then controlled between the top of active fuel and the Minimum Steam Cooling RPV Water Level (MSCRWL). Provided RPV water level is being controlled and maintained within the procedurally specified band, this loss threshold is not met.

Developer Notes:

None

3. RCS Leakage

Loss Threshold 3.A

Large high-energy lines that rupture outside primary containment can discharge significant amounts of inventory and jeopardize the pressure-retaining capability of the RCS until they are isolated. The RCS barrier should be considered lost, and the appropriate emergency declaration made as soon as the plant operator determines that the leak cannot be isolated and, in all cases, within 15 minutes of initial event indications.

Loss Threshold 3.B

If emergency RPV depressurization is required, plant operators are directed by EOPs to vent the RPV using the safety relief valves (SRVs) or an alternative depressurization system/method. When this condition occurs, the RCS barrier should be considered lost. This is true even when venting the RPV into the suppression pool since the RCS will have a diminished capability to retain fission products within its boundary under emergency conditions.

Potential Loss Threshold 3.A

Potential loss of RCS based on primary system leakage outside the primary containment is determined from EOP temperature or radiation Max Normal Operating values in areas such as main steam line tunnel, RCIC, HPCI, etc., which indicate a direct path from the RCS to areas outside primary containment.

A Max Normal Operating value is the highest value of the identified parameter expected to occur during normal plant operating conditions with all directly associated support and control systems functioning properly.

The indicators reaching the threshold barriers and confirmed to be caused by RCS leakage from a primary system warrant an Alert classification. A primary system is defined to be the pipes, valves, and other equipment which connect directly to the RPV such that a reduction in RPV pressure will effect a decrease in the steam or water being discharged through an unisolated break in the system.

An UNISOLABLE leak which is indicated by Max Normal Operating values escalates to a Site Area Emergency when combined with Containment Barrier Loss threshold 3.A (after a containment isolation) and a General Emergency when the Fuel Clad Barrier criteria is also exceeded.

Developer Notes:

Loss Threshold 3.A

The list of systems included in this threshold should be the high energy lines which, if ruptured and remain unisolated, can rapidly depressurize the RPV. These lines are typically isolated by actuation of the Leak Detection system.

Large high-energy line breaks such as Main Steam Line (MSL), High Pressure Coolant Injection (HPCI), Feedwater, Reactor Water Cleanup (RWCU), Isolation Condenser (IC) or Reactor Core Isolation Cooling (RCIC) that are UNISOLABLE represent a significant loss of the RCS barrier.

Loss Threshold 3.B

None

Potential Loss Threshold 3.A

The indications used to assess Max Normal temperature and radiation levels should be readily accessible.

4. Emergency Director Judgment

Loss 4.A

This threshold addresses any other factors that are to be used by the Shift Manager/Emergency Director in determining whether the RCS barrier is lost.

Potential Loss 4.A

This threshold addresses any other factors that may be used by the Shift Manager/Emergency Director in determining whether the RCS Barrier is potentially lost. The Shift Manager/Emergency Director should also consider whether or not to declare the barrier potentially lost in the event that barrier status cannot be monitored.

Developer Notes:

None

BWR CONTAINMENT BARRIER THRESHOLDS:

The Primary Containment Barrier includes the drywell, the wetwell, their respective interconnecting paths, and other connections up to and including the outermost containment isolation valves. Containment Barrier thresholds are used as criteria for escalation of the ECL from Alert to a Site Area Emergency or a General Emergency.

1. Primary Containment Conditions

Loss 1.A and 1.B

Rapid UNPLANNED loss of primary containment pressure (i.e., not attributable to drywell spray or condensation effects) following an initial pressure increase indicates a loss of primary containment integrity. Primary containment pressure should increase as a result of mass and energy release into the primary containment from a LOCA. Thus, primary containment pressure not increasing under these conditions indicates a loss of primary containment integrity.

These thresholds rely on operator recognition of an unexpected response for the condition and therefore a specific value is not assigned. The unexpected (UNPLANNED) response is important because it is the indicator for a containment bypass condition.

Potential Loss 1.A

The threshold pressure is the primary containment internal design pressure. Structural acceptance testing demonstrates the capability of the primary containment to resist pressures greater than the internal design pressure. A pressure of this magnitude is greater than those expected to result from any design basis accident and, thus, represent a Potential Loss of the Containment barrier.

Potential Loss 1.B

An elevated hydrogen concentration in the presence of oxygen may lead to a deflagration of the mixture inside the primary containment. The rapid burning of this mixture will lead to a pressure increase that could result in a loss of the primary containment barrier.

Potential Loss 1.C

The Heat Capacity Temperature Limit (HCTL) is the highest suppression pool temperature from which Emergency RPV Depressurization will not raise:

- Suppression chamber temperature above the maximum temperature capability of the suppression chamber and equipment within the suppression chamber which may be required to operate when the RPV is pressurized,

OR

- Suppression chamber pressure above the Primary Containment Pressure Limit, while the rate of energy transfer from the RPV to the containment is greater than the capacity of the containment vent.

The HCTL is a function of RPV pressure, suppression pool temperature and suppression pool water level. It is utilized to preclude failure of the containment and equipment in the containment necessary for the safe shutdown of the plant and therefore, the inability to maintain plant parameters below the limit constitutes a potential loss of containment.

Developer Notes:

Potential Loss 1.B

BWR EPGs/SAGs specifically define the limits associated with explosive mixtures in terms of deflagration concentrations of hydrogen and oxygen. For Mk I/II containments the deflagration limits are “6% hydrogen and 5% oxygen in the drywell or suppression chamber”. For Mk III containments, the limit is the “Hydrogen Deflagration Overpressure Limit”. The threshold term “explosive mixture” is synonymous with the EPG/SAG “deflagration limits”.

Potential Loss 1.C

Since the HCTL is defined assuming a range of suppression pool water levels as low as the elevation of the downcomer openings in Mk I/II containments, or 2 feet above the elevation of the horizontal vents in a Mk III containment, it is unnecessary to consider separate Containment barrier Loss or Potential Loss thresholds for abnormal suppression pool water level conditions. If desired, developers may include a separate Containment Potential Loss threshold based on the inability to maintain suppression pool water level above the downcomer openings in Mk I/II containments, or 2 feet above the elevation of the horizontal vents in a Mk III containment with RPV pressure above the minimum decay heat removal pressure, if it will simplify the assessment of the suppression pool level component of the HCTL.

To align with site-specific EOPs, developers should determine if this threshold also needs to address HCTL criteria related to high suppression pool water level.

2. RPV Water Level

Potential Loss 2.A

This threshold is tied to an operationally significant decision within the SAGs and a precursor to a potential loss of containment. The determination is made from the evaluation of criteria identified in the SAGs and the supporting Technical Support Guidelines, and would occur prior to RPV failure and the release of core debris into the primary containment. If it cannot be determined that core debris will be retained in the RPV, then subsequent events could challenge primary containment integrity (e.g., implementation of containment venting).

Developer Notes:

None

3. Primary Containment Isolation Failure

These thresholds address incomplete containment isolation that allows an UNISOLABLE direct release to the environment.

Loss 3.A

A release path through an interfacing liquid system or a minor release pathway, such as an instrument line, not protected by the Primary Containment Isolation System (PCIS) is not a “direct” path. A release path is “direct” if it allows for the migration of radioactive material from the containment to the environment in a generally uninterrupted manner (e.g., little or no holdup time). A release through the wetwell is a direct release path. Although the water in the wetwell would cause some “scrubbing” of the release by reducing the amount of iodines and particulates, it would not affect the amount of noble gases (Kr, Xe) released to the environment. Noble gases contribute to whole body submersion or immersion dose from cloud shine.

The existence of a filter is not considered in the threshold assessment. Filters do not remove fission product noble gases. In addition, a filter could become ineffective due to iodine and/or particulate loading beyond design limits (i.e., retention ability has been exceeded) or water saturation from steam/high humidity in the release stream.

Following the leakage of RCS mass into primary containment and a rise in primary containment pressure, there may be minor radiological releases associated with allowable primary containment leakage through various penetrations or system components. Minor releases may also occur if a primary containment isolation valve(s) fails to close but the primary containment atmosphere escapes to an enclosed system. These releases do not constitute a loss or potential loss of primary containment but should be evaluated using the Recognition Category A ICs.

Loss 3.B

EOPs or SAGs may direct primary containment isolation valve logic(s) to be intentionally bypassed, even if offsite radioactivity release rate limits will be exceeded. Under these conditions with a valid primary containment isolation signal, the containment should also be considered lost if primary containment venting is actually performed.

Irrespective of the offsite radioactivity release rate, intentional venting of primary containment using EOP support procedures for primary containment pressure or combustible gas control in the EOPs, or for any reason in the SAGs, to the secondary containment and/or the environment is a Loss of the Containment. Venting for primary containment pressure control using normal operating procedures (e.g., to control pressure below the drywell high pressure scram setpoint while in the EOPs) does not meet the threshold condition.

Loss 3.C

The Max Safe Operating Temperature and the Max Safe Operating Radiation Level are each the highest value of these parameters at which neither: (1) equipment necessary for the safe shutdown of the plant will fail, nor (2) personnel access necessary for the safe shutdown of the plant will be precluded. EOPs utilize these temperatures and radiation levels to establish conditions under which RPV depressurization is required.

The temperatures and radiation levels should be confirmed to be caused by RCS leakage from a primary system. A primary system is defined to be the pipes, valves, and other equipment which connect directly to the RPV such that a reduction in RPV pressure will effect a decrease in the steam or water being discharged through an unisolated break in the system.

In combination with RCS potential loss 3.A this threshold would result in a Site Area Emergency.

Potential Loss 3.A and 3.B

These thresholds address a release of gaseous radioactivity that results in projected or actual offsite doses greater than 75% of the EPA PAGs; it includes both monitored and un-monitored releases. Releases of this magnitude indicate that containment leak rates are greater than the allowable leak rates described in site Technical Specifications, and thus a potential loss of Containment. When present with a loss of the Fuel Clad and RCS Barriers, meeting either threshold will appropriately escalate the ECL to a General Emergency.

Emergency classification based on dose projections assumes there is a release path to the environment. If the flow past an effluent monitor used in a dose projection is known to have stopped due to actions to isolate the release path, then the effluent monitor reading is no longer valid for classification purposes.

Developer Notes:

Loss 3.A

None

Loss 3.B

Consideration may be given to specifying the specific procedural step within the Primary Containment Control EOP that defines intentional venting of the Primary Containment regardless of offsite radioactivity release rate.

Loss 3.C

The indications used to assess Max Safe temperature and radiation levels should be readily accessible. If the normally used indications cannot be readily accessed during an emergency (e.g., readouts are in areas that may be inaccessible due to adverse

environmental conditions), then determine if alternate indications are available for use. If no indications are available, then this threshold should not be used.

Potential Loss 3.A and 3.B

The generic wording for these thresholds uses the term “site boundary.” A site may specify the same “site-specific dose receptor point” as used in ICs AA1, AS1, and AG1 provided that the location(s) is coincident with or relatively close to the site boundary (i.e., the Owner Controlled Area boundary). Relatively close should be understood to mean no greater than about ¼ mile away from the site boundary (on either side).

Although the IC references TEDE, field survey results are generally available only as a “whole body” dose rate. For this reason, the field survey EAL specifies a “closed window” survey reading.

4. Emergency Director Judgment

Loss 4.A

This threshold addresses any other factors that are to be used by the Shift Manager/Emergency Director in determining whether the Containment barrier is lost.

Potential Loss 4.A

This threshold addresses any other factors that may be used by the Shift Manager/Emergency Director in determining whether the Containment Barrier is potentially lost. The Shift Manager/Emergency Director should also consider whether or not to declare the barrier potentially lost in the event that barrier status cannot be monitored.

Developer Notes:

None

Table 9-F-3: PWR EAL Fission Product Barrier Table

Thresholds for LOSS or POTENTIAL LOSS of Barriers

FA1 ALERT Any Loss or any Potential Loss of either the Fuel Clad or RCS barrier.	FS1 SITE AREA EMERGENCY Loss or Potential Loss of any two barriers.	FG1 GENERAL EMERGENCY Loss of any two barriers and Loss or Potential Loss of the third barrier.
--	---	---

Fuel Clad Barrier		RCS Barrier		Containment Barrier	
LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS
1. RCS or SG Tube Leakage		1. RCS or SG Tube Leakage		1. RCS or SG Tube Leakage	
Not Applicable	A. RCS/reactor vessel level less than (site-specific level).	A. RCS subcooling has been lost.	A. An automatic or manual ECCS (SI) actuation is required by EITHER of the following: 1. UNISOLABLE RCS leakage OR 2. SG tube RUPTURE OR B. RCS cooldown rate greater than (site-specific pressurized thermal shock criteria/limits defined by site-specific indications).	A.1. There is a Potential Loss or Loss of the RCS Barrier due to a leaking or RUPTURED SG. AND 2. The leaking or RUPTURED SG is FAULTED outside of containment.	Not Applicable

Fuel Clad Barrier		RCS Barrier		Containment Barrier	
LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS
2. Inadequate Heat Removal		2. Inadequate Heat Removal		2. Inadequate Heat Removal	
A. Core exit thermocouple readings greater than (site-specific temperature value).	A. Core exit thermocouple readings greater than (site-specific temperature value).	Not Applicable	A. Inadequate RCS heat removal capability via steam generators as indicated by (site-specific indications).	Not Applicable	A. 1. (Site-specific criteria for entry into core cooling restoration procedure) AND 2. Restoration procedure not effective within 15 minutes.
3. Containment Integrity or Bypass		3. Containment Integrity or Bypass		3. Containment Integrity or Bypass	
Not Applicable	Not Applicable	Not Applicable	Not Applicable	A. Containment isolation is required AND EITHER of the following: 1. Containment integrity has been lost based on Emergency Director judgment. OR 2. UNISOLABLE pathway from the containment atmosphere to the environment exists. OR	A. Containment pressure greater than (site-specific value). OR B. Flammable mixture in containment atmosphere. OR C. Dose assessment using actual meteorology indicates doses greater than 750 mrem TEDE at or beyond the site boundary. OR

Fuel Clad Barrier		RCS Barrier		Containment Barrier	
LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS
				<p>B. 1. There is a Potential Loss or Loss of the RCS Barrier due to UNISOLABLE RCS leakage. AND</p> <p>2. The leakage is to a location outside of containment.</p>	<p>D. Field survey results indicate closed window dose rates greater than 750 mR/hr at or beyond the site boundary that are expected to continue for 60 minutes or longer.</p>
4. Emergency Director Judgment		4. Emergency Director Judgment		4. Emergency Director Judgment	
A. ANY condition in the opinion of the Emergency Director that indicates Loss of the Fuel Clad Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Potential Loss of the Fuel Clad Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Loss of the RCS Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Potential Loss of the RCS Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Loss of the Containment Barrier.	A. ANY condition in the opinion of the Emergency Director that indicates Potential Loss of the Containment Barrier.

Basis Information For PWR EAL Fission Product Barrier Table 9-F-3

Developer Notes:

Threshold Parameters and Values

Each PWR owner's group has developed a methodology for guiding the development and implementation of EOPs (i.e., assessing plant parameters, and determining and prioritizing operator actions). Many of the thresholds contained in the PWR EAL Fission Product Barrier Table reflect conditions that are specifically addressed in EOPs (e.g., a loss of heat removal capability by the steam generators). When developing a site-specific threshold, developers should use the parameters and values specified within their EOPs that align with the condition described by the generic threshold and basis, and related developer notes. This approach will ensure consistency between the site-specific EOPs and emergency classification scheme, and thus facilitate more timely and accurate classification assessments.

In support of EOP development and implementation, the Westinghouse Owners Group (WOG) developed a defined set of Critical Safety Functions as part of their Emergency Response Guidelines. The WOG approach structures EOPs to maintain and/or restore these Critical Safety Functions, and to do so in a prioritized and systematic manner. The WOG Critical Safety Functions are presented below.

- Subcriticality
- Core Cooling
- Heat Sink
- RCS Integrity
- Containment
- RCS Inventory

The WOG ERGs provide a methodology for monitoring the status of the Critical Safety Functions and classifying the significance of a challenge to a function; this methodology is referred to as the Critical Safety Function Status Trees (CSFSTs). For plants that have implemented the WOG ERGs, the guidance in NEI 99-01 allows for use of certain CSFST assessment results as EALs and fission product barrier loss/potential loss thresholds. In this manner, an emergency classification assessment may flow directly from a CSFST assessment.

It is important to understand that the CSFSTs are evaluated using plant parameters, and that they are simply a vendor-specific method for collectively evaluating a set of parameters for purposes of driving emergency operating procedure usage. For the emergency conditions of interest, the generic thresholds within the PWR EAL Fission Product Barrier Table specify the plant parameters that define a potential loss or loss of a fission product barrier; however, as described in the associated Developer Notes, a CSFST terminus may be used as well. For this reason, inclusion of the CSFST-related thresholds would be redundant to the parameter-based thresholds for plants that employ the WOG ERGs.

Sites that employ the WOG ERGs may, at their discretion, include the CSFST-based loss and potential loss thresholds as described in the Developer Notes. Developers at these sites should consult with their classification decision-makers to determine if inclusion would assist with

timely and accurate emergency classification. This decision should consider the effects of any site-specific changes to the generic WOG CSFST evaluation logic and setpoints, as well as those arising from user rules applicable to emergency operating procedures (e.g., exceptions to procedure entry or transition due to specific accident conditions or loss of a support system).

The CSFST thresholds may be addressed in one of 3 ways:

- 1) Not incorporated; thresholds will use parameters and values as discussed in the Developer Notes.
- 2) Incorporated along with parameter and value thresholds (e.g., a fuel clad loss would have 2 thresholds such as “CETs > 1200°F” and “Core Cooling Red entry conditions met”).
- 3) Used in lieu of parameters and values for all thresholds.

With one exception, if a decision is made to include the CSFST-based thresholds, then all such allowed thresholds must be used in the table (e.g., it is not permissible to use only the C Orange terminus as a potential loss of the fuel clad barrier threshold and disregard all other CSFST-based thresholds). The one exception is the RCS Integrity (P) CSFST. Because of the complexity of the P Red decision-point that relies on an assessment a pressure-temperature curve, a P Red condition may be used as an RCS potential loss threshold without the need to incorporate the other CSFST-based thresholds.

PWR FUEL CLAD BARRIER THRESHOLDS:

The Fuel Clad Barrier consists of the cladding material that contains the fuel pellets.

1. RCS or SG Tube Leakage

Potential Loss 1.A

This reading indicates a reduction in reactor vessel water level sufficient to allow the onset of heat-induced cladding damage.

Developer Notes:

Potential Loss 1.A

Enter the site-specific reactor vessel water level value(s) used by EOPs to identify a degraded core cooling condition (e.g., requires prompt restoration action). The reactor vessel level that corresponds to approximately the top of active fuel may also be used.

For plants that have implemented Westinghouse Owners Group Emergency Response Guidelines, enter the reactor vessel level(s) used for the Core Cooling Orange Path (including dependencies upon the status of RCPs, if applicable).

Westinghouse ERG Plants

Developers should consider including a threshold the same as, or similar to, “Core Cooling Orange entry conditions met” in accordance with the guidance at the front of this section.

2. Inadequate Heat Removal

Loss 2.A

This reading indicates temperatures within the core are sufficient to cause significant superheating of reactor coolant.

Potential Loss 2.A

This reading indicates temperatures within the core are sufficient to allow the onset of heat-induced cladding damage.

Developer Notes:

Some site-specific EOPs and/or EOP user guidelines may establish decision-making criteria concerning the number or other attributes of thermocouple readings necessary to drive actions (e.g., 5 CETs reading greater than 1,200°F is required before transitioning to an inadequate core cooling procedure). To maintain consistency with EOPs, these decision-making criteria may be used in the core exit thermocouple reading thresholds.

Loss 2.A

Enter a site-specific temperature value that corresponds to significant in-core superheating of reactor coolant. 1,200°F may also be used.

For plants that have implemented Westinghouse Owners Group Emergency Response Guidelines, enter the parameters and values used in the Core Cooling Red Path.

Potential Loss 2.A

Enter a site-specific temperature value that corresponds to core conditions at the onset of heat-induced cladding damage (e.g., the temperature allowing for the formation of superheated steam assuming that the RCS is intact). 700°F may also be used.

For plants that have implemented Westinghouse Owners Group Emergency Response Guidelines, enter the parameters and values used in the Core Cooling Orange Path.

Westinghouse ERG Plants

As a loss indication, developers should consider including a threshold the same as, or similar to, “Core Cooling Red entry conditions met” in accordance with the guidance at the front of this section.

As a potential loss indication, developers should consider including a threshold the same as, or similar to, “Core Cooling Orange entry conditions met” in accordance with the guidance at the front of this section.

3. Containment Integrity or Bypass

Not Applicable (included for numbering consistency across barrier columns)

4. Emergency Director Judgment

Loss 4.A

This threshold addresses any other factors that may be used by the Shift Manager/Emergency Director in determining whether the Fuel Clad Barrier is lost.

Potential Loss 4.A

This threshold addresses any other factors that may be used by the Shift Manager/Emergency Director in determining whether the Fuel Clad Barrier is potentially lost. The Shift Manager/Emergency Director should also consider whether or not to declare the barrier potentially lost in the event that barrier status cannot be monitored.

Developer Notes:

None

PWR RCS BARRIER THRESHOLDS:

The RCS Barrier includes the RCS primary side and its connections up to and including the pressurizer safety and relief valves, and other connections up to and including the primary isolation valves.

1. RCS or SG Tube Leakage

Loss 1.A

This threshold addresses conditions where leakage from the RCS is greater than the capacity of available inventory control/makeup systems such that a loss of subcooling has occurred. The loss of subcooling is the fundamental indication that inventory control/makeup systems cannot adequately maintain RCS pressure and inventory against the mass loss through the leak. This condition represents a loss of the RCS Barrier.

Potential Loss 1.A

This threshold is based on an UNISOLABLE RCS leak of sufficient size to require an automatic or manual actuation of the Emergency Core Cooling System (ECCS). This condition represents a potential loss of the RCS Barrier.

This threshold is applicable to unidentified and pressure boundary leakage, as well as identified leakage. It is also applicable to UNISOLABLE RCS leakage through an interfacing system. The mass loss may be into any location – inside containment, to the secondary-side (i.e., steam generator tube leakage) or outside of containment.

A steam generator with primary-to-secondary leakage of sufficient magnitude to require a safety injection is considered to be RUPTURED. If a RUPTURED steam generator is also FAULTED outside of containment, the declaration escalates to a Site Area Emergency since the Containment Barrier Loss threshold 1.A will also be met.

Potential Loss 1.B

This condition indicates an extreme challenge to the integrity of the RCS pressure boundary due to pressurized thermal shock – a transient that causes rapid RCS cooldown while the RCS is in Mode 3 or higher (i.e., hot and pressurized).

Developer Notes:

Loss 1.A

None

Potential Loss 1.A

Actuation of the ECCS may also be referred to as Safety Injection (SI) actuation or other appropriate site-specific term.

Potential Loss 1.B

Enter the site-specific indications that define an extreme challenge to the integrity of the RCS pressure boundary due to pressurized thermal shock – a transient that causes rapid RCS cooldown while the RCS is in Mode 3 or higher (i.e., hot and pressurized). These will typically be parameters and values that would require operators to take prompt action to address a pressurized thermal shock condition. Developers should also determine if the threshold needs to reflect any dependencies used as EOP transition/entry decision points or condition validation criteria (e.g., an EOP used to respond to an excessive RCS cooldown may not be entered or immediately exited if RCS pressure is below a certain value).

For plants that have implemented Westinghouse Owners Group Emergency Response Guidelines, enter the parameters and values used in the RCS Integrity Red Path. Because of the complexity of certain decision-points within the Red Path of this CSFST, developers at these plants may elect to not include the specific parameters and values, and instead follow the guidance below.

Westinghouse ERG Plants

As a potential loss indication, developers should consider including a threshold the same as, or similar to, “RCS Integrity Red entry conditions met” in accordance with the guidance at the front of this section. As noted above, developers should ensure that the threshold wording reflects any EOP transition/entry decision points or condition validation criteria. For example, a threshold might read “RCS Integrity (P) Red entry conditions met with RCS pressure > 300 psig.”

2. Inadequate Heat Removal

Potential Loss 2.A

This condition indicates an extreme challenge to the ability to remove RCS heat using the steam generators (i.e., loss of an effective secondary-side heat sink). This condition represents a potential loss of the RCS Barrier. In accordance with EOPs, there may be unusual accident conditions during which operators intentionally reduce the heat removal capability of the steam generators; during these conditions, classification using threshold is not warranted.

Developer Notes:

Potential Loss 2.A

Enter the site-specific parameters and values that define an extreme challenge to the ability to remove heat from the RCS via the steam generators. These will typically be parameters and values that would require operators to take prompt action to address this condition.

For plants that have implemented Westinghouse Owners Group Emergency Response Guidelines, enter the parameters and values used in the Heat Sink Red Path. Plants using

EOP guidance for Combustion Engineering NSSS designs should enter RCS/Core Heat Removal functional recovery safety function criteria or Once-Through-Cooling criteria.

Westinghouse ERG Plants

Developers should consider including a threshold the same as, or similar to, “Heat Sink Red entry conditions met when heat sink is required” in accordance with the guidance at the front of this section.

3. Containment Integrity or Bypass

Not Applicable (included for numbering consistency across barrier columns)

4. Emergency Director Judgment

Loss 4.A

This threshold addresses any other factors that may be used by the Shift Manager/Emergency Director in determining whether the RCS Barrier is lost.

Potential Loss 4.A

This threshold addresses any other factors that may be used by the Shift Manager/Emergency Director in determining whether the RCS Barrier is potentially lost. The Shift Manager/Emergency Director should also consider whether or not to declare the barrier potentially lost in the event that barrier status cannot be monitored.

Developer Notes:

None

PWR CONTAINMENT BARRIER THRESHOLDS:

The Containment Barrier includes the containment building and connections up to and including the outermost containment isolation valves. This barrier also includes the main steam, feedwater, and blowdown line extensions outside the containment building up to and including the outermost secondary side isolation valve. Containment Barrier thresholds are used as criteria for escalation of the ECL from Alert to a Site Area Emergency or a General Emergency.

1. RCS or SG Tube Leakage

Loss 1.A

This threshold addresses a leaking or RUPTURED Steam Generator (SG) that is also FAULTED outside of containment. The SG leakage or RUPTURE condition must be associated with RCS leakage meeting the threshold for either RCS Barrier Loss 1.A or RCS Barrier Potential Loss 1.A. This condition represents a bypass of the containment barrier.

FAULTED is a defined term within the NEI 99-01 methodology; this determination is not necessarily dependent upon entry into, or diagnostic steps within, an EOP. For example, if the pressure in a steam generator is decreasing uncontrollably [*part of the FAULTED definition*] and the faulted steam generator isolation procedure is not entered because EOP user rules are dictating implementation of another procedure to address a higher priority condition, the steam generator is still considered FAULTED for emergency classification purposes.

The FAULTED criterion establishes an appropriate lower bound on the size of a steam release that may require an emergency classification. Steam releases of this size are readily observable with normal Control Room indications.

Steam releases associated with the expected operation of a SG power operated relief valve or safety relief valve do not meet the intent of this threshold. Such releases may occur intermittently for a short period of time following a reactor trip as operators process through emergency operating procedures to bring the plant to a stable condition and prepare to initiate a plant cooldown. Steam releases associated with the unexpected operation of a valve (e.g., a stuck-open safety valve) do meet this threshold.

Following an SG tube leak or rupture, there may be minor radiological releases through a secondary-side system component (e.g., air ejectors, gland seal exhausters, valve packing, etc.). These types of releases do not constitute a loss or potential loss of containment but should be evaluated using the Recognition Category A ICs.

The emergency classification levels resulting from primary-to-secondary leakage, with or without a steam release from the FAULTED SG, are summarized below.

P-to-S Leak Rate	Affected SG is FAULTED Outside of Containment?	
	Yes	No
Requires an automatic or manual ECCS (SI) actuation (<i>RCS Barrier Potential Loss</i>)	Site Area Emergency per FS1	Alert per FA1
Results in a loss of RCS subcooling (<i>RCS Barrier Loss</i>)	Site Area Emergency per FS1	Alert per FA1

Developer Notes:

Loss 1.A

A steam generator power operated relief valve may also be referred to as an atmospheric steam dump valve or other appropriate site-specific term.

Depending upon the plant design, developers should also include an additional site-specific threshold and/or basis statements to address prolonged steam releases necessitated by operational considerations. For example, the AOPs or EOPs for a 2-loop plant could require the steaming of a leaking or RUPTURED steam generator to cooldown the plant if the other steam generator is FAULTED. Forced steaming of a leaking or RUPTURED steam generator may result in a significant and sustained release of radioactive steam to the environment which cannot be terminated without impacting a procedurally driven cooldown strategy. The inability to isolate the steam flow without an adverse effect on plant cooldown meets the intent of a loss of containment.

Developers may wish to consider incorporating the above table into user aids (e.g., a wallboard) or other locations within their basis document.

2. Inadequate Heat Removal

Potential Loss 2.A

This condition represents a potential core melt sequence which, if not corrected, could lead to vessel failure and an increased potential for containment failure. For this condition to occur, there must already have been a loss of the RCS Barrier and the Fuel Clad Barrier. If implementation of a procedure(s) to restore adequate core cooling is not effective (successful) within 15 minutes, it is assumed that the event trajectory will likely lead to core melting and a subsequent challenge of the Containment Barrier.

The restoration procedure is considered “effective” if core exit thermocouple readings are decreasing and/or if reactor vessel level is increasing. Whether or not the procedure(s) will be effective should be apparent within 15 minutes. The Shift Manager/Emergency Director should escalate the emergency classification level as soon as it is determined that the procedure(s) will not be effective.

Severe accident analyses (e.g., NUREG-1150) have concluded that function restoration procedures can arrest core degradation in a significant fraction of core damage scenarios, and that the likelihood of containment failure is very small in these events. Given this, it is appropriate to provide 15 minutes beyond the required entry point to determine if procedural actions can reverse the core melt sequence.

Developer Notes:

Enter site-specific criteria requiring entry into a core cooling restoration procedure or prompt implementation of core cooling restoration actions. A reading of 1,200°F on the CETs may also be used.

For plants that have implemented Westinghouse Owners Group Emergency Response Guidelines, enter the parameters and values used in the Core Cooling Red Path.

As an alternative, a developer may use the threshold statement “Entry into a severe accident management procedure is required.” This alternative is acceptable in cases where EOPs and/or functional restoration procedures direct operators to enter a severe accident management procedure in response to the inability to maintain core temperatures below a certain value.

Some site-specific EOPs and/or EOP user guidelines may establish decision-making criteria concerning the number or other attributes of thermocouple readings necessary to drive actions (e.g., 5 CETs reading greater than 1,200°F is required before transitioning to an inadequate core cooling procedure). To maintain consistency with EOPs, these decision-making criteria may be used in the core exit thermocouple reading thresholds.

Westinghouse ERG Plants

Developers should consider including a threshold the same as, or similar to, “Core Cooling Red entry conditions met for 15 minutes or longer” in accordance with the guidance at the front of this section.

3. Containment Integrity or Bypass

The status of the containment barrier during an event involving steam generator tube leakage or RUPTURE is assessed using Loss Threshold 1.A.

Loss 3.A

These thresholds address a situation where containment isolation is required (i.e., a valid containment isolation signal exists) and one of two conditions exists as discussed below. Users are reminded that there may be accident and release conditions that simultaneously meet both thresholds 3.A.1 and 3.A.2.

3.A.1 – Containment integrity has been lost, i.e., the actual containment atmospheric leak rate likely exceeds that associated with allowable leakage (or sometimes referred to as design leakage). Following the release of RCS mass into containment, containment pressure will fluctuate based on a variety of factors; a loss of containment integrity condition may (or may not) be accompanied by a noticeable drop in containment

pressure. Recognizing the inherent difficulties in determining a containment leak rate during accident conditions, it is expected that the Shift Manager/Emergency Director will assess this threshold using judgment, and with due consideration given to current plant conditions, and available operational and radiological data (e.g., containment pressure, readings on radiation monitors outside containment, operating status of containment pressure control equipment, etc.).

Refer to the middle piping run of Figure 9-F-4. Two simplified examples are provided. One is leakage from a penetration and the other is leakage from an in-service system valve. Depending upon radiation monitor locations and sensitivities, the leakage could be detected by any of the four monitors depicted in the figure.

Another example would be a loss or potential loss of the RCS barrier, and the simultaneous occurrence of two FAULTED locations on a steam generator where one fault is located inside containment (e.g., on a steam or feedwater line) and the other outside of containment. In this case, the associated steam line provides a pathway for the containment atmosphere to escape to an area outside the containment.

Following the leakage of RCS mass into containment and a rise in containment pressure, there may be minor radiological releases associated with allowable (design) containment leakage through various penetrations or system components. These releases do not constitute a loss or potential loss of containment but should be evaluated using the Recognition Category A ICs.

3.A.2 – Conditions are such that there is an UNISOLABLE pathway for the migration of radioactive material from the containment atmosphere to the environment. As used here, the term “environment” includes the atmosphere of a room or area, outside the containment, that may, in turn, communicate with the outside-the-plant atmosphere (e.g., through discharge of a ventilation system or atmospheric leakage). Depending upon a variety of factors, this condition may or may not be accompanied by a noticeable drop in containment pressure.

Refer to the top piping run of Figure 9-F-4. In this simplified example, the inboard and outboard isolation valves remained open after a containment isolation was required (i.e., containment isolation was not successful). There is now an UNISOLABLE pathway from the containment to the environment.

The existence of a filter is not considered in the threshold assessment. Filters do not remove fission product noble gases. In addition, a filter could become ineffective due to iodine and/or particulate loading beyond design limits (i.e., retention ability has been exceeded) or water saturation from steam/high humidity in the release stream.

Leakage between two interfacing liquid systems, by itself, does not meet this threshold.

Refer to the bottom piping run of Figure 9-F-4. In this simplified example, leakage in an RCP seal cooler is allowing radioactive material to enter the Auxiliary Building. The radioactivity would be detected by the Process Monitor. If there is no leakage from the closed water cooling system to the Auxiliary Building, then no threshold has been met. If the pump or system piping developed a leak that allowed steam/water to enter the Auxiliary Building, then threshold 3.B would be met. Depending upon radiation monitor locations and sensitivities, this leakage could be detected by any of the four monitors depicted in the figure and cause threshold 3.A.1 to be met as well.

Following the leakage of RCS mass into containment and a rise in containment pressure, there may be minor radiological releases associated with allowable (design) containment leakage through various penetrations or system components. Minor releases may also occur if a containment isolation valve(s) fails to close but the containment atmosphere escapes to a closed system. These releases do not constitute a loss or potential loss of containment but should be evaluated using the Recognition Category A ICs.

Loss 3.B

Containment sump, temperature, pressure and/or radiation levels will increase if reactor coolant mass is leaking into the containment. If these parameters have not increased, then the reactor coolant mass may be leaking outside of containment (i.e., a containment bypass sequence). Increases in sump, temperature, pressure, flow and/or radiation level readings outside of the containment may indicate that the RCS mass is being lost outside of containment. The RCS leakage outside of containment must be associated with a mass loss that meets the threshold for either RCS Barrier Loss 1.A or RCS Barrier Potential Loss 1.A.

Unexpected elevated readings and alarms on radiation monitors with detectors outside containment should be corroborated with other available indications to confirm that the source is a loss of RCS mass outside of containment. If the fuel clad barrier has not been lost, radiation monitor readings outside of containment may not increase significantly; however, other unexpected changes in sump levels, area temperatures or pressures, flow rates, etc. should be sufficient to determine if RCS mass is being lost outside of the containment.

Refer to the middle piping run of Figure 9-F-4. In this simplified example, a leak has occurred at a reducer on a pipe carrying reactor coolant in the Auxiliary Building. Depending upon radiation monitor locations and sensitivities, the leakage could be detected by any of the four monitors depicted in the figure and cause threshold 3.A.1 to be met as well.

Potential Loss 3.A

If containment pressure exceeds the design pressure, there exists a potential to lose the Containment Barrier. To reach this level, there must be an inadequate core cooling condition for an extended period of time; therefore, the RCS and Fuel Clad barriers would already be lost. Thus, this threshold is a discriminator between a Site Area Emergency and General Emergency since there is now a potential to lose the third barrier.

Potential Loss 3.B

The existence of a flammable mixture means, at a minimum, that the containment atmospheric hydrogen concentration is sufficient to support a hydrogen burn (i.e., at the lower deflagration limit). A hydrogen burn will raise containment pressure and could result in collateral equipment damage leading to a loss of containment integrity. It therefore represents a potential loss of the Containment Barrier.

Potential Loss 3.C and 3.D

These thresholds address a release of gaseous radioactivity that results in projected or actual offsite doses greater than 75% of the EPA PAGs; it includes both monitored and un-monitored releases. Releases of this magnitude indicate that containment leak rates are greater than the allowable leak rates described in site Technical Specifications, and thus a potential loss of Containment. When present with a loss of the Fuel Clad and RCS Barriers, meeting either threshold will appropriately escalate the ECL to a General Emergency.

Emergency classification based on dose projections assumes there is a release path to the environment. If the flow past an effluent monitor used in a dose projection is known to have stopped due to actions to isolate the release path, then the effluent monitor reading is no longer valid for classification purposes.

Developer Notes:

Loss 3.A.1

Developers may include a list of site-specific radiation monitors to better define this threshold. Expected monitor alarms or readings may also be included.

Potential Loss 3.A

The site-specific pressure is the containment design pressure.

For plants that have implemented Westinghouse Owners Group Emergency Response Guidelines, the pressure value in Potential Loss 3.A is that used for the Containment Red Path. If the Containment CSFST contains more than one Red Path due to other dependencies (e.g., status of containment isolation), enter the highest containment pressure value shown on the tree. This is typically the containment design pressure.

Westinghouse ERG Plants

In lieu of specifying a containment pressure in Potential Loss 3.A, developers may use a threshold the same as, or similar to, “Containment Red entry conditions met” in accordance with the guidance at the front of this section.

Potential Loss 3.B

Developers may enter the minimum containment atmospheric hydrogen concentration necessary to support a hydrogen burn (i.e., the lower flammability limit). A concurrent containment oxygen concentration may be included if the plant has this indication available in the Control Room.

Potential Loss 3.C and 3.D

The generic wording for these thresholds uses the term “site boundary.” A site may specify the same “site-specific dose receptor point” as used in ICs AA1, AS1, and AG1 provided that the location(s) is coincident with or relatively close to the site boundary (i.e., the Owner Controlled Area boundary). Relatively close should be understood to mean no greater than about ¼ mile away from the site boundary (on either side).

Although the IC references TEDE, field survey results are generally available only as a “whole body” dose rate. For this reason, the field survey EAL specifies a “closed window” survey reading.

4. Emergency Director Judgment

Loss 4.A

This threshold addresses any other factors that may be used by the Shift Manager/Emergency Director in determining whether the Containment Barrier is lost.


Potential Loss 4.A

This threshold addresses any other factors that may be used by the Shift Manager/Emergency Director in determining whether the Containment Barrier is potentially lost. The Shift Manager/Emergency Director should also consider whether or not to declare the barrier potentially lost in the event that barrier status cannot be monitored.

Developer Notes:

None

Figure 9-F-4: PWR Containment Integrity or Bypass Examples



10 HAZARDS AND OTHER CONDITIONS AFFECTING PLANT SAFETY ICS/EALS

Table H-1: Recognition Category “H” Initiating Condition Matrix

UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
HU1 Confirmed SECURITY CONDITION or threat. <i>Op. Modes: All</i>	HA1 HOSTILE ACTION within the OWNER CONTROLLED AREA or airborne attack threat within 30 minutes. <i>Op. Modes: All</i>	HS1 HOSTILE ACTION within the PROTECTED AREA. <i>Op. Modes: All</i>	
HU2 Seismic event greater than OBE levels. <i>Op. Modes: All</i>			
HU3 Gaseous release impeding access to equipment necessary for normal plant operations, cooldown or shutdown. <i>Op. Modes: All</i>			
HU4 FIRE potentially degrading the level of safety of the plant. <i>Op. Modes: All</i>			
HU5 Other conditions exist which in the judgment of the Shift Manager/Emergency Director warrant declaration of a (NO)UE. <i>Op. Modes: All</i>	HA5 Other conditions exist which in the judgment of the Shift Manager/Emergency Director warrant declaration of an Alert. <i>Op. Modes: All</i>	HS5 Other conditions exist which in the judgment of the Shift Manager/Emergency Director warrant declaration of a Site Area Emergency. <i>Op. Modes: All</i>	HG5 Other conditions exist which in the judgment of the Shift Manager/Emergency Director warrant declaration of a General Emergency. <i>Op. Modes: All</i>

Table intended for use by
EAL developers.
Inclusion in licensee
documents is not required.

HU1

ECL: Notification of Unusual Event

Initiating Condition: Confirmed SECURITY CONDITION or threat.

Operating Mode Applicability: All

Example Emergency Action Levels: (1 or 2 or 3)

- (1) A SECURITY CONDITION that does not involve a HOSTILE ACTION as reported by the (site-specific security shift supervision).
- (2) Notification of a credible security threat directed at the site.
- (3) A validated notification from the NRC providing information of an aircraft threat.

Basis:

This IC addresses events that pose a threat to plant personnel or SAFETY SYSTEM equipment, and thus represents a potential degradation in the level of plant safety. A site Independent Spent Fuel Storage Installation (ISFSI) is also within the scope of this IC. Security events which do not meet one of these EALs are adequately addressed by the requirements of 10 CFR 73.71 or 10 CFR 50.72. Security events assessed as HOSTILE ACTIONS are classified under ICs HA1 and HS1.

Timely and accurate communications between Security Shift Supervision and the Control Room is essential for proper classification of a security-related event. Classification of these events will initiate appropriate threat-related notifications to plant personnel and OROs.

Security plans and terminology are based on the guidance provided by NEI 03-12, *Template for the Security Plan, Training and Qualification Plan, Safeguards Contingency Plan [and Independent Spent Fuel Storage Installation Security Program]*.

EAL #1 references (site-specific security shift supervision) because these are the individuals trained to confirm that a security event is occurring or has occurred. Training on security event confirmation and classification is controlled due to the nature of Safeguards and 10 CFR 2.39 information.

EAL #2 addresses the receipt of a credible security threat. The credibility of the threat is assessed in accordance with (site-specific procedure).

EAL #3 addresses the threat from the impact of an aircraft on the plant. The NRC Headquarters Operations Officer (HOO) will communicate to the licensee if the threat involves an aircraft. The status and size of the plane may also be provided by NORAD through the NRC. Validation of the threat is performed in accordance with (site-specific procedure).

Escalation of the emergency classification level would be via IC HA1.

Developer Notes:

The (site-specific security shift supervision) is the title of the on-shift individual responsible for supervision of the on-shift security force.

The (site-specific procedure) is the procedure(s) used by Control Room and/or Security personnel to determine if a security threat is credible, and to validate receipt of aircraft threat information.

Emergency plans and implementing procedures are public documents; therefore, EALs should not incorporate Security-sensitive information. This includes information that may be advantageous to a potential adversary, such as the particulars concerning a specific threat or threat location. Security-sensitive information should be contained in non-public documents such as the Security Plan.

With due consideration given to the above developer note, EALs may contain alpha or numbered references to selected events described in the Security Plan and associated implementing procedures. Such references should not contain a recognizable description of the event. For example, an EAL may be worded as “Security event #2, #5 or #9 is reported by the (site-specific security shift supervision).”

HU2

ECL: Notification of Unusual Event

Initiating Condition: Seismic event greater than OBE levels.

Operating Mode Applicability: All

Example Emergency Action Level: (1 or 2)

- (1) Seismic event greater than Operating Basis Earthquake (OBE) as indicated by:
(site-specific indication that a seismic event met or exceeded OBE limits)
- (2)
 - a. Seismic monitoring instrumentation is unavailable to the extent that an OBE cannot be determined (e.g., out-of-service for testing or maintenance).

AND
 - b. Control Room personnel feel an actual or potential seismic event.

AND
 - c. The occurrence of a seismic event is confirmed in manner deemed appropriate by the Shift Manager or Emergency Director.

Basis:

This IC addresses a seismic event that results in accelerations at the plant site greater than those specified for an Operating Basis Earthquake (OBE).⁵ An earthquake greater than an OBE but less than a Safe Shutdown Earthquake (SSE)⁶ should have no significant impact on safety-related systems, structures and components; however, some time may be required for the plant staff to ascertain the actual post-event condition of the plant (e.g., performs walk-downs and post-event inspections). Given the time necessary to perform walk-downs and inspections, and fully understand any impacts, this event represents a potential degradation of the level of safety of the plant.

When the site seismic monitoring instrumentation is operable, verification of the event through an external source should not be necessary during or following an OBE. Earthquakes of this magnitude should be readily felt by on-site personnel and recognized as a seismic event (e.g., typical lateral accelerations are in excess of 0.08g). The Shift Manager or Emergency Director may seek external verification if deemed appropriate (e.g., a call to the USGS, check internet news sources, etc.); however, the verification action must not preclude a timely emergency declaration.

⁵ An OBE is vibratory ground motion for which those features of a nuclear power plant necessary for continued operation without undue risk to the health and safety of the public will remain functional.

⁶ An SSE is vibratory ground motion for which certain (generally, safety-related) structures, systems, and components must be designed to remain functional.

EAL #2 is used during periods when the occurrence on an OBE cannot be determined because the site's seismic monitoring instrumentation is out-of-service (i.e., when EAL #1 cannot be assessed). The EAL 2.c statement is included to ensure that a declaration does not result from felt vibrations caused by a non-seismic source (e.g., a dropped heavy load). The Shift Manager or Emergency Director may seek external verification if deemed appropriate (e.g., a call to the USGS, check internet news sources, etc.); however, the verification action must not preclude a timely emergency declaration. It is recognized that EAL #2 may cause a site to declare an Unusual Event while another site, similarly affected but with readily assessable OBE indications in the Control Room, may not.

Depending upon the plant mode at the time of the event, escalation of the emergency classification level would be via IC CA6 or SA7.

Developer Notes:

This "site-specific indication that a seismic event met or exceeded OBE limits" should be based on the indications available from site-specific seismic monitoring equipment. The goal is to specify indications that can be assessed within 15-minutes of the actual or suspected seismic event.

Preferred indications for this EAL are those that are immediately available to Control Room personnel and which can be readily assessed. The EAL may specify instrumentation with readout locations outside the main Control Room provided it can support an EAL assessment and emergency declaration within 15 minutes of the initial seismic activity. Indications available outside the Control Room that require lengthy times to assess (e.g., processing of scratch plates or recorded data) should not be used.

For sites that do not have readily assessable OBE indications, developers should use just EAL #2, and delete the 2.a statement (i.e., 2.b and 2.c as shown above become 2.a and 2.b).

Sites are encouraged to develop an EAL based on the examples presented above. Other proposed approaches (e.g., based on reported Richter values) will lengthen NRC review and may not be found acceptable.

HU3

ECL: Notification of Unusual Event

Initiating Condition: Gaseous release impeding access to equipment necessary for normal plant operations, cooldown or shutdown.

Operating Mode Applicability: All

Example Emergency Action Level:

Note: If the equipment in the listed room or area was already inoperable or out-of-service before the event occurred, then no emergency classification is warranted.

- (1) a. Release of a toxic, corrosive, asphyxiant or flammable gas into any of the following plant rooms or areas:

(site-specific list of plant rooms or areas with entry-related mode applicability identified)

AND

- b. Entry into the room or area is prohibited or impeded.

Basis:

This IC addresses an event involving a release of a hazardous gas that precludes or impedes access to equipment necessary to maintain normal plant operation, or required for a normal plant cooldown and shutdown. This condition represents a potential degradation of the level of safety of the plant.

A declaration is warranted if entry into the affected room/area is, or may be, procedurally required during the plant operating mode in effect at the time of the gaseous release. The emergency classification is not contingent upon whether entry is actually necessary at the time of the release.

Evaluation of the IC and EAL do not require atmospheric sampling; it only requires the Shift Manager/Emergency Director's judgment that the gas concentration in the affected room/area is sufficient to preclude or significantly impede procedurally required access. This judgment may be based on a variety of factors including an existing job hazard analysis, report of ill effects on personnel, advice from a subject matter expert or operating experience with the same or similar hazards. Access should be considered as impeded if extraordinary measures are necessary to facilitate entry of personnel into the affected room/area (e.g., requiring use of protective equipment, such as SCBAs, that is not routinely employed).

An emergency declaration is not warranted if any of the following conditions apply.

- The plant is in an operating mode different than the mode specified for the affected room/area (i.e., entry is not required during the operating mode in effect at the time of the gaseous release). For example, the plant is in Mode 1 when the gaseous release occurs, and

the procedures used for normal operation, cooldown and shutdown do not require entry into the affected room until Mode 4.

- The gas release is a planned activity that includes compensatory measures which address the temporary inaccessibility of a room or area (e.g., fire suppression system testing).
- The action for which room/area entry is required is of an administrative or record keeping nature (e.g., normal rounds or routine inspections).
- The access control measures are of a conservative or precautionary nature, and would not actually prevent or impede a required action.

An asphyxiant is a gas capable of reducing the level of oxygen in the body to dangerous levels. Most commonly, asphyxiants work by merely displacing air in an enclosed environment. This reduces the concentration of oxygen below the normal level of around 19%, which can lead to breathing difficulties, unconsciousness, or death.

This EAL does not apply to firefighting activities that automatically or manually activate a fire suppression system in an area, or to intentional inerting of containment (BWR only).

Depending on the nature of the event, escalation of the emergency classification level would be via an IC in Recognition Category A, C, F or S.

Developer Notes:

The “site-specific list of plant rooms or areas with entry-related mode applicability identified” should specify those rooms or areas that contain equipment which require a manual/local action as specified in operating procedures used for normal plant operation, cooldown and shutdown. Do not include rooms or areas in which actions of a contingent or emergency nature would be performed (e.g., an action to address an off-normal or emergency condition such as emergency repairs, corrective measures or emergency operations). In addition, the list should specify the plant mode(s) during which entry would be required for each room or area.

The list should not include rooms or areas for which entry is required solely to perform actions of an administrative or record keeping nature (e.g., normal rounds or routine inspections).

The list need not include the Control Room if adequate engineered safety/design features are in place to preclude a Control Room evacuation due to the release of a hazardous gas. Such features may include, but are not limited to, capability to draw air from multiple air intakes at different and separate locations, inner and outer atmospheric boundaries, or the capability to acquire and maintain positive pressure within the Control Room envelope.

If the equipment in the listed room or area was already inoperable, or out-of-service, before the event occurred, then no emergency should be declared since the event will have no adverse impact beyond that already allowed by Technical Specifications at the time of the event.

HU4

ECL: Notification of Unusual Event

Initiating Condition: FIRE potentially degrading the level of safety of the plant.

Operating Mode Applicability: All

Example Emergency Action Level: (1 or 2)

Note: For EAL #1, the Emergency Director should declare the Unusual Event promptly upon determining that 60 minutes has been exceeded or will likely be exceeded.

- (1) A FIRE within the plant or ISFSI [*for plants with an ISFSI outside the plant Protected Area*] PROTECTED AREA not extinguished within 60-minutes of the initial report, alarm or indication.
- (2) A FIRE within the plant or ISFSI [*for plants with an ISFSI outside the plant Protected Area*] PROTECTED AREA that requires firefighting support by an offsite fire response agency to extinguish.

Basis:

This IC addresses the magnitude and extent of FIRES that may be indicative of a potential degradation of the level of safety of the plant.

EAL #1 - A FIRE within the plant PROTECTED AREA not extinguished within 60-minutes may potentially degrade the level of plant safety. This basis extends to a FIRE occurring within the PROTECTED AREA of an ISFSI located outside the plant PROTECTED AREA. [*Sentence for plants with an ISFSI outside the plant Protected Area.*]

EAL #2 - If a FIRE within the plant or ISFSI [*for plants with an ISFSI outside the plant Protected Area*] PROTECTED AREA is of sufficient size to require a response by an offsite firefighting agency (e.g., a local town Fire Department), then the level of plant safety is potentially degraded. The dispatch of an offsite firefighting agency to the site requires an emergency declaration only if it is needed to actively support firefighting efforts because the fire is beyond the capability of the Fire Brigade to extinguish. Declaration is not necessary if the agency resources are placed on stand-by, or supporting post-extinguishment recovery or investigation actions.

Depending upon the plant mode at the time of the event, escalation of the emergency classification level would be via IC CA6 or SA7.

Developer Notes:

As noted in the EALs and Basis section, include the ISFSI (or site-specific term) if the site has an ISFSI outside the plant Protected Area.

HU5

ECL: Notification of Unusual Event

Initiating Condition: Other conditions exist which in the judgment of the Shift Manager/Emergency Director warrant declaration of a (NO)UE.

Operating Mode Applicability: All

Example Emergency Action Level:

- (1) Other conditions exist which in the judgment of the Shift Manager/Emergency Director indicate that events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant or indicate a security threat to facility protection has been initiated. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety systems occurs.

Basis:

This IC addresses unanticipated conditions not addressed explicitly elsewhere but that warrant declaration of an emergency because conditions exist which are believed by the Shift Manager/Emergency Director to fall under the emergency classification level description for a NOUE.

HA1

ECL: Alert

Initiating Condition: HOSTILE ACTION within the OWNER CONTROLLED AREA or airborne attack threat within 30 minutes.

Operating Mode Applicability: All

Example Emergency Action Levels: (1 or 2)

- (1) A HOSTILE ACTION is occurring or has occurred within the OWNER CONTROLLED AREA as reported by the (site-specific security shift supervision).
- (2) A validated notification from NRC of an aircraft attack threat within 30 minutes of the site.

Basis:

This IC addresses the occurrence of a HOSTILE ACTION within the OWNER CONTROLLED AREA or notification of an aircraft attack threat. This event will require rapid response and assistance due to the possibility of the attack progressing to the PROTECTED AREA, or the need to prepare the plant and staff for a potential aircraft impact.

Timely and accurate communications between Security Shift Supervision and the Control Room is essential for proper classification of a security-related event.

Security plans and terminology are based on the guidance provided by NEI 03-12, *Template for the Security Plan, Training and Qualification Plan, Safeguards Contingency Plan [and Independent Spent Fuel Storage Installation Security Program]*.

As time and conditions allow, these events require a heightened state of readiness by the plant staff and implementation of onsite protective measures (e.g., evacuation, dispersal or sheltering). The Alert declaration will also heighten the awareness of Offsite Response Organizations, allowing them to be better prepared should it be necessary to consider further actions.

This IC does not apply to incidents that are accidental events, acts of civil disobedience, or otherwise are not a HOSTILE ACTION perpetrated by a HOSTILE FORCE. Examples include the crash of a small aircraft, shots from hunters, physical disputes between employees, etc. Reporting of these types of events is adequately addressed by other EALs, or the requirements of 10 CFR 73.71 or 10 CFR 50.72.

EAL #1 is applicable for any HOSTILE ACTION occurring, or that has occurred, in the OWNER CONTROLLED AREA. This includes any action directed against an ISFSI that is located outside the plant PROTECTED AREA.

EAL #2 addresses the threat from the impact of an aircraft on the plant, and the anticipated arrival time is within 30 minutes. The intent of this EAL is to ensure that threat-related notifications are made in a timely manner so that plant personnel and OROs are in a heightened

state of readiness. This EAL is met when the threat-related information has been validated in accordance with (site-specific procedure).

The NRC Headquarters Operations Officer (HOO) will communicate to the licensee if the threat involves an aircraft. The status and size of the plane may be provided by NORAD through the NRC.

In some cases, it may not be readily apparent if an aircraft impact within the OWNER CONTROLLED AREA was intentional (i.e., a HOSTILE ACTION). It is expected, although not certain, that notification by an appropriate federal agency to the site would clarify this point. In this case, the appropriate federal agency is intended to be NORAD, FBI, FAA or NRC. The emergency declaration, including one based on other ICs/EALs, should not be unduly delayed while awaiting notification by a federal agency.

Escalation of the emergency classification level would be via IC HS1.

Developer Notes:

The (site-specific security shift supervision) is the title of the on-shift individual responsible for supervision of the on-shift security force.

Emergency plans and implementing procedures are public documents; therefore, EALs should not incorporate Security-sensitive information. This includes information that may be advantageous to a potential adversary, such as the particulars concerning a specific threat or threat location. Security-sensitive information should be contained in non-public documents such as the Security Plan.

With due consideration given to the above developer note, EALs may contain alpha or numbered references to selected events described in the Security Plan and associated implementing procedures. Such references should not contain a recognizable description of the event. For example, an EAL may be worded as “Security event #2, #5 or #9 is reported by the (site-specific security shift supervision).”

The term OWNER CONTROLLED AREA means the site property owned by, or otherwise under the control of, the licensee. The developer may define a smaller area with all or portions of the perimeter closer to the plant Protected Area perimeter. In these cases, developers should consider using the area defined by the Restricted or Secured Owner Controlled Area (ROCA/SOCA). Whatever area is selected, it must be under the control of the licensee (e.g., not an area leased to another company) and consistent with the description of the same area contained in the Security Plan.

HA5

ECL: Alert

Initiating Condition: Other conditions exist which in the judgment of the Shift Manager/Emergency Director warrant declaration of an Alert.

Operating Mode Applicability: All

Example Emergency Action Level:

- (1) Other conditions exist which, in the judgment of the Shift Manager/Emergency Director, indicate that events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant or a security event that involves probable life threatening risk to site personnel or damage to site equipment because of HOSTILE ACTION. Any releases are expected to be limited to small fractions of the EPA Protective Action Guideline exposure levels.

Basis:

This IC addresses unanticipated conditions not addressed explicitly elsewhere but that warrant declaration of an emergency because conditions exist which are believed by the Shift Manager/Emergency Director to fall under the emergency classification level description for an Alert.

HS1

ECL: Site Area Emergency

Initiating Condition: HOSTILE ACTION within the PROTECTED AREA.

Operating Mode Applicability: All

Example Emergency Action Level:

- (1) A HOSTILE ACTION is occurring or has occurred within the PROTECTED AREA as reported by the (site-specific security shift supervision).

Basis:

This IC addresses the occurrence of a HOSTILE ACTION within the PROTECTED AREA. This event will require rapid response and assistance due to the possibility for damage to plant equipment.

Timely and accurate communications between Security Shift Supervision and the Control Room is essential for proper classification of a security-related event.

Security plans and terminology are based on the guidance provided by NEI 03-12, *Template for the Security Plan, Training and Qualification Plan, Safeguards Contingency Plan [and Independent Spent Fuel Storage Installation Security Program]*.

As time and conditions allow, these events require a heightened state of readiness by the plant staff and implementation of onsite protective measures (e.g., evacuation, dispersal or sheltering). The Site Area Emergency declaration will mobilize ORO resources and have them available to develop and implement public protective actions in the unlikely event that the attack is successful in impairing multiple safety functions.

This IC does not apply to a HOSTILE ACTION directed at an ISFSI PROTECTED AREA located outside the plant PROTECTED AREA; such an attack should be assessed using IC HA1. It also does not apply to incidents that are accidental events, acts of civil disobedience, or otherwise are not a HOSTILE ACTION perpetrated by a HOSTILE FORCE. Examples include the crash of a small aircraft, shots from hunters, physical disputes between employees, etc. Reporting of these types of events is adequately addressed by other EALs, or the requirements of 10 CFR 73.71 or 10 CFR 50.72.

Escalation of the emergency classification level would be via an IC in Recognition Category A, C, F or S.

Developer Notes:

The (site-specific security shift supervision) is the title of the on-shift individual responsible for supervision of the on-shift security force.

Emergency plans and implementing procedures are public documents; therefore, EALs should not incorporate Security-sensitive information. This includes information that may be

advantageous to a potential adversary, such as the particulars concerning a specific threat or threat location. Security-sensitive information should be contained in non-public documents such as the Security Plan.

With due consideration given to the above developer note, EALs may contain alpha or numbered references to selected events described in the Security Plan and associated implementing procedures. Such references should not contain a recognizable description of the event. For example, an EAL may be worded as “Security event #2, #5 or #9 is reported by the (site-specific security shift supervision).”

See the related Developer Note in Appendix B, Definitions, for guidance on the development of a scheme definition for the PROTECTED AREA.

HS5

ECL: Site Area Emergency

Initiating Condition: Other conditions exist which in the judgment of the Shift Manager/Emergency Director warrant declaration of a Site Area Emergency.

Operating Mode Applicability: All

Example Emergency Action Level:

- (1) Other conditions exist which in the judgment of the Shift Manager/Emergency Director indicate that events are in progress or have occurred which involve actual or likely major failures of plant functions needed for protection of the public or HOSTILE ACTION that results in intentional damage or malicious acts, (1) toward site personnel or equipment that could lead to the likely failure of or, (2) that prevent effective access to equipment needed for the protection of the public. Any releases are not expected to result in exposure levels which exceed EPA Protective Action Guideline exposure levels beyond the site boundary.

Basis:

This IC addresses unanticipated conditions not addressed explicitly elsewhere but that warrant declaration of an emergency because conditions exist which are believed by the Shift Manager/Emergency Director to fall under the emergency classification level description for a Site Area Emergency.

HG5

ECL: General Emergency

Initiating Condition: Other conditions exist which in the judgment of the Shift Manager/Emergency Director warrant declaration of a General Emergency.

Operating Mode Applicability: All

Example Emergency Action Level:

- (1) Other conditions exist which in the judgment of the Shift Manager/Emergency Director indicate that events are in progress or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity or HOSTILE ACTION that results in an actual loss of physical control of the facility. Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area.

Basis:

This IC addresses unanticipated conditions not addressed explicitly elsewhere but that warrant declaration of an emergency because conditions exist which are believed by the Shift Manager/Emergency Director to fall under the emergency classification level description for a General Emergency.

11 SYSTEM MALFUNCTION ICS/EALS

Table S-1: Recognition Category “S” Initiating Condition Matrix

UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
SU1 Loss of all offsite AC power capability to emergency buses for 15 minutes or longer. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>	SA1 Loss of all but one AC power source to emergency buses for 15 minutes or longer. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>	SS1 Loss of all offsite and all onsite AC power to emergency buses for 15 minutes or longer. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>	SG1 Extended loss of AC power to emergency buses. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>
	SA2 UNPLANNED loss of Control Room indications for 15 minutes or longer with a significant transient in progress. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>		
	SA3 Control Room evacuation resulting in transfer of plant control to alternate locations. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>	SS3 Challenge to a fission product barrier with Control Room evacuated. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>	
SU4 Loss of all onsite or offsite communications capabilities. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>			
SU5 Failure to isolate containment or loss of containment pressure control. [PWR] <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>			

Table intended for use by EAL developers. Inclusion in licensee documents is not required.

UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
		SS6 Loss of all Vital DC power for 15 minutes or longer. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>	SG6 Loss of all AC and Vital DC power sources for 15 minutes or longer. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>
SU7 Internal flooding affecting a SAFETY SYSTEM component required for the current operating mode. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>	SA7 Hazardous event affecting two or more SAFETY SYSTEM trains. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>		
SU8 Automatic or manual (trip [PWR] / scram [BWR]) fails to shutdown the reactor, and subsequent manual actions taken at the reactor control consoles are not successful in shutting down the reactor. <i>Op. Modes: Power Operation</i>	SA9 Reactor coolant activity > 2% fuel clad failure. <i>Op. Modes: Power Operation, Startup, Hot Standby, Hot Shutdown</i>		

Table intended for use by
EAL developers.
Inclusion in licensee
documents is not required.

SU1

ECL: Notification of Unusual Event

Initiating Condition: Loss of all offsite AC power capability to emergency buses for 15 minutes or longer.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

Note: The Shift Manager/Emergency Director should declare the Unusual Event promptly upon determining that 15 minutes has been exceeded or will likely be exceeded.

- (1) Loss of **ALL** offsite AC power capability to (site-specific emergency buses) for 15 minutes or longer.

Basis:

This IC addresses a prolonged loss of offsite power. The loss of offsite power sources renders the plant more vulnerable to a complete loss of power to AC emergency buses. This condition represents a potential reduction in the level of safety of the plant.

For emergency classification purposes, “capability” means that an offsite AC power source(s) is available to the emergency buses, whether or not the buses are powered from it.

Fifteen minutes was selected as a threshold to exclude transient or momentary losses of offsite power.

Escalation of the emergency classification level would be via IC SA1.

Developer Notes:

The “site-specific emergency buses” are the buses fed by offsite or emergency AC power sources that supply power to the electrical distribution system that powers SAFETY SYSTEMS. There is typically 1 emergency bus per train of SAFETY SYSTEMS.

At multi-unit stations, the EALs may credit compensatory measures that are proceduralized. Consider capabilities such as power source cross-ties, “swing” generators, other power sources described in abnormal or emergency operating procedures, etc. Plants that have a proceduralized capability to supply offsite AC power to an affected unit via a cross-tie to a companion unit may credit this power source in the EAL provided that the planned cross-tie strategy meets the requirements of 10 CFR 50.63.

SU4

ECL: Notification of Unusual Event

Initiating Condition: Loss of all onsite or offsite communications capabilities.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Levels: (1 or 2 or 3)

- (1) Loss of **ALL** of the following onsite communication methods:
(site-specific list of communications methods)
- (2) Loss of **ALL** of the following ORO communications methods:
(site-specific list of communications methods)
- (3) Loss of **ALL** of the following NRC communications methods:
(site-specific list of communications methods)

Basis:

This IC addresses a significant loss of on-site or offsite communications capabilities. While not a direct challenge to plant or personnel safety, this event warrants prompt notifications to OROs and the NRC.

This IC should be assessed only when extraordinary means are being utilized to make communications possible (e.g., use of non-plant, privately owned equipment, relaying of on-site information via individuals or multiple radio transmission points, individuals being sent to offsite locations, etc.).

EAL #1 addresses a total loss of the communications methods used in support of routine plant operations.

EAL #2 addresses a total loss of the communications methods used to notify all OROs of an emergency declaration. The OROs referred to here are (see Developer Notes).

EAL #3 addresses a total loss of the communications methods used to notify the NRC of an emergency declaration.

Developer Notes:

EAL #1 - The “site-specific list of communications methods” should include all communications methods used for routine plant communications (e.g., commercial or site telephones, page-party systems, radios, etc.). This listing should include installed plant equipment and components, and not items owned and maintained by individuals.

EAL #2 - The “site-specific list of communications methods” should include all communications methods used to perform initial and follow-up emergency notifications to OROs as described in

the site Emergency Plan. The listing should include installed plant equipment and components, and not items owned and maintained by individuals. Example methods are ring-down/dedicated telephone lines, commercial telephone lines, cellular telephones, radios, and satellite telephones. A method may also include electronic or internet-based communications technologies with a procedural means to determine if the message was accessed by an ORO (e.g., a read or opened receipt, or other acknowledgement that the notification message was displayed such as an independent phone call).

In the Basis section, insert the site-specific listing of the OROs requiring notification of an emergency declaration from the Control Room in accordance with the site Emergency Plan, and typically within 15 minutes.

EAL #3 – The “site-specific list of communications methods” should include all communications methods used to perform initial emergency notifications to the NRC as described in the site Emergency Plan. The listing should include installed plant equipment and components, and not items owned and maintained by individuals. These methods are typically the dedicated Emergency Notification System (ENS) telephone line and commercial telephone lines.

SU5

ECL: Notification of Unusual Event

Initiating Condition: Failure to isolate containment or loss of containment pressure control.
[PWR]

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Levels: (1 or 2)

- (1) a. Failure of containment to isolate when required by an actuation signal.

AND
 - b. ALL required penetrations are not closed within 15 minutes of the actuation signal.
- (2) a. Containment pressure greater than (site-specific pressure).

AND
 - b. Less than one full train of (site-specific system or equipment) is operating per design for 15 minutes or longer.

Basis:

This IC addresses a failure of one or more containment penetrations to automatically isolate (close) when required by an actuation signal. It also addresses an event that results in high containment pressure with a concurrent failure of containment pressure control systems. Absent challenges to another fission product barrier, either condition represents potential degradation of the level of safety of the plant.

For EAL #1, the containment isolation signal must be generated as the result on an off-normal/accident condition (e.g., a safety injection or high containment pressure); a failure resulting from testing or maintenance does not warrant classification. The determination of containment and penetration status – isolated or not isolated – should be made in accordance with the appropriate criteria contained in the plant AOPs and EOPs. The 15-minute criterion is included to allow operators time to manually isolate the required penetrations, if possible.

EAL #2 addresses a condition where containment pressure is greater than the setpoint at which containment energy (heat) removal systems are designed to automatically actuate, and less than one full train of equipment is capable of operating per design. The 15-minute criterion is included to allow operators time to manually start equipment that may not have automatically started, if possible. The inability to start the required equipment indicates that containment heat removal/depressurization systems (e.g., containment sprays or ice condenser fans) are either lost or performing in a degraded manner.

This event would escalate to a Site Area Emergency in accordance with IC FS1 if there were a concurrent loss or potential loss of either the Fuel Clad or RCS fission product barriers.

Developer Notes:

Developers may list specific equipment or combinations of equipment to support the assessment of “Less than one full train.” For example, a table could show the principal components of each train.

Enter the “site-specific pressure” value that actuates containment pressure control systems (e.g., containment spray). Also enter the site-specific containment pressure control system/equipment that should be operating per design if the containment pressure actuation setpoint is reached. If desired, specific condition indications such as parameter values can also be entered (e.g., a containment spray flow rate less than a certain value).

EAL #2 is not applicable to the U.S. Evolutionary Power Reactor (EPR) design.

SU7

ECL: Notification of Unusual Event

Initiating Condition: Internal flooding affecting a SAFETY SYSTEM component required for the current operating mode.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

- (1) Internal room or area flooding of a magnitude sufficient to require manual or automatic electrical isolation of a SAFETY SYSTEM component required by Technical Specifications for the current operating mode.

Basis:

This IC addresses flooding of a building room or area that results in operators isolating power to a SAFETY SYSTEM component or causes an automatic isolation of a SAFETY SYSTEM component (e.g., a breaker or relay trip). To warrant classification, operability of the affected component must be required by Technical Specifications for the current operating mode. This event represents a potential degradation of the level of safety of the plant.

Escalation of the emergency classification level would be based on IC SA7.

Developer Notes:

Flooding is a condition where water is entering a room or area faster than available equipment is capable removing it, resulting in a rise of water level within the room or area. Developers may add this clarification or definition if it improves user understanding.

SU8

ECL: Notification of Unusual Event

Initiating Condition: Automatic or manual (trip [*PWR*] / scram [*BWR*]) fails to shutdown the reactor, and subsequent manual actions taken at the reactor control consoles are not successful in shutting down the reactor.

Operating Mode Applicability: Power Operation

Example Emergency Action Level:

Note: A manual action is any operator action, or set of actions, which causes the control rods to be rapidly inserted into the core, and does not include manually driving in control rods or implementation of boron injection strategies.

- (1) a. An automatic or manual (trip [*PWR*] / scram [*BWR*]) did not shutdown the reactor.

AND

- b. Manual actions taken at the reactor control consoles are not successful in shutting down the reactor.

Basis:

This IC addresses a failure of the RPS to initiate or complete an automatic or manual reactor (trip [*PWR*] / scram [*BWR*]) that results in a reactor shutdown, and subsequent operator manual actions taken at the reactor control consoles to shutdown the reactor are also unsuccessful. Under these conditions, operators will take prompt actions to shutdown the reactor from a location outside the Control Room (e.g., opening the reactor trip breakers). This event is a precursor to a more significant condition and thus represents a potential degradation of the level of safety of the plant. An emergency declaration is required even if the reactor is subsequently shutdown by an action taken away from the reactor control consoles since this event entails a significant failure of the RPS.

A manual action at the reactor control consoles is any operator action, or set of actions, which causes the control rods to be rapidly inserted into the core (e.g., initiating a manual reactor (trip [*PWR*] / scram [*BWR*])). This action does not include manually driving in control rods or implementation of boron injection strategies. Actions taken at back-panels or other locations within the Control Room, or any location outside the Control Room, are not considered to be “at the reactor control consoles”.

Taking the Reactor Mode Switch to SHUTDOWN is considered to be a manual scram action. [*BWR*]

The plant response to this event will vary based upon several factors; these include the reactor power level at the time of the reactor (trip [*PWR*] / scram [*BWR*]), availability of the condenser, performance of mitigation equipment and actions, and other concurrent plant conditions or

transients. If the failure to shutdown the reactor is prolonged enough to cause a challenge to the core cooling [*PWR*] / RPV water level [*BWR*] or RCS heat removal safety functions, the emergency classification level will escalate to an Alert (or higher) via the thresholds in the Fission Product Barrier (FPB) Matrix. Absent plant conditions that exceed Alert or higher FPB Matrix thresholds, an Unusual Event declaration is appropriate for this event.

Operators will determine when the reactor is shutdown in accordance with applicable EOP criteria.

Developer Notes:

This IC is applicable in any Mode in which the actual reactor power level could exceed the power level at which the reactor is considered shutdown. A PWR with a shutdown reactor power level that is less than or equal to the reactor power level which defines the lower bound of Power Operation (Mode 1) will need to include Startup (Mode 2) in the Operating Mode Applicability. For example, if the reactor is considered to be shutdown at 3% and Power Operation starts at >5%, then the IC is also applicable in Startup Mode.

The term “reactor control consoles” may be replaced with the appropriate site-specific term (e.g., main control boards).

SA1

ECL: Alert

Initiating Condition: Loss of all but one AC power source to emergency buses for 15 minutes or longer.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

Note: The Shift Manager/Emergency Director should declare the Alert promptly upon determining that 15 minutes has been exceeded or will likely be exceeded.

- (1) Only one power source listed in Table SA1-1 is available to supply power to (site-specific emergency buses) for 15 minutes or longer.

Table SA1-1: AC Power Sources	
<u>Offsite</u>	
• Source #1	
• Source #2, etc.	
<u>Onsite</u>	
• Source #1	
• Source #2, etc.	

Basis:

This IC describes a significant degradation of offsite and onsite AC power sources such that any additional power source failure would result in a loss of all AC power to SAFETY SYSTEMS. During this condition, the margin to a potential fission product barrier challenge is reduced. It thus represents a potential substantial degradation in the level of safety of the plant.

In this condition, the sole AC power source may be powering one, or more than one, train of safety-related equipment.

An “AC power source” is a source recognized in AOPs and EOPs, and capable of supplying required power to an emergency bus. Some examples of this condition are presented below.

- A loss of all offsite power with a concurrent failure of all but one emergency power source (e.g., an onsite diesel generator).
- A loss of all offsite power and loss of all emergency power sources (e.g., onsite diesel generators) with a single train of emergency buses being back-fed from the unit main generator.
- A loss of emergency power sources (e.g., onsite diesel generators) with a single train of emergency buses being back-fed from an offsite power source.

Fifteen minutes was selected as a threshold to exclude transient or momentary losses of power.

The subsequent loss of the remaining single power source would escalate the event to a Site Area Emergency in accordance with IC SS1.

Developer Notes:

For a power source that has multiple generators, the EAL and/or Basis section should reflect the minimum number of operating generators necessary for that source to provide required power to an AC emergency bus. For example, if a backup power source is comprised of two generators (i.e., two 50%-capacity generators sized to feed 1 AC emergency bus), the EAL and Basis section must specify that both generators for that source are operating.

The “site-specific emergency buses” are the buses fed by offsite or emergency AC power sources that supply power to the electrical distribution system that powers SAFETY SYSTEMS. There is typically 1 emergency bus per train of SAFETY SYSTEMS.

Developers should modify the bulleted examples provided in the basis section, above, as needed to reflect their site-specific plant designs and capabilities.

The EALs and Basis should reflect that each independent offsite power circuit constitutes a single power source. For example, three independent 345kV offsite power circuits (i.e., incoming power lines) comprise three separate power sources. Independence may be determined from a review of the site-specific UFSAR, SBO analysis or related loss of electrical power studies.

The EAL and/or Basis section may specify the use of a non-safety-related power source provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with ECCS and decay heat removal functions.

At multi-unit stations, the EALs may credit compensatory measures that are proceduralized. Consider capabilities such as power source cross-ties, “swing” generators, other power sources described in abnormal or emergency operating procedures, etc. Plants that have a proceduralized capability to supply offsite AC power to an affected unit via a cross-tie to a companion unit may credit this power source in the EAL provided that the planned cross-tie strategy meets the requirements of 10 CFR 50.63.

SA2

ECL: Alert

Initiating Condition: UNPLANNED loss of Control Room indications for 15 minutes or longer with a significant transient in progress.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

Note: The Shift Manager/Emergency Director should declare the Alert promptly upon determining that 15 minutes has been exceeded or will likely be exceeded.

- (1) a. An UNPLANNED event results in the inability to monitor one or more of the following parameters from within the Control Room for 15 minutes or longer. [PWR]
- a. One or more of the following parameters cannot be determined from within the Control Room for 15 minutes or longer due to an UNPLANNED event. [BWR]

[BWR parameter list]	[PWR parameter list]
Reactor Power	Reactor Power
RPV Water Level	RCS Level
RPV Pressure	RCS Pressure
Primary Containment Pressure	In-Core/Core Exit Temperature
Suppression Pool Level	Levels in at least (site-specific number) steam generators
Suppression Pool Temperature	Steam Generator Auxiliary or Emergency Feed Water Flow to at least (site-specific number) steam generators

AND

- b. **EITHER** of the following events has occurred.
 - Reactor scram [BWR] / trip [PWR]
 - ECCS (SI) actuation

Basis:

This IC addresses the difficulty associated with monitoring rapidly changing plant conditions during a transient without the ability to obtain SAFETY SYSTEM parameters from within the Control Room. During this condition, the margin to a potential fission product barrier challenge is reduced. It thus represents a potential substantial degradation in the level of safety of the plant.

As used in this EAL, an “inability to monitor” means that values for one or more of the listed parameters cannot be determined from within the Control Room. [The preceding sentence may be deleted for a BWR.] This condition requires a loss of all of the Control Room sources for the given parameter(s). For example, the reactor power level cannot be determined from any analog, digital and recorder source within the Control Room.

An event involving a loss of plant indications, annunciators and/or display systems is evaluated in accordance with 10 CFR 50.72 (and associated guidance in NUREG-1022) to determine if an NRC event report is required. The event would be reported if it significantly impaired the capability to perform emergency assessments. In particular, emergency assessments necessary to implement abnormal operating procedures, emergency operating procedures, and emergency plan implementing procedures addressing emergency classification, accident assessment, or protective action decision-making.

This EAL is focused on a selected subset of plant parameters associated with the key safety functions of reactivity control, core cooling [*PWR*] / RPV level [*BWR*] and RCS heat removal. The loss of the ability to determine one or more of these parameters from within the Control Room is considered to be more significant than simply a reportable condition. In addition, if all indication sources for one or more of the listed parameters are lost, then the ability to determine the values of other SAFETY SYSTEM parameters may be impacted as well. For example, if the value for reactor vessel level [*PWR*] / RPV water level [*BWR*] cannot be determined from the indications and recorders on a main control board, the SPDS or the plant computer, the availability of other parameter values may be compromised as well.

Fifteen minutes was selected as a threshold to exclude transient or momentary losses of indication.

Escalation of the emergency classification level would be via ICs FS1 or IC AS1.

Developer Notes:

In the PWR parameter list column, developers may use either pressurizer level or reactor vessel level for the RCS Level entry. Also, the “site-specific number” should reflect the minimum number of steam generators necessary for plant cooldown and shutdown. The steam generator level value may be wide-range, narrow-range or both, depending upon the monitoring requirements in emergency operating procedures.

The number, type, location and layout of Control Room indications, and the range of possible failure modes, can challenge the ability of an operator to accurately determine, within the time period available for emergency classification assessments, if a specific percentage of indications have been lost. The approach used in this EAL facilitates prompt and accurate emergency classification assessments by focusing on the indications for a selected subset of parameters.

By focusing on the availability of the specified parameter values, instead of the sources of those values, the EAL recognizes and accommodates the wide variety of indications in nuclear power plant Control Rooms. Indication types and sources may be analog or digital, safety-related or not, primary or alternate, individual meter value or computer group display, etc.

A loss of plant annunciators will be evaluated for reportability in accordance with 10 CFR 50.72 (and the associated guidance in NUREG-1022), and reported if it significantly impairs the capability to perform emergency assessments. Compensatory measures for a loss of annunciation can be readily implemented and may include increased monitoring of main control boards and more frequent plant rounds by non-licensed operators. Their alerting function notwithstanding, annunciators do not provide the parameter values or specific component status information used to operate the plant, or process through AOPs or EOPs. Based on these considerations, a loss of annunciation is considered to be adequately addressed by reportability criteria, and therefore not included in this IC and EAL.

With respect to establishing event severity, the response to a loss of radiation monitoring data (e.g., process or effluent monitor values) is considered to be adequately bounded by the requirements of 10 CFR 50.72 (and associated guidance in NUREG-1022). The reporting of this event will ensure adequate plant staff and NRC awareness, and drive the establishment of appropriate compensatory measures and corrective actions. In addition, a loss of radiation monitoring data, by itself, is not a precursor to a more significant event.

Personnel at sites that have a Failure Modes and Effects Analysis (FMEA) included within the design basis of a digital I&C system should consider the FMEA information when developing their site-specific EALs.

Due to changes in the configurations of SAFETY SYSTEMS, including associated instrumentation and indications, during the cold shutdown, refueling, and defueled modes, no analogous IC is included for these modes of operation.

SA3

ECL: Alert

Initiating Condition: Control Room evacuation resulting in transfer of plant control to alternate locations.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

- (1) An event has resulted in plant control being transferred from the Control Room to (site-specific remote shutdown panels and local control stations).

Basis:

This IC addresses an evacuation of the Control Room that results in transfer of plant control to alternate locations outside the Control Room. The loss of the ability to control the plant from the Control Room is considered to be a potential substantial degradation in the level of plant safety.

Following a Control Room evacuation, control of the plant will be transferred to alternate shutdown locations. The necessity to control a plant shutdown from outside the Control Room, in addition to responding to the event that required the evacuation of the Control Room, will present challenges to plant operators and other on-shift personnel. Activation of the ERO and emergency response facilities will assist in responding to these challenges.

Escalation of the emergency classification level would be via IC SS3.

Developer Notes:

The “site-specific remote shutdown panels and local control stations” are the panels and control stations referenced in plant procedures used to cooldown and shutdown the plant from a location(s) outside the Control Room.

SA7

ECL: Alert

Initiating Condition: Hazardous event affecting two or more SAFETY SYSTEM trains.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

- (1) a. The occurrence of **ANY** of the following hazardous events:
- Seismic event (earthquake)
 - Internal or external flooding event
 - High winds or tornado strike
 - FIRE
 - EXPLOSION
 - (site-specific hazards)
 - Other events with similar hazard characteristics as determined by the Shift Manager

AND

- b. The event has resulted in **BOTH** of the following:
1. Indications of degraded performance on a SAFETY SYSTEM train.

AND

2. **EITHER** of the following:

- a) **VISIBLE DAMAGE** to a second SAFETY SYSTEM train.

OR

- b) Indications of degraded performance to a second SAFETY SYSTEM train.

Basis:

This IC addresses a hazardous event of sufficient magnitude to cause degraded performance to a SAFETY SYSTEM train with either 1) **VISIBLE DAMAGE** to a second SAFETY SYSTEM train or 2) indications of degraded performance on a second SAFETY SYSTEM train. The affected trains may be on the same SAFETY SYSTEM or different SAFETY SYSTEMS. Commercial nuclear power plant SAFETY SYSTEMS are typically comprised of two or more separate and redundant trains of equipment in accordance with site-specific design criteria. This permits a plant to respond to an event affecting a single train without compromising public health and safety from radiological events. Nonetheless, a hazardous event of sufficient magnitude to impact two SAFETY SYSTEM trains has the potential to significantly reduce the margin to a loss or potential loss of a fission product barrier, and therefore represents an actual or potential substantial degradation of the level of safety of the plant.

The “second SAFETY SYSTEM train” referenced in EAL statement (1)b.2 may be associated with the same SAFETY SYSTEM as the train experiencing the indications of degraded performance per statement (1)b.1 or a different SAFETY SYSTEM. In addition, the EAL assessment is independent of the operability status of the second train. For example, if a system train is out-of-service for maintenance at the time of the event and sustains VISIBLE DAMAGE, then an emergency declaration is warranted if another SAFETY SYSTEM train has indications of degraded performance.

The “indications of degraded performance” address damage to a SAFETY SYSTEM train that is in service/operation since indications for it will be readily available. The indications of degraded performance should be significant enough to cause concern regarding the functionality or reliability of the SAFETY SYSTEM train. It is recognized that a train may be put into service sometime after the event has occurred; in that case, the emergency classification assessment should be made at the time the train displays indications of degraded performance.

The term VISIBLE DAMAGE addresses damage to a SAFETY SYSTEM train that is not in service/operation or readily apparent through indications alone. Operators will make a determination of VISIBLE DAMAGE based on the totality of available event and damage report information. This is intended to be a brief assessment not requiring lengthy analysis or quantification of the damage.

Escalation of the emergency classification level would be via IC FS1 or AS1.

Developer Notes:

Developers may add one or more of the following paragraphs to the Basis section as applicable to the plant design.

1. An event affecting equipment common to two or more SAFETY SYSTEMS or SAFETY SYSTEM trains (i.e., there are indications of degraded performance and/or VISIBLE DAMAGE affecting the common equipment) should be classified under this IC. By affecting the functionality or reliability of multiple system trains, the loss of the common equipment effectively meets the two-train impact criteria that underlie the EALs and Basis. Examples of such equipment include a Refueling Water Storage Tank [*PWR*] or a Condensate Storage Tank [*BWR*].
2. An event affecting a single-train SAFETY SYSTEM (i.e., there are indications of degraded performance and/or VISIBLE DAMAGE affecting the one train) would not be classified under this IC because the two-train impact criteria that underlie the EALs and Basis would not be met. If an event affects a single-train SAFETY SYSTEM, then the emergency classification should be made based on plant parameters/symptoms meeting the EALs for another IC. Depending upon the circumstances, classification may also occur based on Shift Manager/Emergency Director judgement.
3. An event that affects two trains of a SAFETY SYSTEM (e.g., one train has indications of degraded performance and the other VISIBLE DAMAGE) that also has one or more additional trains should be classified under this IC. This approach maintains consistency with the two-train impact criteria that underlie the EALs and

Basis, and is warranted because the event was severe enough to affect the functionality or reliability of two trains of a SAFETY SYSTEM despite plant design criteria associated with system and system train separation and protection. Such an event may have caused other plant impacts that are not immediately apparent.

For (site-specific hazards), developers should consider including other significant, site-specific hazards to the bulleted list contained in EAL 1.a (e.g., a seiche).

SA9

ECL: Alert

Initiating Condition: Reactor coolant activity > 2% fuel clad failure.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

- (1) (Site-specific indications that reactor coolant activity is greater than 2% fuel clad failure.)

Basis:

This IC addresses conditions or events that result in RCS radioactivity exceeding levels corresponding to approximately 2% fuel clad failure. This level of clad failure represents an actual or potential substantial degradation of the level of safety of the plant.

When assessing this threshold via an RCS sample analysis, the 15-minute emergency classification period begins when plant operators receive the results of the analysis.

Escalation of the emergency classification level would be via IC FS1 or AS1.

Developer Notes:

The site-specific indications should be determined assuming RCS radioactivity concentration equals that associated with the failure of 2% of the fuel cladding (and NOT 2% fuel failure). Alternatively, a site may specify threshold indications corresponding to 300 $\mu\text{Ci/gm}$ dose equivalent I-131 and change the Basis section accordingly. Other site-specific units may be used for RCS radioactivity concentrations (e.g., $\mu\text{Ci/cc}$).

The selection of site-specific indications for this threshold should consider any site commitments made to the NRC associated changes to the post-accident sampling system - for generic background, refer to Technical Specification Task Force (TSTF) issue number:

- 366 (Westinghouse and Combustion Engineering), or
- 413 (General Electric), or
- 442 (Babcock and Wilcox),

and the associated model safety evaluation. Depending on site-specific capabilities, this threshold may have a sample analysis component and/or a radiation monitor reading component. Sites employing a sample analysis method should add this sentence (or similar wording) to the Basis: "It is recognized that sample collection and analysis of reactor coolant with highly elevated radioactivity levels could require several hours to complete; however, a sample-related threshold is included as a backup to other indications."

SS1

ECL: Site Area Emergency

Initiating Condition: Loss of all offsite and all onsite AC power to emergency buses for 15 minutes or longer.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

Notes:

- The Shift Manager/Emergency Director should declare the Site Area Emergency promptly upon determining that 15 minutes has been exceeded or will likely be exceeded.
 - Any power source, safety-related or not, is acceptable provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with ECCS and decay heat removal functions.
- (1) Loss of **ALL** offsite and **ALL** onsite AC power to (site-specific emergency buses) for 15 minutes or longer.

Basis:

This IC addresses a total loss of AC power that compromises the performance of all SAFETY SYSTEMS requiring electric power including those necessary for emergency core cooling, containment heat removal/pressure control, spent fuel heat removal and the ultimate heat sink. In addition, fission product barrier monitoring capabilities may be degraded under these conditions. This IC represents a condition that involves actual or likely major failures of plant functions needed for the protection of the public.

Any power source, safety-related or not, is acceptable provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with ECCS and decay heat removal functions.

Fifteen minutes was selected as a threshold to exclude transient or momentary power losses.

Escalation of the emergency classification level would be via ICs AG1, FG1 or SG1.

Developer Notes:

For a power source that has multiple generators, the EAL and/or Basis section should reflect the minimum number of operating generators necessary for that source to provide adequate power to an AC emergency bus. For example, if a backup power source is comprised of two generators (i.e., two 50%-capacity generators sized to feed 1 AC emergency bus), the EAL and Basis section must specify that both generators for that source are operating.

The “site-specific emergency buses” are the buses fed by offsite or emergency AC power sources that supply power to the electrical distribution system that powers SAFETY SYSTEMS. There is typically 1 emergency bus per train of SAFETY SYSTEMS.

The EAL and/or Basis section may specify the use of a non-safety-related power source provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with ECCS and decay heat removal functions. This includes sources that support implementation of strategies required by 10 CFR 50.155, “Mitigation of beyond-design-basis events.”

At multi-unit stations, the EALs may credit compensatory measures that are proceduralized. Consider capabilities such as power source cross-ties, “swing” generators, other power sources described in abnormal or emergency operating procedures, etc. Plants that have a proceduralized capability to supply offsite AC power to an affected unit via a cross-tie to a companion unit may credit this power source in the EAL provided that the planned cross-tie strategy meets the requirements of 10 CFR 50.63.

SS3

ECL: Site Area Emergency

Initiating Condition: Challenge to a fission product barrier with Control Room evacuated.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

- (1) a. Plant control has been transferred to locations outside the Control Room.
- AND**
- b. **ANY** of the following conditions exist:
- The reactor is not shutdown with adequate shutdown margin verified
 - A loss or potential loss of Fuel Clad Barrier (*per the Fission Product Barrier Table*)
 - A loss or potential loss of RCS Barrier (*per the Fission Product Barrier Table*)

Basis:

This IC addresses an evacuation of the Control Room with a concurrent challenge to a fission product barrier. The challenge to a fission product barrier is indicative of an inability to gain control of one or more safety functions following the transfer of plant control to locations outside the Control Room. This condition is a precursor to a challenge to one or more fission product barriers within a relatively short period of time.

Plant control is “transferred” upon completion of (site-specific action or procedure step).

Escalation of the emergency classification level would be via IC AG1 or FG1.

Developer Notes:

The “site-specific action or procedure step” should be the procedural action/step that concludes the process to transfer plant control to remote locations such that key safety functions are controlled from locations outside the Control Room.

SS6

ECL: Site Area Emergency

Initiating Condition: Loss of all Vital DC power for 15 minutes or longer.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

Note: The Shift Manager/Emergency Director should declare the Site Area Emergency promptly upon determining that 15 minutes has been exceeded or will likely be exceeded.

- (1) Indicated voltage is less than (site-specific bus voltage value) on **ALL** (site-specific Vital DC busses) for 15 minutes or longer.

Basis:

This IC addresses a loss of Vital DC power which compromises the ability to monitor and control SAFETY SYSTEMS. This condition involves a major failure of plant functions needed for the protection of the public.

Fifteen minutes was selected as a threshold to exclude transient or momentary power losses.

Escalation of the emergency classification level would be via ICs AG1, FG1 or SG6.

Developer Notes:

The “site-specific bus voltage value” should be based on the minimum bus voltage necessary for adequate operation of SAFETY SYSTEM equipment. This voltage value should incorporate a margin of at least 15 minutes of operation before the onset of inability to operate those loads. This voltage is usually near the minimum voltage selected when battery sizing is performed.

The “site-specific Vital DC busses” are the DC busses that provide monitoring and control capabilities for SAFETY SYSTEMS.

SG1

ECL: General Emergency

Initiating Condition: Extended loss of all AC power to emergency buses.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

- (1) a. Loss of ALL offsite and ALL onsite AC power to (site-specific emergency buses).

AND

- b. (Site-specific indication of inadequate core cooling)

Basis:

This IC addresses a loss of all power sources to AC emergency buses leading to indications of inadequate core cooling. This condition challenges the RCS and Fuel Clad Barriers and, if further mitigation actions are unsuccessful, the Containment Barrier. Although this IC may be viewed as redundant to Fission Product Barrier IC FG1, it is included to provide for a timelier escalation of the emergency classification level (i.e., IC SG1 will likely be met before IC FG1). This approach should allow additional time for the identification and implementation of offsite protective actions.

Nuclear power plants maintain FLEX strategies and equipment as required by 10 CFR 50.155, "Mitigation of beyond-design-basis events." In response to an extended loss of AC power, a site will implement a FLEX strategy to maintain or restore the capability for core cooling. For example, a strategy could involve a portable generator to repower a safety bus or a standalone power source (e.g., a diesel engine) to drive a pump used to inject water into the core. Provided the strategy is successful, the ability to cool the core will be preserved and EAL statement 1.b will not be met. If the strategy is not successful, an inadequate core cooling condition will result; under these conditions, EAL statement 1.b will be met and a General Emergency declared.

Developer Notes:

This IC reflects direction in Emergency Operating Procedures (EOPs) for operators to declare an extended loss of AC power (ELAP), and implement strategies and guidelines developed to meet the requirements of 10 CFR 50.155(b)(1). These strategies and guidelines rely on FLEX equipment to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities for an indefinite period. Provided the plant can successfully implement FLEX strategies and guidelines, there will be no challenge to fission product barriers within a fixed amount of time. For this reason, IC SG1 does not consider Station Blackout (SBO) analyses and derived coping times determined in accordance with 10 CFR 50.63 and Regulatory Guide 1.155. Because SBO analyses do not credit FLEX response capabilities, the coping times derived from these analyses are not suitable criteria for this IC. Following an ELAP, escalation to a General Emergency should be based on the inability to establish and maintain adequate core cooling, and this basis is reflected in the EALs for IC SG1.

The “site-specific emergency buses” are the buses fed by offsite or emergency AC power sources that supply power to the electrical distribution system that powers SAFETY SYSTEMS. There is typically 1 emergency bus per train of SAFETY SYSTEMS.

The EAL and/or Basis section may specify the use of a non-safety-related power source provided the source is adequately maintained and able to power the equipment needed to implement a core cooling strategy (i.e., to maintain or restore the core cooling capability). This includes sources that support implementation of strategies required by 10 CFR 50.155, “Mitigation of beyond-design-basis events.”

At multi-unit stations, the EALs may credit compensatory measures that are proceduralized. Consider capabilities such as power source cross-ties, “swing” generators, other power sources described in abnormal or emergency operating procedures, etc. Plants that have a proceduralized capability to supply offsite AC power to an affected unit via a cross-tie to a companion unit may credit this power source in the EAL provided that the planned cross-tie strategy meets the requirements of 10 CFR 50.63.

Site-specific indication of inadequate core cooling:

BWR – Reactor vessel water level cannot be restored and maintained above Minimum Steam Cooling RPV Water Level as described in the plant EOP bases.

PWR – Insert site-specific values for an incore/core exit thermocouple temperature and/or reactor vessel water level that drive entry into a core cooling restoration procedure (or otherwise requires implementation of prompt restoration actions). Alternately, a site may use incore/core exit thermocouple temperatures greater than 1,200°F and/or a reactor vessel water level that corresponds to approximately the middle of active fuel. Plants with reactor vessel level instrumentation that cannot measure down to approximately the middle of active fuel should use the lowest on-scale reading that is not above the top of active fuel. If the lowest on-scale reading is above the top of active fuel, then a reactor vessel level value should not be included.

For plants that have implemented Westinghouse Owners Group Emergency Response Guidelines, EAL statement (1).b. can specify Core Cooling Red Path or the associated parameters and Red Path values.

ECL Assignment Attributes: 3.1.4.B

SG6

ECL: General Emergency

Initiating Condition: Loss of all AC and Vital DC power sources for 15 minutes or longer.

Operating Mode Applicability: Power Operation, Startup, Hot Standby, Hot Shutdown

Example Emergency Action Level:

Notes:

- The Shift Manager/Emergency Director should declare the Site Area Emergency promptly upon determining that 15 minutes has been exceeded or will likely be exceeded.
- Any AC power source, safety-related or not, is acceptable provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with ECCS and decay heat removal functions.

- (1) a. Loss of **ALL** offsite and **ALL** onsite AC power to (site-specific emergency buses) for 15 minutes or longer.

AND

- b. Indicated voltage is less than (site-specific bus voltage value) on ALL (site-specific Vital DC busses) for 15 minutes or longer.

Basis:

This IC addresses a concurrent and extended loss of both AC and Vital DC power. A loss of all AC power compromises the performance of all SAFETY SYSTEMS requiring electric power including those necessary for emergency core cooling, containment heat removal/pressure control, spent fuel heat removal and the ultimate heat sink. A loss of Vital DC power compromises the ability to monitor and control SAFETY SYSTEMS. A sustained loss of both AC and DC power will lead to multiple challenges to fission product barriers.

Any AC power source, safety-related or not, is acceptable provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with ECCS and decay heat removal functions.

Fifteen minutes was selected as a threshold to exclude transient or momentary power losses. The 15-minute emergency declaration clock begins at the point when both EAL thresholds are met.

This IC and EAL were included to address operating experience from the March 2011 accident at Fukushima Daiichi and research outcomes discussed in NUREG-1935, *State-of-the-Art Reactor Consequence Analyses (SOARCA) Report*.

Developer Notes:

The “site-specific emergency buses” are the buses fed by offsite or emergency AC power sources that supply power to the electrical distribution system that powers SAFETY SYSTEMS. There is typically 1 emergency bus per train of SAFETY SYSTEMS.

The EAL and/or Basis section may specify the use of a non-safety-related power source provided the source is adequately maintained in an appropriate maintenance program and able to power the bus loads associated with ECCS and decay heat removal functions. This includes sources that support implementation of strategies required by 10 CFR 50.155, “Mitigation of beyond-design-basis events.”

At multi-unit stations, the EALs may credit compensatory measures that are proceduralized. Consider capabilities such as power source cross-ties, “swing” generators, other power sources described in abnormal or emergency operating procedures, etc. Plants that have a proceduralized capability to supply offsite AC power to an affected unit via a cross-tie to a companion unit may credit this power source in the EAL provided that the planned cross-tie strategy meets the requirements of 10 CFR 50.63.

The “site-specific bus voltage value” should be based on the minimum bus voltage necessary for adequate operation of SAFETY SYSTEM equipment. This voltage value should incorporate a margin of at least 15 minutes of operation before the onset of inability to operate those loads. This voltage is usually near the minimum voltage selected when battery sizing is performed.

The “site-specific Vital DC busses” are the DC busses that provide monitoring and control capabilities for SAFETY SYSTEMS.

APPENDIX A – ACRONYMS AND ABBREVIATIONS

AC	Alternating Current
AOP	Abnormal Operating Procedure
APRM	Average Power Range Monitor
ATWS	Anticipated Transient Without Scram
B&W	Babcock and Wilcox
BIIT	Boron Injection Initiation Temperature
BWR	Boiling Water Reactor
CDE	Committed Dose Equivalent
CFR	Code of Federal Regulations
CTMT/CNMT	Containment
CSF	Critical Safety Function
CSFST	Critical Safety Function Status Tree
DBA	Design Basis Accident
DC	Direct Current
EAL	Emergency Action Level
ECCS	Emergency Core Cooling System
ECL	Emergency Classification Level
ELAP	Extended Loss of AC Power
EOF	Emergency Operations Facility
EOP	Emergency Operating Procedure
EPA	Environmental Protection Agency
EPG	Emergency Procedure Guideline
EPIP	Emergency Plan Implementing Procedure
EPR	Evolutionary Power Reactor
EPRI	Electric Power Research Institute
ERG	Emergency Response Guideline
FEMA	Federal Emergency Management Agency
FSAR	Final Safety Analysis Report
GE	General Emergency
HCTL	Heat Capacity Temperature Limit
HPCI	High Pressure Coolant Injection
HSI	Human System Interface
IC	Initiating Condition
ID	Inside Diameter
IPEEE	Individual Plant Examination of External Events (Generic Letter 88-20)
ISFSI	Independent Spent Fuel Storage Installation
Keff	Effective Neutron Multiplication Factor
LCO	Limiting Condition of Operation
LOCA	Loss of Coolant Accident
MCR	Main Control Room
MSIV	Main Steam Isolation Valve
MSL	Main Steam Line
mR, mRem, mrem, mREM	milli-Roentgen Equivalent Man
MW	Megawatt
NEI	Nuclear Energy Institute
NPP	Nuclear Power Plant

NRC	Nuclear Regulatory Commission
NSSS	Nuclear Steam Supply System
NORAD	North American Aerospace Defense Command
(NO)UE	(Notification Of) Unusual Event
NUMARC ⁷	Nuclear Management and Resources Council
OBE	Operating Basis Earthquake
OCA	Owner Controlled Area
ODCM/ODAM	Offsite Dose Calculation (Assessment) Manual
ORO	Off-site Response Organization
PA	Protected Area
PACS	Priority Actuation and Control System
PAG	Protective Action Guideline
PICS	Process Information and Control System
PRA/PSA	Probabilistic Risk Assessment / Probabilistic Safety Assessment
PWR	Pressurized Water Reactor
PS	Protection System
PSIG	Pounds per Square Inch Gauge
R	Roentgen
RCC	Reactor Control Console
RCIC	Reactor Core Isolation Cooling
RCS	Reactor Coolant System
Rem, rem, REM	Roentgen Equivalent Man
RETS	Radiological Effluent Technical Specifications
RHR	Residual Heat Removal
RPS	Reactor Protection System
RPV	Reactor Pressure Vessel
RVLIS	Reactor Vessel Level Instrumentation System
RWCU	Reactor Water Cleanup
SAG	Severe Accident Guideline
SAR	Safety Analysis Report
SAS	Safety Automation System
SBO	Station Blackout
SCBA	Self-Contained Breathing Apparatus
SG	Steam Generator
SI	Safety Injection
SICS	Safety Information and Control System
SPDS	Safety Parameter Display System
SRO	Senior Reactor Operator
TEDE	Total Effective Dose Equivalent
TOAF	Top of Active Fuel
TSC	Technical Support Center
WOG	Westinghouse Owners Group

⁷ NUMARC was a predecessor organization of the Nuclear Energy Institute (NEI).

APPENDIX B – DEFINITIONS

The following definitions are taken from Title 10, Code of Federal Regulations, and related regulatory guidance documents.

Alert: Events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant or a security event that involves probable life threatening risk to site personnel or damage to site equipment because of HOSTILE ACTION. Any releases are expected to be limited to small fractions of the EPA PAG exposure levels.

General Emergency: Events are in progress or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity or HOSTILE ACTION that results in an actual loss of physical control of the facility. Releases can be reasonably expected to exceed EPA PAG exposure levels offsite for more than the immediate site area.

Notification of Unusual Event (NOUE)⁸: Events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant or indicate a security threat to facility protection has been initiated. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety systems occurs.

Site Area Emergency: Events are in progress or have occurred which involve actual or likely major failures of plant functions needed for protection of the public or HOSTILE ACTION that results in intentional damage or malicious acts; 1) toward site personnel or equipment that could lead to the likely failure of or; 2) that prevent effective access to, equipment needed for the protection of the public. Any releases are not expected to result in exposure levels which exceed EPA PAG exposure levels beyond the site boundary.

The following are key terms necessary for overall understanding the NEI 99-01 emergency classification scheme.

Emergency Action Level (EAL): A pre-determined, site-specific, observable threshold for an Initiating Condition that, when met or exceeded, places the plant in a given emergency classification level.

Emergency Classification Level (ECL): One of a set of names or titles established by the US Nuclear Regulatory Commission (NRC) for grouping off-normal events or conditions according to (1) potential or actual effects or consequences, and (2) resulting onsite and offsite response actions. The emergency classification levels, in ascending order of severity, are:

- Notification of Unusual Event (NOUE)
- Alert
- Site Area Emergency (SAE)
- General Emergency (GE)

⁸ This term is sometimes shortened to Unusual Event (UE) or other similar site-specific terminology.

Fission Product Barrier Threshold: A pre-determined, site-specific, observable threshold indicating the loss or potential loss of a fission product barrier.

Initiating Condition (IC): An event or condition that aligns with the definition of one of the four emergency classification levels by virtue of the potential or actual effects or consequences.

Selected terms used in Initiating Condition and Emergency Action Level statements are set in all capital letters (e.g., ALL CAPS). These words are defined terms that have specific meanings as used in this document. The definitions of these terms are provided below.

CONTAINMENT CLOSURE: (Insert a site-specific definition for this term.) **Developer Note** – The procedurally defined conditions or actions taken to secure containment (primary or secondary for BWR) and its associated structures, systems, and components as a functional barrier to fission product release under shutdown conditions.

EXPLOSION: A rapid, violent and catastrophic failure of a piece of equipment due to combustion, chemical reaction or overpressurization. A release of steam (from high energy lines or components) or an electrical component failure (caused by short circuits, grounding, arcing, etc.) should not automatically be considered an explosion. Such events may require a post-event inspection to determine if the attributes of an explosion are present.

FAULTED: The term applied to a steam generator that has a steam leak on the secondary side of sufficient size to cause an uncontrolled drop in steam generator pressure or the steam generator to become completely depressurized. **Developer Note** – This term is applicable to PWRs only.

FIRE: Combustion characterized by heat and light. Sources of smoke such as slipping drive belts or overheated electrical equipment do not constitute FIRES. Observation of flame is preferred but is NOT required if large quantities of smoke and heat are observed.

HOSTAGE: A person(s) held as leverage against the station to ensure that demands will be met by the station.

HOSTILE ACTION: An act toward a NPP or its personnel that includes the use of violent force to destroy equipment, take HOSTAGES, and/or intimidate the licensee to achieve an end. This includes attack by air, land, or water using guns, explosives, PROJECTILES, vehicles, or other devices used to deliver destructive force. Other acts that satisfy the overall intent may be included. HOSTILE ACTION should not be construed to include acts of civil disobedience or felonious acts that are not part of a concerted attack on the NPP. Non-terrorism-based EALs should be used to address such activities (i.e., this may include violent acts between individuals in the owner controlled area).

HOSTILE FORCE: One or more individuals who are engaged in a determined assault, overtly or by stealth and deception, equipped with suitable weapons capable of killing, maiming, or causing destruction.

IMMINENT: The trajectory of events is such that a condition will occur or an EAL be met

within a relatively short period of time and the implementation of effective mitigation actions is not expected.

INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI): A complex that is designed and constructed for the interim storage of spent nuclear fuel and other radioactive materials associated with spent fuel storage.

PROJECTILE: A fired, projected object, such as a bullet or pellet having no capacity for self-propulsion, directed toward a nuclear power plant that could cause concern for the plant's continued operability, reliability, or personnel safety. **Developer Note** – This definition is from NUREG 2203, *Glossary of Security Terms for Nuclear Power Reactors*.

PROTECTED AREA: (Insert a site-specific definition for this term.) **Developer Note** – This term is typically taken to mean the area under continuous access monitoring and control, and armed protection as described in the site Security Plan.

REFUELING PATHWAY: (Insert a site-specific definition for this term.) **Developer Note** – This description should include all the cavities, tubes, canals and pools through which irradiated fuel may be moved, but not including the reactor vessel.

RUPTURE(D): The condition of a steam generator in which primary-to-secondary leakage is of sufficient magnitude to require a safety injection. **Developer Note** – This term is applicable to PWRs only.

SAFETY SYSTEM: A system required for safe plant operation, cooling down the plant and/or placing it in the cold shutdown condition, including the ECCS. These are typically systems classified as safety-related. **Developer Note** – This term may be modified to include the attributes of "safety-related" in accordance with 10 CFR 50.2 or other site-specific terminology, if desired.

SECURITY CONDITION: Any Security Event as listed in the approved security contingency plan that constitutes a threat/compromise to site security, threat/risk to site personnel, or a potential degradation to the level of safety of the plant. A SECURITY CONDITION does not involve a HOSTILE ACTION.

UNISOLABLE: An open or breached system line that cannot be isolated, remotely or locally. An RCS or containment line opened to implement an AOP or EOP strategy, and that cannot be isolated without impacting the effectiveness of the strategy, is considered UNISOLABLE.

UNPLANNED: A parameter change or an event that is not 1) the result of an intended evolution or 2) an expected plant response to a transient. The cause of the parameter change or event may be known or unknown.

VISIBLE DAMAGE: Damage that is readily observable without measurements, testing, or analysis and of sufficient visual impact to cause concern about the functionality or reliability of the affected structure, system or component.

The licensee of a BWR facility may add the definitions of "cannot be maintained above/below" and "cannot be restored above/below," from EPG/SAG, Revision 4, to their emergency

classification scheme, if those definitions appear in the site-specific EOPs and/or controlling development procedures. The defined terms may then be used in ICs, EALs and fission product barrier thresholds where appropriate. The goal of this provision is to promote alignment between EOP and emergency classification assessments; however, care should be taken to ensure that the use of these definitions do not lead to unintended consequences (e.g., a user interpretation that delays an emergency declaration or protective action recommendation).

APPENDIX C – GUIDANCE FOR RADIATION EFFLUENT MONITOR EALS

The guidance in this appendix should be followed if it becomes necessary for the licensee to develop EALs based on calculated readings for effluent radiation monitors, as directed by the Developer Notes for ICs AA1, AS1, and AG1. The resulting three EALs should be included as EAL #1 under ICs AA1, AS1, and AG1.

Example Emergency Action Level:

Add this note to the other IC notes: The pre-calculated effluent monitor values presented in EAL #1 should be used for emergency classification assessments until the results from a dose assessment using actual meteorology are available.

- (1) Reading on ANY of the following radiation monitors greater than the reading shown for 15 minutes or longer:

(site-specific monitor list and threshold values)

Developer Notes:

The “site-specific monitor list and threshold values” should be determined with consideration of the following:

- Selection of the appropriate installed gaseous effluent monitors.
- The effluent monitor readings should correspond to the following doses:
 - AA1 - 10 mrem TEDE or 50 mrem thyroid CDE at the “site-specific dose receptor point” (consistent with the calculation methodology employed) for one hour of exposure.
 - AS1 - 100 mrem TEDE or 500 mrem thyroid CDE at the “site-specific dose receptor point” (consistent with the calculation methodology employed) for one hour of exposure.
 - AG1 - 1,000 mrem TEDE or 5,000 mrem thyroid CDE at the “site-specific dose receptor point” (consistent with the calculation methodology employed) for one hour of exposure.
- Monitor readings will be calculated using a set of assumed meteorological data or atmospheric dispersion factors; the data or factors selected for use should be the same for all three EALs. Acceptable sources of this information include, but are not limited to, the RETS/ODCM and values used in the site’s emergency dose assessment methodology.
- The calculation of monitor readings will also require use of an assumed release isotopic mix; the selected mix should be the same for all three EALs. Acceptable sources of this information include, but are not limited to, the RETS/ODCM and values used in the site’s emergency dose assessment methodology. Calculations to determine monitor readings should consider the potentially significant radionuclides in the release stream that contribute to the CDE and CEDE.

- Depending upon the methodology used to calculate the EAL values, there may be overlap of some values between different ICs. Developers will need to address this overlap by adjusting these values in a manner that ensures a logical escalation in the ECL.

Developers should research radiation monitor design documents or other information sources to ensure that 1) the EAL value being considered is within the usable response and display range of the instrument, and 2) there are no automatic features that may render the monitor reading invalid (e.g., an auto-purge feature triggered at a particular indication level).

The condition described by an IC may result in a radiological effluent value beyond the operating or display range of an installed effluent monitor. In those cases, EAL values should be determined with a margin sufficient to ensure that an accurate monitor reading is available. For example, an EAL monitor reading might be set at 90% to 95% of the highest accurate monitor reading. This provision notwithstanding, if the estimated/calculated monitor reading is greater than approximately 110% of the highest accurate monitor reading, then developers may choose not to include the monitor as an indication and identify an alternate EAL threshold.

