

50.72 Rulemaking Update

Chris Speer

Status

- Federal Register Notice (FRN) posted – available for comments
 - 87 FR 67571 - November 9, 2022
 - <https://www.federalregister.gov/documents/2022/11/09/2022-24463/reporting-requirements-for-nonemergency-events-at-nuclear-power-plants>
- NRC Staff recommend rulemaking to remove 6 criteria and update the guidance for 2 criteria
- Regulatory Basis document (ML22108A004)

Reporting Requirements Summary Table

- 11 Total Reports
- 6 Reports recommended for removal
- 2 Reports recommended for updates to NUREG 1022
- Revise NUREG 1022
- 1 Addition - MAP-X

10 CFR 50.72 Paragraph	Condition Requiring Notification	Recommendation
(b)(1)	Deviation from TS under 10 CFR 50.54(x)	No change
(b)(2)(i)	Plant shutdown required by TS	No change
(b)(2)(iv)(A)	System actuation (ECCS discharge)	Eliminate
(b)(2)(iv)(B)	System actuation (RPS actuation)	No change
(b)(2)(xi)	News release or notifications of other government agency	Eliminate
(b)(3)(ii)(A)	Degraded condition	Update NUREG 1022
(b)(3)(ii)(B)	Unanalyzed condition	Update NUREG 1022
(b)(3)(iv)	System actuation (valid or invalid actuation)	Eliminate
(b)(3)(v)	Event or condition that could have prevented fulfillment of a safety function	Eliminate
(b)(3)(xii)	Transport of a contaminated person offsite	Eliminate
(b)(3)(xiii)	Loss of EP capabilities	Eliminate
(a)(1)	Alternative Reporting Method (MAP-X)	New

Path Forward

- Public Meeting - Early December
 - Communicate regulatory process forward
 - Describe recommendations and their bases
 - Describe process for submitting comments
 - Answer questions from public
- Consider comments during next steps of the rulemaking

Future

Proposed rule to the
Commission: May 2024

- Public meeting(s)
- Public comment period after
Commission approval

Final rule to the
Commission: February 2026

These are estimated dates.