

# **PRA Configuration Control Workshop Tabletop Review**

March 30, 2023

Lundy Pressley  
Reliability and Risk Analyst  
Office of Nuclear Reactor Regulation  
Division of Risk Assessment  
PRA Oversight Branch

# Purpose of PRA Configuration Control (PCC) Initiative

- Gain familiarization with licensee's PCC programs.
- Leverage insights from the information gathered from the voluntarily tabletops to develop options and a draft recommendation for the PCC framework.
- Perform PCC oversight gap analysis.
- Utilize a **Balanced approach** to ensure appropriate implementation of PCC programs for licensee PRA models that support risk-informed decision-making.

# Why is PCC Important?


- PRA is used to allow licensees to make important plant decisions often **without NRC approval** such as SSC categorization and treatment (50.69), fire program changes (NFPA 805), Surveillance Frequency Control Program (SFCP) and Risk Informed Completion Times (RICT).
- If the PRA is not maintained up to date, plant baseline **risk changes may not be properly understood**, risk insights and key sources of uncertainty could be impacted but not understood, leading to quantitative estimates that underestimate risk.
- If the baseline risk model is no longer reflective of the as-built, as-operated plant, then any **risk estimates and risk-informed decisions could be impacted and could impact safety management of the facility.**

# PCC Requirements:

- **50.69**: Specific requirement to review plant changes and OpE and Update the PRA as appropriate.
- **Risk Informed Completion Time (RICT)**: Tech Spec – Administrative requirement that the PRA reflect the “as-built, as-operated” plant.
- **NFPA 805**: Requirement that PSA/PRA data reflect as-built, as-operated and maintained plant, and reflect OpE at the plant.
- **Surveillance Frequency Control Program (SFCP)**: Tech Spec – Admin control of frequency changes IAW NEI 04-10. NEI 04-10 refers to RG 1.200 for Technical Adequacy for PRA which includes PRA Configuration Control.
- **RG 1.200** and the **ASME PRA standard** address PRA configuration control.

# PRA Configuration Control Oversight Gap

PRA found acceptable ► Issuance of SE/LA



**Plant Modifications**

Operating Experience and Data

**PRA Maintenance and Upgrades**


No Current permanent  
NRC Oversight  
of PRA Changes

# Cross-Agency Effort

Working Group (WG)  
consists of:

- NRR/DRA
- NRR/DRO
- RES
- Region I
- Region II
- Region III
- Region IV

# Overall Tabletops Plan



# Performed 8 Tabletop Site Visits, Combination of Risk-informed Initiatives

- **2 Sites with:**

- Surveillance Frequency Control Program (SFCP)
- National Fire Protection Association (NFPA) 805

- **2 Sites with:**

- Risk-Informed Completion Times (RICT)
- SFCP
- NFPA 805

- **2 Sites with:**

- 50.69 Risk-Informed Categorization of SSC
- SFCP
- NFPA 805

- **2 Sites with:**

- SFCP
- RICT
- 50.69
- NFPA 805

**Performed 2 in each Region**



# Tabletop Staffing

- Team Composition (Typically 4 – 5 personnel)
  - 2 – Reliability & Risk Analysts
  - 1 – Headquarters Senior Reactor Analyst (SRA)
  - 1 – Regional SRA
  - 1 – Additional Technical Specialist (i.e., NFPA 805, as needed)
- Typically 3 days onsite
  - 2 – 4 weeks preparation/coordination for tabletop site visit

# Key Messages from Tabletops

- Focus on PRA Configuration Control (PCC) rather than PRA Acceptability.
- Variations on how licensees implement and manage PCC.
- NRC staff confirmed licensees are meeting the consensus standard; however, NRC staff identified several specific and general observations associated with PCC.

# Tabletop Observation 1: Plant Representation Discrepancy

The reliability of components that protect from a major flood were potentially not appropriately reflected in the internal flooding hazard group model, following a plant modification.

# Tabletop Observation 2: Data Updates

Unreliability and Unavailability Data had potentially not been updated for the internal hazard group model since 2016 (plant specific data) and 2010 (generic data).

## Tabletop Observation 3: Operating Experience

The internal events hazard model did not represent the as-built as operated-plant with regards to Open Phase Condition (OPC) as a potential pre-initiator for a scram or Loss of Offsite Power (LOOP) event.

# Tabletop General Observations

- Rigor of documentation and management of plant changes and the associated impacts on the PRA.
- Some PCC programs knowledge based versus proceduralized.
- Rigor of documentation of model changes/updates and conclusions and justification for determinations (i.e., Maintenance vs. Upgrade).
- Variations in the use of Human Reliability Analysis.
- Engineering Changes and Operating Experience (OE) inputs did not take advantage of official structured processes to alert the PRA organization for reviews.

# Tabletops Informed Future Guidance Development

**Be riskSMART**  


- Items of Interest that were touched upon:
  - Licensee PRA maintenance/upgrade drivers and decision points, methods of documentation and tracking.
  - Potential future sample selection and areas of focus and hazard groups, risk significance, etc.
  - Information on potential future NRC inspection level of effort.
  - Potential NRC required proficiency and technical knowledge, training and qualifications for inspection staff.

# Proposed Path Forward

Working Group recommendations will be covered in Part 2 of the NRC presentation, “PCC Path Forward” later in the Workshop.



# Questions

