

**PRELIMINARY NOTIFICATION – REGION III**

September 18, 2024

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-III-24-002

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information may not yet be fully verified or evaluated by the Region III staff.

**Facility**

Palisades Nuclear Plant  
Holtec Decommissioning International  
Covert, MI  
Docket No: 50-255

**Licensee Emergency Classification**

Notification of Unusual Event  
 Alert  
 Site Area Emergency  
 General Emergency  
 Not Applicable

**SUBJECT: PRELIMINARY RESULTS OF STEAM GENERATOR INSPECTIONS AT PALISADES NUCLEAR PLANT**

On August 24, 2024, with the plant defueled, Holtec, the owner of the Palisades Nuclear Plant, commenced steam generator (SG) tube inspections in their two SGs. The steam generators are large heat exchangers that transfer heat from the primary coolant system (reactor vessel) to the secondary plant systems (main steam system). The inspections were planned as part of Palisades' restart activities. Experienced NRC inspectors were on-site and observed the SG inspections.

During Holtec's analysis of the inspection data, preliminary results identified a large number of SG tubes with indications that require further analysis and/or repair. Further data analysis is in progress with additional tube inspections, testing, and repairs to be completed over the next few months.

There is no impact on public health. The unit remains defueled.

The NRC is aware of the preliminary findings and will inspect further Holtec activities related to the SGs as they are conducted. The NRC has assembled a team of subject matter experts who are evaluating the data and assessing Holtec's plans to correct the conditions. The NRC will ensure appropriate actions are taken prior to the potential restart of Palisades. The NRC will document the status and results of its inspection activities for this issue in publicly available inspection reports.

While this information does not present an immediate safety concern, the NRC is issuing this Preliminary Notification because it involves the potential restart of Palisades, which has high public and media interest.

The NRC maintains its public webpage on Palisades current as to the status of potential restart activities, including information on upcoming public meetings, which can be found at <https://www.nrc.gov/info-finder/reactors/pali.html>. Specific questions on this project should be directed to [PalisadesRestartProject@nrc.gov](mailto:PalisadesRestartProject@nrc.gov).

**OFFICIAL RECORD COPY**

The State of Michigan has been notified.

This preliminary notification is issued for information only. The information presented herein has been discussed with the licensee and is current as of 9:45 a.m. EST on September 18, 2024.

ADAMS Accession Number: ML24262A092

Contact: April Nguyen  
630-829-9587  
[April.Nguyen@nrc.gov](mailto:April.Nguyen@nrc.gov)