

# **Inspection Activities**

Decommissioning Lessons Learned Workshop January 15, 2025 Elise Eve Team Leader, USNRC Region I



- Radiation Protection
  - Failure to control airborne radioactivity
  - Failure to implement adequate controls in alpha level 3A areas
  - Unauthorized access to locked high radiation areas



- Transportation
  - Failure to ensure shipment was leakproof
  - Failure to ensure packaging was appropriate for the contents being shipped
  - Radioactive material shipment package dose rate exceeded



### Fire Protection

- Failure to control fire hazards with transient combustible permit
- Failure to include fire dampers in fire protection program evaluation and fire pre-plans
- Failure to perform fire watch duties with trained personnel
- Failure to implement fire protection system impairment control procedure



## Decommissioning Trust Fund (DTF)

- Use of the DTF for expenses that were not legitimate decommissioning activities (i.e., community outreach, restart activities).
- Discouraging Language in Agreements
  - Licensee agreements that contain language that would restrict or otherwise discourage employees from participating in protected activities.



### Industrial Safety

- Continue to monitor OSHA reportable events
- Referrals to OSHA as appropriate



## **Discussion & Questions**