

Discussion on UT in lieu of RT for Construction

Nuclear

Ronnie Swain EPRI

NRC-Industry NDE Technical Information Exchange Meeting January 2025

in X f www.epri.com © 2025 Electric Power Research Institute, Inc. All rights reserved.

Problem - UT in Lieu of RT is Disallowed for Section III

Regulator Issues with Relevant Section III Code Cases:

N-659 (UT in lieu of RT)

- 1. Qualifies procedure by adding 2-3 construction flaws to Sect. V or XI qualified procedure
- Inadequate evaluation of capabilities; not all flaws represented
- 2. Credits beam skipping for bi-directional coverage
- Seen as problematic in stainless steels and complex geometries
- 3. Specifies a weld plus 1/2 t exam volume
- Thought inadequate for thin-wall components
- 4. Staff wants 2%t flaws with Section III, NB-2553(c) specified lengths included in qualification

Code Case N-818 (Analytical approach to acceptance criteria)

- "... an analytical approach for the acceptance of certain fabrication flaws could be acceptable if appropriately justified and the scope limited to ferritic materials."
- Adding stainless or dissimilar metal requires more research (see N-659 issues above)

Summary of Industry Issues with Section III Status Quo

NDE Redundant and Costly (financially and structurally)

- Weld subjected to RT
 - Shutting down other area work and exposing personnel to additional radiological exposure
- Results failing RT acceptance criteria are repaired
- Continue 1-2 until weld is accepted
- Weld subjected to Section XI PSI with qualified UT
- Results failing Section XI PSI acceptance criteria are repaired
- If indications are detected that RT missed
 - Evaluated to Section III AND Section XI acceptance criteria
 - Unacceptable results are repaired, and the examination process must be repeated

RT Acceptance Criteria in Section III

- Forces repair of benign volumetric discontinuities
 - Operating experience has not shown these to be detrimental to component life
 - Repairs increase likelihood of in-service cracking



Intended and Potential Actions

- 1. Develop technical basis to support code case revisions
 - a. Explore qualification options that alleviate regulatory concerns
 - b. Explore adequacy of UT beam skipping for characterization
 - c. Determine proper exam volumes for thin wall components
 - d. Evaluate disposition options to eliminate repair of benign discontinuities
- 2. Revise Case(s) to obtain regulatory acceptance for UT option
- 3. Explore crediting Sect. III UT for PSI

Potential Challenges

- Would a 2%t flaw size prove difficult to detect & characterize?
- Is the adequacy of beam skipping easily justifiable?
- Would acceptance of benign fabrication discontinuities prove difficult for regulator approval?
- Using Section III examinations to meet Section XI PSI may require changes to qualification requirements in Section III
- Are there other challenges?
 - If so, please let me know your thoughts and concerns



TOGETHER...SHAPING THE FUTURE OF ENERGY®

in X f www.epri.com

© 2025 Electric Power Research Institute, Inc. All rights reserved