

**EPRI REPORT 3002025288, "ENHANCED RISK-INFORMED CATEGORIZATION  
METHODOLOGY FOR PRESSURE BOUNDARY COMPONENTS"**

**REQUESTS FOR ADDITIONAL INFORMATION (RAIS)**

**RAI 01 – Accounting for High Consequence Scenarios**

Background/Issue:

EPRI report criteria 11-13 propose to categorize SSCs as LSS if their individual contribution to CDF is less than  $10^{-6}$  per year, or if the SSC contribution to LERF is less than  $10^{-7}$  per year without any consideration of consequences. Further, for CDF contribution between  $10^{-6}$  per year and  $10^{-8}$  per year or LERF contribution between  $10^{-7}$  and  $10^{-9}$  per year, a sliding scale of consequence consideration of conditional core damage probability (CCDP) or conditional large early release probability (CLERP) of 1.0 or greater than 0.1 or 0.01 is introduced for HSS categorization.

Based on a review of the documents in the audit, the NRC staff found SSCs with a CCDP of greater than  $10^{-4}$  and a CDF contribution of less than  $10^{-6}$  per year. Some internal flooding analyses have identified areas with CCDPs greater than  $10^{-3}$  but would be LSS using the proposed 14 criteria. RISC-3 LSS SSCs would not be covered by American Society of Mechanical Engineers (ASME) Code or 10 CFR Part 50, Appendix B, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants," requirements and can be repaired or replaced with uncodified nonmetallic repairs with no significant operating experience or lower-quality materials with unknown failure probabilities.

The staff notes that prior approved precedents (such as: EPRI TR-112657, "Revised Risk-Informed Inservice Inspection Evaluation Procedure" (ADAMS Accession No. ML013470102); ASME Code Case N-660, "Risk-Informed Safety Classification for Use in Risk-Informed Repair/Replacement Activities Section XI, Division 1," ASME Code Case N-752, "Risk-Informed Categorization and Treatment for Repair/Replacement Activities in Class 2 and 3 Systems Section XI, Division 1," ANO2-R&R-004, Rev. 1, "ANO-2 Risk-informed Repair and Replacement Methodology" (ADAMS Accession No. ML071150108) currently approved by the NRC for categorization of passive components) considered failure scenarios with a CCDP greater than  $10^{-4}$ , or CLERP greater than  $10^{-5}$ , as high consequence scenarios, resulting in HSS categorization for the corresponding SSCs. Additionally, these approved precedents were consequence-based evaluations, where only the consequences of a postulated passive component failure were evaluated, and the failure frequencies or contribution to CDF/LERF were not taken into account. In contrast to prior approved precedents, the proposed EPRI methodology uses products of CDF (LERF) and CCDP (CLERP) as a comparison to CDF (LERF) which can contain a pipe rupture frequency as low as  $10^{-8}$  per year ( $10^{-9}$  per year for LERF and CLERP) coupled with a consequence (CCDP or CLERP) as high as 1.0 and still be categorized as LSS. The staff finds the change in CCDP/CLERP thresholds and the introduction of CDF/LERF contributions are insufficiently justified to categorically conclude that those SSCs would be LSS subject to alternative treatments.

Requests:

- a. The staff has identified the issue above regarding potentially not adequately addressing high consequence failures, specifically consequence failures with CCDP greater than  $10^{-4}$  or CLERP greater than  $10^{-5}$ . Discuss how EPRI intends to modify the TR to address these areas. As discussed during the audit, please provide consideration of the following two options:

- Provide a description and justification of how high consequence SSCs with CCDP greater than  $10^{-4}$  or CLERP greater than  $10^{-5}$  are addressed.
- As an alternative to first item above, provide a clearly defined minimum set of requirements such as the repair methods of nationally recognized postconstruction codes and standards (e.g., ASME B31.1, ASME PCC-2) for SSCs with a CCDP of  $10^{-4}$  and CLERP of  $10^{-5}$  or higher.

#### EPRI RAI Response to 1a:

The EPRI Technical Report 3002025288 (referred to as “TR 3002025288” in the rest of this document) uses a multi-step process consisting of prerequisites (including integrity management), a set of predetermined HSS components, and a plant-specific search for risk-significant passive components to address all passive SSCs.

The ten pre-determined risk-informed criteria are intended to capture common high consequence components building off decades of experience in risk-informing the pressure boundary. The EPRI streamlined RI-ISI methodology (ASME Code Case N-716 as endorsed in Regulatory Guide 1.147, ML21181A222) provides valuable insights for justifying the assignment of HSS for specific Class 2, Class 3 and non-safety related systems/subsystems in the context of in-service inspection (e.g., criteria 1, 2, 3, 4, 11). As discussed in the supplementary information provided by EPRI, valuable inputs were obtained from its application as well as other risk-informed pressure boundary applications (e.g. TR-112657, Rev B-A, WACAP-14572-A, 1006937). However, because of the breadth of 10CFR50.69, those insights could not be the sole basis for an enhanced categorization methodology.

As such, additional risk-informed criteria were developed to specifically address the increased scope and content brought about by a 10CFR50.69 application (e.g., criteria 5,6,7,8,9 and 10). In addition to the ten risk-informed criteria, criteria 11-13 are added to capture the remaining risk-significant passive components. Specifically, criteria 11<sup>1</sup> requires passive components with a CDF >  $1\text{E-}6/\text{year}$  (or LERF >  $1\text{E-}7/\text{year}$ ) to be assigned HSS. Criteria 11 is similar to the risk criteria in N-716 for streamlined RI-ISI. The Grand Gulf (ML072430005) and DC Cook (ML11073A084) Safety Evaluation Reports for ASME Code Case N-716 relief request confirm these guidelines (CDF> $1\text{E-}6/\text{year}$  and LERF > $1\text{E-}7/\text{year}$ ) are suitably small and consistent with the decision guidelines for CDF/LERF in RG 1.174. It is also consistent with the guidelines contained in EPRI TR-112657, Rev B-A. Criterion 11 is a defense-in-depth measure to capture plant-specific locations that are important to safety.

---

<sup>1</sup> As a point of clarification on the background for RAI 1, criterion 11 does not propose to categorize SSCs as LSS if their individual contribution to CDF is less than  $1\text{E-}6/\text{year}$  (LERF less than  $1\text{E-}7/\text{year}$ ). SSCs that meet the requirements of Criteria 11 are categorized as HSS.


It should be noted that “high consequence” was a term used to identify passive SSCs that exceed a particular CCDP/CLERP threshold, and this is not equivalent to high risk. When CCDP/CLERP is paired with frequency, as in licensee’s internal flooding PRA models, decision-makers can obtain more holistic insights on both frequency of occurrence and consequences of pipe ruptures in assessing risk, without unduly biasing the results towards overly conservative treatment of SSCs that are not significant to risk as measured by CDF and LERF (RG 1.174).

EPRI TR-112657, WCAP-14572, and N-716 (all NRC approved RI-ISI methodologies) use failure frequencies and CDF/LERF in determining risk/safety significance. Furthermore, failure frequencies and CDF/LERF are an inherent part of risk-informed applications such as risk-informed Technical Specifications (e.g., surveillance frequencies and completion times).

On the prior supplementary information, submitted in June 2024, as part of the on-going NRC review of TR 3002025288 Attachment 4: Updated Chapter 5 Table 7, examples are provided that have improved plant safety through vulnerabilities identified from implementing criteria 11. Table 7 documents plant hardware modifications, procedure updates, and new NDE and inspection for risk-significant scenarios. Pipe segments with internal flood PRA CDF/LERF of greater than  $1\text{E-}6/1\text{E-}7$  respectively are HSS.

Peer reviewed internal flooding PRA models that use industry experience derived failure rates/pipe rupture frequencies paired with plant-specific direct and indirect effects is consistent with the NRC’s PRA Policy Statement that “PRA evaluations should be as realistic as practical”. Revision 5 of EPRI’s *Pipe Rupture Frequencies for Internal Flooding Probabilistic Risk Assessment*, provides service experience through 2020 to determine the frequencies.

Criteria 12 and 13 were added to provide additional means of ensuring that any-plant specific location(s) important to safety are identified. Similar to Criterion 11, Criteria 12 and 13 can only add HSS segments (and are not used to remove prior HSS segments). Criteria 12 (CDF\*CCDP) and Criteria 13 (LERF\*CLERP) are intended to capture lower frequencies with higher consequences (CCDP or CLERP) as shown in Figure 4 from 3002025288 (reproduced below). This provides additional margin that any lower-frequency/higher consequence scenarios are carefully considered.



Candidate RISC-3 segments are further subjected to a sensitivity study, which increases the failure rate by a factor of 3 as required by Section 4.3 of TR 3002025288 (and in line with currently approved guidance in NEI 00-04). Any segment(s) that exceeds the RG 1.174

acceptance criteria will be provided to the IDP as candidate HSS. The remaining segments will be presented to the IDP as candidate LSS.

Consistent with the guidance in NEI 00-04 (and summarized in Table 1 on TR 3002025288) once passive segments are categorized as HSS (meeting any one of the thirteen criteria), the IDP is not allowed to change HSS to LSS. The IDP, serving as a multi-disciplinary review panel, ensures all attributes of the evaluations are fully addressed to provide a valid risk-informed conclusion or decision that addresses the maintenance of defense-in-depth and adequate safety margin. This is explicitly covered in existing industry instruction documents and templates developed and maintained by the Nuclear Energy Institute (NEI), under the suite of documents covering the implementation of 10 CFR 50.69 (titled "Risk Informed Engineering Programs" (under RIEP-NEI-16-005):

When applying the methodology in TR 3002025288:

- The IDP shall ensure the prerequisites in Section 4.1 of TR 3002025288 are met
- The IDP shall confirm the assignment of HSS components (from the results of using criteria 1 through 13) is appropriate.
- The IDP shall confirm that the assignment of HSS criteria is valid in the context of other hazards (fire, seismic, other hazards).
- The IDP shall confirm LSS assignment for CCDPs > 1E-02 / CLERPs > 1E-03
  - When reviewing the results for criteria 12 and 13, the IDP shall review internal flooding segments/scenarios with high CCDP/CLERP values (i.e., > 1E-02 / 1E-03). The IDP may accept the LSS assignment, review categorization assignment to ensure defense in depth and safety margins are maintained, or optionally assign HSS on a case-by-case basis.

The 1E-02 / 1E-03 values are similar to EPRI TR-112657, Rev B-A and deterministic single failure criteria in that having a success path results in adequate protection.

For those segments that receive a final LSS assignment, the prerequisites shall continue to be met, i.e.:

- PRA technical adequacy requirements, which include periodic maintenance and updates of the inputs, quality, and results that can impact applications such as 10 CFR 50.69.
- Integrity management programs (e.g., localized corrosion programs for raw-water cooling systems), feedback and process adjustment.
- Additionally, per 10CFR50.69(d)(2), the licensee will continue to be required to meet the following requirements:
  - Shall ensure, with reasonable confidence, that RISC-3 SSCs remain capable of performing their safety related functions under design basis conditions, including seismic conditions and environmental conditions and effects throughout their service life.
  - The treatment of RISC-3 SSCs must be consistent with the categorization process.
  - Inspection and testing, and corrective action shall be provided for RISC-3 SSCs.

Any segment assigned as LSS will have a negligible impact on plant risk consistent with US NRC risk-informed decision making criteria (even if CDF and LERF were not previously

directly used in 50.69 passive categorization), as there is no change to plant design basis or system configuration (e.g., a two-train system with a specific required flow rate will remain a two-train system without any reduction in redundancy), defense in depth is maintained, and the prerequisites of Section 4.1 in TR 3002025288 and the requirements of 10CFR50.69(d)(2) will ensure that these components shall continue to reliably perform their safety related function under design basis conditions.

Because of:

- The robust assessment of the overall risk,
- The multiple criteria that pre-determine HSS categorization for specific SSCs (e.g., all Class 1 are HSS without any considerations for changing to LSS),
- The use of CDF/LERF thresholds that are consistent with risk-informed guidance,
- The IDP's review of all candidate LSS SSCs with an additional focus on those with CCDPs > 1E-2 (CLERPs > 1E-3),
- Required sensitivity analysis, increasing the failure rate of candidate RISC-3 components by a factor of 3, and
- Licensee's programs and processes, and 10CFR50.69 rule requirements, to ensure RISC-3 SSCs continue to meet design function.

It is deemed that the alternative of imposing additional commitments to specific codes and standards is not needed, and would represent a deviation from the SOC for 50.69:

*Through this rulemaking, RISC-3 SSCs are removed from the scope of these requirements and instead are subject to the requirements in § 50.69(d)(2). For the reasons discussed in Section III.4.0, the Commission has determined that for low safety significant SSCs, it is not necessary to impose the specific detailed provisions of the Code, as endorsed by NRC, and these requirements can be replaced by the more "high-level" alternative treatment requirements, which allow greater flexibility to licensees in implementation.*

## **RAI 02 – SSC Categorization as a Single Plant Unit**

Background/Issue: 10 CFR 50.69(c)(1)(v) requires that the 10 CFR 50.69 categorization process “be performed for entire systems and structures, not for selected components within a system or structure.” The final rule’s SoC explain that

This required scope ensures that all safety functions associated with a system or structure are properly identified and evaluated when determining the safety significance of individual components within a system or structure and that the entire set of components that comprise a system or structure are considered and addressed.

EPRI TR 3002025288 Section 4.4, Alternative Treatment Requirements Under 10 CFR 50.69(d)(2), states that

this enhanced methodology defines the pressure boundary function of each individual plant unit as a system for 10 CFR 50.69 categorization and alternative treatment purposes. Consistent with 10 CFR 50.69 rule language and several citations in the final rule’s SoC, the system boundaries for the pressure boundary function are limited to pressure retention. Therefore, there will be no other important functions that would escape categorization and appropriate assignment of safety significance. As covered in the Statements of Condition, this ensures that all safety functions in the selected system are properly identified and categorized regarding their safety significance.

Further, Table 7 of the TR, “Comparison to 10 CFR 50.69(c)(1)” states that the “enhanced methodology requires categorization of all systems providing a pressure boundary function.”

The statements in the TR appear to imply that all the pressure-retaining components in the plant are considered as one system and that only the pressure-retaining function will be used to define the “system.” The staff does not find the TR provides sufficient explanation on how the proposed passive categorization will be implemented in the overall 50.69 categorization and did not find sufficient justification to support the statement that “all safety functions in the selected system are properly identified and categorized regarding their safety significance.”

Figure 1 of the TR, “Categorization process overview”, depicts the overall 50.69 categorization process as intended to be implemented, and shows that the passive categorization is performed in parallel to the other aspects of the categorization, such as considerations based on PRA and other qualitative consideration. All these aspects are considered for the preliminary categorization step, per the guidance in Nuclear Energy Institute (NEI) 00-04 Section 7. The guidance in NEI 00-04 Section 7 states that SSCs that support multiple functions should be assigned the highest risk significant of any function that the SSC, or part thereof, supports. Finally, the inputs from the preliminary categorization are provided to the integrated decision-making panel (IDP). Table 1 of the TR states that the IDP cannot change categorization from HSS to LSS for passive components.

### Requests:

- a. Clarify what is meant by that statements that the methodology “defines the pressure boundary function of each individual plant unit as a system.” Describe how the EPRI methodology proposes to organize passive components in systems for the purpose of

the passive component categorization. Describe how system functions are defined per Section 4 of NEI 00-04, "10 CFR 50.69 SSC Categorization Guideline in the context of passive SSCs."

EPRI Response to RAI 2a:

The system boundaries for the pressure boundary function are limited to pressure retention and there will be no other important functions that would escape categorization and appropriate assignment of safety significance.

The statements in the TR are not intended to designate pressure-retaining components in the plant as one system in a way that would impact the categorization of active functions per current guidance in NEI 00-04. Because the enhanced passive categorization uses the experience of categorizing passive functions in various previously approved applications by the US NRC, pre-determined criteria provide an upfront categorization for certain pressure-retaining components. This is in distinction to the current approach in NEI 00-04, where once a system is chosen both the active and passive functions are categorized by the licensee.

As such, a licensee may submit for approval to implement 10 CFR 50.69 and choose not to categorize any system (neither active, nor passive function) or choose a small subset of specific systems and not categorize other systems. Defining upfront categorization (which can include an HSS determination) assigns a result (HSS or LSS) across the plant and, if the plant proceeds in categorizing a system(s) further, both the active and passive functions need to be considered per the current guidance (no change).

The pre-determined categorization of pressure retaining functions does not impact the active function categorization (i.e., there is no allowance to categorize the passive function as LSS and automatically assign the LSS categorization to the active function). In the current method, if the licensee chooses to categorize several systems, they will need to have both active and passive functions considered, with the difference under the enhanced methodology being that all of the pressure-retaining components will have been categorized as HSS/LSS. The the active function will be categorized via the approved NEI 00-04 guidance (and alternate treatments remain the same, as TR 3002025288 does not change any of the alternate treatment requirements, which still remain in place for RISC-3 items).

More importantly, because the pre-determined criteria are strictly applicable to the pressure-retaining portion of the passive categorization, no change in special treatment for RISC-3 components is allowed until all aspects of the enhanced methodology and relevant portions of NEI 00-04 are completed (prerequisites, criteria 1-13, sensitivity study, and IDP) and an LSS categorization is confirmed by the IDP. While a pressure boundary component may have a HSS or LSS categorization via the enhanced methodology, no change in the active function special treatment is allowed from the current safety-related treatment. Only if the guidance in NEI 00-04 for active function were to be followed, and the safety-related active function were to be identified as LSS (i.e., binned as RISC-3) following the current approach in NEI 00-04 would the potential for alternate treatments of the active function be allowed.

As such, the guidance does not imply, nor does it provide any options for the active function of a safety-related (or non-safety-related) component to be categorized as LSS without complying with the current NEI 00-04 guidance. Doing so would not follow guidance in TR 3002025288 and NEI

00-04, for active functions, which are not in scope of TR 3002025288, nor does the TR unduly change as submitted for review.

A peer reviewed internal flooding model that meets the ASME/ANS PRA Standard (consistent with US NRC technical adequacy expectations) is part of the enhanced categorization methodology. The internal flooding model is intended to identify plant-specific HSS components using a plant-specific PRA of pressure boundary failures. This includes impacts of the pressure boundary failure, impacts of the pressure boundary failure on the active system it supports, as well as impacts of the pressure boundary failure on any other plant SSC (i.e., all relevant active and passive functions). This includes direct effects (e.g. loss of the flow path) of the component failure and indirect effects of the component failure (e.g. flooding, spray, pipe whip, loss of inventory). This comprehensive assessment of total plant impact (i.e., active and passive functions) caused by a postulated pressure boundary component failure is then used to determine the HSS or LSS assignment of that pressure boundary component. As such, there are no safety functions (i.e., active or passive) associated with other components or systems that would not be properly identified and evaluated and therefore improperly determine the safety significance of the pressure boundary components under evaluation even before the guidance in TR 3002025288 is implemented.

In other words, implementation of the enhanced categorization methodology ensures the licensee develop a wider understanding of the implication of passive failures than the current approach. From a practical perspective, this effort is very similar to the initial RI-ISI pilot plant applications (i.e., Millstone Unit 3, Surry Units 1 & 2, ANO Unit 2, and Fitzpatrick) which were all full-scope applications. As such, the enhanced methodology is a full scope risk-informed categorization effort and provides more insights into the plant's understanding of passive failures than currently required.

- b. As indicated in Figure 1 of the TR, the passive categorization is one aspect of the systematic and integrated categorization process outlined in NEI 00-04. Describe further how the passive categorization will be executed part of the overall integrated categorization process. Describe how the guidance in NEI 00-04 Section 7 for preliminary categorization will be implemented for passive components. How will all aspects of the categorization process be considered for the preliminary categorization of SSCs (both active and passive) that will be provided to the IDP?

EPRI Response to RAI 2b:

As stated in part (a), the passive categorization will continue to follow the applicable guidance outlined in NEI 00-04, with the addition of the prerequisites, the pre-determined set of HSS components (criteria 1-10) and the plant-specific HSS criteria (criteria 11-13). TR 3002025288 does not change active function categorization.

Exercising the process in TR 3002025288 would allow for pre-determined criteria to be applied upfront to the pressure-retaining function as described in Section 4.2. When using TR 3002025288, the existing integrated categorization process (e.g., NEI 00-04) would remain in place for components with active functions (i.e., no change in the active function or the integrated approach).



To fully address the systematic and integrated categorization interactions with NEI 00-04, it is being proposed to add a new section to chapter 4 of 3002025288 (Section 4.5 NEI 00-04 Integration Guidance) as follows:

*After the performance of the evaluations required by sections 4.1, 4.2 and 4.3 a preliminary (candidate) HSS / LSS assignment of all safety related and non-safety related pressure retaining components has been completed. To determine the final HSS / LSS assignments the remaining relevant portions of NEI 00-04 must be completed including:*

- *Fire Assessment (NEI 00-04 Section 5.2),*
- *Seismic Assessment (NEI 00-04 Section 5.3),*
- *Assessment of Other External Hazards (NEI 00-04 Section 5.4),*
- *Integral Assessment (NEI 00-04 Section 5.6),*

*Additionally, as required by Section 9.2 of NEI 00-04, the IDP is responsible for reviewing candidate HSS and LSS assignments and determining the final HSS and LSS assignment. Consistent with past practice any candidate HSS assignment (i.e. components meeting any one of the 13 criteria or determined to be HSS by a non-PRA external hazard evaluation) cannot be assigned LSS by the IDP. Per NEI 00-04, the IDP may determine a function/SSC has not been appropriately characterized and may be re-evaluated based on insights from the IDP. Also, NEI 00-04 allows for more detailed characterization of the SSC associated with a safety-significant function. This can be performed after the initial IDP, but the basis for that re-categorization must be considered and discussed in a follow up IDP session.*

*For application of the enhanced categorization methodology for pressure boundary components the IDP shall also confirm that all steps in the process have been followed.*

- *The IDP shall ensure that the prerequisites cited in Section 4.1 are met.*
- *The IDP shall confirm the assignment of HSS components (from the results of using criteria 1 through 13) is appropriate.*
- *The IDP shall confirm that the assignment of HSS criteria is valid in the context of other hazards (fire, seismic, other hazards).*
- *The IDP shall confirm LSS assignment for CCDPs > 1E-02 / CLERPs > 1E-03*
  - *When reviewing the results for criteria 12 and 13, the IDP shall review internal flooding segments/scenarios with high CCDP/CLERP values (i.e., > 1E-02 / 1E-03). The IDP may accept the LSS assignment, review categorization assignment to ensure defense in depth and safety margins are maintained, or optionally assign HSS on a case-by-case basis.*

*The 1E-02 / 1E-03 (CCDP/CLERP) values are similar to EPRI TR-112657, Rev B-A and deterministic single failure criteria in that having a success path results in adequate protection.*

- c. Describe IDP's role in addressing both the passive and active functions of SSCs. Confirm the intent in TR Table 1 that IDP will not change HSS categorization of passive components.

EPRI Response to RAI 2c:

See part of the response in (b) regarding the IDP's role in passive function categorization. Additionally, as required by Section 9.2 of NEI 00-04, the IDP is responsible for reviewing candidate HSS and LSS assignments and determining the final HSS and LSS assignment.

The key aspect is that the IDP cannot change a HSS classification for passive function categorization. This is consistent with industry practices in that passive HSS assignment (i.e. components meeting any one of the 13 criteria or determined to HSS by a non-PRA external hazard evaluation) cannot be assigned LSS by the IDP in the final 50.69 categorization process.

- d. Justify how the approach taken in EPRI TR 3002025288 for passive pressure boundary SSC categorization complies with 10 CFR 50.69(c)(1)(v) and the associated statements of considerations to ensure that "all safety functions associated with a system or structure are properly identified and evaluated when determining the safety significance of individual components within a system or structure and that the entire set of components that comprise a system or structure are considered and addressed."

EPRI Response to RAI 2d:

10 CFR 50.69(c) requires a categorization process that determines if an SSC (structures, systems and components) performs one or more safety significant functions and identifies those functions. In particular, 10 CFR 50.69(c)(1)(v) requires that the categorization "be performed for entire systems and structures, not for selected components within a system or structure." However, 10 CFR 50.69, the statements of considerations for the final rule (SOC), NEI 00-04 and Reg Guide 1.201 do not provide a prescriptive definition for a system or its boundaries.

As discussed in the SOC, the concern is that by limiting the categorization to isolated components within a complex system, all of the safety functions associated with that complex system might not be properly identified and evaluated and therefore improperly determine the safety significance of the isolated component(s) under evaluation.

It is also noted in the SOC that this requirement should be understood to exclude entire support systems (e.g., if system A is categorized as RISC-3, but is dependent on system B components which in turn have been categorized as RISC-1, then system A is understood not to include the system B components and is not to be categorized as RISC-1).

As discussed in Section 4.4 of TR 3002025288, this enhanced methodology is defining the pressure boundary function as a system for 10CFR50.69 categorization and alternate treatment purposes. When applying the enhanced methodology, in particular criteria 9, 10, 11, 12 and 13, all of the impacts on active and passive functions caused by the loss of the pressure retention function need to be accounted for consistent with the ASME/ANS PRA Standard and Regulatory

Guide 1.200 (e.g. all direct and indirect effects of the postulated failure need to be accounted). This includes impacts of the pressure boundary failure, impacts of the pressure boundary failure on the active system it supports, as well as impacts of the pressure boundary failure on any other plant SSC (i.e. all relevant active and passive functions). This includes direct effects (e.g. loss of the flow path) of the component failure and indirect effects of the component failure (e.g. flooding, spray, pipe whip, loss of inventory). This comprehensive assessment of total plant impact (i.e. active and passive functions) caused by a postulated pressure boundary component failure is then used to determine the HSS versus LSS assignment of that pressure boundary component. As such, there are no safety functions (i.e. active or passive) associated with other components or systems that would not be properly identified and evaluated and therefore improperly determine the safety significance of the pressure boundary components under evaluation.

This approach is consistent with and more conservative than a number of NRC precedents. For example, it is consistent with the incorporation of ASME Case N-660 into RG 1.174, Revision 14 in 2005, NRC approval of draft N-752 at ANO-2 for RI-repair/replacement activities in 2009, NRC approval of ASME Case N-752 at ANO 1 and 2 in 2021, NRC approval of ASME Case N-752 at Oconee in 2023, NRC approval of ASME Case N-752 at NextEra in 2024 and NRC approval of N-752 at Entergy in 2024 in that alternate treatment may be applied to pressure boundary components (e.g. repair / replacement activities, quality assurance) without requiring the categorization of supported active functions. These NRC precedents allow for limiting the categorization to only those pressure boundary components within a single supported active system and in many cases allow for limiting the categorization to individual pressure boundary components within a single supported active system. As such, the enhanced methodology is more conservative than these NRC precedents because the enhanced methodology requires that all pressure boundary components within the "pressure boundary system" (i.e., all safety related and non-safety related pressure boundary components) be categorized thereby increasing the likelihood that RISC-2 components will be identified.

Note: 10CFR50.69(f)(2) requires that Licensees shall update their final safety analysis report (FSAR) to reflect which systems have been categorized.

- e. Can the proposed methodology create a situation where a component is only categorized for its passive function, but the associated active function is left uncategorized? If so, explain why this is acceptable. Also, if the proposed methodology can create situations where a single SSCs receives different categorization based on its active and passive functions, describe and justify such scenarios and the mechanisms on how that would occur. For each scenario, describe and justify how it is ensured that an active HSS function would not be impacted by the LSS designation of a passive SSC that supports that function. Describe the guidance and approach for resolving differences.

#### EPRI Response to RAI 2e:

Yes, as discussed in (a), the methodology is applied so that a component is only categorized for its passive (pressure retaining) function and the associated active function(s) are left uncategorized. The function(s) will remain uncategorized, and the associated SSCs will not be subject to alternate treatment and therefore will continue to reliably perform its safety related active function.

The proposed enhanced methodology meets the intent of the rule because it has a process in place to prevent the miscategorization between active and passive functions and, ultimately, it is not intended to change the active categorization by only considering the passive function. While the vast majority of passive components only perform a pressure retaining function, there are a number of components (e.g., valves) that perform both active and passive (pressure retaining) functions. As such, it is possible when applying the 10 CFR 50.69 process for an SSC to have an active HSS and passive LSS categorization. As discussed and docketed during the Oconee N-752 relief request review (2023), this question was addressed in the Vogtle pilot plant review for 10 CFR 50.69 implementation in RAI 29 and specifically discussed in the NRC Safety Evaluation for that application. The Vogtle response is provided below with minor edits for clarification.

Vogtle Response (adapted): The NEI 00-04 categorization methodology assigns risk at the component level. Per the methodology, a component gets assigned final risk if any of the following risks is HSS: active risk, passive risk, or defense in depth. Active risk is determined using insights from the PRA and other qualitative considerations. Passive risk is determined using a passive component categorization methodology. Risk associated with defense in depth is determined using guidance provided in the NEI 00-04 categorization methodology. The final risk of a component is the highest of these three risks. Then the critical attributes are identified for each HSS components to further understand the reason(s) for being HSS. For example, an HSS Motor Operated Valve (MOV) may have a critical attribute of fail to close because that is what made it HSS. However, the same valve may be LSS for passive risk (i.e., pressure boundary retention) assuming there is sufficient redundancy to respond to the event of interest and LSS from a defense in depth evaluation.

Further, the following words are taken directly from the Safety Evaluation written by NRC staff on the Vogtle 10CFR50.69 LAR:

In the response, the licensee confirmed that the failure of a passive component (e.g., motor operated valve body) that supports an HSS active function may be assigned LSS by the passive categorization methodology if confirmed LSS by the IDP. This can occur because, for example, there are no common cause failures (CCF) among passive components (i.e., multiple and simultaneous pipe ruptures are not expected), so an active function may be HSS due to CCF considerations but the individual pressure retaining components whose individual failures do not fail the function can be LSS. The NRC staff finds that risk assessments generally do not consider the very unlikely simultaneous multiple failures of passive components (except for external hazard events impacts that should be included in the external hazard evaluation) and therefore the proposed method is acceptable.

Additionally, as discussed above, the application of the enhanced methodology is consistent with and more conservative than a number of NRC precedents (e.g., N-660, ANO-2, Oconee, Entergy, NextEra) in that all safety related and non-safety related components must be categorized using the enhanced methodology, as well as subject to the prerequisites of Section 4.1, thereby increasing the likelihood of identifying RISC-2 components (see Section 5.3 of TR 3002025288) as compared to NRC endorsed precedent.

- 2005 – NRC endorsement of ASME Code Case N660 into revision 14 of Reg Guide 1.147, August 2005
- 2009 – Arkansas Nuclear One, Unit 2 – Approval of Request for Alternative ANO2-R&R-004, Revision 1, Request to Use Risk-Informed Safety Classification and Treatment for

Repair/Replacement Activities in Class 2 and 3 Moderate and High Energy Systems (TAC NO. MD5250), April 22, 2009, ML090930246

- 2014 – Vogtle Electric Generating Plant, Units 1 and 2 – Issuance of Amendments Re: Use of 10 CFR 50.69 (TAC NOS. ME9472 AND ME9473), dated December 17, 2014 (ADAMS Accession No. ML14237A034)
  - Vogtle Electric Generating Plant - Unit 1 and Unit 2 Pilot 10 CFR 50.69 License Amendment Request, Response to Request for Additional Information, dated May 2, 2014
- 2021 – Arkansas Nuclear One, Units 1 and 2 – Approval of Request for Alternative from Certain Requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (EPID L-2020-LLR-0076), May 19, 2021, ML21118B039
- 2023 – Oconee Nuclear Station, Units 1, 2, and 3 – Re: Authorization of Alternative to Use RR-22-0174, “Risk-Informed Categorization and Treatment for Repair/Replacement Activities in Class 2 and 3 Systems Section XI, Division 1” (EPID L-2022-LLR-0060), December 13, 2023, ML23262A967
  - Second Response to Request for Additional Information (RAI) Regarding Proposed Alternative to Use American Society of Mechanical Engineers Code Case N-752, “Risk-Informed Categorization and Treatment for Repair/Replacement Activities in Class 2 and 3 Systems Section XI, Division 1” dated October 20, 2023
- 2024 – Entergy EN-RR-22-0011 for Grand Gulf Nuclear Station, River Bend Station, Waterford 3 (ML22181B114, ML23111A213, ML24012A196, ML24101A388) approved in NRC SE dated May 30, 2024 (ML24060A219, ML24151A238)
- 2024 – NextEra FRR-23-011 for St. Lucie Units 1 & 2, Turkey Point Units 3 & 4, Seabrook Station, Point Beach Units 1 & 2 (ML23074A155) approved in SE dated June 12, 2024 (ML24149A286, ML24164A193)

### **RAI 03 – Addressing Uncertainty and Other Events in Individual Assessments**

Background/Issue: Paragraph 50.69(c)(1)(i) states that the SSC categorization process must “consider results and insights from the plant-specific PRA. This PRA must, at a minimum, model severe accident scenarios resulting from internal initiating events occurring at full power operation. The PRA must be of sufficient quality and level of detail to support the categorization process and must be subjected to a peer review process assessed against a standard or set of acceptance criteria that is endorsed by the NRC.” In response, Table 7 of TR 3002025288, “Comparison to 10 CFR 50.69(c)(1)”, further states,

As stated previously, the plant needs to have a robust internal events PRA, including IF [internal flooding], that addresses failure of all pressure boundary components (main steam line breaks, main feedwater line breaks, internal flooding events, interfacing system LOCA [loss of coolant accident], and so on). Because this methodology is being used in support of 10 CFR 50.69 applications, the plant-specific PRA needs to be sufficient to support the license amendment request approval process, including consideration of PRA assumptions and sources of uncertainty.

#### Requests:

- a. Criteria 11-13 are the only criteria in the methodology that involves a direct use of the licensee’s PRA model-of-record. From Figure 3, “CCDP versus CDF threshold” and Figure 4, “CLERP versus LERF threshold”, it appears that each of the three criteria have “hard” risk thresholds. Explain how uncertainty is taken into account within the use of these thresholds to categorize a passive pressure-retaining component. Also, explain how the potential cumulative impact of changes is addressed.

#### EPRI response to 3a:

All pressure boundary failures that are plant initiating events are modeled in the PRA, as required per the NRC-endorsed ASME/ANS Level 1/LERF PRA standard. As discussed in Section 4.1.1 Prerequisite 1: PRA Technical Adequacy, the licensee must have a plant-specific internal events and internal flooding PRA of sufficient quality (peer reviewed against the ASME/ANS PRA Standard) to support the LAR approval process. Pressure boundary failure initiating events are evaluated quantitatively per criteria 11-13 of the enhanced methodology. Regarding uncertainty within the use of the thresholds to categorize a passive pressure-retaining component, NUREG-1855 and the two companion EPRI reports (1016737 and 1026511) provides the methodology for assessing and addressing uncertainties in PRA models used in risk-informed decision making.

In implementing 3002025288, the list of assumptions and sources of uncertainty needs to be reviewed to identify those which would be significant for the risk-informed categorization of the pressure boundary. If the plant-specific PRA model uses non-conservative treatments, or uses methods not commonly accepted, the underlying assumption or source of uncertainty would need to be reviewed to determine its impact on the risk-informed categorization of the pressure boundary. Only those assumptions or sources of uncertainty that could significantly impact the categorization risk calculations (i.e., could change a RISC outcome) would be considered key for this application. An example is shown in Table 1.

Supporting Requirement	Finding Description	Disposition
IF-C2b Now IFSN-A4	Appendix E appears to take credit for drains, however calculation of drain capacity was not evident.	<p>A formal analysis of drain capacities has not been performed.</p> <p>Section E.5 of the internal flood notebook provides a discussion of flood scenarios in Flood Zone XX. A drain capacity of 60,000 gallons was estimated and credited based on discussion with engineers and review of plant drawings. A probabilistic estimate of drainage failure is provided to address uncertainties in the drainage capacity. With the exception of Flood Zone RBFLZZ, floor drains were not credited to conservatively estimate the time available for operator intervention.</p> <p>A conservative estimate was used for floor drain credit, which primarily impacts the associated human action importance; therefore, specific analysis is expected to improve the analysis and will have no material impact on the pressure boundary categorization process.</p>

Additionally, consistent with Section 4.3 of 3002025288, a sensitivity study must be conducted by increasing the failure rates of candidate RISC-3 pressure boundary components. Candidate RISC-3 pressure boundary components that exceed the Regulatory Guide 1.174 acceptance criteria shall be candidate HSS. Since this sensitivity is being conducted for all RISC-3 components it also accounts for the cumulative impact.

To further respond to this input – a proposed revision to prerequisite 1 is to add a third paragraph in Section 4.1.1 to look for potential non-conservatisms or uncommon methods as outlined below:

*Prior to using the enhanced categorization methodology, non-conservatisms or the use of methods not commonly accepted must be reviewed to determine their impact, if any, on the risk-informed categorization of the pressure boundary. The analyst should also review key assumptions and sources of model uncertainty in the context of this application.*

The potential cumulative impact of changes from implementation of 3002025288 is addressed consistently with, and more conservatively than the existing approved process in NEI 00-04. That is, NEI 00-04 requires that a risk sensitivity analysis be performed for each system that has undergone the 50.69 categorization process by increasing the failure rate of RISC-3 components. Also, a cumulative risk sensitivity analysis for all systems that have undergone 50.69 categorization process categorized is required. The enhanced passive categorization methodology also requires a sensitivity analysis increasing the failure rate of candidate RISC-3 components by a factor of 3 (consistent with NEI 00-04 guidance). However, because the enhanced methodology is required to be performed on the whole plant (i.e., all pressure boundary systems), the sensitivity analysis will be cumulative of the entire pressure boundary function in that all pressure boundary RISC-3 components will be included.

To make this requirement clearer, it is proposed to modify the third paragraph of Section 4.3 of 3002025288 as follows:


*For this effort, pressure boundary components that are modeled in the internal events or internal flooding PRA that have been determined to be RISC-3 shall have their failure rates (such as pipe break frequency) increased by a factor of 3 and their CDF and LERF*

*quantified so that the cumulative impact of any potential alternate treatment is assessed. As previously covered, due to the requirements of this enhanced methodology and the requirements that RISC-3 SSCs continue to perform their safety-related functions under design basis conditions, this type of degradation is extremely unlikely for any single component, let alone entire groups of components. Therefore, the factor of 3 is a conservative bound and consistent with NEI 00-04, Section 8.1.*

- b. Discuss and justify how current risk thresholds for Criteria 11-13 take into account cases of lower initiating event frequencies coupled with higher failure consequences. Discuss how these higher failure consequences are considered.

EPRI response to 3b:

Criterion 11 (i.e.  $1\text{E-}6/\text{year}$  and  $1\text{E-}7/\text{year}$  risk thresholds for CDF and LERF respectively) is consistent with Regulatory Guide 1.174 risk-informed decision-making acceptance criteria regarding what constitutes low values of risk importance, this has been used in a number of risk-informed applications or in applications where risk insights are used to further the understanding of the acceptability of a plant change/activity. As 10CFR50.69 applications can impact a number of different plant programs/activities it was decided that additional margin (defense-in-depth) should be considered for low frequency initiators ( $\sim 1\text{E-}6/\text{year}$ ) resulting in the development of criteria 12 and 13.



Criterion 12 of TR 3002025288 accounts for low frequency initiators ( $\sim 1\text{E-}6/\text{year}$  to  $1\text{E-}8/\text{year}$ ) with high CCDPs. Criteria 13 of TR 3002025288 accounts for low frequency initiators and high CLERPs. At CDFs below  $1\text{E-}8/\text{year}$  (LERFs below  $1\text{E-}9/\text{year}$ ) the flood scenario risk is sufficiently low. For perspective, the value of  $1\text{E-}8/\text{year}$  is similar (yet more conservative) for reactor vessel rupture (RVR) initiating events. RVR, also known as Excessive LOCA, Very Large LOCA, exceeds the capacity of emergency core cooling systems and leads directly to core damage (e.g.,  $\text{CCDP} = 1.0$ ).



To put these threshold values into further context, Table 3-2.5-2 (IFQU-A3) of the NRC endorsed ASME/ANS PRA standard states that for PRAs meeting capability categories I or II, flood scenarios with a contribution to CDF of less than  $1\text{E-}08/\text{year}$  may be screened out. And while these scenarios may be screened out of the PRA there is not an implication that scenarios “screened in” with a contribution to CDF of greater than  $1\text{E-}08/\text{year}$  are risk/safety significant.

IFQU-A3	<p>When choosing to screen, SCREEN OUT a flood-induced accident sequence if the product of the flood-induced initiating-event or initiating-event-group frequency and a conservative estimate of the conditional core damage probability (CCDP) for the sequence, including any flood mitigation events not included in the flood-induced initiating-event frequency, is less than <math>10^{-8}/\text{reactor-yr}</math>.</p> <p>DO NOT SCREEN OUT individual sequences if the frequency of a group of sequences with similar characteristics (e.g., similar flood scenario, initiating event, and accident sequence) exceeds this screening criterion.</p>	<p>When choosing to screen, SCREEN OUT a flood-induced accident sequence if the product of the flood-induced initiating-event or initiating-event-group frequency and the conditional core damage probability (CCDP) for the sequence, including any flood mitigation events not included in the flood-induced initiating-event frequency, is less than <math>10^{-9}/\text{reactor-yr}</math>.</p> <p>DO NOT SCREEN OUT individual sequences if the frequency of a group of sequences with similar characteristics (e.g., similar flood scenario, initiating event, and accident sequence) exceeds this screening criterion.</p>
---------	--	---

Further, Section 6-2.3 of the ASME/ANS PRA Standard provides criteria for screening out internal and external hazards if:

- (a) The hazard meets the criteria in the U.S. Nuclear Regulatory Commission (NRC) Standard Review Plan (SRP) [6-2] or a later revision; or
- (b) it can be shown, by using a demonstrably conservative analysis, that the mean value of the frequency of the design-basis hazard event used in the plant design is less than  $\sim 10^{-5}/\text{yr}$  and that the conditional core damage probability is  $<10^{-1}$ , given the occurrence of the design basis hazard event; or
- (c) it can be shown, by using a demonstrably conservative analysis, that the CDF is  $<10\text{E-}6/\text{yr}$

Additionally, Table 6-2-4 (EXT-C1) of the NRC endorsed ASME/ANS PRA standard identifies two criteria that can be used to quantitatively screen hazards as follows:

- The current design-basis hazard event has a mean frequency  $<10\text{E-}5/\text{yr}$ , and the mean value of the conditional core damage probability (CCDP) is assessed to be  $<10\text{E-}1$ .
- The core damage frequency, calculated using a bounding or demonstrably conservative analysis, has a mean frequency  $<10\text{E-}6/\text{yr}$ .

**Table 6-2-4 Supporting Requirements for HLR-EXT-C**

A bounding or demonstrably conservative analysis, if used for screening, shall be performed using defined quantitative screening criteria (HLR-EXT-C).

Index No. EXT-C	Requirement
EXT-C1	<p>For screening out a hazard other than internal events, internal flood, internal fire, and seismic events, USE either of the following two screening criteria, each of which provides an acceptable basis for bounding analysis or demonstrably conservative analysis:</p> <p><i>Criterion A:</i> The current design-basis hazard event has a mean frequency <math>&lt;10^{-5}/\text{yr}</math>, and the mean value of the conditional core damage probability (CCDP) is assessed to be <math>&lt;10^{-1}</math>.</p> <p><i>Criterion B:</i> The core damage frequency, calculated using a bounding or demonstrably conservative analysis, has a mean frequency <math>&lt;10^{-6}/\text{yr}</math>.</p> <hr/> <p><b>Commentary:</b> The bounding or demonstrably conservative analysis is intended to provide a conservative calculation showing, if true, either that the hazard would not result in core damage or that the core damage frequency (CDF) is acceptably low. Some or all of the key elements of the external-hazard risk analysis could be used to reach and support this conclusion: hazard analysis, fragility analysis, or systems analysis (plant-systems analysis, human-reliability analysis, accident-sequence analysis, etc.).</p> <p>In some cases, Criterion A can allow an efficient way to verify that the original design-basis hazard (frequency) is low and that the CDF is also acceptably low. Using Criterion A requires a refined modeling of the hazard and an approximate evaluation of conditional core damage probability (CCDP).</p> <p>The numerical screening values in Criteria A and B are set low enough so that if either of them is met, the external hazard can be screened out.</p>

To provide additional insights into the robustness of the use of these thresholds in this application, a summary of the conclusion derived from [EPRI 3002012967, INSIGHTS ON RISK MARGINS AT NUCLEAR POWER PLANTS, A Technical Evaluation of Margins in Relation to Quantitative Health Objectives and Subsidiary Risk Goals in the United States, 2018] is provided below:

- Quantitative risk criteria or goals are employed in a variety of ways in the context of risk-informed decision making at nuclear power plants.
- The metrics most commonly used relate to the frequency of core damage (CDF) and of large, early releases (LERF) following severe accidents. These metrics correspond to the quantitative health objectives and are meant to be used as surrogates for the higher level safety goals.
- The subsidiary objectives were derived in such a way that they provide margin to the actual safety goals.
- With respect to uncertainty, the insights are that only in the most extreme cases could uncertainties play a significant enough role in this respect, at least with regard to cases in which the CDF approaches (or even exceeds) the subsidiary objective.
- The most recent information available indicates that there are significant margins between the quantitative representations of the U.S. NRC's safety goals (that is, the quantitative health objectives – QHOs) and the subsidiary objectives widely used in considering risk-informed applications in the U.S. (that is, CDF and LERF).
- Using the guidance contained in RG1.174, changes that result in small increases in risk may be found to be acceptable. "Small" in this case typically refers to a change in core-damage frequency of  $10^{-6}/\text{year}$  or less, or an increase in LERF of  $10^{-7}/\text{year}$  or less (essentially 1% of the levels of the respective subsidiary objectives). Given the large margin between the subsidiary objectives and the QHOs, these changes can be seen to

be extremely small with respect to the impact on adequate safety.

In conclusion, the threshold values contained in criteria 11, 12 and 13 are robust in that as documented in 3002025288 they will result in voluntary safety improvements (see section 5.3 of 3002025288) and are logically consistent and quantitatively more conservative than NRC approved precedents.

- c. As a risk-informed process, discuss how the preservation of defense-in-depth and maintenance of safety margins are accounted for in using Criteria 11-13. Also elaborate on the assessment of qualitative criteria and defense-in-depth for passive categorization, and if any additional guidance is required for the IDP when applying the methodology in EPRI TR 3002025288.

EPRI response to 3c:

While criteria 11, 12, and 13 are important components of the overall enhanced categorization methodology contained in 3002025288, they should not be viewed in isolation. Criteria 11-13 coupled with criteria 1 through 10, the prerequisites contained in Section 4.1.1 (PRA Technical Adequacy), 4.1.2 (robust program assuring pressure boundary integrity management), and 4.1.3 (barriers against internal flood propagation), 4.1.4 (reflect the as built / as operated plant) together with the assurance of only acceptably small increases in risk consistent with Regulatory Guide 1.174 and meeting the requirements on 10CFR50.69(d)(2) assures that implementation of 3002025288 will not adversely impact the preservation of defense in depth or maintenance of safety margins. Further implementation of the methodology contained in 3002025288 does not impact defense-in-depth (DID) and safety margins because there is no change to the design or design basis functions of RISC-3 SSCs. Additionally, 10CFR50.69(d)(2) requires that the licensee ensure, with reasonable confidence, that components categorized as LSS (RISC-3 SSCs) remain capable of performing their safety related functions under design basis conditions, including seismic conditions and environmental conditions and effects throughout their service.

The qualitative criteria of the existing process is addressed by the enhanced methodology as provided in the second set of supplemental information provided on June 28, 2024. As detailed in Table 2 (below), these considerations are addressed by the enhanced methodology.

Additionally, as discussed in the response to RAI 2 it is proposed to add a new Section 4.5 (Section 4.5 NEI 00-04 Integration Guidance) which provides additional IDP responsibilities when implementing the enhanced methodology.

Table 2

ANO2 RI-RRA Section	ANO2 RI-RRA from letter 2CAN010901 (ML090120620) January 12, 2009	Enhanced Methodology
I-3.2 Classification	<p>Piping is assigned a RISC value of HSS or LSS.</p> <p>Piping segments determined to fall into the HIGH consequence category shall be considered HSS.</p> <p>Piping segments determined to fall into the Medium, Low, or none category shall be determined to be HSS or LSS by considering the 10 additional considerations (evaluated below).</p>	<p>The proposed methodology uses the same designation of HSS and LSS.</p> <p>The existing and the new proposed methodology defines components RISC determination as only HSS or LSS and does not use the high, medium, low or none categories to evaluate the components.</p>
I-3.2.2 (b) (1) Classification Considerations: Additional considerations:	<p>Evaluate the additional considerations:</p> <ol style="list-style-type: none"> <li>1. Failure of the pressure retaining function of the segment will not fail a basic safety function.</li> </ol>	<p>Components whose failure could fail a basic safety function are outlined in the pre-determined HSS criterion. Any pressure boundary failure that could fail a safety function is considered a high consequence (HSS). Criterion 5 (loss of ultimate heat sink), Criterion 6 (loss of ECCS), Criterion 7 (loss of secondary cooling in a PWR), and Criterion 8 (loss of CCW in a PWR), and Criterion 11-13 address loss of safety functions.</p> <p>This consideration is still evaluated through the proposed methodology, just in a different approach.</p>
I-3.2.2 (b) (2) Classification Considerations: Additional considerations:	<p>Evaluate the additional considerations:</p> <ol style="list-style-type: none"> <li>2. Failure of the pressure retaining function of the segment will not prevent the plant from reaching or maintaining safe shutdown conditions; and the pressure retaining function is NOT significant to safety during mode changes or shutdown.</li> </ol>	<p>Key functions that would prevent the plant from reaching or maintaining safe shutdown conditions include a total loss of reactor pressure control, reactor coolant inventory control, decay heat removal, or the loss of vital auxiliaries (e.g., instrumentation or AC/DC power). These functions are addressed through the proposed methodology in that any pressure boundary failure that could fail these basic safety functions is considered a high consequence (HSS). Criterion 5 (loss of ultimate heat sink), Criterion 6 (loss of ECCS), Criterion 7 (loss of secondary cooling in a PWR), and Criterion 8 (loss of CCW in a PWR), and Criterion 11-13 address loss of safety functions (including loss of power due to a pressure boundary failure).</p> <p>This consideration is still evaluated through the proposed methodology, just in a different approach.</p>

Table 2

ANO2 RI-RRA Section	ANO2 RI-RRA from letter 2CAN010901 (ML090120620) January 12, 2009	Enhanced Methodology
I-3.2.2 (b) (3) Classification Considerations: Additional considerations:	<p>Evaluate the additional considerations:</p> <p>The pressure retaining function of the segment is not called out or relied upon in the plant Emergency/Abnormal Operating Procedures or similar guidance as the sole means for the successful performance of operator actions required to mitigate an accident or transient.</p>	<p>The BWROG and PWROG have evaluated the standard plant Emergency Operating Procedures. No instances of any components were found to be the sole means for successful performance of actions required to mitigate and accident or transient.</p> <p>Further, the PRA model scope includes the equipment needed to successfully mitigate an accident or transient which could lead to core damage or a large early release. If failure of one component leads directly to core damage or large, early release, then its contribution to risk is evaluated in the proposed methodology (please see criterion 11, 12 and 13.</p> <p>This consideration is still evaluated through the proposed methodology, just in a different approach.</p>
I-3.2.2 (b) (4) Classification Considerations: Additional considerations:	<p>Evaluate the additional considerations:</p> <p>The pressure retaining function of the segment is NOT called out or relied upon in the plant Emergency/Abnormal Operating Procedures or similar guidance as the sole means for assuring long term containment integrity, monitoring of post-accident conditions, or offsite emergency planning activities.</p>	<p>The BWROG and PWROG have evaluated the standard plant Emergency Operating Procedures. No instances of any components were found to be the sole means for assuring long term containment integrity, monitoring of post-accident conditions, or offsite emergency planning activities.</p> <p>Further, any pressure boundary failure that could fail these basic safety functions is considered a high consequence (HSS). Criterion 5 (loss of ultimate heat sink), Criterion 6 (loss of ECCS), Criterion 7 (loss of secondary cooling in a PWR), and Criterion 8 (loss of CCW in a PWR), and Criteria 11 and 13 address loss of safety functions for maintaining containment integrity.</p> <p>This consideration is still evaluated through the proposed methodology, just in a different approach.</p>

Table 2

ANO2 RI-RRA Section	ANO2 RI-RRA from letter 2CAN010901 (ML090120620) January 12, 2009	Enhanced Methodology
I-3.2.2 (b) (5) Classification Considerations: Additional considerations:	<p>Evaluate the additional considerations:</p> <p>Failure of the pressure retaining function of the segment will not result in an unintentional release of radioactive material that would result in the implementation of offsite radiological protective actions.</p>	<p>The proposed methodology requires all Class 1 SSCs be HSS. Class 1 components compose one of the key fission product barriers.</p> <p>Further, criterion #9 ensures components that could lead to containment bypass are HSS.</p> <p>Any other component failures which would lead to LERF, and potentially offsite radiological protective actions, would be identified through Criteria 11 and 13.</p> <p>This consideration is still evaluated through the proposed methodology, just in a different approach.</p>
I-3.2.2 (b) (6) Classification Considerations: Defense-in-Depth	<p>Evaluate the Defense-in-Depth considerations:</p> <p>6. Reasonable balance is preserved among prevention of core damage, prevention of containment failure or bypass, and mitigation of an offsite release.</p>	<p>10 CFR 50.69 categorization does not change the design, design basis or operation of plant components. Therefore, reasonable balance is preserved among prevention of core damage, prevention of containment failure or bypass, and mitigation of an offsite release as there is no change to the design, design basis or operation of plant components. Additionally, the PRA consequence assessment of the methodology requires an evaluation and ranking of postulated failures on core damage and containment performance (e.g., bypass, LERF). Finally, with implementation of the 50.69 process for plant components, the RISC-3 components are still safety-related and are still required to reliably perform their safety-related function (per the rule).</p> <p>The inherent process maintains this defense-in-depth attribute. No further evaluation is required when implementing the proposed methodology.</p>

Table 2

ANO2 RI-RRA Section	ANO2 RI-RRA from letter 2CAN010901 (ML090120620) January 12, 2009	Enhanced Methodology
I-3.2.2 (b) (7) Classification Considerations: Defense-in-Depth	Evaluate the Defense-in-Depth considerations:  7. There is no over-reliance on programmatic activities and operator actions to compensate for weaknesses in the plant design.	The proposed methodology evaluation reflects the as-operated / as-designed plant (per prerequisite #4). This evaluation does not increase the reliance on programmatic activities or operator actions. Operator actions, when credited, are credited consistent with the NRC endorsed PRA standard.  The inherent process maintains this defense-in-depth attribute. No further evaluation is required when implementing the proposed methodology.
I-3.2.2 (b) (8) Classification Considerations: Defense-in-Depth	Evaluate the Defense-in-Depth considerations:  8. System redundancy, independence, and diversity are preserved commensurate with the expected frequency of challenges, consequences of failure of the system, and associated uncertainties in determining these parameters.	System redundancy, independence, and diversity are preserved as there is no change to the design, design basis or operation of plant components by the risk categorization of the plant components. RISC-3 components will still be required to reliably perform their safety-related function as designed by the plants licensing basis.  The inherent process maintains this defense-in-depth attribute. No further evaluation is required when implementing the proposed methodology.
I-3.2.2 (b) (9) Classification Considerations: Defense-in-Depth	Evaluate the Defense-in-Depth considerations:  9. Potential for common cause failures is taken into account in the risk analysis categorization.	Common cause is a fundamental aspect of the PRA consequence evaluation methodology and therefore is taken into account.  The inherent process maintains this defense-in-depth attribute. No further evaluation is required when implementing the proposed methodology.
I-3.2.2 (b) (10) Classification Considerations: Defense-in-Depth	Evaluate the Defense-in-Depth considerations:  10. Independence of fission-product barriers is NOT degraded.	The proposed methodology makes no changes to plant design, including independence of fission-product barriers.  The inherent process maintains this defense-in-depth attribute. No further evaluation is required when implementing the proposed methodology.

- d. In computing the CDF/LERF and CCDP/CLERP for Criteria 11-13, discuss how various embedded events in PRA models such as recovery actions (i.e., FLEX) and human reliability analyses are taken into account.

EPRI response to 3d:

Human actions/recovery actions credited in the PRA must satisfy the requirements of the ASME/ANS PRA Standard. The technical element – Human Reliability Analysis (HR) of Part 2 of the ASME/ANS PRA Standard outlines the requirements for human actions including that the action(s) must be proceduralized and address plant-specific and scenario-specific influences on human performance, and address the timing and availability of cues. Recovery actions shall only be modeled if the action is plausible and feasible.

Additionally, for internal flooding, the following additional supporting requirements apply, specifically: IFQU-A5 (ensuring additional human failure events are in accordance with the human reliability requirements in Part 2) & IFQU-A6 (accounting for flood scenario-specific performance shaping factors such as additional workload and stress, cue availability, effect of flood on mitigation, timing and recovery actions, etc.).

For HRA, in addition to the ASME/ANS PRA Standard requirements for FLEX there is the NRC memo on modeling of FLEX actions that need to be considered. In the NRC public memo (May 6, 2022; ML22014A084), the NRC updated its assessment of NEI 16-06, “Crediting Mitigating Strategies in Risk-Informed Decision Making” originally published in a 2017 memo.

With respect to FLEX actions, most licensee credited actions are fed through loss of offsite power (LOOP) events that go to station blackout (SBO) with late failures or direct SBO. Most pressure boundary initiators are generally mapped to transients (e.g., reactor trip or loss of cooling system initiators). For pressure boundary failures, multiple non-pressure retaining related, failures would need to occur before typical FLEX actions would be credited (likely near the truncation of the internal flood model). As such, cutsets with FLEX credited are likely to be low frequency events in this context.

- e. For plants which have a high seismic contribution to pipe rupture, discuss how the results of various analyses (e.g., seismic PRA, Seismic Margins Analysis) are taken into account for Criteria 11-13. If these considerations are addressed qualitatively, please explain how they will be addressed. If these considerations are addressed solely by the IDP, explain how this is communicated to the IDP and what guidance is available for the IDP.

EPRI response to 3e:

As summarized in Figure 1 and Table 1 below, NEI 00-04 provides an integrated and comprehensive process for RI-categorizing SSCs that incorporates risk insights from various hazards into a final HSS / LSS determination. The enhanced methodology contained in 3002025288 provides an alternative only to that portion of the process pertaining to pressure



boundary categorization (e.g., bottom path of Figure 1 and bottom row of Table 1).

Seismic insights as well as other external hazards and shutdown events are incorporated into the overall risk categorization through several avenues. For seismic, these include the use of a SMA, a seismic PRA or the “tiered approach” defined in EPRI report 3002017583. For fires and other hazards Licensees will need to follow the guidance contained in NEI 00-04 or describe explicitly in their LAR what alternate approach is being requested.




Figure 1. Categorization process overview [2]

Table 1  
IDP changes from preliminary HSS to LSS

Element	Categorization Step—NEI 00-04 Section	Evaluation Level	IDP Change HSS to LSS	Drives Associated Functions
Risk (PRA modeled)	Internal Events Base Case—Section 5.1	Component	Not allowed	Yes
	Fire, Seismic, and Other External Events Base Case		Allowable	No
	PRA Sensitivity Studies		Allowable	No
	Integral PRA Assessment—Section 5.6		Not allowed	Yes
Risk (non-modeled)	Fire, Seismic and Other External Hazards	Component	Not allowed	No
	Shutdown—Section 5.5	Function/ component	Not allowed	No
DID	Core Damage—Section 6.1	Function/ component	Not allowed	Yes
	Containment—Section 6.2	Component	Not allowed	Yes
Qualitative criteria	Considerations—Section 9.2	Function	Allowable	N/A
Passive	Passive—Section 4	Segment/ component	Not allowed	No

#### **RAI-04 – Qualitative Considerations for Shutdown Operations and External Events**

Background/Issue: Section 2 of EPRI TR 3002025288 describes how the 10 CFR 50.69 categorization process is performed in accordance with NEI 00-04, Revision 0, as endorsed in Regulatory Guide (RG) 1.201, “Guidelines for Categorizing Structures, Systems, and Components in Nuclear Power Plants According to Their Safety Significance,” Revision 1. Figure 1 of EPRI TR 3002025288, “Categorization process overview” shows passive categorization as a “separate path” for preliminary categorization of pressure-retaining components, prior to IDP review and final categorization. The NRC notes that the guidance in NEI 00-04 includes considerations for fire, seismic, and other external hazards, which may be assessed qualitatively, as well as additional qualitative criteria and requirements for assessment of defense-in-depth. (These are also shown in Figure 1.) The NRC notes that the NRC approved methodology for passive categorization in ANO2-R&R-004, Revision 1, also includes considerations for assessing shutdown operations, external events, and DID.

Requests:

- a. It is unclear how the methodology in EPRI TR 3002025288, whether independently or in conjunction with the guidance in NEI 00-04, requires the assessment of shutdown operations and external events, including external events that do not affect likelihood of pressure boundary failure but create demands that might cause pressure boundary failure and events (e.g., fires), for potential impact on the categorization of passive, pressure-retaining components. Please explain how these considerations are addressed. If these considerations are addressed solely by the IDP, explain how this is communicated to the IDP and what guidance is available for the IDP.

EPRI response to 4a:

See the response for RAI 3e for assessment of seismic considerations. Additionally, as further described in RAI 3e, the prior response outlines how TR 3002025288 works with the process in NEI 00-04 for assessment of fire, seismic, and other external hazards.

For all stations, shutdown risk is evaluated consistent with NUMARC 91-06 (ML14365A203) with a focus on protecting decay heat removal defense in depth. In the enhanced methodology, any pressure boundary failure that could fail a safety function is considered HSS. Criterion 1 (reactor pressure boundary), Criterion 2 (applicable portions of the shutdown cooling pressure boundary function), Criterion 5 (loss of ultimate heat sink), Criterion 6 (loss of ECCS), Criterion 7 (loss of secondary cooling in a PWR), Criterion 8 (loss of CCW in a PWR) and Criterion 9 (heat exchangers that interface with RCS). These systems are relied upon during shutdown conditions and also for decay heat removal. No additional specific review is required for additional pressure boundary failures during shutdown conditions.

## **RAI 05 - Plant Design Scope for Methodology**

Background/Issue: EPRI TR 3002025288 states that plant-specific 10 CFR 50.69 system categorization was verified for robustness through evaluation of several boiling water reactor (BWR) and pressurized water reactor (PWR) plants. This group of plants is described as consisting of multiple designs and “included earlier-vintage and later-vintage designs.” No basis is given for the generic applicability of the EPRI TR to other designs, including ones not yet designed. No limitation is presented in the report regarding which designs the report may be applied.

EPRI clarified, during the audit, that the methodology was not verified for designs such as the NuScale US600 or Westinghouse AP1000. The NRC staff needs this clarified on the docket.

### Requests:

- a. If the methodology was not meant to include such designs, or other future PWR and BWR designs, provide revisions limiting the use of the methodology to the designs for which it was verified.
- b. If the methodology is meant to include designs other than those evaluated, clarify how this was verified and how it is controlled within the methodology.

### EPRI response to 5a&b:

The methodology in TR 3002025288 is limited to plants currently or previously licensed via 10CFRPart50 and plants with renewed licenses under 10CFRPart54. It is also applicable to plants/designs licensed via 10CFRPart52 which have light water reactor designs with active features for the primary and secondary heat removal and as well the emergency core cooling functions.

However, it is noted that an applicant for a design approval, a combined license, or manufacturing license under 10CFRPart52 could include the methodology contained in 3002025288 in its application for review and approval by NRC. While 10CFR50.69 is not currently available for plants with a combined license under 10CFRPart52, a petition for rulemaking ([ML15037A481](#), [ML15015A703](#)) may allow this option.

## **RAI 06 - Clarification for Required Prerequisite Programs to the Methodology**

Background/Issue: EPRI TR 3002025288 includes, in Section 4.1, that “robust program[s]” for localized corrosion, flow accelerated corrosion (FAC), and erosion must be ensured before implementing the categorization in Section 4.2 of the methodology. The necessary quality and effectiveness of such programs is verified through, “self-assessment, benchmarking, or peer review” for localized corrosion; and reference to EPRI reports for FAC and erosion. The descriptions include optional language such as “should.”

During the audit EPRI provided an example “application” that relied on referencing individually identified EPRI guidance documents and an NEI bulletin. Further, it was clarified that applicants changing their programs may fall outside of the methodology, despite this not being explicitly controlled in the methodology. The NRC staff needs this clarified on the docket.

### Requests:

- a. It is unclear within the methodology whether an applicant must meet the descriptions of the three programs or what alternatives would be acceptably similar. Clarify how this should be determined and whether optional elements of the descriptions (those including language like “should”) are genuinely optional.

### EPRI response to RAI 6a:

A Licensee must have programs that address localized corrosion, flow-accelerated corrosion, and erosion that follow the guidance and recommendations contained in 3002025288 or identify alternatives that would be described in a plant-specific LAR.

- b. On what basis are the cited programs, or alternatives chosen by an applicant, determined to be sufficiently “robust,” and what would constitute an indication that these programs were insufficiently robust in implementation or due to future alterations?

### EPRI response to 6b:

Programs utilizing the integrity management guidance cited on 3002025288 have been developed over the past 20 years. These programs are well established and grounded in operating experience, an understanding of degradation mechanisms, and how the degradation can evolve over time and the factors (e.g. material, environment) that influence that evolution. This guidance has been peer reviewed by US and international industry subject matter experts and is updated as additional operating experience is obtained and response strategies (e.g. online monitoring versus periodic NDE) evolve.

As stated in 3002025288, Licensee must have living programs that address localized corrosion, flow-accelerated corrosion, and erosion that follow the guidance and recommendations contained in 3002025288 or identify alternatives that would be described in a plant-specific LAR.

An example is provided below that demonstrates how conformance with the Prerequisite 2 integrity management requirement to have robust programs in place that address (i) localized corrosion, (ii) flow-accelerated corrosion, and (iii) erosion could be met.

- (i) Localized Corrosion: Plant X has programs that address localized corrosion (e.g., pitting and microbiologically influenced corrosion). The programs follow the guidance in the following EPRI technical reports:

- TR-103403 (service water corrosion),
- 3002003190 (service water chemical addition systems),
- TR-102063 (examination of service water systems),
- 1010059 (service water piping guidelines), and
- 3002018352 (1016456, Revision 2 which is an update to 1016456, Revision 0 referenced in EPRI 300201599) (management of buried piping)

Therefore, Plant X meets the prerequisite to have a robust program that addresses localized corrosion.

- (ii) Flow-Accelerated Corrosion (FAC): Plant X follows the guidance in the industry standard document, EPRI 3002000563 (NSAC 202L R4, Recommendations for an Effective Flow-Accelerated Corrosion Program). Additionally, the FAC programs implement the use of standardized health reporting that is consistent with those developed out of NEI Efficiency Bulletin 16-34, "Streamline Program Health Reporting."

Therefore, Plant X meets the prerequisite to have a robust program that addresses FAC.

- (iii) Erosion: Erosion in FAC-susceptible systems is addressed by the FAC Program. Erosion in non-FAC susceptible systems is addressed by the respective system owner unless another program (such as GL 89-13) addresses erosion in a particular system. Inspections are selected based on plant experience and engineering judgement and are performed and analyzed in accordance with the guidance in EPRI 3002005530 (Recommendations for an Effective Program Against Erosive Attack).

- c. The methodology does not explicitly require that these programs continue after implementation of the methodology.

1. How is this controlled in the methodology if these programs were discontinued or modified?
2. How would an applicant referencing this methodology determine whether modifications supported a sufficiently robust program?

EPRI response to 6c:

As stated in Section 4.1 of TR 3002025288, licensees must ensure the integrity management prerequisite for having robust programs for localized corrosion, flow-accelerated corrosion, and

erosion have been met before implementing the categorization process described in Section 4.2. If any of these integrity management programs are discontinued or modified such that this prerequisite is no longer fulfilled, then application of the categorization process using this enhanced passive methodology is not allowed.

To clarify this, an additional concluding paragraph in TR 3002025288 is proposed to confirm that integrity management programs are expected to be maintained:

*Consistent with 10CFR50.69(e) Feedback and Process Adjustment, the licensee is required to review changes to the plant, operational practices, applicable plant and industry operational experience, and, as appropriate, update the PRA and SSC categorization and treatment processes. This requirement equally applies to implementing and maintaining integrity management programs.*

- d. The methodology references specific revisions of EPRI reports as necessary “robust” programs. Describe the process of how an applicant using the methodology will do if or when those references were updated?

EPRI response to 6d:

Applicants would need to assess the impact of any updated references on meeting the prerequisite for robust programs via the feedback and adjustment process of 10CRF50.69(e). Please see the response to RAI 6c that describes proposed additional text on how integrity management programs advancements should be considered.

- e. Would the 50.69 categorization need to be revisited if the referenced EPRI reports are revised and/or otherwise become insufficiently robust?

EPRI response to 6e:

Applicants would need to assess the impact of any updated references on meeting the prerequisite for robust programs via the feedback and adjustment process of 10CRF50.69(e). Please see the response to RAI 6c that describes proposed additional text.

## **RAI 07 - Reference to Industry Guidance for Quantitative Assessment**

Background/Issue: EPRI TR 3002025288 includes, in Section 4.2 under Criteria 11-13, that users should rely on “industry guidance” for a number of risk impacts. It is unclear if NRC review and approval is being sought to generically accept use of unspecified “industry guidance” (examples are given but are not required) as being sufficient for regulatory review of performance of Criteria 13.

During the audit, EPRI stated that this could be clearer to refer to Prerequisite 4.1.1. The NRC staff needs this clarified on the docket.

### Requests:

- a. Please confirm or clarify if this was the intent.
- b. Please clarify what “industry guidance” is meant and for which purpose it is to be used.

### EPRI response to 7a&b:

That portion of Section 4.2 could have been worded more clearly. The intent of the paragraph was to state that regardless of whether a pipe segment is determined to be HSS or LSS by criteria 1 through 10, the pipe segment must still be assessed against criteria 11, 12 and 13. Criteria 11, 12 and 13 use the plant-specific PRA (internal events and internal flood) to determine if there are any pipe segments that exceed the threshold provided in criteria 11, 12 and 13. The term “industry guidance” in the existing paragraph was intended to reflect the requirements as stated in Prerequisite 4.1.1, in that the plant-specific PRA must be subjected to a peer review assessed against a standard or set of acceptance criteria endorsed by the NRC.

#### **Existing words from section 4.2**

For purposes of applying criteria 11–13, the definition of a pipe segment is not a function of whether it was categorized as HSS or LSS according to criteria 1–10. That is, even if a piping segment or a portion of a pipe segment is HSS according to one of the first 10 of the preceding criteria, the impact on risk due to its postulated failure is determined consistent with industry guidance (such as the PRA standard, EPRI 1019194). Also, even if a piping segment or a portion of a pipe segment is LSS according to all of the first 10 criteria, the impact on risk due to its postulated failure is determined consistent with industry guidance.

#### **Proposed changes to section 4.2**

For purposes of applying criteria 11–13, the definition of a pipe segment is not a function of whether it was categorized as HSS or LSS according to criteria 1–10. That is, even if a piping segment or a portion of a pipe segment is HSS according to one of the first 10 of the preceding criteria, the impact on risk due to its postulated failure is determined using the plant-specific PRA (see Prerequisite 4.1.1). Also, even if a piping segment or a portion of a pipe segment is LSS according to the first 10 criteria, the impact on risk due to its postulated failure is determined using the plant-specific PRA (see Prerequisite 4.1.1).



## **RAI 08 - Clarification of Reactor Coolant Boundary Categorization**

Background/Issue: EPRI TR 3002025288 Criteria 1 differentiates components based on whether the components can be isolated from the reactor coolant system by two valves in series. Table 3, "HSS criteria: considerations", amends this to note that the piping between these two valves may be medium/low consequence. It is unclear how a valve whose function is dependent on a lower classification can retain a higher classification function as a matter of categorization.

During the audit EPRI stated that this could have been more clearly worded and provided a proposed revision. The NRC staff needs this clarified on the docket.

### Requests:

- a. Submit the proposed revision, similar equivalent, or otherwise clarify why such is not needed.

### EPRI response to 8a:

The note in the Table 3 could have been worded more clearly. A proposed revision is as follows:

*This is a conservative portrayal of the safety significance of some of the Class 1 piping as experience using the existing methodology has shown that the Class 1 piping between the first and second isolation valve is typically a low consequence rank (e.g., CCDP less than 1E-06).*

Note that regardless of this observation, all Class 1 components will be HSS.

## **RAI 09 - Sensitivity Calculation to Account for Uncertainty**

Background/Issue: EPRI TR 3002025288 section 4.3 states that analysis using a factor of 3 reduction in reliability for systems categorized as RISC-3 is conservative and appropriate, citing NEI 00-04. It is unclear why this factor is conservative and appropriate in the reversed context of this methodology, where components are presumed LSS by default, in contrast to the traditional 50.69 methodology which presumes components are HSS by default. Notably, the proposed methodology is relatively simplified compared to the traditional use of NEI 00-04 for supporting 10 CFR 50.69 applications which includes a relatively fine-grained assessment of subject systems.

NEI 00-04 does not state that a factor of 3 is appropriate, rather it provides a range of values useful in conducting sensitivity studies of an analysis. No basis is given for this range in NEI 00-04 beyond that it would provide “trend” insights for the consequences of reductions in reliability due to reduced treatments. The factor of 3 is generally used when assessing sensitivity to uncertainty as it is an approximation of the likely “tail” of a distribution for active systems. When altering the general approach (e.g. changing from HSS treatment to LSS treatment for passive systems), it is unclear why it is reasonable to assess the future distribution (LSS treatment) as matching the prior distribution (HSS treatment).

Addressing this uncertainty is particularly important in the context of other relaxations in treatment that may occur due to changes in ASME code requirements, for example, that may be implemented separately and concurrently with this methodology. This is particularly important in understanding whether the factor chosen genuinely informs regarding uncertainties in the context of passive systems and the performance monitoring associated with such.

The NRC staff needs a justification of the use of a factor of 3 provided on the docket.

### Requests:

- a. Clarify on what basis a factor of 3 is determined to be conservative. In particular, provide any operating experience meta-analysis and/or data distributions supporting that a factor of 3 is conservative, or realistic for passive systems.

### EPRI response to 9a:

The factor of 3 as recommended in NRC approved NEI 00-04 Section 8.1 has been applied in over 50 NRC approved 10CFR50.69 License applications and is not meta-analyses derived nor a statistically developed level of confidence for addressing uncertainty. Rather, as stated in NEI 00-04, Section 8.1, the purpose of utilizing a factor of 3 is that it *could* provide an indication of the potential trend in CDF and LERF, *if* there were a degradation in the performance of all RISC-3 SSCs. Such degradation is extremely unlikely for an entire group of components. It is even more remote for implementation of 3002025288 in that the prerequisites that must be implemented as part of the 3002025288 methodology has shown that these programs coupled with Licensee’s corrective action programs would see a rise in failure events and corrective actions would be taken long before even a small population of RISC-3 items see degradation, let alone the entire population of RISC-3 items experienced such degradation. As such, while there is some possibility that an individual item could see variations in performance on this order, it is exceedingly unlikely that the performance of a large group of items would all shift in an unfavorable manner at the same time.

As stated in 3002025288 as well as the Supplemental information packages previously provided to NRC staff as well as public meetings held with NRC on 3002025288 as well as numerous other industry / NRC interactions (e.g., docketed Licensee submittals, public meetings, ACRS meetings, etc.) it is expected that RISC-3 components will not see an increase in failure rates. This expectation is supported by the fact that 10CFR50.69(d)(2) requires that the license ensure, with reasonable confidence, that RISC-3 SSCs remain capable of performing their safety related functions under design basis conditions, including seismic conditions and environmental conditions and effects throughout their service life and that alternate treatment, if applied, be consistent with the categorization process.

Further, 10CFR50.69(e) requires that Licensees consider data collected in 10CFR50.69(d)(2)(i) for RISC-3 SSCs to determine if there are any adverse changes in performance such that the SSC unreliability values approach or exceed the values used in the evaluations conducted to satisfy §50.69(c)(1)(iv). The licensee is required to make adjustments as necessary to the categorization or treatment processes so that the categorization process and results are maintained and valid.

Finally, 10CFR50.69(d)(2)(ii) requires that for conditions that would prevent a RISC-3 SSC from performing its safety-related functions under design basis conditions that they be corrected in a timely manner. For significant conditions adverse to quality, measures must be taken to provide reasonable confidence that the cause of the condition is determined and corrective action taken to preclude repetition.

To provide further context, examples were randomly selected from Appendix A-1 (PWR Service Water Data Tables) of EPRI 3002024904, "Pipe Rupture Frequencies for Internal Flooding Probabilistic Risk Assessments: Revision 5," for 4-inch, 10-inch and 24-inch pipe sizes that represent spray and double ended guillotine breaks. A comparison table is provided below between 3x mean (failure rates increased by factor of 3) and 95% confidence level. Thus, it can be concluded that the factor of 3 increase approaches the 95<sup>th</sup> percentile of the uncertainty distribution which has been used in sensitivity analyses.

Pipe Size (in.)	Flow rate @ 70psig <sup>1</sup> (gpm)	EBS (in.)	CBF Mean	RF	95th	3x Mean
4	100	0.63	9.60E-07	10.8	3.64E-06	2.88E-06
4	4503	4.24	7.47E-08	15.3	2.89E-07	2.24E-07
10	100	0.63	3.49E-07	12.3	1.34E-06	1.05E-06
10	18012	8.49	2.08E-08	21.8	7.83E-08	6.23E-08
24	100	0.63	9.75E-08	6.2	3.27E-07	2.93E-07
24	128083	22.63	3.90E-10	54.3	1.11E-09	1.17E-09