



U.S. PWR Core Barrel Specimens Laboratory Evaluation



Frank Gift,
Sr. Principal Technical Leader

Kyle Amberge
Technical Executive

June 17, 2025


in collaboration with



and




EPRI-Funded Work Scope





Laboratory Examination and Testing of 2 Core Drill Specimens (Indication #3 and Tip of Indication #4)

- Identify Mode(s) of Degradation
- Identify Contributing Factors to the Degradation

Sample 3








Sample 4




- Fractography
- Metallography
- Microscopy
- Chemistry
- Hardness Testing
- ASTM A262 Pr. A
- Dosimetry

Fractography, Metallography, Microscopy



INITIATION IN THE HEAT AFFECTED ZONE (HAZ)



Crack path confined to base metal, within HAZ of the upper girth weld

Intergranular mode of cracking, indicative of stress corrosion cracking, on all fracture faces

Investigation of Potential Contributing Factors to Degradation

Chemistry Analysis

Element / Sample Identification	Co	Cr	Cu	Fe	Mn	Mo	Ni	P	Si	C	S
ASTM A240-69, Type 304	-	18.00- 20.00	-	-	2.00 max	-	8.00- 12.00	0.045 max	1.00 max	0.08 max	0.030 max
Upper CB Plate	0.11	18.36	0.09	69.66	1.47	0.19	9.58	0.01	0.49	0.039	0.015
Upper CB CMTR	0.13	18.32	0.08	69.53	1.53	0.21	9.60	0.031	0.51	0.045	0.015
Middle CB Plate	0.07	18.84	0.05	68.89	1.43	0.22	9.79	0.01	0.66	0.047	0.012
Middle CB CMTR	-	18.92	0.05	68.85	1.50	-	9.85	0.023	0.70	0.048	0.011
Weldment	0.08	20.05	0.08	67.29	2.07	0.06	9.89	0.00	0.43	0.050	0.007

- Chemistry measurements made by combustion analysis (C, S) and inductively coupled plasma optical emission spectroscopy (ICP-OES) for remaining elements
- Base metal chemistry conforms to plate specification ASTM A240 for Type 304
- Experimental data matches well with the respective plate certified material test report (CMTR) values
- Weld metal chemistry meets vintage SFA 5.4 weld metal specification for E308

Investigation of Potential Contributing Factors to Degradation


Microhardness Testing (HV_{0.5})

Location	Average Vickers Microhardness Value	Standard Deviation
Middle Core Barrel Plate	218	30
Middle Core Barrel HAZ	224	33
Weldment	221	21
Upper Core Barrel HAZ	213	9
Upper Core Barrel Plate	194	12

- Weld metal hardness appears typical, with highest values near root of weld
- Upper shell and middle shell (away from weld HAZ/fracture face) hardness values appear typical
- ID Surface hardness does not appear to be significantly elevated, but fewer points available in HAZ

ASTM A262 Practice A Testing

- Middle cylinder plate
 - Base metal – Not sensitized (left image)
 - HAZ – Potentially sensitized (right image)
- Upper cylinder plate
 - Base metal – Potentially sensitized
 - HAZ – Potentially sensitized




Investigation of Potential Contributing Factors to Degradation

Retrospective Dosimetry Analysis

- One sample from each respective location in each Core Sample, both on ID and OD.
- Chemistry quantification supported by X-ray Fluorescence (XRF)

Average between Specimens	Upper CB Plate ID	Weldment ID	Middle CB Plate ID
Integrated Fluence (E > 1.0 MeV) (n/cm ²)	6.60E+17	8.01E+17	1.05E+18
Integrated Iron Atom Displacements (dpa)	9.85E-04	1.19E-03	1.56E-03
Integrated Fluence (E > 0.1 MeV) (n/cm ²)	1.10E+18	1.37E+18	1.87E+18

Maximum Best-Estimate Values	Upper CB Plate OD	Weldment OD	Middle CB Plate OD
Integrated Fluence (E > 1.0 MeV) (n/cm ²)	4.22E+17	4.99E+17	7.76E+17
Integrated Iron Atom Displacements (dpa)	6.30E-04	7.43E-04	1.16E-03
Integrated Fluence (E > 0.1 MeV) (n/cm ²)	7.77E+17	9.52E+17	1.52E+18



With irradiation damage less than 0.002 dpa, irradiation effects are considered insignificant with respect to the degradation observed

Key Observations Summary

- **Degradation Mode**: Intergranular cracking is observed throughout the crack surface of both indications. Intergranular stress corrosion cracking (IGSCC) is the only mechanism observed.

- **Contributing (or Unique) Factors**:
 - IGSCC is confined to the HAZ of middle core barrel shell
 - No indication of weld repairs in the vicinity of the cracks
 - Typical carbon and sulfur levels measured for Type 304 stainless steel of this vintage
 - ASTM A262 Practice A indicates some “suspect” microstructures present in samples, notably HAZs.
 - “Suspect” is language from A262 specification, meaning HAZ is *potentially sensitized*
 - Microstructure otherwise seems typical for base metal and weld metal
 - Moderately elevated hardness in some regions (notable near root pass), but not so high as to be a significant contributor to initiation
 - Irradiation damage is not a contributing factor to the degradation



TOGETHER...SHAPING THE FUTURE OF ENERGY®