



ACRS Subcommittee – ANP-10358 Increased Burnup for PWRs

Chris Allison, Brian Friend, Lisa Gerken,
Michelle Guzzardo, Nathan Hottle

February 17, 2026




Open Meeting



Agenda

- Open meeting - overview
 - Motivation for increased burnup
 - Scope of topical report
- Closed meeting
 - Extension of methods
 - ARCADIA
 - Fuel assembly growth
 - Updates to current methods
 - Fuel rod internal pressure criteria
 - LOCA
 - Fuel dispersal





1. Overview

Advanced Fuel Management

Industry need

- Market demand and government incentives for increased power production
- Increased enrichment and burnup → efficient core designs, longer operating cycles
- 24-month cycles for W17-4L PWRs → significant cost and operational benefits







Framatome Approach to AFM

- Employ fuel components with a service record of robust performance
- Use focused subject topical reports to build up foundation of code and methods enabling advanced features and flexibility to support AFM core designs

Increased Burnup

Proven fuel designs that maintain their performance through irradiation are essential

- With over 20 years of operation, M5_{Framatome} cladding remains the gold standard
- Deployed in over 7 million fuel rods worldwide
- Recognized for its mechanical properties, superior corrosion resistance, and very low hydrogen pickup



Advanced codes and methods suite is fully compliant with NRC regulations and guidance

- The cladding and fuel performance code are the key elements for high burnup licensing and are fully approved to target burnup
- Increased enrichment topical validated suite for target enrichment
- Increased burnup topical report is the last piece to licensing PWR AFM operation



ANP-10358 Topical Report

1. Introduction
 2. Fuel Designs
 3. Nuclear Design – ARCADIA
 4. Thermal Hydraulics
 5. Mechanical
 6. Non-LOCA
 7. LOCA
 8. Reactor Pressure Vessel Fluence
-
- Appendix A – Decay Heat
 - Appendix B – Fuel Dispersal
 - Appendix C – LOCA Sample Problems



ANP-10358 Topical Report

- Umbrella topical report establishing Framatome's suite of advanced codes and methods
- Extends applicability of codes and methods to target burnup
- Follows the same approach as Increased Enrichment Topical Report that extended applicability to greater than 5 wt% U-235
- Includes:
 - Burnup extension for all methods through disposition, additional justification, or updated models
 - **Today's meeting: ARCADIA extension and fuel assembly growth model**
 - Enrichment extension for select areas not previously addressed
 - Enhancements to provide increased flexibility for AFM operating region
 - **Today's meeting: Rod internal pressure limit, LOCA modifications, fuel dispersal**




Closed Meeting




AFM Range of Applicability

- [] GWd/mtU rod average burnup
- [] wt% U-235




2. Extensions



2.1 ARCADIA

ARCADIA

- ARCADIA is used for all reactor core physics calculations
 - Pin-by-pin and subchannel-by-subchannel coolant modeling
 - 3D kinetic modeling captures
- ANP-10297P-A, Rev. 0 (2013) with Supplement 1P-A, Rev. 1 (2020)
 - Burnup limit of 71 GWd/mtU fuel rod average
 - Accurate and reliable prediction of fuel and core behavior for licensing basis event analyses
 - Captures transient changes in reactivity, conductivity, and enthalpy



Fundamental element to core design optimization and accident analyses capabilities



ARCADIA Benchmarks

- The ARCADIA TR included benchmarks over a wide variety of core and operation conditions
 - Critical experiments, integral experiments, and spent fuel analyses
 - Startup physics testing and core follow comparisons
 - Burnup limit set by spent fuel analyses
- Additional spent fuel comparisons included in ANP-10358 to extend range
 - Samples taken from various elevations of 3 rods that operated for 5 cycles at Vandellós Unit 2
 - Westinghouse 157 17x17-assembly PWR
 - Rated thermal power = 2711 MW (Cycles 7-10) = 2830 MW (Cycle 11)
 - Sample burnups ranged from 63.8 -78.2 GWd/mtU



ARCADIA Benchmarks Cont.

- Complexities of Modeling and Measurements
 - Operating history – multiple assemblies, locations in core, surrounding assemblies, reconstituted assembly
 - Three different measurement techniques used
 - Measurement uncertainties vary across different measurement techniques and different isotopes
- Benchmarking analysis provides practical validation of the ARCADIA models
 - Qualitative assessment of modeling
 - Results were acceptable, typically within two standard deviations

Results for the Vandellos samples support the extension of the ARCADIA code package to a rod average burnup limit of [] GWd/mtU





2.2 Fuel Assembly Growth

Q12 Fuel Assembly Growth Model




Q12 Fuel Assembly Growth Model





3. Updates



3.1 Rod Internal Pressure Limit



Rod Internal Pressure Limit

- Limit is tied to three phenomena
 - No reorientation of the hydrides in the radial direction in the cladding
 - No clad liftoff during normal operation
 - Consideration for additional fuel failures from DNB propagation in postulated accidents
 - Framatome's DNB Propagation methodology is **independent** of fuel rod overpressure magnitude
 - Simple, conservative methodology
 - Documented in Section 9.1.4.5 of ANP-10339PA-00 (ARITA), Section 6.8.4 of ANP-10338PA-00 (AREA)

ANP-10358 Overpressure Limit: []



Radial Hydride Reorientation

- Radial hydride reorientation in M5Framatome clad does not occur for overpressure of []
 - Documented in ANP-10323PA-01, Appendix B (GALILEO)
 - Corresponding US NRC Safety Evaluation: Section 3.7.5

ANP-10358 limit is []



Cladding Liftoff

- ROPE-II, IFA-610 (series), and IFA-683 experiments
 - Devised to study fuel rod behavior in overpressure conditions
 - Range of rod overpressure: 5 ~ 28 MPa
 - Range of burnup: 40 ~ 90 GWd/mtU
 - Clear evidence of radial hydride reorientation below the threshold of cladding liftoff
 - Overpressure liftoff threshold
 - Framatome evaluation: []
 - Independent evaluation: 13.8 +/- 0.9 MPa (*)
- Analytical studies with GALILEO concluded:


(*) Wolfgang WIESENACK, Terje TVERBERG, Margaret MCGRATH, Erik KOLSTAD & Stephan BÉGUIN (2006), "Rod Overpressure/Lift-off Testing at Halden In-pile Data and Analysis," Journal of Nuclear Science and Technology, 43:9, 1037-1044, DOI:10.1080/18811248.2006.9711193.



Conclusion

- DNB propagation methodology approved in ARITA and AREA TR is not impacted by overpressure magnitude
- [] overpressure precludes radial hydride reorientation in M5 cladding
- [] overpressure precludes clad liftoff in M5 cladding
 - ANP-10358 provides conclusive evidence from both experimental results and GALILEO analyses
 - []

Fuel rod overpressure limit for M5 cladding with ANP-10358 is []




3.2 LOCA




LOCA Evaluation Models

- Framatome conservatively reduces the 10 CFR 50.46 space into two sub-regions with a separate NRC-approved evaluation model (EM) for each
 - SBLOCA EM: EMF-2328, Rev. 0 & Supplement 1
 - RLBLOCA EM: EMF-2103, Rev. 3
- ANP-10358 Modifications
 - []
 - []
 - Implementation of Alternative Compliance Criteria

Today's meeting: Alternative Compliance and Dispersal Validation






3.3 Fuel Dispersal



FFRD: Fuel Fragmentation, Relocation, and Dispersal




Economical 24-month core designs with increased enrichment and burnup



Once-burned fuel has higher rod internal pressure and burnup



Increasing fragmentation with burnup



Increased likelihood of fuel dispersal during accident with cladding breach



ANP-10358 addressed these changes within the existing regulatory framework





















Fuel Dispersal Summary





4. Summary



ANP-10358 Topical Report Summary

- Umbrella topical report establishing Framatome's suite of advanced codes and methods
- Extends applicability of codes and methods to [] GWd/mtU rod average burnup
- The last building block to license PWR AFM operation

Framatome's advanced codes and methods support safe operation of the fuel and reactor system in the AFM operating region



*Thank
you*



Acronyms

AFM	Advanced Fuel Management	HBU	High Burnup
BJ-ECR	Baker Just – Equivalent Cladding Reacted	LB	Large Break
CDF	Cumulative Distribution Frequency	LBLOCA	Large Break Loss of Coolant Accident
CHF	Critical Heat Flux	LTOM	Least Transient Oxidation margin
CLD	Cold Leg Discharge	LOCA	Loss of Coolant Accident
CP-ECR	Cathcart Pawel - Equivalent Cladding Reacted	LOOP	Loss of Offsite Power
DNB	Departure from Nucleate Boiling	NRC	Nuclear Regulatory Commission
ECC	Emergency Core Cooling	PCT	Peak Cladding Temperature
ECCS	Emergency Core Cooling Systems	PRA	Probabilistic Risk Assessment
EM	Evaluation Model	PWR	Pressurized Water Reactor
FGR	Fission Gas Release	RCS	Reactor Coolant System
FFRD	Fuel Fragmentation, Relocation, and Dispersal	RLBLOCA	Realistic Large Break Loss of Coolant Accident
FOM	Figure of Merit	SBLOCA	Small Break Loss of Coolant Accident
FPC	Fuel Performance Code	SF	Single Failure
FRM	Fuel Rod Model	TOM	Transient Oxidation Margin
GDC	General Design Criterion	TR	Topical Report



Trademarks

AFA3G, AGORA, ARCADIA, AREA, ARITA, ARTEMIS, COBRA-FLX, GAIA, GALILEO, HTP, M5, M5_{Framatome}, Q12, and S-RELAP5 are trademarks or registered trademarks of Framatome or its affiliates, in the USA or other countries.

Any reproduction, alteration, transmission to any third party or publication in whole or in part of this document and/or its content is prohibited unless Framatome has provided its prior and written consent.

This document and any information it contains shall not be used for any other purpose than the one for which they were provided.

Legal and disciplinary actions may be taken against any infringer and/or any person breaching the aforementioned obligations.