

# **Technical Basis for Regulatory Guidance on the Alternate Pressurized Thermal Shock Rule**

Draft Report for Comment

## AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

### NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents  
U.S. Government Printing Office  
Mail Stop SSOP  
Washington, DC 20402-0001  
Internet: [bookstore.gpo.gov](http://bookstore.gpo.gov)  
Telephone: 202-512-1800  
Fax: 202-512-2250
2. The National Technical Information Service  
Springfield, VA 22161-0002  
[www.ntis.gov](http://www.ntis.gov)  
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission  
Office of Administration  
Publications Branch  
Washington, DC 20555-0001

E-mail: [DISTRIBUTION.RESOURCE@NRC.GOV](mailto:DISTRIBUTION.RESOURCE@NRC.GOV)  
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

### Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library  
Two White Flint North  
11545 Rockville Pike  
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute  
11 West 42<sup>nd</sup> Street  
New York, NY 10036-8002  
[www.ansi.org](http://www.ansi.org)  
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

**DISCLAIMER:** This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

# **Technical Basis for Regulatory Guidance on the Alternate Pressurized Thermal Shock Rule**

Draft Report for Comment

Manuscript Completed: November 2014  
Date Published: February 2015

Prepared by:  
Gary L. Stevens, Mark T. Kirk, and Mohammad Modarres\*

\*University of Maryland

Gary L. Stevens, NRC Project Manager

Office of Nuclear Regulatory Research

## COMMENTS ON DRAFT REPORT

Any interested party may submit comments on this report for consideration by the NRC staff. Comments may be accompanied by additional relevant information or supporting data. Please specify the report number **NUREG-2163** in your comments, and send them by the end of the comment period specified in the *Federal Register* notice announcing the availability of this report.

**Addresses:** You may submit comments by any one of the following methods. Please include Docket ID **NRC-2014-0137** in the subject line of your comments. Comments submitted in writing or in electronic form will be posted on the NRC website and on the Federal rulemaking website <http://www.regulations.gov>.

**Federal Rulemaking Website:** Go to <http://www.regulations.gov> and search for documents filed under Docket ID **NRC-2014-0137**. Address questions about NRC dockets to Carol Gallagher at 301-415-3463 or by e-mail at [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov).

**Mail comments to:** Cindy Bladey, Chief, Rules, Announcements, and Directives Branch (RADB), Division of Administrative Services, Office of Administration, Mail Stop: OWFN-12-H08, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

For any questions about the material in this report, please contact: Gary Stevens, Senior Materials Engineer, 301-415-3608, or by e-mail at [Gary.Stevens@nrc.gov](mailto:Gary.Stevens@nrc.gov); or Mark Kirk, Senior Materials Engineer, 301-251-7631 or by e-mail at [Mark.Kirk@nrc.gov](mailto:Mark.Kirk@nrc.gov).

Please be aware that any comments that you submit to the NRC will be considered a public record and entered into the Agencywide Documents Access and Management System (ADAMS). Do not provide information you would not want to be publicly available.

1 **ABSTRACT**

---

2 During plant operation, the walls of reactor pressure vessels (RPVs) are exposed to neutron  
3 radiation, resulting in embrittlement of the vessel steel and weld materials in the area of the  
4 RPV adjacent to the core. If an embrittled RPV had a flaw of critical size and certain severe  
5 system transients were to occur, the flaw could rapidly propagate through the vessel, resulting  
6 in a through-wall crack and, thereby, challenging the integrity of the RPV. The severe transients  
7 of concern, known as pressurized thermal shock (PTS), are characterized by a rapid cooling of  
8 the internal RPV surface in combination with repressurization of the RPV. Advancements in  
9 understanding and knowledge of materials behavior, the ability to realistically model plant  
10 systems and operational characteristics, and the ability to better evaluate PTS transients to  
11 estimate loads on vessel walls led the U.S. Nuclear Regulatory Commission (NRC) to develop a  
12 risk-informed revision of the existing PTS Rule that was published in Section 50.61a, "Alternate  
13 Fracture Toughness Requirements for Protection against Pressurized Thermal Shock Events,"  
14 of Title 10, "Energy," of the *Code of Federal Regulations* (10 CFR 50.61a).

15  
16 This report explains the basis for the requirements that establish the entry conditions to permit  
17 use of 10 CFR 50.61a and describes methods by which the following four requirements can be  
18 met: (1) criteria relating to the date of construction and design requirements, (2) criteria relating  
19 to evaluation of plant-specific surveillance data, (3) criteria relating to inservice inspection (ISI)  
20 data and non-destructive examination (NDE) requirements, and (4) criteria relating to alternate  
21 limits on embrittlement.  
22



# 1 FOREWORD

---

2 The reactor pressure vessel (RPV) is exposed to neutron radiation during normal operation.  
3 Over time, the RPV steel becomes progressively more brittle in the region adjacent to the core.  
4 If a vessel had a preexisting flaw of critical size and certain severe system transients occurred,  
5 this flaw could propagate rapidly through the vessel, resulting in a through-wall crack. The  
6 severe transients of concern, known as pressurized thermal shock (PTS), are characterized by  
7 rapid cooling (i.e., thermal shock) of the internal RPV surface that may be combined with  
8 repressurization. The simultaneous occurrence of critical-size flaws, embrittled steel, and a  
9 severe PTS transient is a low-probability event. U.S. pressurized-water reactors (PWRs) are  
10 not projected to approach the levels of embrittlement to make them susceptible to PTS failure,  
11 even during extended operation beyond the original 40-year design life.  
12

13 Advancements in understanding and knowledge of materials behavior, the ability to realistically  
14 model plant systems and operational characteristics, and the ability to better evaluate PTS  
15 transients to estimate loads on vessel walls led to the development of a risk-informed revision of  
16 the existing PTS Rule that was published in Section 50.61a, "Alternate Fracture Toughness  
17 Requirements for Protection against Pressurized Thermal Shock Events," of Title 10, "Energy,"  
18 of the *Code of Federal Regulations* (10 CFR 50.61a).  
19

20 The "Alternate PTS Rule" contained in 10 CFR 50.61a provides revised PTS screening criteria in  
21 the form of an embrittlement reference temperature,  $RT_{MAX-X}$ , which characterizes the RPV  
22 material's resistance to fracture from initiated flaws. The Alternate PTS Rule is based on more  
23 comprehensive analysis methods than the existing PTS Rule contained in 10 CFR 50.61, "Fracture  
24 Toughness Requirements for Protection against Pressurized Thermal Shock Events." This  
25 alternate rule became desirable because the existing requirements contained in 10 CFR 50.61 are  
26 based on unnecessarily conservative assumptions. The Alternate PTS Rule reduces regulatory  
27 burden for those PWR licensees who expect to exceed the 10 CFR 50.61 embrittlement  
28 requirements before the expiration of their operating licenses, while still maintaining adequate safety  
29 margins. PWR licensees may choose to comply with the Alternate PTS Rule as a voluntary  
30 alternative to complying with the requirements contained in 10 CFR 50.61.  
31

32 This document explains the basis for the requirements that establish the entry conditions to  
33 permit use of the Alternate PTS Rule. It also describes methods by which the following four  
34 requirements can be met:  
35

- 36 1. Criteria relating to the date of construction and design requirements;
- 37 2. Criteria relating to evaluation of plant-specific surveillance data;
- 38 3. Criteria relating to inservice inspection (ISI) data and non-destructive examination (NDE)  
39 requirements; and
- 40 4. Criteria relating to alternate limits on embrittlement.  
41

42  
43  
44 Brian W. Sheron, Director  
45 Office of Nuclear Regulatory Research  
46 U.S. Nuclear Regulatory Commission  
47





1 **TABLE OF CONTENTS**

---

2 ABSTRACT..... iii

3 FOREWORD .....v

4 TABLE OF CONTENTS .....vii

5 LIST OF FIGURES .....ix

6 LIST OF TABLES.....xi

7 EXECUTIVE SUMMARY ..... xiii

8 ABBREVIATIONS AND ACRONYMS .....xv

9 SYMBOLS AND EXPRESSIONS..... xvii

10 1. INTRODUCTION..... 1

11     1.1 Background..... 1

12     1.2 Scope of this Report ..... 3

13 2. OVERVIEW OF THE ALTERNATE PTS RULE ..... 7

14     2.1 Background..... 7

15     2.2 Applicability of the Alternate PTS Rule..... 7

16     2.3 Updated Embrittlement Correlation ..... 8

17     2.4 ISI Volumetric Examination and Flaw Assessments..... 8

18     2.5 NDE-Related Uncertainties .....10

19     2.6 Surveillance Data.....10

20 3. RESPONSES TO STAKEHOLDER FEEDBACK.....11

21 4. GUIDANCE FOR CRITERIA RELATING TO THE DATE OF CONSTRUCTION AND

22 DESIGN REQUIREMENTS .....19

23     4.1 Requirements in the Alternate PTS Rule.....19

24     4.2 Regulatory Guidance .....19

25 5. GUIDANCE FOR CRITERIA RELATING TO THE EVALUATION OF PLANT-SPECIFIC

26 SURVEILLANCE DATA.....21

27     5.1 Embrittlement Trend Curve .....22

28     5.2 Data Used in Statistical Tests .....24

29     5.3 Statistical Evaluation of Surveillance Data .....26

30     5.4 How to Perform Statistical Tests of Surveillance Data.....29

31         5.4.1 *Type A Deviations* .....29

32         5.4.2 *Type B Deviations* .....30

33         5.4.3 *Type D Deviations* .....31

34         5.4.4 *Comments on the Statistical Tests*.....32

35     5.5 Evaluation of Plant Data Relative to the Statistical Tests .....33

36     5.6 Considerations When Statistical Tests Are Failed .....36

37         5.6.1 *Factors to Consider When Statistical Tests Are Failed* .....36

38         5.6.2 *Specific Procedures*.....37

39     5.7 Summary and Conclusions .....38

40 6. GUIDANCE RELATING TO ISI DATA AND NDE REQUIREMENTS .....41

41     6.1 Background.....41

42     6.2 Guidance on Criteria Relating to Alternate Limits on Embrittlement .....46

43         6.2.1 *Guidance on a Procedure to Preclude Brittle Fracture*.....46

44         6.2.2 *Guidance on Considerations to Include in a Plant-Specific PFM Analysis*.....49

45     6.3 Guidance for Initial Evaluation of NDE Data.....52

46     6.4 Guidance for Further Evaluation of NDE Data.....61

47         6.4.1 *Guidance on the Elements and NDE Techniques Associated with ASME Code*

48             *Examinations*.....61

1                    6.4.2 *Guidance on a Procedure to Adjust NDE Data and Comparison to Flaws*  
2                        *Assumed in PFM Calculations* ..... 62  
3                        6.4.2.1 *Guidance on Application of NDE Uncertainties* ..... 64  
4 7. GUIDANCE ON CRITERIA RELATING TO ALTERNATE LIMITS ON  
5     EMBRITTLEMENT ..... 67  
6 8. SUMMARY ..... 69  
7 9. REFERENCES ..... 71  
8 APPENDIX A: DERIVATION OF THE STATISTICAL TEST FOR TYPE D DEVIATIONS ..... A-1  
9 APPENDIX B: REGULATORY ASSESSMENT OF STATISTICAL SURVEILLANCE  
10     TESTS ..... B-1  
11 APPENDIX C: FLAW DEPTH AND DENSITY DISTRIBUTIONS CONSIDERING  
12     PROBABILITY OF DETECTION AND BIAS IN NDE DATA WITH  
13     APPLICATIONS ..... C-1  
14 APPENDIX D: SENSITIVITY-STUDY RESULTS ON FLAW DISTRIBUTIONS  
15     CONSIDERING VFLAW DATA, POD, AND MEASUREMENT ERRORS  
16     IN NDE DATA ..... D-1  
17

1 **LIST OF FIGURES**

---

2 Figure 1. Four Types of Deviation between Heat-Specific Surveillance Data  
3 and a  $\Delta T_{30}$  ETC. ....28  
4 Figure 2.  $\Delta T_{30}$  Prediction Residuals Based on Eqn. (1). Low flux points are from  
5 power reactors while high flux points are from test reactors. Similar trends  
6 exist for both plates and welds [15]. ....29  
7 Figure 3. Procedure to Assess Type B Deviations. ....30  
8 Figure 4. Specific Procedures to Account for Failure of the Mean Test (left) or Low  
9 Fluence Outlier Statistical Test (right). ....38  
10 Figure 5. Flow Diagram with Recommendations for Meeting the Requirements of the  
11 Alternate PTS Rule. ....45  
12 Figure 6. ASME Code Section XI Examination and Flaw Evaluation Process and  
13 Identification of Flaws for Comparison to Alternate PTS Rule. ....55  
14 Figure 7. Sample Appendix VIII Examination Results for Plant J. ....56  
15



1 **LIST OF TABLES**

---

2 Table 1.  $RT_{MAX-X}$  PTS Embrittlement Limits from the Alternate PTS Rule..... 2  
3 Table 2. Flaw Limit Tables from the Alternate PTS Rule..... 5  
4 Table 3. EPRI Recommendations for Addressing Alternate PTS Rule Requirements [10]..... 12  
5 Table 4. Standard Deviation of Residuals about Eqn. (1) .....23  
6 Table 5. Independent Variables in the Eqn. (1) ETC and the Ranges and Mean Values  
7 of the Calibration Dataset .....23  
8 Table 6.  $\alpha = 1\%$  Student's t-Values .....31  
9 Table 7.  $\alpha = 1\%$  Threshold Value for the Outlier Test .....32  
10 Table 8. Heats of Material that Exhibit Statistically Significant Deviations ( $\alpha = 1\%$ ) of  
11 Type A, B, or D .....35  
12 Table 9. Proportion of Material Heats in the Current Surveillance Database that Exhibit  
13 Statistically Significant Deviations ( $\alpha = 1\%$ ) of Type A, B, or D .....35  
14 Table 10. Sample Brittle Fracture Assessment.....48  
15 Table 11. Summary of the Revised Flaw Depth and Flaw Density VFLAW Parameters  
16 to be Used in a Revised PFM Analysis for Beaver Valley 2 (from Appendix C).....51  
17 Table 12. Determination of Total Weld Length Examined for Plant J.....57  
18 Table 13. Determination of Total Plate Surface Area Examined for Plant J .....58  
19 Table 14. Determination of the Flaw Positions for Plant J .....59  
20 Table 15. Comparison of Flaws to Alternate PTS Rule Flaw Tables for Plant J.....60  
21 Table 16. Example for Plant J After Applying an Initial Alternate PTS Rule Flaw Table  
22 Check Using the Procedure in Section 6.3.....64  
23



# EXECUTIVE SUMMARY

---

In early 2010, the U.S. Nuclear Regulatory Commission (NRC) promulgated the Alternate Pressurized Thermal Shock (PTS) Rule as 10 CFR 50.61a, "Alternate Fracture Toughness Requirements for Protection against Pressurized Thermal Shock Events," which amended existing regulations to provide alternate embrittlement requirements for protection against PTS events for pressurized-water reactor (PWR) pressure vessels. These requirements are based on more comprehensive, accurate, and realistic analysis methods than those used to establish the limits in 10 CFR 50.61, "Fracture Toughness Requirements for Protection against Pressurized Thermal Shock Events." This alternate rule became desirable because the existing requirements, as contained in 10 CFR 50.61, are based on unnecessarily conservative assumptions. The Alternate PTS Rule reduces regulatory burden for those PWR licensees who expect to exceed the 10 CFR 50.61 embrittlement requirements before the expiration of their operating licenses while still maintaining adequate safety margins. PWR licensees may choose to comply with the Alternate PTS Rule as a voluntary alternative to complying with the requirements contained in 10 CFR 50.61.

The Alternate PTS Rule provides revised PTS screening criteria in the form of embrittlement reference temperatures,  $RT_{MAX-X}$ , that characterize the RPV material's resistance to fracture initiating from flaws. The  $RT_{MAX-X}$  embrittlement limits may be used by licensees provided that the following criteria are met:

1. **Criteria relating to the date of construction and design requirements:** The Alternate PTS Rule is applicable to licensees whose construction permits were issued before February 3, 2010, and whose RPVs were designed and fabricated to the 1998 Edition (or an earlier edition) of the ASME (formerly the American Society of Mechanical Engineers) Boiler and Pressure Vessel Code ("Code"). The reason for this applicability restriction is because the structural and thermal hydraulic analyses that established the basis for the Alternate PTS Rule embrittlement limits only represented plants constructed before this date. It is the responsibility of a licensee to demonstrate that the risk-significant factors controlling PTS for any plant constructed after February 3, 2010, are adequately addressed by the technical-basis calculations developed in support of the Alternate PTS Rule. Chapter 4 of this document describes methods by which licensees can satisfy these criteria and identifies factors to be considered in such an evaluation.
2. **Criteria relating to evaluation of plant-specific surveillance data:** The Alternate PTS Rule includes statistical tests that must be performed on RPV surveillance data to determine whether the surveillance data are sufficiently close to the predictions of an embrittlement trend curve (ETC) that the predictions of the ETC are valid for use. From a regulatory perspective, it is of particular interest to determine whether plant-specific surveillance data deviate significantly from the predictions of the ETC in a manner that suggests that the ETC is likely to underpredict plant-specific data trends. Chapter 5 of this document describes guidance by which licensees can assess the closeness of plant-specific data to the ETC using statistical tests, including:
  - A detailed description of the mathematical procedures to use to assess compliance with the three statistical tests in the Alternative PTS Rule.
  - A list of factors to consider in diagnosing the reason that particular surveillance data sets might fail these statistical tests.
  - A description of certain situations in which adjustments of the ETC predictions can be made.

- 1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35
3. **Criteria relating to inservice inspection (ISI) data and nondestructive examination (NDE) requirements:** The Alternate PTS Rule describes a number of tests of and conditions on the collection and analysis of ISI data that are intended to provide reasonable assurance that the distribution of flaws that was assumed to exist in the probabilistic fracture mechanics (PFM) calculations that provided the basis for the  $RT_{MAX-X}$  limits provide an appropriate, or bounding, model of the population of flaws in the RPV of interest. Chapter 6 of this document provides guidance by which licensees can satisfy these criteria. The guidance discussed in this NUREG includes the following components:
- Guidance for initial evaluation of NDE data obtained from qualified ISI examinations.
  - Guidance for further evaluation of NDE data obtained from qualified ISI examinations, as follows:
    - i. Elements and NDE techniques associated with the qualified ASME Code, Section XI, Mandatory Appendix VIII ISI examinations performed to assess compliance with the requirements of the Alternate PTS Rule.
    - ii. A mathematical procedure that can be used to adjust NDE data to account for flaw detection and sizing errors and comparison of the adjusted data to the population of flaws assumed in PFM technical basis for the Alternate PTS Rule.
  - Guidance for plants with RPV flaws that fall outside the applicability of the flaw tables in the Alternate PTS Rule, including:
    - i. A mathematical procedure that can be used to preclude brittle fracture based on  $RT_{NDT}$  information.
    - ii. A mathematical procedure that can be used to combine the NDE data with the population of flaws assumed in the PFM calculations to estimate the total flaw distribution that is predicted to exist in the RPV, and guidance on the use of this total flaw distribution as part of a PFM calculation using the Fracture Analysis of Vessels—Oak Ridge (FAVOR) computer code.
4. **Criteria relating to alternate limits on embrittlement:** Guidance is provided by which licensees can estimate a plant-specific value of through-wall cracking frequency (TWCF) for cases in which the  $RT_{MAX-X}$  limits of the Alternate PTS Rule are not satisfied. Chapter 7 of this document describes these two sets of guidance so that licensees can satisfy embrittlement acceptability criteria.

36 This document provides guidance and the associated technical basis for methods by which these  
37 requirements can be met.



1 **ABBREVIATIONS AND ACRONYMS**

---

Abbreviation	Definition
AP	Advanced Passive
APWR	Advanced Pressurized-Water Reactor
ASME	(Not an abbreviation now; formerly stood for the American Society of Mechanical Engineers)
BWR	boiling-water reactor
CFR	<i>Code of Federal Regulations</i>
E	energy
EPR	Evolutionary Power Reactor
EPRI	Electric Power Research Institute
ETC	embrittlement trend curve
FAVOR	Fracture Analysis of Vessels—Oak Ridge
FRN	<i>Federal Register Notice</i>
IGSCC	intergranular stress-corrosion cracking
ISI	inservice inspection
MeV	million electron-Volts
MRP	Materials Reliability Program
NDE	non-destructive examination
NRC	United States Nuclear Regulatory Commission
NRR	Office of Nuclear Reactor Regulation
NSSS	Nuclear Steam Supply System
ORNL	Oak Ridge National Laboratory
PDF	probability density function
PDI	Performance Demonstration Initiative
PFM	Probabilistic Fracture Mechanics
PNNL	Pacific Northwest National Laboratory
POD	probability of detection
PRA	probabilistic risk assessment
PTS	pressurized thermal shock
PVRUF	Pressure Vessel Research User Facility
PWR	pressurized-water reactor
RES	Office of Nuclear Regulatory Research
RPV	reactor pressure vessel
TLR	Technical Letter Report
TWCF	through-wall cracking frequency
TWE	through-wall extent
UT	ultrasonic testing

2  
3



# 1 SYMBOLS AND EXPRESSIONS

Symbol	Definition
A	Multiplier for determining $\Delta T_{30}$ based on product form
ADJ	An adjustment in the embrittlement prediction to account for a failure of the mean test
B	Multiplier for determining $\Delta T_{30}$ based on product form
$C_1$ and $C_2$	Critical values of the outlier test
CRP	Intermediate term for determining $\Delta T_{30}$ in degrees Fahrenheit or Celsius
Cu	Copper content in weight-percent
$Cu_e$	Effective copper content in weight-percent
$f(Cu_e, P)$	Intermediate term for determining $\Delta T_{30}$ based on effective copper content and phosphorus content
$g(Cu_e, Ni, \phi t_e)$	Intermediate term for determining $\Delta T_{30}$ based on effective copper content, nickel content, and effective fluence
m	Slope of $\Delta T_{30}$ prediction residuals plotted vs. the base-10 logarithm of fluence
$Max(Cu_e)$	Intermediate term for determining $\Delta T_{30}$ based on effective copper content
MD	Intermediate term for determining $\Delta T_{30}$ based on degrees Fahrenheit or Celsius
Mn	Manganese content in weight percent
n	Number of $\Delta T_{30}$ observations in a plant-specific surveillance dataset
Ni	Nickel content in weight percent
P	Phosphorus content in weight percent
$r^*$	Normalized residual
$r^*_1$ and $r^*_2$	Calculated values of residuals for the outlier test
$r_{LIMIT(1)}$ and $r_{LIMIT(2)}$	Critical values of the outlier test (same as $C_1$ and $C_2$ )
$r_{max}$	Maximum permissible $\Delta T_{30}$ prediction residual
$r_{mean}$	Mean $\Delta T_{30}$ prediction residual for a plant-specific surveillance dataset
$R_{(max1)}$	The largest $\Delta T_{30}$ prediction residual for a plant-specific surveillance dataset
$R_{(max2)}$	The second-largest $\Delta T_{30}$ prediction residual for a plant-specific surveillance dataset
$RT_{MAX-X}$	Any or all of the material properties $RT_{MAX-AW}$ , $RT_{MAX-PL}$ , $RT_{MAX-FO}$ , $RT_{MAX-CW}$ , or sum of $RT_{MAX-AW}$ and $RT_{MAX-PL}$ for a particular reactor vessel, expressed as a temperature in degrees Fahrenheit ( $^{\circ}F$ ) or Celsius ( $^{\circ}C$ )
$RT_{MAX-AW}$	Material property, expressed as a temperature in degrees Fahrenheit ( $^{\circ}F$ ) or Celsius ( $^{\circ}C$ ), which characterizes the reactor vessel's resistance to fracture initiating from flaws found along axial weld fusion lines
$RT_{MAX-PL}$	Material property, expressed as a temperature in degrees Fahrenheit ( $^{\circ}F$ ) or Celsius ( $^{\circ}C$ ), which characterizes the reactor vessel's resistance to fracture initiating from flaws found in plates remote from welds
$RT_{MAX-FO}$	Material property, expressed as a temperature in degrees Fahrenheit ( $^{\circ}F$ ) or Celsius ( $^{\circ}C$ ), which characterizes the reactor vessel's resistance to fracture initiating from flaws in forgings remote from welds
$RT_{MAX-CW}$	Material property, expressed as a temperature in degrees Fahrenheit ( $^{\circ}F$ ) or Celsius ( $^{\circ}C$ ), which characterizes the reactor vessel's resistance to fracture initiating from flaws found along circumferential weld fusion lines
$RT_{NDT}$	Nil ductility transition temperature in degrees Fahrenheit ( $^{\circ}F$ ) or Celsius ( $^{\circ}C$ )
$RT_{NDT(u)}$	Unirradiated nil ductility transition temperature in degrees Fahrenheit ( $^{\circ}F$ ) or Celsius ( $^{\circ}C$ )
$RT_{PTS}$	The $RT_{NDT}$ value at end of license, as defined in 10 CFR 50.61, in degrees Fahrenheit ( $^{\circ}F$ ) or Celsius ( $^{\circ}C$ )
S	Distance of flaw below surface in inches (in) or millimeters (mm)
se(m)	Standard error of m
$t_e$	Effective time in seconds
$T_C$	Irradiated (coolant) temperature in degrees Fahrenheit ( $^{\circ}F$ ) or Celsius ( $^{\circ}C$ )

1

2 **SYMBOLS AND EXPRESSIONS (concluded)**

3

Symbol	Definition
$T_{CRIT(\alpha)}$	Critical value of Student's t-distribution
$T_m$	T-statistic for m
t, $T_{WALL}$	Wall thickness in inches (in) or millimeters (mm)
t(...)	Student's t-distribution
TWE	Through-wall extent in inches (in) or millimeters (mm)
$TWE_{MAX}$	Maximum through-wall extent in inches (in) or millimeters (mm)
$TWE_{MIN}$	Minimum through-wall extent in inches (in) or millimeters (mm)
$\alpha$	Statistical significance level
$\Delta T_{30}$	Increase in the Charpy-V notch energy transition temperature, in degrees Fahrenheit (°F) or Celsius (°C), at 30 foot-pounds (ft-lb) or 41 Joules (J) caused by neutron-irradiation embrittlement
$\Delta T_{30(ADJ)}$	An adjusted value of $\Delta T_{30}$ in degrees Fahrenheit (°F) or Celsius (°C) that accounts for a failure in the mean slope test
$\Delta T_{30i(measured)}$	A measured value of $\Delta T_{30}$ in degrees Fahrenheit (°F) or Celsius (°C)
$\Delta T_{30i(ETC-mean)}$	A value of $\Delta T_{30}$ predicted by Eqn. (1) in degrees Fahrenheit (°F) or Celsius (°C)
$\Delta YS$	Change in yield strength in thousands of pounds per square inch (ksi) or Megapascals (MPa)
$\phi$	Flux in neutrons per square centimeter per second ( $n/cm^2$ -sec)
$\phi t$	Fluence in neutrons per square centimeter ( $n/cm^2$ )
$\phi t_e$	Effective fluence in neutrons per square centimeter ( $n/cm^2$ )
$\sigma$	Standard deviation in degrees Fahrenheit (°F) or Celsius (°C)

4

5

# 1. INTRODUCTION

---

## 1.1 Background

The United States Nuclear Regulatory Commission (NRC) promulgated Section 50.61a, "Alternate Fracture Toughness Requirements for Protection against Pressurized Thermal Shock Events," of Title 10, "Energy," of the *Code of Federal Regulations* (10 CFR 50.61a) [1] on January 4, 2010, as reported in the *Federal Register* Notice (FRN) 75 FR 13 [2]. 10 CFR 50.61a amended existing regulations to provide alternate fracture toughness requirements for protection against pressurized thermal shock (PTS) events for pressurized-water reactor (PWR) pressure vessels.

The "Alternate PTS Rule" contained in 10 CFR 50.61a provides alternate embrittlement requirements based on more comprehensive analysis methods. This action became desirable because the existing requirements, as contained in 10 CFR 50.61, "Fracture Toughness Requirements for Protection against Pressurized Thermal Shock Events" [3], are based on unnecessarily conservative assumptions. The Alternate PTS Rule reduces regulatory burden for those PWR licensees who expect to exceed the 10 CFR 50.61 embrittlement requirements before the expiration of their operating licenses, while maintaining adequate safety. PWR licensees may choose to comply with the Alternate PTS Rule as a voluntary alternative to complying with the requirements contained in 10 CFR 50.61.

The Alternate PTS Rule provides revised PTS screening criteria in the form of embrittlement reference temperatures,  $RT_{MAX-X}$ , that characterize the reactor pressure vessel (RPV) material's resistance to fracture initiation from flaws. The PTS screening criteria are provided in Table 1 of the Alternate PTS Rule, and are shown in Table 1 of this document. The values shown in Table 1 below are based on up-to-date understandings and models of the many factors affecting the operating safety of PWRs. Further discussion on the provisions and use of the Alternate PTS Rule appear in Chapter 2 of this report.

1  
2  
3  
4

Table 1. RT<sub>MAX-X</sub> PTS Embrittlement Limits from the Alternate PTS Rule

Product form and RT <sub>MAX-X</sub> Values	RT <sub>MAX-X</sub> limits [°F] for different vessel wall thicknesses <sup>6</sup> (T <sub>WALL</sub> )		
	T <sub>WALL</sub> ≤ 9.5 in.	9.5 in. < T <sub>WALL</sub> ≤ 10.5 in.	10.5 in. < T <sub>WALL</sub> ≤ 11.5 in.
Axial Weld RT <sub>MAX-AW</sub> .....	269	230	222
Plate RT <sub>MAX-PL</sub> .....	356	305	293
Forging without underclad cracks RT <sub>MAX-FO</sub> <sup>7</sup> .....	356	305	293
Axial Weld and Plate RT <sub>MAX-AW + RT<sub>MAX-PL</sub></sub> .....	538	476	445
Circumferential Weld RT <sub>MAX-CW</sub> <sup>8</sup> .....	312	277	269
Forging with underclad cracks RT <sub>MAX-FO</sub> <sup>9</sup> ...	246	241	239

5

<sup>6</sup> Wall thickness is the beltline wall thickness including the clad thickness.

<sup>7</sup> Forgings without underclad cracks apply to forgings for which no underclad cracks have been

detected and that were fabricated in accordance with Regulatory Guide 1.43.

<sup>8</sup> RT<sub>PTS</sub> limits contribute  $1 \times 10^{-8}$  per reactor year to the reactor vessel TWCF.

<sup>9</sup> Forgings with underclad cracks apply to forgings that have detected underclad cracking or were not fabricated in accordance with Regulatory Guide 1.43.

6  
7

## 1.2 Scope of this Report

The  $RT_{MAX-X}$  embrittlement limits shown in Table 1 may be used by licensees provided that certain criteria are met, as outlined in the Alternate PTS Rule. This document explains the basis for these requirements (which establish the entry conditions to permit use of the Alternate PTS Rule) and describes methods by which the following four requirements can be met:

1. **Criteria relating to the date of construction and design requirements:**  
Paragraph (b) of 10 CFR 50.61a restricts the applicability of the Alternate PTS Rule to reactors for which a construction permit was issued before February 3, 2010, and whose RPV was designed and fabricated to the 1998 Edition, or earlier, of the ASME (formerly the American Society of Mechanical Engineers) Boiler and Pressure Vessel Code (“Code”). Chapter 4 of this document describes the criteria related to the date of plant construction by which licensees can make use of the Alternate PTS Rule.
2. **Criteria relating to evaluation of plant-specific surveillance data:** Paragraph (f) of the Alternate PTS Rule requires that the licensee verify that plant-specific surveillance data for the RPV in question satisfy three statistical tests described in the Alternate PTS Rule. These tests assess whether or not the plant-specific surveillance data are adequately predicted by the embrittlement trend curve (ETC) used in the Alternate PTS Rule. If this verification cannot be made, the licensee is required to submit an evaluation of plant-specific surveillance data to the Director of the NRC Office of Nuclear Reactor Regulation (NRR) that proposes a method to account for plant-specific surveillance data when assessing the subject RPV relative to the Alternate PTS Rule limits on  $RT_{MAX-X}$ . Chapter 5 of this document describes methods by which licensees can satisfy these criteria.
3. **Criteria relating to inservice inspection (ISI) data and non-destructive examination (NDE) requirements:** Paragraph (e) of the Alternate PTS Rule requires that the licensee verify that the flaw density and size distributions detected within the beltline region of the RPV during a qualified examination under Section XI of the ASME Code [4] are bounded by flaw tables contained within the Alternate PTS Rule. The Alternate PTS Rule requires that any flaws detected within the inner 1 inch or 10 percent of the wall thickness of the vessel base material, whichever is greater, do not exceed the limits shown in Table 2. If this verification cannot be made, the licensee must demonstrate that the RPV will have a through-wall cracking frequency (TWCF) of less than  $1 \times 10^{-6}$  per reactor year. Chapter 6 of this document describes methods by which licensees can satisfy these criteria.
4. **Criteria relating to alternate limits on embrittlement:** Chapter 7 of this document describes criteria by which licensees can assess plant-specific TWCF for cases in which the  $RT_{MAX-X}$  limits of the Alternate PTS Rule are not satisfied.

References to the “beltline” region of the RPV throughout this report refer to all regions of the RPV adjacent to the reactor core that are exposed to a fluence of  $1 \times 10^{17}$  n/cm<sup>2</sup> or higher during the operating lifetime of the reactor [25]. Fluence values should be determined in accordance with methodology consistent with that specified in Regulatory Guide 1.190 [27] or using methods otherwise acceptable to the staff.

The NRC solicited input from interested stakeholders regarding an Alternate PTS regulation during three public meetings in 2011 [17]. The Materials Reliability Program (MRP) developed

1 recommended technical methods or approaches in seven areas. Those recommended  
2 technical methods are described in MRP-334 [10] and were provided to reduce the resources  
3 needed by utilities and the NRC to implement the Alternate PTS Rule, as well as to provide a  
4 consistent and acceptable level of safety subsequent to Rule implementation, especially in  
5 those instances in which alternate evaluations are required to demonstrate compliance with the  
6 Alternate PTS Rule. NRC responses to the recommendations made in MRP-334 are discussed  
7 in Chapter 3.

8  
9



1  
2  
3

Table 2. Flaw Limit Tables from the Alternate PTS Rule

Through-wall extent, TWE [in.]		Maximum number of flaws per 1000-inches of weld length in the inspection volume that are greater than or equal to $TWE_{MIN}$ and less than $TWE_{MAX}$
$TWE_{MIN}$	$TWE_{MAX}$	
0	0.075	No Limit
0.075	0.475	166.70
0.125	0.475	90.80
0.175	0.475	22.82
0.225	0.475	8.66
0.275	0.475	4.01
0.325	0.475	3.01
0.375	0.475	1.49
0.425	0.475	1.00
0.475	Infinite	0.00

4  
5  
5

Through-wall extent, TWE [in.]		Maximum number of flaws per 1000 square-inches of inside surface area in the inspection volume that are greater than or equal to $TWE_{MIN}$ and less than $TWE_{MAX}$ . This flaw density does not include underclad cracks in forgings.
$TWE_{MIN}$	$TWE_{MAX}$	
0	0.075	No Limit
0.075	0.375	8.05
0.125	0.375	3.15
0.175	0.375	0.85
0.225	0.375	0.29
0.275	0.375	0.08
0.325	0.375	0.01
0.375	Infinite	0.00

6  
7



## 2. OVERVIEW OF THE ALTERNATE PTS RULE

---

### 2.1 Background

PTS events are system transients in a PWR during which there is a rapid cooldown that results in cold vessel temperatures with or without repressurization of the RPV. The rapid cooling of the inside surface of the RPV causes thermal stresses which can combine with stresses caused by high pressure. The aggregate effect of these stresses is an increase in the potential for fracture if a pre-existing flaw is present in a region of the RPV having significant embrittlement.

The PTS Rule, described in 10 CFR 50.61, establishes screening criteria below which the potential for a RPV to fail because of a PTS event is deemed to be acceptably low. These screening criteria effectively define a limiting level of embrittlement beyond which operation cannot continue without further plant-specific compensatory action or analysis unless the licensee receives an exemption from the requirements of 10 CFR 50.61. Some compensatory actions are neutron-flux reduction, plant modifications to reduce the PTS event probability or severity, and RPV annealing, which are addressed in 10 CFR 50.61(b)(3), (b)(4), and (b)(7) and in 10 CFR 50.66, "Requirements for Thermal Annealing of the Reactor Pressure Vessel" [5].

Currently, no operating PWR RPV is projected to exceed the 10 CFR 50.61 screening criteria before the expiration of its original 40-year operating license. However, several PWR RPVs are approaching the screening criteria, while others are likely to exceed the screening criteria during the period of license renewal.

The NRC developed technical bases that support updating the PTS regulations (see References [6], [7], [8], [9], and [14]). These technical bases concluded that the risk of through-wall cracking because of a PTS event is much lower than previously estimated. This finding indicated that the screening criteria in 10 CFR 50.61 are unnecessarily conservative. Therefore, the NRC developed 10 CFR 50.61a, the Alternate PTS Rule, which provides alternate screening criteria based on the updated technical bases. These technical bases covered the following topics:

- a. Applicability of the Alternate PTS Rule;
- b. Updated embrittlement correlation;
- c. ISI volumetric examination and flaw assessments;
- d. NDE-related uncertainties; and
- e. Surveillance data.

A brief overview of these topics is provided in the following sections.

In addition, seven subsequent requirements that licensees must satisfy as a part of implementation of the Alternate PTS Rule are defined in paragraph (d) of 10 CFR 50.61a.

### 2.2 Applicability of the Alternate PTS Rule

The Alternate PTS Rule is based, in part, on analysis of information from three currently operating PWRs. Because the severity of the risk-significant transient classes (e.g., primary-side pipe breaks and stuck-open valves on the primary side that may later reclose) is controlled by factors that are common to PWRs in general, the NRC concluded that the results and screening criteria developed from these analyses could be applied with confidence to the entire fleet of operating PWRs. This

1 conclusion was based on an understanding of the characteristics of the dominant transients that  
2 drive their risk significance and on an evaluation of a larger population of high-embrittlement PWRs.  
3 This evaluation revealed no design, operational, training, or procedural factors that could credibly  
4 increase either the severity of these transients or the frequency of their occurrence in the general  
5 PWR population above the severity and frequency characteristic of the three plants that were  
6 modeled in detail. The NRC also concluded that PTS events that were insignificant risk contributors  
7 in these analyses are not expected to become dominant contributors in other plants.  
8

9 The Alternate PTS Rule is applicable to licensees whose construction permits were issued before  
10 February 3, 2010, and whose RPVs were designed and fabricated to the 1998 Edition or an earlier  
11 edition of the ASME Code.  
12

## 13 **2.3 Updated Embrittlement Correlation**

14 The technical basis for the Alternate PTS Rule used many different models and parameters to  
15 estimate the yearly probability that a PWR will develop a through-wall crack as a consequence of  
16 PTS loading. One of these models was a revised ETC that uses information on the chemical  
17 composition and neutron exposure of low-alloy steels in the RPV beltline region to estimate the  
18 fracture-mode transition temperature of these materials. Although the general trends predicted by  
19 the embrittlement models in 10 CFR 50.61 and the Alternate PTS Rule are similar, the mathematical  
20 form of the revised ETC in the Alternate PTS Rule differs substantially from the ETC in  
21 10 CFR 50.61. The ETC in the Alternate PTS Rule was updated to more accurately represent the  
22 substantial amount of RPV surveillance data that has accumulated between the last revision of the  
23 10 CFR 50.61 ETC in the mid-1980s and the database supporting the 10 CFR 50.61a ETC, which  
24 was finalized in 2002. The specifics of the updated ETC used in the Alternate PTS Rule are  
25 discussed in Section 5.1.  
26

## 27 **2.4 ISI Volumetric Examination and Flaw Assessments**

28 The Alternate PTS Rule differs from 10 CFR 50.61 in that it requires licensees who choose to follow  
29 its requirements to analyze the results from ISI volumetric examinations done in accordance with  
30 Section XI, "Inservice Inspection of Nuclear Power Plant Components," of the ASME Code. The  
31 analyses of ISI volumetric examinations may be used to determine whether the flaw density and  
32 size distribution in the licensee's RPV beltline region are bounded by the flaw density and size  
33 distribution used in the development of the Alternate PTS Rule.  
34

35 The Alternate PTS Rule was developed using a flaw density, spatial distribution, and size  
36 distribution determined from experimental data, as well as from physical models and expert  
37 judgment. The experimental data were obtained from samples removed from RPV materials from  
38 cancelled plants (i.e., from the Shoreham and the Pressure Vessel Research Users Facility  
39 (PVRUF) vessels). The NRC considers that comparison of the results from qualified ASME Code  
40 Section XI ISI volumetric examination is needed to confirm that the flaw density and size  
41 distributions in the RPV to which the Alternate PTS Rule may be applied are consistent with the flaw  
42 density and size distribution used in the development of the Alternate PTS Rule.  
43

44 Paragraph (g)(6)(ii)(C) in 10 CFR 50.55a, "Codes and Standards" [11], requires licensees to  
45 implement ISI examinations in accordance with Supplements 4 and 6

46 [12] to Mandatory Appendix VIII to Section XI of the ASME Code. Supplement 4 contains  
47 qualification requirements for the RPV ISI volume from the clad-to-base-metal interface to the  
48 inner 15 percent of the RPV base material wall thickness. Supplement 6 contains qualification

1 requirements for RPV weld volumes that lie within the outer 85% of the RPV base material wall  
2 thickness.

3  
4 A simplified representation of the flaw density and size distribution used in the development of the  
5 Alternate PTS Rule is summarized by numerical values in Tables 2 and 3 of the Alternate PTS Rule  
6 for weld and plate/forging materials, respectively, as duplicated in Table 2. Hereafter, Tables 2  
7 and 3 of the Alternative PTS rule are referred to, collectively, as “the flaw tables.” These limits  
8 represent the number of flaws in each size range that were evaluated in the underlying technical  
9 bases. If a distribution of flaws having size and density greater than that of the flaw tables is found  
10 in a RPV, those flaws must be evaluated to ensure that they are not causing the TWCF to exceed a  
11 value of  $1 \times 10^{-6}$ .

12  
13 The technical basis for the Alternate PTS Rule also indicated that flaws buried more deeply than  
14 1 inch from the clad-to-base interface are not as susceptible to brittle fracture as flaws of similar size  
15 located closer to the inner surface. Therefore, the Alternate PTS Rule does not require an  
16 assessment of the density of these flaws, but still requires large flaws, if discovered, to be evaluated  
17 for contributions to TWCF if they are within the inner three-eighths of the vessel base material wall  
18 thickness. Section II, “Discussion,” of the January 4, 2010, Federal Register Notice [2] for the  
19 Alternate PTS Rule indicates that the limitation for flaw acceptance, specified in Table IWB-3510-1  
20 in Section XI of the ASME Code, approximately corresponds to the threshold for the sizes of flaws  
21 that can make a significant contribution to TWCF if they are present in RPV material at this depth.  
22 Therefore, the Alternate PTS Rule requires that flaws exceeding the size limits in Table IWB-3510-1  
23 be evaluated for contribution to TWCF in addition to the other evaluations for such flaws that are  
24 prescribed in the ASME Code.

25  
26 The Alternate PTS Rule also clarifies that, to be consistent with Mandatory Appendix VIII to  
27 Section XI of the ASME Code, the smallest flaws that must be sized are 0.075 inch in through-wall  
28 extent (TWE). For each flaw detected that has a TWE equal to or greater than 0.075 inch, the  
29 licensee is required to document the dimensions of the flaw, its orientation, its location within the  
30 RPV, and its depth from the clad-to-base-metal interface. Those planar flaws for which the major  
31 axis of the flaw is identified by a circumferentially-oriented ultrasonic transducer must be categorized  
32 as “axial.” All other planar flaws may be categorized as “circumferential.” If there is uncertainty  
33 about which flaw dimension constitutes the major axis for a given flaw identified with an ultrasonic  
34 transducer oriented in the circumferential direction, it should be considered as an axial flaw. The  
35 NRC may also use this information to evaluate whether plant-specific information gathered suggests  
36 that the NRC staff should generically re-examine the technical basis for the Alternate PTS Rule.

37  
38 Surface cracks that penetrate through the RPV stainless steel clad and more than 0.070 inch into  
39 the welds or the adjacent RPV base metal were not included in the technical basis for the Alternate  
40 PTS Rule because these types of flaws have not been observed in the beltline of any operating  
41 PWR vessel. However, flaws of this type were observed in a boiling-water reactor (BWR) RPV  
42 head in 1990 that were attributed to intergranular stress-corrosion cracking (IGSCC) of the stainless  
43 steel cladding. BWRs are not susceptible to PTS events and hence are not subject to the  
44 requirements of 10 CFR 50.61. However, if similar cracks were found in the beltline region of a  
45 PWR, they would be a significant contributor to TWCF because of their size and location. As a  
46 result, the Alternate PTS Rule requires licensees to determine whether cracks of this type exist in  
47 the beltline weld region as a part of each required ASME Code Section XI ultrasonic examination.  
48

## 2.5 NDE-Related Uncertainties

The flaw sizes shown in Table 2 represent actual flaw dimensions, while the results from ASME Code Section XI examinations are estimated dimensions. The available information indicates that, for most flaw sizes in Table 2, qualified inspectors will oversize flaws. Comparing oversized flaws to the size and density distributions in Table 2 is conservative, but not necessary.

As a result of stakeholder feedback received during the NRC's solicitation for public comments on a preliminary draft of the Alternate PTS Rule, the final published Alternate PTS Rule permits licensees to adjust the flaw sizes estimated by inspectors qualified under Supplements 4 and 6 to Mandatory Appendix VIII to Section XI of the ASME Code. The NRC also determined that licensees should be allowed to consider other NDE uncertainties, such as probability of detection (POD) and flaw density and location, because these uncertainties may affect the ability of a licensee to demonstrate compliance with the Alternate PTS Rule. As a result, the language in 10 CFR 50.61a(e) allows licensees to account for the effects of NDE-related uncertainties in meeting the flaw size and density requirements of Table 2. The Alternate PTS Rule does not provide specific guidance on a methodology to account for the effects of NDE-related uncertainties, but notes that accounting for such uncertainties may be based on data collected from ASME Code inspector-qualification tests or any other tests that measure the difference between the actual flaw size and the size determined from the ultrasonic examination. Because collecting, evaluating, and using data from ASME Code inspector-qualification tests requires extensive engineering judgment, the Alternate PTS Rule requires that the methodology used to adjust flaw sizes to account for the effects of NDE-related uncertainties be reviewed and approved by the Director of NRR.

## 2.6 Surveillance Data

Paragraph (f) of the Alternate PTS Rule defines the process for calculating the values for the reference temperature,  $RT_{MAX-X}$ , for a particular RPV material. These values may be based on the RPV material's copper (Cu), manganese (Mn), phosphorus (P), and nickel (Ni) weight percentages, reactor cold-leg coolant temperature, and fast neutron flux and fluence values, as well as the unirradiated nil-ductility transition reference temperature,  $RT_{NDT}$ .

The Alternate PTS Rule includes a procedure by which the  $RT_{MAX-X}$  values, which are predicted for plant-specific RPV materials using an ETC, are compared to heat-specific surveillance data that are collected as part of surveillance programs under Appendix H, "Reactor Vessel Material Surveillance Requirements"

[13], to 10 CFR Part 50. The purpose of this comparison is to assess how well the surveillance data are represented by the ETC. If the surveillance data are close (closeness is assessed statistically) to the ETC, the predictions of this ETC are used. This is expected to be the case most often. However, if the heat-specific surveillance data deviate significantly and non-conservatively from the predictions of the ETC, this indicates that alternative methods (i.e., other than the ETC) may be needed to reliably predict the temperature-shift trend (and to estimate  $RT_{MAX-X}$ ) for the conditions being assessed. Therefore, the Alternate PTS Rule includes three statistical tests to determine the significance of the differences between heat-specific surveillance data and the ETC.

### 3. RESPONSES TO STAKEHOLDER FEEDBACK

---

The NRC solicited input from interested stakeholders regarding an Alternate PTS Implementation Regulatory Guide during three of public meetings in 2011 [17]. Based on those meetings, the Electric Power Research Institute's (EPRI's) Materials Reliability Program (MRP) developed recommended technical methods or approaches that would be useful for Alternate PTS Rule implementation in seven areas. Those recommended technical methods are described in MRP-334 [10]. That report provided fifteen specific recommendations that might reduce the resources needed by utilities and the NRC to implement the Alternate PTS Rule. In addition, EPRI stated that the recommendations would provide a consistent and acceptable level of safety subsequent to Alternate PTS Rule implementation, especially in those instances where evaluations are required to demonstrate compliance with the Alternate PTS Rule.

EPRI's recommendations from MRP-334 are included in Table 3. The NRC responses to the recommendations made in MRP-334 are shown in the last column of the table. As indicated by some of the responses to EPRI's recommendations, some of the guidance established in this document was adjusted for further clarification.

1 Table 3. EPR1 Recommendations for Addressing Alternate PTS Rule Requirements [10]

No.	10 CFR 50.61a Paragraph	MRP-334 Recommendation	MRP-334 Justification	NRC Response
1	(f)(6), (a)(10)	Adjustments should not be made to sister-plant $\Delta T_{30}$ values for the purposes of performing the surveillance data tests in 10 CFR 50.61a.	The 10 CFR 50.61a ETC directly takes into consideration the material properties and the irradiation temperature in the calculation of $\Delta T_{30}$ and the residual for each point of plant or sister-plant data. Additional detail is provided in Section 3.1.	The NRC agrees with the comment. Sister-plant data are used as part of the surveillance data set (see Step (1a) of the surveillance procedure), but no adjustments to the data are made.
2	(f)(6), (a)(10)	Limitations should be placed on the variation in chemistry within a weld heat that must be considered when considering sister-plant data.	An example of a weld heat with significant variation is shown in Appendix A of this report. Additional discussion is provided in Section 3.1.	The NRC agrees that variations in composition should be considered if there is a need to explain/understand deviations identified by the statistical tests that are required for surveillance data. This is pointed out in Step 2(d)(ii)(a) in the section entitled "Factors to Consider when the Statistical Tests of Step 2 are Failed" under the heading "Composition and Exposure Variables." Specific limits are not provided; these should be justified on a case-specific basis.
3	(f)(6)(vi), (a)(11)	If the surveillance data tests cannot be met using exact time weighted average $T_C$ values, a tolerance that is equivalent to plus or minus one half of the range of the operating temperatures over the irradiation time should be considered. If the surveillance data tests can be satisfied by using a temperature within this tolerance range on $T_C$ , adjustment to $\Delta T_{30}$ values should not be required.	Large differences in irradiation temperature can also have significant effects on the calculated $\Delta T_{30}$ values. 10 CFR 50.61a defines TC as a time-weighted average of the cold-leg temperature under normal full-power operating conditions. However, the values used in the development of the ETC may not have reflected an accurate time-weighted average for each specific plant. This tolerance accounts for the uncertainty in the actual operating temperature when the largest changes in the embrittlement index occurred. Additional discussion is provided in Section 3.1.	The NRC agrees that variations in cold-leg temperature should be considered if there is a need to explain/understand deviations identified by the statistical tests that are required for surveillance data. This is pointed out in Step 2(d)(ii)(a) in the section entitled "Factors to Consider when the Statistical Tests of Step 2 are Failed" under the heading "Composition and Exposure Variables." Specific limits are not provided; these should be justified on a case-specific basis.



No.	10 CFR 50.61a Paragraph	MRP-334 Recommendation	MRP-334 Justification	NRC Response
4	(f)(6)(vi), (f)(6)(v)(A), (f)(6)(v)(C)	A procedure is recommended in Section 3.2 of the report for calculating the $\Delta T_{30}$ adjustment to meet the requirements of Paragraph (f)(6)(vi) when either the mean or outlier statistical tests are failed when applying the requirements of Paragraph (f)(6)(v) of 10 CFR 50.61a.	The surveillance capsule data (SCD) statistical tests in (f)(6) can be overly conservative, so any needed adjustments to $\Delta T_{30}$ and $RT_{MAX}$ for failing the SCD statistical tests should be minimal. The proposed procedure is simple to implement and addresses the concerns with deviation from the ETC without excessive conservatism. Additional discussion is provided in Section 3.2.	<p>The NRC adopted this recommendation to address failures of the mean test. Refer to Step 2(b)(i).</p> <p>The NRC adopted a different approach to address outlier failures caused by a low fluence datum. Refer to Step 2(b)(ii). The NRC does not disagree with the proposed procedure for outlier failures, but considers that use of this procedure should be justified on a case-specific basis.</p>
5	(f)(6)(vi), (f)(6)(v)(B)	An industry-consensus ETC that addresses irradiation-induced shifts caused by fluence values up to $1 \times 10^{20}$ n/cm <sup>2</sup> ( $E > 1$ MeV) should be used to calculate the predicted values of $\Delta T_{30}$ if the slope test is not satisfied.	Data from several plants, with fluence exposures of up to $8.5 \times 10^{19}$ n/cm <sup>2</sup> , have been evaluated and no slope-test deviations were encountered. It is possible that high-fluence surveillance capsule data could fail the statistical slope test. The industry has developed a Coordinated Surveillance program in order to obtain high fluence data from power reactors. The intent is to use this data to develop an industry-consensus ETC that addresses irradiation-induced shifts caused by fluence values up to $1 \times 10^{20}$ n/cm <sup>2</sup> ( $E > 1$ MeV). Additional discussion is provided in Section 3.3.	<p>As of the current date, an ETC agreed on by broad consensus between the NRC and industry stakeholders does not exist. Also, the data from the coordinated surveillance program will not be available in large quantities until 2025.</p> <p>The NRC agrees that, in the event of a slope-test failure, the best current understanding of irradiation damage mechanics should be used to help explain the failure and suggest corrective actions. However, because technical consensus on this matter has not been reached, the NRC is not providing guidance on this matter.</p> <p>As discussed in Step 2(d) of the Regulatory Guide, the NRC agrees that there are many situations in which adjustment of the <math>\Delta T_{30}</math> values is neither needed nor justifiable. Some of these situations are discussed in Step 2(d). However, specific exceptions are not provided; these should be justified on a case-specific basis.</p>
6	(f)(6)(vi), (f)(6)(v)(A), (f)(6)(v)(B), (f)(6)(v)(C)	Recommendations for possible criteria for not adjusting $\Delta T_{30}$ values in accordance with (f)(6)(vi) when the tests of (f)(6)(v)(A), (B), and (C) cannot be satisfied are provided in Section 3.4.	There are several scenarios where an adjustment to $\Delta T_{30}$ values would not be appropriate. These scenarios and criteria are discussed in Section 3.4.	<p>As discussed in Step 2(d) of the Regulatory Guide, the NRC agrees that there are many situations in which adjustment of the <math>\Delta T_{30}</math> values is neither needed nor justifiable. Some of these situations are discussed in Step 2(d). However, specific exceptions are not provided; these should be justified on a case-specific basis.</p>

No.	10 CFR 50.61a Paragraph	MRP-334 Recommendation	MRP-334 Justification	NRC Response
7	(d)(4), (c)(3)	<p>A provision should be included in the proposed Regulatory Guide for direct calculation of <math>TWCF_{95-TOTAL}</math> using the plant-specific <math>RT_{MAX-XX}</math> values for cases in which the <math>RT_{MAX-XX}</math> limits in Table 1 of 10 CFR 50.61a cannot be met.</p>	<p>There are some conservatisms in the <math>RT_{MAX-XX}</math> screening limits. Also, plate and forging limited plants are likely to reach the more restrictive limit for circumferential welds before reaching the plate or forging limits. Additional discussion is provided in Section 3.5</p>	<p>The NRC agrees with this recommendation. Guidance was added to the Regulatory Guide as Position 4 that refers to the appropriate formulae and methods in Section 3.5.1 of NUREG-1874.</p>
8	(e)(1)	<p>Any small flaws detected by ISI within +0.5 inch of the outer boundaries of the ASME Section XI inspection volume can be treated as potential plate flaws. All other flaws within the inspection volume should be treated as weld flaws.</p>	<p>The plate flaw limits in Table 3 of 10 CFR 50.61a should only be evaluated for RPV base metal flaws not affected by welding that are detected by ISI. Additional discussion is provided in Section 3.6.</p>	<p>The NRC agrees with this comment. Guidance for establishing whether the flaws are in the plate or the weld is included in this NUREG (see Step D in Section 6.1).</p>
9	(e)(1)	<p>Plate flaws that have a depth (TWE) of 0.4 inch or more should be evaluated as weld flaws.</p>	<p>This is needed to ensure that the small flaws created during fabrication of the plates and forgings, which is what was simulated in the FAVOR probabilistic fracture mechanics analysis code, have not been expanded to larger-sized flaws by the effects of welding, which were simulated by FAVOR as weld flaws. Additional discussion is provided in Section 3.6.</p>	<p>The NRC disagrees with this recommendation because it is arbitrary. A case-specific justification would need to be developed to demonstrate why a plate flaw should be recategorized as a weld flaw.</p>

No.	10 CFR 50.61a Paragraph	MRP-334 Recommendation	MRP-334 Justification	NRC Response
10	(e)(4)(i)	The proposed Regulatory Guide should provide criteria or methods for determining whether the deviation in flaw limits will have a detrimental effect on the applicability of the PTS Screening Criteria in Table 1 of 10 CFR 50.61a.	Such criteria would reduce burden on both the NRC and industry while providing an acceptable level of safety and quality. Additional discussion is provided in Section 3.7 and Appendix E.	The NRC agrees with this comment. Both simplified and more detailed procedures are given in Step 3(i) of the Regulatory Guide that address evaluations that may be performed when the flaw limits are exceeded. The industry may choose to justify alternatives to these procedures on a case-specific basis.
11	(e)(4)(i)	Deviations to the flaw limits for plants that have low embrittlement should be generically allowed. Low embrittlement can be defined as having $RT_{MAX-X}$ values that are equivalent to or less than a TWCF of 1% of the PTS risk objective, or approximately $1 \times 10^{-8}$ events per year.	The vessel material at these plants would still have high enough fracture toughness that even large increases in the number of flaws above the 10 CFR 50.61a limits would not result in reaching the PTS risk objective of $1 \times 10^{-6}$ events per year. Additional discussion is provided in Section 3.7.	The NRC disagrees with this recommendation and the associated justification. If the flaw limits are failed, it would be inappropriate to use the relationships between TWCF and $RT_{MAX-X}$ that depend on these limits being correct to address the issue. Simplified criteria for assessing brittle fracture are provided in the Regulatory Guide that may be used in this situation or, alternatively, another valid case-specific solution may be proposed.

No.	10 CFR 50.61a Paragraph (e)(1)	MRP-334 Recommendation	MRP-334 Justification	NRC Response
12	The flaw limits in Tables 2 and 3 of 10 CFR 50.61a should be applied to axial flaws only.	This proposed approach addresses what the real technical concern should be; that is, the maximum number of axial flaws that could lead to potential vessel failure. Additional discussion is provided in the flaw-orientation discussion in Section 3.7.1.	The NRC disagrees with this comment. All flaws, whether axial or circumferential, are considered in the comparison to Tables 2 and 3 of 10 CFR 50.61a because under subpart (e), "Examination and Flaw Assessment Requirements," paragraph (e)(1)(iii) states:  “(iii) For each flaw detected in the inspection volume described in paragraph (e)(1) with a through-wall extent equal to or greater than 0.075 inches, the licensee shall document the dimensions of the flaw, including through-wall extent and length, whether the flaw is axial or circumferential in orientation and its location within the reactor vessel, including its azimuthal and axial positions and its depth embedded from the clad-to-base-metal interface.”  Paragraph (e)(4) states, in part:  “(4) The licensee shall perform analyses to demonstrate that the reactor vessel will have a TWCF of less than $1 \times 10^{-6}$ per reactor year if the ASME Code, Section XI volumetric examination required by paragraph (c)(2) or (d)(2) of this section indicates any of the following: “(i) The flaw density and size in the inspection volume described in paragraph (e)(1) exceed the limits in Tables 2 or 3 of this section. [...]”	

No.	10 CFR 50.61a Paragraph	MRP-334 Recommendation	MRP-334 Justification	NRC Response
13	(e)(1), (e)(4)	A qualitative assessment process should be provided for addressing a flaw that exceeds the maximum size allowed in the flaw limit tables but is less than 0.875" in through-wall extent.	A qualitative process that considers flaw orientation, flaw location, flaw size, and material properties is proposed in Section 3.7.1.	The NRC agrees with this comment. The recommendation is addressed in Step I of the Regulatory Guide.
14	(e)(1), (e)(4), (e)(5)	A quantitative assessment process should be provided (a) for instances in which multiple flaws exceed the flaw limit tables or (b) if the requirements of the qualitative process cannot be satisfied.	A quantitative process that considers the contribution of individual flaws to the total vessel TWCF is provided in Section 3.7.2. If needed, an additional process that reduces some of the conservatism in the Section 3.7.2 process is provided in Appendix F.	The NRC agrees with this comment. The recommendation is addressed in Step I of the Regulatory Guide.
15	(e)(1)	When assessing the flaw-limit tables, multiple flaws that are combined into one flaw in accordance with the ASME Section XI proximity rules should not be counted as multiple ISI flaws.	The ASME Section XI proximity rules were considered in the development of the flaw distributions used in the technical basis for 10 CFR 50.61a. Additional discussion is provided in Section 3.7.2.	The NRC agrees with this comment. Flaw proximity is considered in the Regulatory Guide, as indicated in Figure 3.



## 4. GUIDANCE FOR CRITERIA RELATING TO THE DATE OF CONSTRUCTION AND DESIGN REQUIREMENTS

---

The Alternate PTS Rule is applicable to plants with construction permits issued before February 3, 2010, and with RPVs designed and fabricated in accordance with the 1998 Edition or an earlier edition of the ASME Code. This chapter provides guidelines and supporting bases for this requirement.

### 4.1 Requirements in the Alternate PTS Rule

Paragraph (b), "Applicability," of the Alternate PTS Rule identifies that the Alternate PTS Rule is applicable for plants for which a construction permit was issued after February 3, 2010. Section II, "Discussion," of the January 4, 2010, Federal Register Notice [2] includes the following:

*...The final rule is applicable to licensees whose construction permits were issued before February 3, 2010 and whose reactor vessels were designed and fabricated to the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), 1998 Edition or earlier. This would include applicants for plants such as Watts Bar Unit 2 who have not yet received an operating license. However, it cannot be demonstrated, a priori, that reactor vessels that were not designed and fabricated to the specified ASME Code editions will have material properties, operating characteristics, PTS event sequences and thermal hydraulic responses consistent with those evaluated as part of the technical basis for this rule. Therefore, the NRC determined that it would not be prudent at this time to extend the use of the rule to future PWR plants and plant designs such as the Advanced Passive (AP) 1000, Evolutionary Power Reactor (EPR) and U.S. Advanced Pressurized Water Reactor (US-APWR). These designs have different reactor vessels than those in the currently operating plants, and the fabrication of the vessels based on these designs may differ from the vessels evaluated in the analyses that form the bases for the final rule. Licensees of reactors who commence commercial power operation after the effective date of this rule or licensees with reactor vessels that were not designed and fabricated to the 1998 Edition or earlier of the ASME Code may, under the provisions of § 50.12, seek an exemption from § 50.61a(b) to apply this rule if a plant-specific basis analyzing their plant operating characteristics, materials of fabrication, and welding methods is provided....*

Regulatory guidance for the above requirements is discussed in the next section.

### 4.2 Regulatory Guidance

The purpose of the restriction given in Section 4.1 on the applicability of the Alternate PTS Rule embrittlement limits is that the structural and thermal hydraulic analyses that established the basis for the Alternate PTS Rule only represented plants constructed before February 3, 2010. A licensee that applies the Alternate PTS Rule to a plant with a construction permit issued after February 3, 2010, must demonstrate that the risk-significant factors controlling PTS for the plant in question are adequately addressed by the technical-bases calculations, which are detailed in NUREG-1806 [6] and its supporting technical references. Factors to be considered in this evaluation should include, but might not be limited to, the following:

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11

- the event sequences that may lead to overcooling of the RPV;
- the thermal-hydraulic response of the nuclear steam supply system (NSSS) in response to such sequences;
- Characteristics of the RPV design (e.g., vessel diameter, vessel wall thickness, and operating pressure) that influence the stresses that develop in the beltline region of the vessel (as defined in Section 1.2) in response to the event sequences; and
- Characteristics of the RPV materials and their embrittlement behavior.



## 5. GUIDANCE FOR CRITERIA RELATING TO THE EVALUATION OF PLANT-SPECIFIC SURVEILLANCE DATA

---

The information in this chapter was developed and published in support of the development of the Alternate PTS Rule. Relevant information from this work is repeated here for completeness and clarity [14]. In some cases, the information in Reference [14] is further clarified here compared to the technical bases supporting the Alternate PTS Rule. Additionally, the information presented in this chapter adds to that from Reference [14] in two respects: in Section 5.2 procedures for data grouping (e.g., treatment of “sister plant” data) before performing the statistical tests are described, and Section 5.6.2 describes procedures that can be used if the statistical tests are failed.

In this chapter, procedures are described by which the plant-specific surveillance data that are collected as part of surveillance programs (in accordance with Appendix H to 10 CFR 50) can be analyzed to assess how well they are represented by the ETC for  $\Delta T_{30}$  adopted in the Alternate PTS Rule. If the surveillance data are “close” (closeness is assessed statistically) to the prediction of the ETC, the predictions of the ETC are used. Statistically significant differences between plant-specific data sets and the ETC prediction identify situations in which more focused attention is warranted, and are taken as an indication that methods other than, or in addition to, the ETC may be needed to predict  $\Delta T_{30}$  trends. While standard statistical procedures exist to assess the significance of differences between individual data sets and ETC predictions, similarly standard procedures are not as commonly available to assess the practical importance of such differences, or to adjust the data to account for these differences. This chapter concludes with discussions of (1) factors that may be considered if the statistical tests are failed and (2) procedures that could be used to adjust the predictions of the ETC in certain circumstances.

The remainder of this chapter is divided into six sections, as follows:

- Section 5.1 describes the  $\Delta T_{30}$  ETC. Details on the development of this ETC appear in ORNL/TM-2006/530 [9].
- Section 5.2 describes entry conditions that need to be met to use the proposed surveillance assessment procedure.
- Section 5.3 describes different types of deviations between plant-specific surveillance data and the trends represented by the  $\Delta T_{30}$  ETC from Reference [9].
- Section 5.4 describes procedures that statistically assess the deviations described in Section 5.3.
- Section 5.5 applies the procedures of Section 5.4 to the surveillance database that supported the development of the ETC [9].
- Section 5.6 discusses factors that should be considered if the statistical tests of Section 5.4 are failed; it also describes procedures that could be used to adjust the predictions of the ETC in certain circumstances.

## 1 5.1 Embrittlement Trend Curve

2 As detailed in ORNL/TM-2006/530 [9], the numerical coefficients in the following equations were  
 3 determined by fitting them to the  $\Delta T_{30}$  data collected in 10 CFR 50 Appendix H surveillance  
 4 programs that have been reported to the NRC through approximately 2002. This  $\Delta T_{30}$  ETC,  
 5 which is used in the Alternate PTS Rule, has the following form:  
 6

$$7 \quad \Delta T_{30} = MD + CRP \quad (1)$$

$$8 \quad MD = A \times (1 - 0.001718 \times T_C) \times (1 + 6.13 \times P \times Mn^{2.471}) \times \phi t_e^{0.5} \quad (2)$$

$$9 \quad A = \begin{cases} 1.140 \times 10^{-7} & \text{for forgings} \\ 1.561 \times 10^{-7} & \text{for plates} \\ 1.417 \times 10^{-7} & \text{for welds} \end{cases} \quad (3)$$

$$10 \quad CRP = B \times (1 + 3.77 \times Ni^{1.191}) \times f(Cu_e, P) \times g(Cu_e, Ni, \phi t_e) \quad (4)$$

$$11 \quad B = \begin{cases} 102.3 & \text{for forgings} \\ 102.5 & \text{for plates in vessels not manufactured by Combustion Engineering} \\ 135.2 & \text{for plates in vessels manufactured by Combustion Engineering} \\ 155.0 & \text{for welds} \end{cases} \quad (5)$$

$$12 \quad Cu_e = \begin{cases} 0 & \text{for } Cu \leq 0.072 \text{ wt\%} \\ \text{MIN}[Cu, \text{MAX}(Cu_e)] & \text{for } Cu > 0.072 \text{ wt\%} \end{cases} \quad (6)$$

$$13 \quad \text{MAX}(Cu_e) = \begin{cases} 0.243 & \text{for Linde 80 welds} \\ 0.301 & \text{for all other materials} \end{cases} \quad (7)$$

$$14 \quad f(Cu_e, P) = \begin{cases} 0 & \text{for } Cu \leq 0.072 \\ [Cu_e - 0.072]^{0.668} & \text{for } Cu > 0.072 \text{ and } P \leq 0.008 \\ [Cu_e - 0.072 + 1.359 \times (P - 0.008)]^{0.668} & \text{for } Cu > 0.072 \text{ and } P > 0.008 \end{cases} \quad (8)$$

$$15 \quad g(Cu_e, Ni, \phi t_e) = 0.5 + (0.5 \times \tanh \left\{ \frac{[\log_{10}(\phi t_e) + (1.1390 \times Cu_e) - (0.448 \times Ni) - 18.120]}{0.629} \right\}) \quad (9)$$

$$16 \quad \phi t_e = \begin{cases} \phi t & \text{for } \phi \geq 4.39 \times 10^{10} \text{ n/cm}^2 / \text{sec} \\ \phi t \times \left( \frac{4.39 \times 10^{10}}{\phi} \right)^{0.2595} & \text{for } \phi < 4.39 \times 10^{10} \text{ n/cm}^2 / \text{sec} \end{cases} \quad (10)$$

17 The dependent variable,  $\Delta T_{30}$ , is estimated by Eqn. (1) in degrees Fahrenheit. The standard  
 18 deviation of residuals about Eqn. (1) for different product forms and copper contents appears in

1 Table 4. The units and descriptions of independent variables in these equations are given in  
 2 Table 5. As with any equation calibrated to empirical data, inaccuracies have a greater  
 3 tendency to occur at the extremes of, or beyond this limits of, the calibration dataset. Users of  
 4 Eqn. (1) should therefore exercise caution when applying it to conditions near to or beyond the  
 5 extremes of its calibration dataset, which appear in Table 5. For example, for materials having  
 6 copper contents below 0.072 weight percent, Eqn. (1) predicts negative  $\Delta T_{30}$  values when the  
 7 irradiation temperature exceeds 582.1°F; clearly, negative shift values are incorrect.

9 Table 4. Standard Deviation of Residuals about Eqn. (1)  
 10

Product Form	Standard Deviation, $\sigma$ (°F)	
	Cu $\leq$ 0.072 wt %	Cu $>$ 0.072 wt %
Weld	18.6	26.4
Plate		21.2 <sup>(a)</sup>
Forging		19.6

a. Includes the standard reference materials.

11  
 12  
 13 Table 5. Independent Variables in the Eqn. (1) ETC and the Ranges and Mean Values of the  
 14 Calibration Dataset

Variable	Symbol	Units	Values of Surveillance Database			
			Average	Standard Deviation	Minimum	Maximum
Neutron Fluence (E > 1 MeV)	$\phi t$	n/cm <sup>2</sup>	1.24E+19	1.19E+19	9.26E+15	1.07E+20
Neutron Flux (E > 1 MeV)	$\phi$	n/cm <sup>2</sup> /sec	8.69E+10	9.96E+10	2.62E+08	1.63E+12
Irradiation Temperature	$T_C$	°F	545	11	522	570
Copper Content	$Cu$	weight %	0.140	0.084	0.010	0.410
Nickel Content	$Ni$	weight %	0.56	0.23	0.04	1.26
Manganese Content	$Mn$	weight %	1.31	0.26	0.58	1.96
Phosphorus Content	$P$	weight %	0.012	0.004	0.003	0.031

15  
 16

## 5.2 Data Used in Statistical Tests

Surveillance data used to perform the statistical tests outlined in this chapter should be as follows:

1. Materials Evaluated (i.e., the Meaning of “Plant-Specific”)
  - a) When performing the statistical tests required by the Alternate PTS Rule, each shell and weld material in the RPV beltline region for which 10 CFR 50 Appendix H surveillance data exist should be evaluated. The statistical tests should be performed separately for each heat.
  - b) For each heat for which data are available, the  $\Delta T_{30}$  values used in the statistical tests should include data from both of the following sources:
    - Data obtained for the heat of material in question as part of a 10 CFR 50 Appendix H surveillance program conducted for the plant in question; and
    - Data obtained for the heat of material in question as part of a 10 CFR 50 Appendix H surveillance program conducted for any other plant that is operating, or has operated, under a license issued by the NRC. Data from this source is often referred to as having come from a “Sister Plant.” Such data may have different best-estimate chemistry values and different irradiation temperatures (e.g., the Cu and T values for Heat “123” at Plant “XYZ” may be 0.23 and 553°F, respectively, whereas the Cu and T values for Heat “123” at Plant “ABC” may be 0.21 and 544°F, respectively). The statistical tests described in Sections 5.3 and 5.4 operate on the residuals (i.e., the difference between the surveillance measurement of  $\Delta T_{30}$  and the prediction of the ETC). In so doing, the ETC takes account of these plant-specific variations in chemistry and/or temperature, so there is no need to make further adjustments to account for so-called “Sister Plant” data (see Reference [10]).
2. Data-Quantity Requirements: To perform these statistical tests, at least three plant-specific  $\Delta T_{30}$  values measured at three different fluence levels should be available. If this condition is not met, the ETC described in the Alternate PTS Rule should be used to estimate  $\Delta T_{30}$ .
3. Data-Binning Requirements
  - a) As discussed in Item 1, data obtained for the heat of material in question as part of a 10 CFR 50 Appendix H surveillance program conducted for any plant that is operating, or has operated, under a license issued by the NRC should be binned together and considered in these statistical evaluations.
  - b) For plates and forgings, Charpy data is often obtained for different orientations of the notch relative to the primary working direction of the plate or forging. For the purpose of these statistical tests,  $\Delta T_{30}$  values for a particular plate or forging should be computed from unirradiated specimens having the same notch orientation. Once  $\Delta T_{30}$  values are calculated, different notch orientation data from the same heat of material should be binned together for the purpose of the statistical tests described in Sections 5.3 and 5.4. This is appropriate because the differences in unirradiated transition temperature caused by notch orientation will be subtracted out when  $\Delta T_{30}$  values are calculated.
4. Data-Characterization Requirements: For all materials meeting the requirements of the three preceding items, the following information is needed:
  - heat identification
  - plant identification
  - capsule identification

- 1 • product form
- 2 • notch orientation
- 3 • the unirradiated reference temperature,  $RT_{NDT(U)}$
- 4 •  $\Delta T_{30}$
- 5 • Charpy V-notch energy data used to estimate  $\Delta T_{30}$
- 6 • fluence
- 7 • operating time
- 8 • cold-leg temperature under normal full-power operating conditions ( $T_c$ )
- 9 ○ Note:  $T_c$  ( $^{\circ}F$ ) is determined as the time-weighted average coolant
- 10 temperature of the cold leg of the reactor coolant system covering the
- 11 time period from the start of full-power operation through the end of
- 12 licensed operation.
- 13 • copper (Cu) content
- 14 • nickel (Ni) content
- 15 • phosphorus (P) content
- 16 • manganese (Mn) content
- 17 • citation

18 The values of Cu, Ni, P, and Mn are the best-estimate values for the material. For a  
19 plate or forging, the best-estimate value is normally the mean of the measured values for  
20 that plate or forging. For a weld, the best-estimate value is normally the mean of the  
21 measured values for a weld deposit made using the same weld wire heat number as the  
22 critical vessel weld. If these values are not available, either the upper limiting values  
23 given in the material specifications to which the vessel material was fabricated, or  
24 conservative estimates (i.e., mean plus one standard deviation) based on generic data  
25 should be used. Table 4 of 10 CFR 50.61a provides upper-bound estimates for P  
26 and Mn. Similarly, upper bound estimates for Cu and Ni are provided in 10 CFR 50.61.

### 5.3 Statistical Evaluation of Surveillance Data

In developing this surveillance assessment procedure, consideration was given to the development of statistical tests capable of detecting the four types of deviations between heat-specific surveillance data and the  $\Delta T_{30}$  ETC expressed by Eqns. (1) through (10). These deviations are illustrated in Figure 1 and are identified as Types A, B, C, and D. The potential origins and implications of these types of statistical deviations are described briefly in the following sections. Only situations in which the data suggest that the  $\Delta T_{30}$  ETC may provide a non-conservative prediction (i.e., situations in which the data exceed the ETC prediction) are illustrated in Figure 1. The opposite situation is also possible; i.e., situations in which the data are underestimated by the ETC. However, from a regulatory standpoint, only non-conservative predictions are important.

- **Type A Deviations:** For Type A deviations, measurements differ from the mean ETC prediction more or less uniformly at all fluence levels. Additionally, the magnitude of this deviation is larger than would be expected based on the population of data used to calibrate the ETC. Potential origins of Type A deviations may include, but are not limited to, errors in the chemical composition values or errors in the unirradiated  $\Delta T_{30}$  value associated with the surveillance sample. The implication of a statistically significant Type A deviation (procedures for evaluating statistical significance are described in Section 5.4.1) is that the ETC may systematically underestimate the value of  $\Delta T_{30}$  for the heat of steel being evaluated.
- **Type B Deviations:** For Type B deviations, measurements differ from the mean ETC prediction by an amount that increases as fluence increases. Additionally, the magnitude of this deviation is larger than would be expected based on the population of data used to calibrate the ETC. Potential origins of Type B deviations may include, but are not limited to, (1) errors in the temperature value associated with the surveillance sample or (2) the existence in the surveillance sample of an embrittlement mechanism that is not represented in the ETC calibration dataset. A recent review of high-fluence data has revealed the possible existence of Type B deviations in a large empirical database (see Figure 2 and Reference [15]). The implications of a statistically significant Type B deviation (procedures for evaluating statistical significance are described in Section 5.4.2) are that the ETC may systematically underestimate the value of  $\Delta T_{30}$  for the heat of steel being evaluated and that the magnitude of this underestimation will increase as the plant operation continues.
- **Type C Deviations:** For Type C deviations, measurements differ from the mean ETC by exhibiting more scatter than would be expected based on the population of data used to calibrate the ETC. Potential origins of Type C deviations may include, but are not limited to, errors made in testing, labeling, or controlling the notch orientation of surveillance specimens. The implication of statistically significant Type C deviations is not that the ETC may systematically underpredict the true embrittlement, but rather that the ability of the surveillance data to provide insight into embrittlement trends is called into question for a specific heat of material.
- **Type D Deviations:** For Type D deviations, one or more of the  $\Delta T_{30}$  measurements differ significantly from the mean ETC prediction even though all other measurements for the heat of steel being evaluated agree well with that prediction. The magnitude of the

1 deviation of these outliers is larger than would be expected based on the population of  
2 data used to calibrate the ETC. Potential origins of Type D deviations may include, but  
3 are not limited to, (1) a large measurement error in the single datum or (2) the rapid  
4 emergence in the surveillance sample of an embrittlement mechanism that is not  
5 represented in the calibration dataset (e.g., rapid emergence of a Type B deviation).  
6 The implication of a statistically significant Type D deviation (procedures for evaluating  
7 statistical significance are described in Section 5.4.3) is that the ETC may systematically  
8 underestimate the value of  $\Delta T_{30}$  for the heat of steel being evaluated.  
9

10 If they are statistically significant, Type A, B, and D deviations all give rise to concerns that the  
11 embrittlement trends predicted by the ETC may produce non-conservative estimates of the  
12 embrittlement experienced by materials used to construct the RPV that is being evaluated. For  
13 this reason, methods to assess the statistical significance of these deviations are described in  
14 Sections 5.4.1 through 5.4.3. Type C deviations, if they are statistically significant, suggest that  
15 the surveillance program for the material in question may not provide a reliable indication of  
16 embrittlement trends for that material. Because Appendix H to 10 CFR 50 requires the  
17 performance of surveillance on the “limiting” (meaning “most irradiation-sensitive”) materials  
18 used to construct the RPV beltline, the existence of a Type C deviation is important from a  
19 regulatory viewpoint, but not in the context of indicating a potential non-conservatism in the  
20 predictions of the  $\Delta T_{30}$  ETC adopted in the Alternate PTS Rule. For this reason, statistical  
21 procedures to detect Type C deviations were not included in the Alternate PTS Rule (see  
22 Reference [1]) and, therefore, are not described in Section 5.4.





Figure 1. Four Types of Deviation between Heat-Specific Surveillance Data and a  $\Delta T_{30}$  ETC.



1



2

3

Figure 2.  $\Delta T_{30}$  Prediction Residuals Based on Eqn. (1). Low flux points are from power reactors while high flux points are from test reactors. Similar trends exist for both plates and welds [15].

4

5

6

7

8

## 5.4 How to Perform Statistical Tests of Surveillance Data

9

This section describes how to perform the Type A (mean test), Type B (slope test), and Type D (outlier test) assessments of surveillance data that are required by the Alternate PTS Rule.

10

11

12

### 5.4.1 Type A Deviations

13

As illustrated by Figure 1, Type A deviations are characterized by measurements that differ from the mean ETC prediction more or less uniformly at all fluence levels. The following procedure can be used to detect Type A deviations when the  $\Delta T_{30}$  measurements for a specific heat of material are uniformly underpredicted by Eqn. (1). A statistical significance level of  $\alpha = 1\%$  (i.e., 2.33 standard deviations) is recommended for this one-sided test; Section 5.4.4 discusses the rationale for this selection.

14

15

16

A-1. Ensure that the entry conditions of Section 5.2 have been met.

17

A-2. Estimate the residual for each datum using the following formula:

$$r = \Delta T_{30(\text{measured})} - \Delta T_{30(\text{predicted})} \quad (11)$$

18

where  $\Delta T_{30(\text{measured})}$  represents each individual measurement, and  $\Delta T_{30(\text{predicted})}$  is the value of  $\Delta T_{30}$  predicted using Eqn. (1) and best-estimate composition and exposure values for the plant from which the companion  $\Delta T_{30(\text{measured})}$  value was obtained.

19

20

21

22

23

24

25

26

27

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12

A-3. Estimate the mean residual ( $r_{\text{mean}}$ ) for the  $\Delta T_{30}$  dataset using the following formula:

$$r_{\text{mean}} = \frac{1}{n} \sum_{i=1}^n \{r_i\} \tag{12}$$

where  $n$  is the number of  $\Delta T_{30}$  measurements for the specific heat of material being assessed.

A-4. Estimate the maximum allowable residual ( $r_{\text{max}}$ ) using the following formula:

$$r_{\text{max}} = \frac{2.33\sigma}{\sqrt{n}} \tag{13}$$

where  $n$  is the number of  $\Delta T_{30}$  measurements for the specific heat of material being assessed and  $\sigma$  is the population standard deviation, which is taken from Table 4.

A-5. If  $r_{\text{mean}}$  exceeds  $r_{\text{max}}$ , the subject dataset is judged to show a Type A deviation.

### 5.4.2 Type B Deviations

As illustrated by Figure 1, Type B deviations are characterized by measurements that differ from the ETC prediction by an amount that increases as fluence increases. The following procedure is used to detect Type B deviations. Similarly to the test for Type A deviations, a statistical significance level of  $\alpha = 1\%$  is recommended for this one-sided test; Section 5.4.4 discusses the rationale for this selection.

- B-1. Ensure that the entry conditions of Section 5.2 have been met.
- B-2. For each measured  $\Delta T_{30}$  value, calculate the difference between the measured and predicted value of  $\Delta T_{30}$  using Eqn. (11). As illustrated in Figure 3, plot  $r$  vs. the  $\log_{10}$  value of fluence. The abscissa is expressed in this way because embrittlement, as quantified by  $\Delta T_{30}$ , increases approximately linearly with the logarithm of fluence.




Figure 3. Procedure to Assess Type B Deviations.

- B-3. Using the method of least squares, estimate the slope ( $m$ ) of the data plotted as shown in Figure 3. Also estimate the standard error of the estimated value of the slope,  $se(m)$ .

1 B-4. Estimate the T-statistic for the slope as follows:

$$T_m = \frac{m}{\text{se}(m)} \quad (14)$$

2 B-5. Establish the critical T-value as follows:

$$T_{\text{CRIT}(\alpha)} \equiv t(\alpha, n-2) \quad (15)$$

3 where  $t(\dots)$  represents Student's t-distribution,  $\alpha$  is the selected significance  
4 level, and  $n$  is the number of  $\Delta T_{30(\text{Measured})}$  values. Adoption of  $\alpha = 1\%$  is  
5 recommended for regulatory implementation of this procedure (Section 5.4.4  
6 discusses the rationale for this selection). Table 6 provides values of  $T_{\text{CRIT}(1\%)}$ .  
7

8 Table 6.  $\alpha = 1\%$  Student's t-Values

Number of $\Delta T_{30}$ Values, n	n-2	One-Tailed $T_{\text{CRIT}}$ (1%, n-2)
3	1	31.82
4	2	6.96
5	3	4.54
6	4	3.75
7	5	3.36
8	6	3.14
9	7	3.00
10	8	2.90
11	9	2.82
12	10	2.76
13	11	2.72
14	12	2.68
15	13	2.65

9

10 B-6. If  $T_m$  exceeds  $T_{\text{CRIT}(\alpha)}$ , the subject dataset is judged to show a Type B deviation.  
11

### 12 5.4.3 Type D Deviations

13 As illustrated by Figure 1, Type D deviations are characterized by one or more of the  
14  $\Delta T_{30}$  measurements differing significantly from the mean ETC prediction even though all other  
15 measurements for the heat of steel being evaluated agree well with the ETC. Similarly to the  
16 tests for both Type A and Type B deviations, a statistical significance level of  $\alpha = 1\%$  is  
17 recommended for this one-sided test; Section 5.4.4 discusses the rationale for this selection.  
18

19 D-1. Ensure that the entry conditions of Section 5.2 have been met.

20 D-2. Estimate the normalized residual,  $r^*$ , for each or the  $n$  observations in the  
21  $\Delta T_{30}$  dataset using the following formula:

$$r^* = \frac{r}{\sigma} \quad (16)$$

22 where  $r$  is defined from Eqn. (11) and  $\sigma$  is the population standard deviation  
23 taken from Table 4.

24 D-3. Find the largest and second largest  $r^*$  values from Step D-2; designate these  $r^*_1$   
25 and  $r^*_2$  respectively.

- 1 D-4. Find the limit values  $r_{LIMIT(1)}$  and  $r_{LIMIT(2)}$  corresponding to  $n$  in Table 7. These  
 2 threshold values correspond to a significance level of  $\alpha = 1\%$ . Appendix A of this  
 3 document describes how the values of  $C_1$  and  $C_2$  that appear in Table 7 were  
 4 derived.  
 5 D-5. If  $r^*_1 \leq r_{LIMIT(1)}$  and  $r^*_2 \leq r_{LIMIT(2)}$ , the dataset is judged to not show a Type D  
 6 deviation. Otherwise the surveillance dataset is judged to show a Type D  
 7 deviation.  
 8

9 Table 7.  $\alpha = 1\%$  Threshold Value for the Outlier Test

$n$	$r_{LIMIT(2)}$	$r_{LIMIT(1)}$
3	1.55	2.71
4	1.73	2.81
5	1.84	2.88
6	1.93	2.93
7	2.00	2.98
8	2.05	3.02
9	2.11	3.06
10	2.16	3.09
11	2.19	3.12
12	2.23	3.14
13	2.26	3.17
14	2.29	3.19
15	2.32	3.21
17	2.37	3.24
26	2.53	3.36
64	2.83	3.62

Note: In Appendix A,  $r_{LIMIT(1)}$  is referred to as  $C_2$  and  $r_{LIMIT(2)}$  is referred to as  $C_1$ . The notation is changed here to improve clarity.

10  
 11 **5.4.4 Comments on the Statistical Tests**

12 The significance level recommended for regulatory implementation of the Type A, B, and D tests  
 13 is  $\alpha = 1\%$ . At this significance level, there is less than a 1% chance that the underlying cause of  
 14 the detected difference (Type A, B, or D) between the plant-specific surveillance data and the  
 15 value of  $\Delta T_{30}$  predicted by Eqn. (1) has occurred as a result of chance alone. The following  
 16 considerations informed this recommendation:  
 17

- 18 • A 1% significance level makes it more difficult for plant-specific surveillance data to be  
 19 declared “different” from the predictions of the ETC than has traditionally been the case.  
 20 For example, both 10 CFR 50.61 [3] and Revision 2 of Regulatory Guide 1.99 [16] use a  
 21 “ $2\sigma$ ” criterion which, for a one-sided test, implies an  $\alpha = 2.5\%$  significance level. The  
 22 staff views this change in significance level from 2.5% to 1% as appropriate in view of  
 23 the greater physical and empirical support of Eqn. (1) than was available at the time both  
 24 10 CFR 50.61 and Revision 2 of Regulatory Guide 1.99 were adopted.
- 25 • The selection of the  $\alpha = 1\%$  significance level represents a conscious tradeoff between  
 26 the competing goals of providing high confidence in the determination of a statistically  
 27 significant difference between plant-specific surveillance data and the predictions of  
 28 Eqn. (1) versus limiting the risk of judging that a particular set of plant-specific

1 surveillance data are similar to the  $\Delta T_{30}$  ETC when, in fact, they are not. The former  
2 goal is achieved by adopting a small value for  $\alpha$ , whereas the latter goal is achieved by  
3 increasing the  $\alpha$  value.

- 4 • If a plant-specific data set is determined by these statistical tests to be “different” from  
5 the predictions of Eqn. (1), the alternatives that are available to licensees to either  
6 troubleshoot the cause of the difference or develop new/replacement data are limited,  
7 expensive, or have long lead times. Consequently, while the NRC recognizes that it is  
8 important to compare plant-specific data to generic trends and to take action when such  
9 comparisons show differences, the NRC believes it is technically justified to reserve  
10 such actions for those cases in which the differences are the most clear and are the  
11 most practically significant.

12  
13 Considering all of these factors, a significance level for Type A, B, and D deviations of  $\alpha = 1\%$   
14 was adopted in the Alternative PTS Rule.

## 15 **5.5 Evaluation of Plant Data Relative to the Statistical Tests**

16  
17 The information presented in this section appeared previously in Reference [14]. It is repeated  
18 here for clarity and completeness.

19  
20 The plant surveillance data used in ORNL/TM-2006/530 [9] to calibrate Eqn. (1) were evaluated  
21 according to the statistical tests detailed in Section 5.4. After filtering to remove heats having  
22 less than three  $\Delta T_{30}$  observations at three different fluence values, 159 data sets remained for  
23 evaluation. These sets included data from both PWRs and BWRs, as well as from plants that  
24 are no longer in operation. While the BWR and ex-plant data are not directly pertinent to the  
25 Alternate PTS Rule, they were retained in this analysis for information. The detailed results of  
26 these analyses appear in Appendix B.  
27

1 Table 8 summarizes the 14 heats of material from 12 plants that show a statistically significant  
2 deviation of Type A, B, or D, while Table 9 summarizes the proportion of heats in the  
3 surveillance database that exhibit statistically significant deviations at the  $\alpha = 1\%$  level. The  
4 information in Table 9 demonstrates that both the mean and the outlier tests exhibit a rate of  
5 deviation above the expected value for a population of 159 data sets (i.e., 1% of 159, or 1.59),  
6 while the deviation rate of the slope test is close to this expected value. These observations  
7 suggest that, for the mean and outlier tests, the assumption that the residuals are distributed  
8 normally about the ETC (Eqn. (1)) may be incorrect. One possible explanation for this situation  
9 could be the presence of systematic biases in some of the unirradiated  $T_{30}$  values (arising from,  
10 for example, measurement error or imprecision). Such biases, if present, would have no effect  
11 on the detection rate of the slope test because it operates on the differences between  
12  $\Delta T_{30}$  residuals, not on their absolute values. Thus, any systematic biases in the unirradiated  
13  $\Delta T_{30}$  values would be subtracted out of the  $\Delta T_{30}$  difference values that are used to perform the  
14 slope test and, consequently, could not affect the outcome of the test. Conversely, the mean  
15 and outlier tests both operate on the absolute values of  $\Delta T_{30}$  residuals. Consequently,  
16 systematic biases in the unirradiated values of  $\Delta T_{30}$  could affect the normalcy of the  
17  $\Delta T_{30}$  residuals and, thereby, the detection rate of the mean and outlier tests.  
18

1 Table 8. Heats of Material that Exhibit Statistically Significant Deviations ( $\alpha = 1\%$ ) of Type A, B,  
 2 or D

Plant Name	Heat ID	Product Form	Population $\sigma$ ( $^{\circ}\text{F}$ )	Number of $\Delta T_{30}$ Values	Test Results		
					A - Mean Test	B - Slope Test	D - Outlier Test
<b>Operating PWRs</b>							
San Onofre Unit 3	PSO301	Plate	18.6	3	FAIL	PASS	FAIL
D.C. Cook 2	PCK201	Plate	21.2	8	FAIL	PASS	PASS
Beaver Valley 1	PBV101	Plate	21.2	8	FAIL	PASS	FAIL
Callaway	WCL101	Weld	18.6	4	FAIL	PASS	FAIL
Surry 1	WSU101	Weld	26.4	3	FAIL	PASS	FAIL
Indian Point 2	PIP203	Plate	21.2	3	FAIL	PASS	PASS
Sequoyah 1	FSQ101	Forging	19.6	8	FAIL	PASS	PASS
Sequoyah 1	WSQ101	Weld	26.4	4	FAIL	PASS	PASS
Sequoyah 2	WSQ201	Weld	26.4	4	PASS	PASS	FAIL
<b>Operating BWRs</b>							
River Bend 1 and Oyster Creek	WRB01	Weld	18.6	3	FAIL	PASS	FAIL
<b>Decommissioned PWRs</b>							
Maine Yankee	PMY01	Plate	21.2	6	FAIL	PASS	PASS
Zion 1	WZN101	Weld	18.6	5	PASS	FAIL	PASS
<b>Decommissioned BWRs</b>							
Big Rock Point	PBR01	Plate	21.2	5	FAIL	FAIL	FAIL

3  
 4  
 5  
 6 Table 9. Proportion of Material Heats in the Current Surveillance Database that Exhibit  
 7 Statistically Significant Deviations ( $\alpha = 1\%$ ) of Type A, B, or D

Test Type		Data Sets that Show Statistically Significant ( $\alpha = 1\%$ ) Deviation	
		Count	Percent
A	Mean Test	11	6.9%
B	Slope Test	2	1.3%
D	Outlier Test	7	4.4%

8

## 5.6 Considerations When Statistical Tests Are Failed

Failure of plant-specific surveillance data to pass any of these statistical tests indicates a situation in which Eqn. (1) may underestimate the embrittlement magnitude; use of Eqn. (1) in such situations without additional justification is not advised. Such failures suggest that more focused assessment of the surveillance data is warranted, and are taken as an indication that methods other than, or in addition to, the ETC may be needed to reliably predict  $\Delta T_{30}$  trends. However, the most appropriate approach may not be a heat-specific adjustment of the ETC predictions in all cases. For example, statistically significant differences may indicate situations in which the available data (i.e., the  $\Delta T_{30}$  measurements and/or the composition and exposure values associated with the  $\Delta T_{30}$  measurements) are incorrect, making adjustment of the ETC predictions to match these data unwise.

The discussion of this section is divided into two parts. First, a list of factors is provided that could be helpful in diagnosing the reason that the surveillance data failed the statistical tests. This is followed by a discussion of situations in which adjustments of the ETC predictions may be made using simple procedures.

### 5.6.1 Factors to Consider When Statistical Tests Are Failed

Before adjustments of the ETC predictions to match surveillance data are considered, a detailed assessment of the accuracy and appropriateness of the  $\Delta T_{30}$  data is suggested. Such an assessment should consider, but not be limited to, the following factors:

- Unirradiated  $RT_{NDT}$  value: As noted in Section 5.5, the occurrence of mean and outlier failures in the available surveillance data exceeds the statistically expected value. Both of these tests are sensitive to the accuracy of the unirradiated  $RT_{NDT}$  value. In these cases, a records investigation of the unirradiated  $RT_{NDT}$  value, and/or the performance of additional testing of archival material may provide a more accurate estimate of  $RT_{NDT}$ , which may explain the reason for failure of the mean and/or outlier tests.
- Irradiated  $\Delta T_{30}$  values: While most CVN energy vs. temperature curves from which  $\Delta T_{30}$  values are estimated are based on 8 to 12 individual measurements, some data sets are more limited, which can increase uncertainty in the  $\Delta T_{30}$  estimate. If any of the statistical tests are not satisfied, a review of the individual CVN energy vs. temperature curves may help to reveal the cause of the failure.
- Composition and exposure variables: The input variables to Eqn. (1) are subject to variability and are often based on limited data. However, the predictions of Eqn. (1) depend on these input variables, particularly Cu content, fluence, temperature, and Ni content. If a sensitivity analysis reveals that small variations of the values input to Eqn. (1) rationalize the failure of the statistical tests, this might indicate that more refined information concerning input values (e.g., additional measurements) could explain the reason for the failure of the statistical tests.
- Notch orientation: The  $\Delta T_{30}$  value for plate and forging materials is sensitive to the orientation of the notch in the CVN specimen relative to the primary working direction of the plate or forging. Differences in notch orientation between the unirradiated  $\Delta T_{30}$  value and the  $\Delta T_{30}$  value of all the irradiated specimens could help to explain why the mean test is not satisfied. Similarly, differences in notch orientation between the unirradiated  $\Delta T_{30}$  value and the  $\Delta T_{30}$  value of the irradiated specimens in a single capsule could help to explain why the outlier test is not satisfied. In these situations, the outcome of a



1 records search or metallurgical investigation of the tested specimens might be useful to  
2 explain the reason for the failure of the statistical tests.

- 3 • Comparative trends analysis: In addition to CVN specimens, surveillance capsules also  
4 contain tensile specimens that are part of the capsule testing program. Like  $\Delta T_{30}$ , the  
5 increase in yield strength with irradiation ( $\Delta YS$ ) also follows certain trends. If the  
6  $\Delta YS$  data for a particular material that failed the statistical tests follows the trends  
7 exhibited by  $\Delta YS$  data for a similar composition, this information might indicate that the  
8 CVN specimens were taken from the wrong material, or have been somehow  
9 mislabeled.

## 11 5.6.2 Specific Procedures

12 If a statistical test is failed, it is permissible to use any of the following procedures:

- 13 1. Mean Test (Type A) Failure: A procedure to adjust ETC predictions to account for a  
14 failure of the mean test is illustrated in Figure 4 (left side). This procedure is as follows:

- a. Calculate the value  $ADJ$  as follows:

$$ADJ = r_{mean} - r_{max} \quad (17)$$

- b. Adjust the prediction of Eqn. (1) as follows:

$$\Delta T_{30(ADJ)} = MD + CRP + ADJ \quad (18)$$

- c. Use the value  $\Delta T_{30(ADJ)}$  in place of  $\Delta T_{30}$  in all calculations required by the Alternate  
19 PTS Rule for the material that failed the mean test.


- 20 2. Slope Test (Type B) Failure: One procedure for adjusting ETC predictions to account for  
21 a failure of the slope test is to adjust the ETC predictions, Eqn. (1), based on the greater  
22 increase of embrittlement with fluence suggested by the plant-specific data. The specific  
23 procedure used should be technically justified and documented.

- 24 3. Outlier Test (Type D) Failure (Not Satisfied at Low Fluence): Figure 4 (right side)  
25 illustrates a situation in which a  $\Delta T_{30}$  value measured at low fluence is the cause of  
26 failing the outlier test. Such a failure is not considered structurally relevant to a PTS  
27 evaluation, and may therefore be ignored, provided both of the following conditions are  
28 satisfied:

- a. The fluence of the datum that caused the outlier test failure,  $\phi_{t_{LOW}}$ , is less than  
29 10% of the fluence at which the PTS evaluation is being performed,  $\phi_{t_{EVAL}}$ , and  
30 b. After elimination of the datum measured at  $\phi_{t_{LOW}}$ , the entry conditions for the  
31 surveillance tests are still met (i.e., at least three data points measured at three  
32 different fluence levels remain) and all three statistical tests are satisfied with the  
33 reduced data set.

34 Other approaches to assessment of surveillance data in which all surveillance measurements  
35 are bounded are subject to review and approval by the NRC.

## Mean Test Failure



## Low Fluence Outlier Test Failure




Figure 4. Specific Procedures to Account for Failure of the Mean Test (left) or Low Fluence Outlier Statistical Test (right).

## 5.7 Summary and Conclusions

This chapter discusses the three statistical tests required by the Alternate PTS Rule and methods by which data can be evaluated relative to these tests. The aim of performing these tests is to determine whether the surveillance data are sufficiently “close” to the predictions of the ETC that the predictions of the ETC may be used. From a regulatory perspective, it is of particular interest to determine whether plant-specific surveillance data deviate significantly from the predictions of the ETC in a manner that suggests that the ETC is likely to underpredict plant-specific trends. To this end, a statistical significance level of  $\alpha = 1\%$  was adopted, which represents a conscious tradeoff between the competing goals of providing high confidence in the determination of a statistically significant difference between plant-specific surveillance data and the  $\Delta T_{30}$  ETC versus limiting the risk of judging that a particular set of plant-specific surveillance data are similar to the ETC when, in fact, they are not. The  $\alpha = 1\%$  tests will show fewer statistically significant deviations than did either 10 CFR 50.61 or Revision 2 of Regulatory Guide 1.99, both of which use a “ $2\sigma$ ” criterion that, for a one-sided test, implies an  $\alpha = 2.5\%$  significance level. The staff views this change in significance level (from 2.5% to 1%) as appropriate in view of the greater empirical support for the ETC used in the Alternate PTS Rule than was available at the time either 10 CFR 50.61 or Regulatory Guide 1.99 (Revision 2) were adopted.

1 Three tests were adopted in the Alternate PTS Rule because they collectively indicate when an  
2 underprediction of embrittlement magnitude by the ETC may have occurred. In Appendix B,  
3 these statistical tests are applied to the operating plant surveillance database assembled  
4 through (approximately) 2002. Of the heats of material considered, only 14 heats from  
5 12 plants fail one or more of the three statistical tests. Failure of plant-specific surveillance data  
6 to pass any of the statistical tests indicates a situation in which the ETC may underestimate the  
7 embrittlement magnitude; use of Eqn. (1) in such situations without additional justification is not  
8 advised. Such failures suggest that more focused assessment of the surveillance data is  
9 warranted, and are taken as an indication that methods other than, or in addition to, the ETC  
10 may be needed to reliably predict  $\Delta T_{30}$  trends. However, the most appropriate approach may  
11 not be a heat-specific adjustment of the ETC predictions in all cases. For example, statistically  
12 significant differences may indicate situations in which the available data (i.e., the  
13  $\Delta T_{30}$  measurements and/or the composition and exposure values associated with the  
14  $\Delta T_{30}$  measurements) are incorrect, making adjustment of the ETC predictions to match these  
15 data unwise. This chapter includes both a list of factors that could be helpful in diagnosing the  
16 reason that the surveillance data fail the statistical tests and a discussion of certain situations for  
17 which adjustments of the ETC predictions can be made.  
18



## 6. GUIDANCE RELATING TO ISI DATA AND NDE REQUIREMENTS

### 6.1 Background

The technical basis for the Alternate PTS Rule concludes that flaws as small as 0.1 inch in through-wall extent contribute to the TWCF, and nearly all of the contributions come from flaws buried less than 1 inch below the inner diameter surface of the reactor vessel wall. Therefore, the Alternate PTS Rule specifies flaw limits for such flaws as indicated in Table 2 in this document. For weld flaws that exceed the sizes prescribed in Table 2, the risk analyses indicated that a single flaw contributes a significant fraction of the  $1 \times 10^{-6}$  per reactor year limit on TWCF. Therefore, if a flaw that exceeds the sizes and quantities described in the flaw tables is found in a reactor vessel, it is important to assess it individually.

The technical basis for the Alternate PTS Rule also indicated that flaws buried deeper than 1 inch from the clad-to-base interface did not contribute as significantly to total risk as flaws of similar size located closer to the inner surface. Therefore, the Alternate PTS Rule does not require the comparison of the density of these flaws, but still requires large flaws, if any are discovered, to be evaluated for contributions to TWCF if they are within the inner three-eighths of the vessel wall's thickness. Because flaws greater than three-eighths of the vessel wall's thickness from the inside surface do not contribute to TWCF, flaws greater than three-eighths of the vessel wall's thickness from the inside surface need not be analyzed.

The limitation for flaw acceptance, specified in Table IWB-3510-1 in Section XI of the ASME Code, approximately corresponds to the threshold for flaw sizes that can make a significant contribution to TWCF if flaws of such sizes are present in reactor vessel material at this depth. Therefore, the final rule requires that flaws exceeding the size limits in Table IWB-3510-1 be evaluated for their contribution to TWCF in addition to the other evaluations for such flaws that are prescribed in the ASME Code.

Paragraph (e) of the Alternate PTS Rule describes a number of tests and conditions on the collection and analysis of NDE data that are intended to provide reasonable assurance that the distribution of flaws assumed to exist in the probabilistic fracture mechanics (PFM) calculations that provided the basis for the  $RT_{MAX-X}$  limits in Table 1 in this document provide an appropriate, or bounding, model of the population of flaws in the RPV of interest. These tests and conditions, the totality of which are illustrated by the diagram in Figure 5 in this document, go beyond a simple comparison of the NDE data to the flaw table limits in Table 2.

A summary of the process depicted in Figure 5 is as follows:

- Step A: All plant-specific recordable flaw data (see Figure 6) should be collected for the inner three-eighths of the wall thickness ( $3/8t$ ) for the base material and weld metal examination volumes<sup>†</sup> within the RPV beltline region by performing ultrasonic test (UT) volumetric examinations and by using procedures, equipment, and personnel required by Supplements 4 and 6 to Mandatory Appendix VIII to Section XI of the ASME Code.

---

<sup>†</sup> Any flaws that are detected within the ultrasonic transducer scan paths but are located outside the examination volume required by Section XI of the ASME Code should also be included in the flaw table evaluation.

- 1 Step B: The plant-specific flaw data from Step A should be evaluated for axial flaw surface  
2 connection. Any flaws with a through-wall extent greater than or equal to 0.075 inch,  
3 axially oriented and located at the clad-to-base-metal interface, should be verified to not  
4 be connected to the RPV inner surface using surface-examination techniques capable  
5 of detecting and characterizing service-induced cracking of the RPV cladding. Eddy  
6 current and visual examination methods are acceptable to the staff for detection of  
7 cladding cracks. An appropriate quality standard shall be implemented to ensure that  
8 these examinations are effective at identification of surface cracking as required by  
9 Criterion IX, "Control of Special Processes," in Appendix B to 10 CFR 50. This  
10 requires, in part, that measures are established to assure that special processes,  
11 including nondestructive testing, are controlled and accomplished by qualified  
12 personnel using qualified procedures in accordance with applicable codes, standards,  
13 specifications, criteria, and other special requirements. Appropriate quality standards  
14 for implementation of surface examinations are identified in Section V, "Nondestructive  
15 Examination," and Section XI of the ASME Code.
- 16 Step C: If the results of Step B are acceptable, the plant-specific flaw data should be evaluated  
17 for acceptability in accordance with the flaw-acceptance standards in  
18 Table IWB-3510-1 in Section XI of the ASME Code.
- 19 Step D: If the results of Step C are satisfactory, or if the results of Step F (if applicable) are  
20 acceptable, the plant-specific flaw data should be compared to Tables 2 and 3 of the  
21 Alternate PTS Rule. A specific example of how this step may be performed is shown in  
22 Section 6.3.
- 23 Step E: If the results of Step B indicate that any axial flaw with a TWE greater than 0.075 inch  
24 are connected to the RPV inner surface, or if the results of Step F (if applicable) are not  
25 acceptable, other plant-specific assessment is required and the provisions of the  
26 Alternate PTS Rule may not be used.
- 27 Step F: If the evaluation associated with Step C is not successful (i.e., if any flaws exceed the  
28 flaw-acceptance standards in Table IWB-3510-1), the flaws must be evaluated and  
29 found to be acceptable in accordance with the flaw-evaluation methods in Section XI of  
30 the ASME Code, and the flaws must be evaluated for acceptability according to  
31 10 CFR 50.61a (see Step I).
- 32 Step G: If the results of Step D are not acceptable, NDE uncertainties may be accounted for in  
33 the evaluation. Appendix C describes the development and application of one  
34 methodology acceptable to the staff that accounts for uncertainties in NDE data. This  
35 method may be used for the purpose of developing more realistic vessel-specific flaw  
36 depth and density distributions for comparison to Tables 2 and 3 of the Alternate PTS  
37 Rule, as well as for use in a plant-specific PFM analysis. The methodology considers  
38 flaw-sizing error, a flaw-detection threshold, POD, and a prior flaw-distribution  
39 assumption. It uses a Bayesian updating methodology to combine the observed NDE  
40 data with the available flaw data and models used as part of the PTS re-evaluation  
41 effort. The licensee must submit the adjustments made to the volumetric test data to  
42 account for NDE-related uncertainties as described in 10 CFR 50.61a(c)(2).
- 43 Step H: The revised flaw distribution results of Step G should be used to compare the revised  
44 plant-specific flaw data to Tables 2 and 3 of the Alternate PTS Rule.

- 1 Step I: If the results of Step H are not acceptable, all flaws should be evaluated for  
2 acceptability using one of the following approaches:  
3 1. *Preclusion of brittle fracture.* Satisfactory demonstration of upper shelf behavior,  
4 which precludes brittle fracture, can be based on keeping temperature above  
5  $RT_{NDT} + 60^{\circ}F$  using the following steps:  
6 i. Compute the irradiated  $RT_{NDT}$  for all flaws as follows:  
7 • Determine the unirradiated value of  $RT_{NDT}$  and  $RT_{NDT(u)}$  for the material at  
8 each flaw location.  
9 • Determine the fluence at each flaw location.  
10 • Compute  $\Delta T_{30}$  for each flaw using Eqn. (1) and the fluence at each flaw  
11 location.  
12 • Compute the flaw-specific value of  $RT_{NDT}$  as  $RT_{NDT(u)} + \Delta T_{30}$  for each  
13 flaw.  
14 ii. Assuming a lower-bound PTS transient temperature of  $75^{\circ}F$ , upper shelf  
15 behavior is assured if  $RT_{NDT} + 60 \leq 75^{\circ}F$ . Therefore, the flaw-specific value  
16 of  $RT_{NDT}$  should be less than or equal to  $15^{\circ}F$ .  
17 iii. The evaluation associated with Step I is acceptable if the flaw-specific value  
18 of  $RT_{NDT}$  is less than or equal to  $15^{\circ}F$  for all flaws.  
19 2. *Calculate the plant-specific TWCF using a plant-specific PFM analysis.*  
20 A plant-specific PFM analysis to calculate TWCF is complex, and there are many  
21 variations of inputs possible for such an analysis. Therefore, specific guidance for  
22 plant-specific PFM analysis to calculate TWCF is not included in this document.  
23 General considerations to include in a plant-specific PFM analysis are provided in  
24 Section 6.2.2. A discussion of the methodology that was used in performing TWCF  
25 calculations for PTS may be found in NUREG-1806 [6], NUREG-1807 [21], and  
26 NUREG/CR-6854 [22]. The steps associated with conducting a plant-specific PFM  
27 calculation are as follows:  
28 i. Perform a Bayesian update of the flaw distribution:  
29 • Apply the procedures of Appendix C and obtain revised flaw-depth and  
30 flaw-density parameters (similar to those shown in Table 16).  
31 ii. Calculate the TWCF using a PFM computer code (e.g., the code in  
32 ORNL/TM-2012/567, "Fracture Analysis of Vessels – Oak Ridge  
33 FAVOR, v12.1, Computer Code: Theory and Implementation of Algorithms,  
34 Methods, and Correlations" [20]):  
35 • Run the generalized procedure for generating flaw-related inputs for the  
36 FAVOR Code described in NUREG/CR-6817 [19] using the revised  
37 flaw-depth and flaw-density parameters.  
38 • Develop necessary plant-specific input using the guidance in  
39 NUREG-1806 [6], NUREG-1807 [21], and NUREG/CR-6854 [22].  
40 • Run a plant-specific PFM analysis.  
41 • Calculate the TWCF.  
42 iii. Compare the plant-specific TWCF to the TWCF limit specified in the  
43 Alternate PTS Rule:  
44 • The evaluation associated with Step I is acceptable if the calculated  
45 TWCF is less than or equal to the limit of  $1 \times 10^{-6}$  events per reactor year  
46 specified in the Alternate PTS Rule.  
47 Step J: If the results of Step I are not acceptable, the licensee must perform a plant-specific  
48 assessment for PTS and submit the assessment to the Director of the Office of Nuclear  
49 Reactor Regulation for review and approval.

1 Step K: If the results of Step D or (if applicable) Step H or (if applicable) Step I are satisfactory,  
2 the screening criteria contained in Table 1 of the Alternate PTS Rule may be applied to  
3 the plant in question. The plant-specific assessment, including explicit details and  
4 results, must be submitted to the Director of the Office of Nuclear Reactor Regulation  
5 for review and approval in the form of a license amendment at least three years before  
6  $RT_{MAX-X}$  is projected to exceed the Alternate PTS Rule screening criteria.  
7

8 Based on this process, the guidelines discussed in this chapter include the following components:  
9

- 10 1. Guidance for plants for the case in which RPV flaws fall outside the applicability of the flaw  
11 tables in the Alternate PTS Rule, including:
  - 12 i. Guidance on a procedure to preclude brittle fracture.
  - 13 ii. Guidance on considerations to include in a plant-specific PFM analysis.
- 14 2. Guidance for initial evaluation of NDE data obtained from qualified ISI examinations.
- 15 3. Guidance on methods for further evaluation of NDE data obtained from qualified ISI  
16 examinations, including:
  - 17 i. Guidance on the elements and NDE techniques associated with the qualified ISI  
18 examinations performed in accordance with Mandatory Appendix VIII to Section XI  
19 of the ASME Code to assess compliance with the requirements of the Alternate PTS  
20 Rule.
  - 21 ii. Guidance on a mathematical procedure that can be used to adjust NDE data to  
22 account for flaw-detection and sizing errors, as well as guidance on comparison of  
23 the adjusted data to the population of flaws assumed in the PFM analysis used to  
24 develop the Alternate PTS Rule.

25  
26 Guidance for these topics is described in detail in the following sections.  
27






Figure 5. Flow Diagram with Recommendations for Meeting the Requirements of the Alternate PTS Rule.

## 6.2 Guidance on Criteria Relating to Alternate Limits on Embrittlement

This section describes guidance for situations in which plant-specific NDE results do not meet the acceptance standards of Table IWB-3510-1 in Section XI of the ASME Code or are not within the limits prescribed by the flaw tables in the Alternate PTS Rule. In such situations, additional efforts beyond those described in Section 6.1 may still allow application of the PTS Screening Criteria shown in Table 1 in this document.

The guidelines discussed in this section include the following components:

- Guidance on a procedure that can be used to preclude brittle fracture based on  $RT_{NDT}$  information for RPV flaws that fall outside the applicability of the Alternate PTS Rule flaw tables.
- Guidance on a procedure that can be used to combine the NDE data with the population of flaws assumed in the TWCF calculations to estimate a total flaw distribution that is predicted to exist in the RPV, as well as guidance on the use of the total flaw distribution if a licensee chooses to conduct a PFM calculation.

These topics are described in detail in the following sections.

### 6.2.1 Guidance on a Procedure to Preclude Brittle Fracture

Guidance on a mathematical procedure to preclude brittle fracture for flaws that exceed the acceptance standards of Table IWB-3510-1, as identified by Step I in Figure 5 in this document, is provided in this section. Such guidance is based on Section II, "Discussion," provided in the Supplemental Information section of the Federal Register Notice for the Alternate PTS Rule [2], which includes the following discussion with respect to ISI Volumetric Examination and Flaw Assessments:

*The technical basis for the final rule also indicates that flaws buried deeper than 1 inch from the clad-to-base interface are not as susceptible to brittle fracture as similar size flaws located closer to the inner surface. Therefore, the final rule does not require the comparison of the density of these flaws, but still requires large flaws, if discovered, to be evaluated for contributions to TWCF if they are within the inner three-eighths of the vessel thickness. The limitation for flaw acceptance, specified in ASME Code, Section XI, Table IWB-3510-1, approximately corresponds to the threshold for flaw sizes that can make a significant contribution to TWCF if present in reactor vessel material at this depth. Therefore, the final rule requires that flaws exceeding the size limits in ASME Code, Section XI, Table IWB-3510-1 be evaluated for contribution to TWCF in addition to the other evaluations for such flaws that are prescribed in the ASME Code.*

A simplified procedure is described here for the situation in which the as-found NDE data for a plant reveals that one or more flaws fall outside the maximum range of the Alternate PTS Rule flaw tables, and that the flaws do not satisfy ASME Code Section XI flaw-acceptance criteria. Therefore, the following situation results:

- The NDE data was obtained using a qualified examination in accordance with Appendix VIII of Section XI of the ASME Code, thereby satisfying Step A in Figure 5.

- 1 • All recordable flaws are located away from the clad-to-base-metal interface. Therefore,  
2 Step B is satisfied with a result of “NO” in Figure 5.
- 3 • Some of the recordable flaws do not meet ASME Code Section XI flaw-acceptance criteria.  
4 Therefore, Step C is not satisfied with a result of “NO” in Figure 5.  
5

6 Thus, based on the above, Step F in Figure 5 requires that flaw evaluation be performed with  
7 acceptable results in accordance with ASME Code Section XI for those recordable flaws that do not  
8 meet ASME Code Section XI flaw-acceptance criteria. In addition, further evaluation for  
9 acceptability using Step I is required. For the purposes of this example, it is assumed that flaw  
10 evaluation in accordance with ASME Code Section XI is successful and is not described in the  
11 assessment that follows.  
12

13 For the further evaluation required by Step I in Figure 5, one approach is to determine whether brittle  
14 fracture can be precluded. For this situation, a recommended evaluation could be as follows:  
15

- 16 • Step I - Preclude Brittle Fracture Option:
  - 17 ○ Satisfactory demonstration of upper shelf behavior, which precludes brittle  
18 fracture, can be based on maintaining temperature above  $RT_{NDT} + 60^{\circ}F$  [23].
  - 19 ○ Compute the irradiated  $RT_{NDT}$  for all flaws as follows:
    - 20 ○ Determine the unirradiated value of  $RT_{NDT}$  and  $RT_{NDT(u)}$  for the material at  
21 each flaw location.
    - 22 ○ Determine the fluence at each flaw location.
    - 23 ○ Compute  $\Delta T_{30}$  for each flaw using Eqn. (1) and the fluence at each flaw  
24 location.
    - 25 ○ Compute the flaw-specific value of  $RT_{NDT}$  as  $RT_{NDT(u)} + \Delta T_{30}$  for each flaw.
  - 26 ○ Assuming a lower-bound PTS transient temperature of  $75^{\circ}F$ , upper shelf behavior is  
27 assured if  $RT_{NDT} + 60 \leq 75^{\circ}F$ . Therefore, the flaw-specific value of  $RT_{NDT}$  should be  
28 less than or equal to  $15^{\circ}F$ .
  - 29 ○ Flaws are acceptable if the flaw-specific value of  $RT_{NDT}$  is less than or equal  
30 to  $15^{\circ}F$ . For this situation, the decision at Step F is “ACCEPTABLE” in Figure 5.
  - 31 ○ Flaws are not acceptable if the flaw-specific value of  $RT_{NDT}$  is greater than  $15^{\circ}F$ . For  
32 this situation, the decision at Step F is “NOT ACCEPTABLE” in Figure 5, other  
33 assessment is required (Step E in Figure 5), and the provisions of the Alternate PTS  
34 Rule may not be used.
- 35 • For the case in which Step F is “ACCEPTABLE”, all recordable flaws less than the  
36 maximum of 0.1t or 1.0” must be checked against the flaw tables (Step D in Figure 5).
- 37 • If the result of Step D is “PASS,” the  $RT_{MAX-X}$  limits of the Alternate PTS Rule may be used  
38 (Step K in Figure 5).  
39

40 A sample calculation demonstrating acceptability by the “Preclude Brittle Fracture” option in Step I is  
41 demonstrated in Table 10.  
42  
43

1 Table 10. Sample Brittle Fracture Assessment

2

STEP D: Preclude Brittle Fracture for J-2 Flaws

Flaw No.	Flaw Position		Fluence at Clad/Base Metal Interface at Flaw Location (n/cm <sup>2</sup> ) <sup>a</sup>	Attenuation Factor, e <sup>-0.24x</sup>	Attenuated Fluence at Flaw Location (n/cm <sup>2</sup> )	End-of-Life Effective Full Power Years (EFPY)	Attenuated Flux at Flaw Location (n/cm <sup>2</sup> -sec)
	Height on RPV (inches)	RPV Circumferential Position (°)					
X	235.00	150.1	1.02E+19	0.6714	6.85E+18	54.0	4.02E+09
Y	235.14	157.7	1.02E+19	0.5231	5.34E+18	54.0	3.13E+09

Flaw No.	LINDE 80 Weld Chemistry <sup>b</sup>			
	RT <sub>NDT(0)</sub> (°F)	Cu (wt %)	Ni (wt %)	P (wt %)
X	-40	0.09	0.48	0.004
Y	-40	0.09	0.48	0.004

Flaw No.	Temperature (°F)	Effective Fluence (n/cm <sup>2</sup> )	φ <sub>0</sub>	A	B	Max(Cu <sub>0</sub> )	Cu <sub>0</sub>	f(Cu <sub>0</sub> ,P)	g(Cu <sub>0</sub> ,Ni,φ <sub>0</sub> )	MfTerm (°F)	CRPterm (°F)	ΔT <sub>30</sub> (°F)	
												RT <sub>NDT</sub> (°F)	RT <sub>NDT</sub> (°F)
X	550.0	1.272E+19	1.417E-07	155.0	155.0	0.2430	0.0900	0.0683	9.412E-01	29.2	256	54.8	14.8
Y	550.0	1.057E+19	1.417E-07	155.0	155.0	0.2430	0.0900	0.0683	9.253E-01	26.6	252	51.8	11.8

Notes: a. Determined from a plant-specific fluence map.  
 b. From RPV surveillance program.

## 6.2.2 Guidance on Considerations to Include in a Plant-Specific PFM Analysis

Guidance on the key considerations that should be included in a plant-specific PFM analysis to calculate TWCF, as identified by Step I in Figure 5, is provided in this section. Such guidance includes a mathematical procedure to combine NDE data with the PFM flow distribution used to develop the Alternate PTS Rule. A plant-specific TWCF analysis might be necessary based on Section d(4) of the Alternate PTS Rule [1], where the following is stated:

*(4) If the analysis required by paragraph (d)(3) of this section indicates that no reasonably practicable flux reduction program will prevent the  $RT_{MAX-X}$  value for one or more reactor vessel beltline materials from exceeding the PTS screening criteria, then the licensee shall perform a safety analysis to determine what, if any, modifications to equipment, systems, and operation are necessary to prevent the potential for an unacceptably high probability of failure of the reactor vessel as a result of postulated PTS events. In the analysis, the licensee may determine the properties of the reactor vessel materials based on available information, research results and plant surveillance data, and may use probabilistic fracture mechanics techniques...*

The PFM computer code, FAVOR [20], was developed by Oak Ridge National Laboratory (ORNL) under NRC funding to predict failure probabilities for embrittled vessels subject to PTS transients. FAVOR was used in the underlying TWCF analyses performed as a part of the development of the Alternate PTS Rule. Critical inputs to FAVOR are the number and sizes of fabrication flaws in the RPVs of interest and the characteristics of cooldown scenarios. The TWCF analysis further requires the expected frequencies of the cooldown scenarios. Work on flow distributions was coordinated with another NRC research program conducted by PNNL to perform examinations of RPV materials to detect and measure the numbers and sizes of fabrication flaws in welds and base metal. To supplement the limited data from flaw detection and measurements, PNNL applied an expert judgment elicitation process and the PRODIGAL flaw simulation model developed in the United Kingdom by Rolls-Royce and Associates. PNNL's experimental work on flaw distributions provided fabrication flaw data from nondestructive and destructive examinations, which were used to develop statistical distributions to characterize the numbers and sizes of flaws in the various regions of RPVs. Based on these statistical distributions, PNNL developed a computer program, VFLAW, which generated flaw distributions that were used as inputs to the FAVOR computer code [19]. These input files for FAVOR describe flaw distributions based on PNNL's research activities. The VFLAW program and the incorporation of plant-specific NDE data are therefore critical input elements for performing plant-specific TWCF analyses.

A recommended methodology for combining plant-specific NDE data with the PFM flow distribution used to develop the Alternate PTS Rule is provided in Appendix C. For the sample application to Beaver Valley 2 discussed in Appendix C (Table C-4), the results of which are repeated in this section in Table 11, revised flow parameters that represent a plant-specific flow distribution are shown. The revised parameters on the flaw uncertainty distribution may be used to generate a revised flaw distribution for Beaver Valley 2 that is consistent with the flaw distribution used in the PTS FAVOR analyses. The revised parameters will lead to revised flaw distributions that may be input to a FAVOR PFM analysis. These parameters have been customized using the Appendix C procedure based on Beaver Valley 2's specific geometry and as-found NDE data. The revised flaw distributions may be generated and used as input to FAVOR by re-running the VFLAW program with the revised parameters shown in Table 11. Re-running the VFLAW program allows adjustment of the generic VFLAW flaw distribution used to develop the Alternate PTS Rule into a plant-specific flaw distribution based on the updated

1 knowledge of flaws obtained from plant-specific ISI. As shown in Table 11, this yields a  
2 Bayesian updated flaw distribution for use in the plant-specific PFM required at Step I in  
3 Figure 5.

4  
5 As described in Appendix C, it is important to note that the VFLAW data, while representing  
6 generic values of flaw characteristics (based on expert judgment and the PVRUF and  
7 Shoreham RPVs), should be specialized to a specific RPV by using RPV-specific weld length,  
8 weld bead thickness, geometry, and other weld characteristics. Therefore, the specialized  
9 VFLAW data that results from this evaluation is the most representative information that can be  
10 used to describe a prior distribution of flaw depth and flaw density for a plant-specific PFM  
11 assessment. If other prior information is available, such information may also be used instead  
12 of, or in addition to, the specialized VFLAW data.

13  
14 A PFM analysis that calculates TWCF also requires (1) the thermal-hydraulic characteristics of  
15 the cooldown scenarios as input to FAVOR and (2) the frequency of those scenarios as input to  
16 the TWCF calculation. The characteristics and frequency of excessive cooldown scenarios are  
17 not developed by existing probabilistic risk assessments (PRAs), which only model the end  
18 states of core damage and containment failure. The PTS rulemaking relied on extensive PRA  
19 analyses to explore, identify, and characterize excessive cooldown end states.

20  
21 A plant-specific PFM analysis that calculates TWCF is complex, and there are many variations  
22 of inputs possible for such an analysis. Therefore, guidance for plant-specific PFM analysis to  
23 calculate TWCF is not included in this report. A discussion of the methodology that was used in  
24 performing a PFM analysis to calculate TWCF for PTS may be found in NUREG-1806 [6],  
25 NUREG-1807 [21], and NUREG/CR-6854 [22]. As indicated in the Alternate PTS Rule,  
26 plant-specific PFM analysis to calculate TWCF and the description of the modifications made to  
27 the plant-specific inputs must be submitted to the Director of NRR in the form of a license  
28 amendment at least three years before  $RT_{MAX-X}$  is projected to exceed the PTS screening  
29 criteria.

30  
31 The steps associated with conducting a plant-specific PFM evaluation are as follows:

- 32
- 33 • Bayesian Update of Flaw Distribution:
    - 34 ○ Apply the procedures of Appendix C and obtain revised flaw depth and flaw density
    - 35 parameters (similar to those shown in Table 11).
  - 36 • Calculate TWCF Using FAVOR:
    - 37 ○ Run VFLAW using the revised flaw depth and flaw density parameters.
    - 38 ○ Develop necessary plant-specific input using the guidance in NUREG-1806,
    - 39 NUREG-1807, and NUREG/CR-6854.
    - 40 ○ Run plant-specific FAVOR analysis.
    - 41 ○ Calculate the TWCF.
  - 42 • Compare Plant-Specific TWCF from FAVOR Analysis to Limit:
    - 43 ○ If the calculated TWCF value is less than or equal to the limit of  $1 \times 10^{-6}$  per reactor
    - 44 year specified in the Alternate PTS Rule, the NDE data are acceptable and the PTS
    - 45 Screening Criteria in Table 1 may be used (Step K in Figure 5).
    - 46 ○ If the TWCF value is greater than the limit of  $1 \times 10^{-6}$  per reactor year specified in the
    - 47 Alternate PTS Rule, the NDE data are unacceptable and the PTS Screening Criteria
    - 48 in Table 1 may not be used. Alternate actions are required to resolve PTS
    - 49 embrittlement issues, which may include changes to the facility to reduce the
    - 50 likelihood and/or severity of the cooldown transients. Plant-specific PTS assessment
    - 51 is required for review and approval by the Director of NRR (Step J in Figure 5).

1  
2  
3  
4  
5  
6

Table 11. Summary of the Revised Flaw Depth and Flaw Density VFLAW Parameters to be Used in a Revised PFM Analysis for Beaver Valley 2 (from Appendix C)

Case	Flaw Size Category	Original VFLAW Parameters of Uncertainty Distribution Used in PTS Work (Flaw Depth Parameters Specialized to Beaver Valley 2)	Revised Parameters of Uncertainty Distribution Based on Beaver Valley 2 NDE Data
1	Small ( $a \leq \Delta$ )	$\alpha_3 = 0.180$ $\alpha_4 = 1419$	$\alpha'_3 = 0.230$ $\alpha'_4 = 1909$
2	Large ( $a > \Delta$ )	$\alpha_3 = 0.180$ $\alpha_4 = 4$	$\alpha'_3 = 0.230$ $\alpha'_4 = 5$
3	Small ( $a \leq \Delta$ )	$U_1 = 34$ $U_2 = 8$ $U_3 = 1$	$U'_1 = 513.75$ $U'_2 = 17.71$ $U'_3 = 1.54$
4	Large ( $a > \Delta$ )	$\alpha_1 = 4.615$ $\alpha_2 = 4$	$\alpha'_1 = 4.563$ $\alpha'_2 = 5$

7  
8  
9

### 6.3 Guidance for Initial Evaluation of NDE Data

Guidance for initial evaluation of NDE data obtained from qualified ISI examinations, as identified in Steps A through F in Figure 5, are provided in this section. These steps are expected to be the most common use of the Alternate PTS Rule, and they represent a comparison of the as-reported NDE results with the flaw tables. Successful comparison of the NDE data to the flaw tables provides reasonable assurance that the plant-specific flaw distribution is bounded by the flaw distribution used in the development of the Alternate PTS Rule, therefore justifying application of the alternate PTS screening limits given in Table 1 to the plant in question.

As indicated under Item (e), "Examination and Flaw Assessment Requirements," of the Alternate PTS Rule, the volumetric examination results evaluated under paragraphs (e)(1), (e)(2), and (e)(3) must be acquired using procedures, equipment, and personnel that have been qualified under Supplements 4 and 6 to Mandatory Appendix VIII to Section XI of the ASME Code, as specified in 10 CFR 50.55a(b)(2)(xv). Paragraph (g)(6)(ii)(C) of 10 CFR 50.55a requires licensees to implement Supplements 4 and 6 to Appendix VIII to Section XI of the ASME Code. Supplement 4 contains qualification requirements for the RPV ISI volume from the clad-to-base-metal interface to the inner 15 percent of the RPV base-metal wall thickness. Supplement 6 contains qualification requirements for RPV weld volumes that lie within the outer 85% of the RPV base-metal wall thickness.

Figure 6 shows the ASME Code Section XI examination and flaw-evaluation process and identifies the flaws from that process that should be used for comparison to the Alternate PTS Rule flaw tables. As noted in the figure, the process used to identify flaws for comparison to the flaw tables is a subset of the process outlined in the ASME Code. All recordable flaws, subsequent to application of the flaw proximity rules of Subarticle IWA-3300 in Section XI of the ASME Code, are used for comparison to the Alternate PTS Rule flaw tables [17b].

A sampling of RPV weld examinations (done in accordance with Appendix VIII to Section XI of the ASME Code) from thirteen PWR RPVs is included in Reference [18]. This sampling is a compilation of several RPV beltline weld examinations performed since 2000 that were provided by Westinghouse in response to a request from the NRC. These results form the basis for the example comparison to the flaw tables that is shown in Figure 7 and in Table 12 through Table 15 in this document. A discussion of this figure and these tables is provided in the following paragraphs.

In the example shown in Figure 7 and in Table 12 through Table 15, the following evaluation process was used (Steps A through D and K in Figure 5):

Step A - Qualified Examination in Accordance with Appendix VIII to Section XI of the ASME Code

- The Appendix VIII examination results are shown for Plant J in Figure 7.
- Eleven welds (two girth welds and nine intersecting axial welds) were examined in the RPV beltline region. A total of eight combined recordable flaws (as defined by the process shown in Figure 6) were detected.

Step B - Do Axial Flaws > 0.075" in Depth at the Clad-to-Base-Metal Interface Open to the RPV Inside Surface?

- Based on the S dimension (distance of flaw below the clad-to-base-metal interface) shown in Figure 7 for all flaws, no flaws at the clad-to-base-metal interface require supplemental examination to confirm that they are not connected to the RPV inside surface.
- If supplemental examination is required, perform a demonstrated surface or visual examination of the clad surface within the required ASME Code Section XI



1 examination volume (e.g., Figures IWB-2500-1 and IWB-2500-2) to identify potential  
2 axial indications in the cladding surface that may extend into the base metal.

3 A demonstrated visual or surface examination is one that has been shown to be  
4 capable of detecting and characterizing inservice cracking in a clad surface  
5 representative of the reactor vessel cladding process. Eddy current test is one  
6 examination method acceptable to the staff for performing this verification.

- 7 ○ A method for determining the uncertainty in locating the position of axial flaws  
8 identified by surface or visual examination and the location of axial flaws identified by  
9 UT examination shall be documented. Any axial flaws located by UT within the  
10 uncertainty bounds of an axial crack shall be considered to be the same axial flaw.
- 11 ○ If it is confirmed that no axial flaws are connected to the RPV inside surface,  
12 Step B = "NO" in Figure 5.

13 Step C - Are All Flaws Acceptable According to Table IWB-3510-1 in Section XI of the ASME  
14 Code?

- 15 ○ As indicated in Figure 7 (in the column titled "ASME Code Disposition" in the second  
16 table), all recordable flaws are acceptable for meeting the requirements of  
17 Table IWB-3510-1 in Section XI of the ASME Code. The details of this  
18 determination are not shown.
- 19 ○ Therefore, Step C = "YES" in Figure 5.

20 Step D - For Flaws Located in the Inner 1.0" or 0.1t (Whichever Is Greater), Check Flaw Tables

- 21 ○ *Compute the Total Weld Length Examined.* The total weld examination length is  
22 determined in Table 12 based on the circumference of the RPV and the percentage  
23 of the weld examined (i.e., the coverage amount) for each of the eleven welds.
- 24 ○ *Compute the Total Plate Surface Area Examined.* The total plate surface area  
25 examined is determined in Table 13 based on the surface area of the ASME Code  
26 Section XI examination volume less the surface area of the weld for each of the  
27 eleven welds examined.
- 28 ○ *Determine the Position of Flaws.* The position of all flaws is determined in  
29 Table 14 as follows:
  - 30 ■ Determine whether the flaw resides in plate or weld material. This  
31 determination is based on the flaw position with respect to the weld  
32 centerline and the maximum crown width<sup>‡</sup> on either surface of the inspected  
33 weld; if the flaw position resides within the span of the weld centerline ±  
34 one-half of the weld crown width, the flaw was considered to be a WELD  
35 flaw. Otherwise, it was treated as a PLATE flaw.
  - 36 ■ Determine whether the flaw resides within the inner one inch or 10% of the  
37 base-metal wall thickness, whichever is greater, for comparison to the  
38 Alternate PTS Rule flaw tables.
  - 39 ■ Determine whether the flaw resides between the inner one inch or 10% of  
40 the base-metal thickness, whichever is greater, and the inner 37.5% of the  
41 base-metal wall thickness (3/8t), for potential evaluation of brittle fracture.

---


<sup>‡</sup> The weld crown width was used in this example for the entire RPV base-metal wall thickness, which can potentially classify flaws located mid-wall as weld flaws rather than plate flaws in single-groove or double-V-groove weld configurations. This approach is conservative with respect to the flaw limits in Table 2. Consideration should also be given to the proximity of the flaw to the weld's heat-affected zone (HAZ). An example might be that any flaw located in the plate material, but within some technically justified minimum distance from the edge of the weld, should be considered to be affected by the HAZ and therefore also considered to be a weld flaw. In addition, if there are any weld-repair areas located within the examination volume, any flaws detected within those areas should be classified as WELD flaws.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

- Based on the results shown in Table 14, two flaws should be compared to the Weld Flaw Table (Table 2) of the Alternate PTS Rule and one flaw should be compared to the Plate/Forging Flaw Table (Table 3) of the Alternate PTS Rule. Although two flaws reside between the inner one inch or 10% of the base-metal thickness, whichever is greater, and the inner 37.5% of the base-metal wall thickness (3/8t) from the clad/base-metal interface, they do not require further assessment for acceptability because they were found to be acceptable in accordance with Table IWB-3510-1.
- *Flaw Assessment:*
  - The flaws determined in the previous step to be located in the inner 1.0" or 0.1t (whichever is greater) are compared to the flaw tables from the Alternate PTS Rule in Table 15 and found to be acceptable.
  - The remaining two flaws located between the inner one inch or 10% of the base-metal thickness, whichever is greater, and the inner 37.5% of the base-metal wall thickness (3/8t) from the clad/base-metal interface are acceptable in accordance with Table IWB-3510-1.
  - Therefore, Step D = "PASS" in Figure 5.

Step K - PTS Screening Criteria (Table 1 of 10 CFR 50.61a) Is Applicable - Submittal Required

- Plant J is allowed to use the PTS Screening Criteria shown in Table 1. The licensee must submit their PTS evaluation to the NRC for review and approval.



1  
2  
3  
4  
5  
6

Figure 6. ASME Code Section XI Examination and Flaw Evaluation Process and Identification of Flaws for Comparison to Alternate PTS Rule.

**Step A: Plant J Examination Results:**

(see Westinghouse Letter LTR-AMLR-11-71 [18])


Reactor Vessel ISI History for Plant J Beltline Materials					
Weld ID	Description	Date Last Inspected	Percent Coverage Obtained	Number of Recordable Indications	Number of Reportable Indications
J-1	Nozzle Shell to Intermediate Shell Circ. Weld	2004	100	None	None
J-2	Intermediate Shell to Lower Shell Circ.	2004	100	4	None
J-3	Nozzle Shell Longitudinal Seam	2004	100	None	None
J-4	Nozzle Shell Longitudinal Seam	2004	100	None	None
J-5	Nozzle Shell Longitudinal Seam	2004	100	None	None
J-6	Intermediate Shell Longitudinal Seam	2004	100	None	None
J-7	Intermediate Shell Longitudinal Seam	2004	100	1	None
J-8	Intermediate Shell Longitudinal Seam	2004	100	None	None
J-9	Lower Shell Longitudinal Seam	2004	77.80 <sup>1</sup>	2	None
J-10	Lower Shell Longitudinal Seam	2004	77.80 <sup>1</sup>	None	None
J-11	Lower Shell Longitudinal Seam	2004	77.80 <sup>1</sup>	1	None

Note 1: Limitations exist due to core support lugs at bottom of lower shell longitudinal welds.

Reactor Vessel ISI Information for Potential Beltline Flaws Plant J																
Weld Number	Indication No.	Beam Direction	Weld Centerline (in.) or (°)	Weld width (in)	x (in)	θ (°)	2a (in)	a (in)	L (in)	t (in)	S (in)	a/L	AR	a/t (%)	Code Allowable a/t (%)	ASME Code Disposition
J-2	1	DN	235.00 in.	1.65	235.00	150.1	0.16	0.08	2.10	8.60	1.66	0.04	25.0	0.9	2.0	Allowable
	2	UP		1.65	235.14	157.7	0.12	0.06	1.25	8.60	2.70	0.05	20.0	0.7	2.2	Allowable
	3	UP		1.65	235.80	129.3	N/A	0.25	1.00	8.60	0.00 <sup>1</sup>	.25	4	2.9	3.3	Allowable
	4	UP		1.65	235.50	332.1	0.24	0.12	1.75	8.60	4.49	0.07	14.3	1.4	2.2	Allowable
J-7	1	CCW	120°	1.38	123.6	123.6	0.22	0.11	2.10	8.60	0.63	0.05	20.0	1.3	7.6	Allowable
J-9	1	DN	60°	1.38	256.50	60.3	0.25	0.13	1.60	8.60	0.11	0.08	12.5	1.5	1.87	Allowable
	2	CCW		1.38	240.30	60.4	0.34	0.17	1.60	8.60	0.79	0.11	9.1	2.0	2.5	Allowable
J-11	1	CCW	300°	1.38	312.61	300.3	0.27	0.14	1.75	8.60	3.60	0.08	12.5	1.6	2.2	Allowable

Note 1: S dimension is from outside diameter surface so this is an OD surface flaw.

Top of core position x=149.1 in.  
 Bottom of core position x=292.6 in.  
 Reactor Vessel Inner Diameter (without cladding)= 173 in.  
 Cladding Thickness= 0.156 in.



- 1
- 2
- 3
- 4

Figure 7. Sample Appendix VIII Examination Results for Plant J.

Table 12. Determination of Total Weld Length Examined for Plant J

**STEP D: Compute Total Weld Length Examined**

Weld ID	Direction	Radius, $R_i$ (inches)	Length (inches)	Comments	Examination Coverage	Examined Length, $L =$ Length * Coverage (inches)
J-1	Circumferential	86.5	543.5	Length computed as $2\pi R_i$	100%	543.5
J-2	Circumferential	86.5	543.5	Length computed as $2\pi R_i$	100%	543.5
J-3	Axial	N/A	70	Length assumed	100%	70.0
J-4	Axial	N/A	70	Length assumed	100%	70.0
J-5	Axial	N/A	70	Length assumed	100%	70.0
J-6	Axial	N/A	70	Length assumed	100%	70.0
J-7	Axial	N/A	70	Length assumed	100%	70.0
J-8	Axial	N/A	70	Length assumed	100%	70.0
J-9	Axial	N/A	70	Length assumed	77.8%	54.5
J-10	Axial	N/A	70	Length assumed	77.8%	54.5
J-11	Axial	N/A	70	Length assumed	77.8%	54.5
<b>Total, L =</b>						<b>1,670.4</b>

1 Table 13. Determination of Total Plate Surface Area Examined for Plant J

**STEP D: Compute Total Plate Surface Area Examined**

Weld ID	Examined Length, L	Weld Width, $W_w$ <sup>(1)</sup> (inches)	Examination Width, $W_E$ <sup>(2)</sup> (inches)	Comments	Plate Surface Area (inches <sup>2</sup> )
J-1	543.5	1.65	8.60	Plate surface area computed as $L \times (W_E - W_w)$	3,777.29
J-2	543.5	1.65	8.60	Plate surface area computed as $L \times (W_E - W_w)$	3,777.29
J-3	70.0	1.38	8.60	Plate surface area computed as $L \times (W_E - W_w)$	505.40
J-4	70.0	1.38	8.60	Plate surface area computed as $L \times (W_E - W_w)$	505.40
J-5	70.0	1.38	8.60	Plate surface area computed as $L \times (W_E - W_w)$	505.40
J-6	70.0	1.38	8.60	Plate surface area computed as $L \times (W_E - W_w)$	505.40
J-7	70.0	1.38	8.60	Plate surface area computed as $L \times (W_E - W_w)$	505.40
J-8	70.0	1.38	8.60	Plate surface area computed as $L \times (W_E - W_w)$	505.40
J-9	54.5	1.38	8.60	Plate surface area computed as $L \times (W_E - W_w)$	393.20
J-10	54.5	1.38	8.60	Plate surface area computed as $L \times (W_E - W_w)$	393.20
J-11	54.5	1.38	8.60	Plate surface area computed as $L \times (W_E - W_w)$	393.20
<b>Total, A =</b>					<b>11,766.6</b>

- 2 Notes: (1) The weld width,  $W_w$ , is defined as the maximum weld crown width from both sides of the RPV wall. From Figure 7,  $W_w$  is 1.65" for  
3 circumferential welds and 1.38" for axial welds.  
4 (2) The examination width,  $W_E$ , is defined as the ASME Code Section XI examination volume width, which is one-half of the wall thickness on  
5 both sides of the weld. From Figure 7, the RPV base-metal wall thickness, which is equal to  $W_E$ , is 8.60".  
6  
7  
8

1 Table 14. Determination of the Flaw Positions for Plant J

STEP D: Determine Position of Flaws

Weld No.	Indication No.	Weld Centerline	Weld Width (inches)	Height on RPV (inches)	Flaw Position		Weld or Plate Flaw?	Is Flaw Within First 1.0" or 0.10k?	Is Flaw Within First 3/8t?	Through Wall Extent (TWE) = 2a (inches)	Evaluation Required
					RPV Circumferential Position (°)	Depth Below Clad (inches)					
J-2	1	235 in	1.65	235.00	150.1	1.66	WELD	NO	YES	0.16	Acceptable per ASME XI Table IWB-3510-1
	2	235 in	1.65	235.14	157.7	2.70	WELD	NO	YES	0.12	Acceptable per ASME XI Table IWB-3510-1
	3	235 in	1.65	235.80	129.3	8.60	WELD	NO	NO	0.50	No evaluation for 50.61a required
	4	235 in	1.65	235.50	332.1	4.49	WELD	NO	NO	0.24	No evaluation for 50.61a required
J-7	1	120 °	1.38	123.60	123.6	0.63	PLATE	YES	N/A	0.22	Compare to Weld Flaw Table
J-9	1	60 °	1.38	256.50	60.3	0.11	WELD	YES	N/A	0.25	Compare to Weld Flaw Table
	2	60 °	1.38	240.30	60.4	0.79	WELD	YES	N/A	0.34	Compare to Weld Flaw Table
J-11	1	300 °	1.38	312.61	300.3	3.60	WELD	NO	NO	0.27	No evaluation for 50.61a required

Table 15. Comparison of Flaws to Alternate PTS Rule Flaw Tables for Plant J

STEP D: Compare Flaws to 10 CFR 50.61a Flaw Tables  
 Table 2 Comparison = Weld Flaws

Bin No.	Minimum TWE (inches)	Maximum TWE (inches)	(Allowable)		(Cumulative)		Acceptable?	Flaws
			Max. # of Flaws per 1,000 inches	# of Flaws Detected	# of Flaws / L x 1,000	# of Flaws Detected		
1	0	0.075	No limit	0	0.00	YES		
2	0.075	0.475	166.70	2	1.20	YES	J-9-1, J-9-2	
3	0.125	0.475	90.80	2	1.20	YES	J-9-1, J-9-2	
4	0.175	0.475	22.82	2	1.20	YES	J-9-1, J-9-2	
5	0.225	0.475	8.66	2	1.20	YES	J-9-1, J-9-2	
6	0.275	0.475	4.01	2	1.20	YES	J-9-1, J-9-2	
7	0.325	0.475	3.01	1	0.60	YES	J-9-1	
8	0.375	0.475	1.49	0	0.00	YES		
9	0.425	0.475	1.00	0	0.00	YES		
10	0.475	Infinite	0.00	0	0.00	YES		

Table 3 Comparison = Plate/Forging Flaws

Bin No.	Minimum TWE (inches)	Maximum TWE (inches)	(Allowable)		(Cumulative)		Acceptable?	Flaws
			Max. # of Flaws per 1,000 inches	# of Flaws Detected	# of Flaws / A x 1,000	# of Flaws Detected		
1	0	0.075	No limit	0	0.00	YES		
2	0.075	0.375	8.05	1	0.08	YES	J-7-1	
3	0.125	0.375	3.15	1	0.08	YES	J-7-1	
4	0.175	0.375	0.85	1	0.08	YES	J-7-1	
5	0.225	0.375	0.29	0	0.00	YES		
6	0.275	0.375	0.08	0	0.00	YES		
7	0.325	0.375	0.01	0	0.00	YES		
8	0.375	Infinite	0.00	0	0.00	YES		



## 6.4 Guidance for Further Evaluation of NDE Data

Guidance for further evaluation of NDE data (Steps G through I in Figure 5) is provided in this section. Such guidance is based on Section II, "Discussion," provided in the Supplemental Information section of the Federal Register Notice for the Alternate PTS Rule [2], where the following discussion is included with respect to NDE-Related Uncertainties:

*The flaw sizes in Tables 2 and 3 represent actual flaw dimensions while the results from the ASME Code examinations are estimated dimensions. The available information indicates that, for most flaw sizes in Tables 2 and 3, qualified inspectors will oversize flaws. Comparing oversized flaws to the size and density distributions in Tables 2 and 3 is conservative and acceptable, but not necessary.*

*As a result of stakeholder feedback received on the NRC solicitation for comments published in the August 2008 supplemental proposed rule, the final rule will permit licenses to adjust the flaw sizes estimated by inspectors qualified under the ASME Code, Section XI, Appendix VIII, Supplement 4 and Supplement 6.*

*The NRC determined that, in addition to the NDE sizing uncertainties, licensees should be allowed to consider other NDE uncertainties, such as probability of detection and flaw density and location, because these uncertainties may affect the ability of a licensee to demonstrate compliance with the rule. As a result, the language in § 50.61a(e) will allow licensees to account for the effects of NDE-related uncertainties in meeting the flaw size and density requirements of Tables 2 and 3. The methodology to account for the effects of NDE-related uncertainties must be based on statistical data collected from ASME Code inspector qualification tests or any other tests that measure the difference between the actual flaw size and the size determined from the ultrasonic examination...*

Specific guidance on various elements of NDE data evaluation is provided in the following sections.

### 6.4.1 Guidance on the Elements and NDE Techniques Associated with ASME Code Examinations

The Alternate PTS Rule was developed using a flaw density, spatial distribution, and size distribution determined from experimental data, as well as from physical models and expert judgment. To implement the Alternate PTS Rule, actual flaw densities and distributions need to be estimated from the results of periodic ISI performed on RPV welds and adjacent base material. The method for these examinations is ultrasonic testing (UT). As discussed in Section 6.3, the data used for evaluation of the Alternate PTS Rule must be acquired using procedures, equipment and personnel that are qualified under Supplements 4 and 6 to Appendix VIII to Section XI of the ASME Code. Appendix VIII provides requirements for performance demonstration for UT examination procedures, equipment, and personnel used to detect and size flaws. Supplement 4 specifies qualification requirements for examination of the inner 15% of clad ferritic reactor vessels, and may also be applied to the inner 15% of unclad ferritic reactor vessels. Supplement 6 specifies qualification requirements for examination of unclad ferritic components and the outer 85% of clad ferritic components.

Supplement 4 provides performance-demonstration rules intended to produce effective procedures, personnel, and equipment for detection and sizing of flaws typical of those that might be expected to form as a result of service conditions. These rules result in targeting flaws

1 that are primarily planar in orientation and emanate from the inside surface (clad-to-base-metal  
2 interface) of the RPV specimens that are used for the qualification process. The aspect ratio of  
3 flaws used for performance demonstration also closely follows the acceptance criteria of  
4 Article IWB-3000 in Section XI of the ASME Code. These flaws are the focus of the  
5 performance demonstration because they are of structural significance under standard  
6 operating conditions. Therefore, the objective of Supplement 4 qualification is to demonstrate  
7 UT capabilities on planar flaws. Examinations using Appendix VIII qualification may also detect  
8 larger fabrication flaws; this is often the case in practice because no known credible subcritical  
9 cracking mechanisms affect the RPV material for the current fleet of U.S. reactors.

10  
11 The PFM analyses supporting the Alternate PTS Rule assumed all flaws were planar in nature.  
12 Because the empirical evidence on which the flaw distribution used in these analyses was  
13 based included both planar flaws and fabrication flaws [19], this assumption was viewed as  
14 being conservative because it produced a higher density of planar flaws than typically exist in  
15 nuclear RPVs. Fabrication flaws are considerably smaller than would be expected to exist  
16 within current Supplement 4 qualification specimens and are not typically connected to the  
17 clad-to-base-metal interface. Nevertheless, it is probable that parameters associated with  
18 qualified UT methods may be optimized to enhance the method's capability to detect and size  
19 small fabrication flaws in the inner one inch of RPV base material. Therefore, licensees should  
20 consider enhancements to Appendix-VIII-qualified procedures to ensure accurate detection and  
21 sizing of the flaws inferred by the Alternate PTS Rule while maintaining the essential variables  
22 for which the procedure was qualified.

23  
24 Within the context of a qualified Appendix VIII RPV examination, various elements and NDE  
25 techniques associated with the examination might be able to be varied to provide better NDE  
26 data for comparison with the flaw limits included in Tables 2 and 3 of the Alternate PTS Rule.  
27 Such elements and techniques may include, but are not be limited to, the following:

- 28
- 29 • Reducing the scan index;
- 30 • Use of an ultrasonic straight-beam examination technique; or
- 31 • Use of an enhanced recording criterion (lower threshold).
- 32

33 NRC staff have been working with UT/NDE experts at Pacific Northwest National Laboratory  
34 (PNNL) to assess RPV examination and implementation of the Alternative PTS Rule. The  
35 assessment, including enhancements to procedures and examination techniques, is addressed  
36 in a Technical Letter Report (TLR) [24]. Due consideration of the above elements should be  
37 given when establishing the protocols and procedures for Appendix VIII examinations used by  
38 licensees who choose to apply the Alternate PTS Rule in order to maximize the usefulness of  
39 the resulting NDE data and provide reasonable assurance of the acceptability of the NDE data  
40 comparisons required by the Alternate PTS Rule.

#### 41

#### 42 **6.4.2 Guidance on a Procedure to Adjust NDE Data and Comparison to Flaws**

#### 43 **Assumed in PFM Calculations**

44 Guidance on a mathematical procedure that can be used to adjust NDE data to account for  
45 flaw-detection and -sizing errors, as identified by Step G in Figure 5, is provided in this section. This  
46 evaluation adjusts the as-found NDE data by taking into account flaw-sizing errors, POD  
47 uncertainties, and prior flaw distributions such as those used in the development of the Alternate  
48 PTS Rule (i.e., VFLAW [19]). Any or all of these uncertainties may be considered, depending on the  
49 level of detail needed for flaw assessment. After such adjustment, the adjusted NDE results may be

1 compared with the flaw tables again (Step H in Figure 5) because NDE techniques tend to oversize  
2 smaller flaws, thereby distributing detected flaws into larger bins where the allowed number of flaws  
3 is smaller. In such cases, adjustment for NDE flaw-detection and -sizing uncertainties may result in  
4 a less conservative distribution of flaw sizes, possibly allowing a comparison of the adjusted NDE  
5 data to the flaw tables to be successful. A successful comparison of the revised NDE data to the  
6 flaw tables would be viewed by the staff as providing reasonable assurance that the plant-specific  
7 flaw distribution is bounded by the flaw distribution used in the development of the Alternate PTS  
8 Rule, indicating that it is appropriate to apply the alternate PTS screening limits (Step K in Figure 5).

9  
10 Appendix C describes the development and application of a methodology to account for  
11 uncertainties in NDE data and for analyzing such data for the purpose of developing more  
12 realistic vessel-specific flaw depth and density distributions for comparison to the flaw tables, as  
13 well as for plant-specific PFM analysis (discussed in Section 6.2.2). The methodology  
14 considers POD, flaw-measurement error, and flaw-detection threshold in its application and  
15 uses Bayesian updating to combine the observed NDE data with the available flaw data and  
16 models used as part of the PTS re-evaluation effort. The Bayesian framework used by this  
17 methodology is described in Appendix C, followed by application details of the NDE data  
18 uncertainties (i.e., POD and measurement/sizing error) and the Bayesian updating procedure.  
19 Application of the methodology is demonstrated in Appendix C using the ultrasonic NDE data  
20 obtained from a previous ISI examination of the Beaver Valley 2 RPV and a MATLAB software  
21 routine that uses the Bayesian equations developed in Appendix C. The MATLAB software  
22 listing is also included in Appendix C.

23 As an example of this procedure, assume that Plant J performs an initial NDE assessment using  
24 the guidance of Section 6.3 with the results shown in Table 16. These results indicate that  
25 Plant J fails the Alternate PTS Rule flaw-table check based on violating the flaw-acceptance  
26 limit for Flaw Bin #2, i.e., 170.10 actual flaws per 1,000 inches of weld vs. 166.70 allowed flaws  
27 per 1,000 inches of weld. Therefore, Step D in Figure 5 yields a “FAIL” decision, thereby  
28 necessitating the evaluations associated with Step G in Figure 5. As a result, procedures  
29 similar to those described in Appendix C should be applied.

30  
31 A key input for this procedure is a POD and associated sizing error data appropriate to the  
32 methods and techniques used to examine the RPV. Example PODs and flaw-sizing error data  
33 have been previously developed by the Electric Power Research Institute (EPRI) based on  
34 Performance Demonstration Initiative (PDI) qualification data [26]. Similar information should be  
35 obtained for the examination technique being applied and technically justified for use as a part  
36 of applying the procedures described in Appendix C.

37

38

1 Table 16. Example for Plant J After Applying an Initial Alternate PTS Rule Flaw Table Check  
 2 Using the Procedure in Section 6.3.

3

Flaw Bin #	Flaw Depth (inch)	Observed (Detected) Number of Flaws from NDE ISI	10 CFR 50.61a Flaw Limits (# of Flaws per 1,000" of Weld)	Acceptable? (Is No. of Flaws < Limit?)
1	$0.000 < a \leq 0.075$	234.45	No limit	Yes
2	$0.075 < a \leq 0.475$	170.10	166.70	No
3	$0.125 < a \leq 0.475$	11.23	90.80	Yes
4	$0.175 < a \leq 0.475$	0.90	22.82	Yes
5	$0.225 < a \leq 0.475$	0.05	8.66	Yes
6	$0.275 < a \leq 0.475$	0.01	4.01	Yes
7	$0.325 < a \leq 0.475$	0.00	3.01	Yes
8	$0.375 < a \leq 0.475$	0.00	1.49	Yes
9	$0.425 < a \leq 0.475$	0.00	1.00	Yes

4

5 **6.4.2.1 Guidance on Application of NDE Uncertainties**

6 Appendix D discusses the results of sensitivity analyses that apply the Appendix C Bayesian  
 7 updating methodology to systematically assess the effect of NDE uncertainties such as POD  
 8 and measurement (sizing) error on the estimated flaw populations. The sensitivity analyses  
 9 were performed for a base case and twelve sensitivity cases that investigated variations in  
 10 observed NDE data and application of prior probability density functions (PDFs), POD, and  
 11 flaw-sizing error.

12 As a part of the sensitivity studies, lower NDE detection limits of 0.04" and 0.075" were also  
 13 evaluated and found to have no significant impact on the observed data.

14 The results obtained from the twelve sensitivity cases consistently show that small (i.e., 10%)  
 15 overpopulation of flaws in Bins 2 and 3 of the Alternate PTS Rule flaw tables, as might be  
 16 expected from actual plant inspections because of oversizing of small flaws, would be shifted to  
 17 Bins 1 and 2 after accounting for the measurement error in the Bayesian inference. When POD  
 18 was also considered, the effects of small flaws that might be missed by NDE methods were  
 19 clearly seen in Bins 1 and 2, with an additional number of flaws in the posterior estimates as  
 20 compared to the observed flaws. However, the results are sensitive to the POD used,  
 21 especially the portion of the POD for smaller flaw sizes. It is therefore important that, if a POD  
 22 is used, the POD must be sufficiently justified.

23 The effects of the consideration and choice of the prior distributions of flaw density and depth  
 24 were significant. When no prior information was used to describe the flaw-density and  
 25 flaw-depth distributions, POD and measurement error were very sensitive, and significantly  
 26 amplified the number of flaws that resulted in Bins 1 and 2. However, when prior PDFs were

1 used, the posteriors were significantly moderated by the existence of the prior PDFs, and the  
2 POD and measurement errors played less significant roles.

3 The results of the sensitivity analysis documented in Appendix D reveal the following:

- 4 • Neglecting consideration of prior PDFs in the evaluation provides a conservative  
5 assessment.
- 6 • Neglecting consideration of flaw-sizing error in the evaluation provides a conservative  
7 assessment.
- 8 • POD has a significant impact in the evaluation and should be included for the case in  
9 which PDFs are not considered. For the case in which PDFs are evaluated, the impact  
10 of POD is relatively small and may be neglected.
- 11 • Consideration of flaw-sizing error, POD, or prior PDFs (identified as “NDE uncertainties”  
12 in the Alternate PTS Rule) using methods similar to those shown in Appendix C is  
13 successful in removing conservatisms that may unnecessarily prevent a licensee from  
14 passing the Alternate PTS Rule flaw tables.

15



## 7. GUIDANCE ON CRITERIA RELATING TO ALTERNATE LIMITS ON EMBRITTLEMENT

Paragraph (c)(3) of 10 CFR 50.61a states the following:

*Each licensee shall compare the projected  $RT_{MAX-X}$  values for plates, forgings, axial welds, and circumferential welds to the PTS screening criteria in Table 1 of this section, for the purpose of evaluating a reactor vessel's susceptibility to fracture due to a PTS event. **If any of the projected  $RT_{MAX-X}$  values are greater than the PTS screening criteria in Table 1 of this section, then the licensee may propose the compensatory actions or plant-specific analyses as required in paragraphs (d)(3) through (d)(7) of this section, as applicable, to justify operation beyond the PTS screening criteria in Table 1 of this section.***

This section describes one method by which licensees could perform the plant-specific analyses indicated by the **highlighted text**. This method is acceptable to the staff provided that the requirements of 10 CFR 50.61a concerning flaw evaluations and surveillance assessment are satisfied.

The  $RT_{MAX-X}$  limits in Table 1 of 10 CFR 50.61a were established in NUREG-1874 to ensure that the TWCF remains below  $1 \times 10^{-6}$  per reactor year. As described in NUREG-1874, the  $RT_{MAX-X}$  limits are based on the results of PFM analyses; they account for the combined TWCF contributions from various flaw populations in the RPV. Some simplifications of the PFM data underlying these limits were necessary to permit their expression in a tabular form. As an example, the TWCF attributable to circumferentially-oriented flaws occurring in circumferential welds was held below  $1 \times 10^{-8}$  per reactor year rather than  $1 \times 10^{-6}$  per reactor year. This simplification was made for expedience and was not intended to address a safety concern. Therefore, the following procedure, which eliminates similar simplifying assumptions, can be used to demonstrate compliance with the  $RT_{MAX-X}$  limits in Table 1 of 10 CFR 50.61a. This procedure was originally described in Section 3.5.1 of NUREG-1874:

1. Determine  $RT_{MAX-X}$  for all axial welds ( $RT_{MAX-AW}$ ), plates ( $RT_{MAX-PL}$ ), circumferential welds ( $RT_{MAX-CW}$ ), and forgings ( $RT_{MAX-FO}$ ) in the RPV beltline region according to the requirements of 10 CFR 50.61a. These  $RT_{MAX-X}$  values must be expressed in units of Rankine (R) (degrees Fahrenheit (°F) plus 459.69).
2. Use the  $RT_{MAX-X}$  values from Step 1 to estimate the 95<sup>th</sup> percentile TWCF contribution from each component in the beltline using the following formulas:

$$TWCF_{95-AW} = \exp\{5.5198 \cdot \ln(RT_{MAX-AW} - 616) - 40.542\} \cdot \beta \quad (19)$$

$$TWCF_{95-PL} = \exp\{23.737 \cdot \ln(RT_{MAX-PL} - 300) - 162.38\} \cdot \beta \quad (20)$$

$$TWCF_{95-CW} = \exp\{9.1363 \cdot \ln(RT_{MAX-CW} - 616) - 65.066\} \cdot \beta \quad (21)$$

$$TWCF_{95-FO} = \exp\{23.737 \cdot \ln(RT_{MAX-FO} - 300) - 162.38\} \cdot \beta + \eta \cdot \{1.3 \times 10^{-137} \cdot 10^{0.185 \cdot RT_{MAX-FO}}\} \cdot \beta \quad (22)$$

where:

$\eta = 0$  if the forging is compliant with Regulatory Guide 1.43; otherwise  $\eta = 1$ .

1  $\beta = 1$  if  $T_{WALL} \leq 9.5$  inches  
 2  $\beta = 1 + 8 \times (T_{WALL} - 9.5)$  if  $9.5 < T_{WALL} < 11.5$  inches  
 3  $\beta = 17$  if  $T_{WALL} \geq 11.5$  inches  
 4

- 5 3. Estimate the total 95<sup>th</sup> percentile TWCF for the RPV using the following formulae  
 6 (noting that, depending on the type of vessel in question, certain terms in the  
 7 following formula will be zero).  
 8

$$TWCF_{95-TOTAL} = \begin{bmatrix} \alpha_{AW} \cdot TWCF_{95-AW} + \\ \alpha_{PL} \cdot TWCF_{95-PL} + \\ \alpha_{CW} \cdot TWCF_{95-CW} + \\ \alpha_{FO} \cdot TWCF_{95-FO} \end{bmatrix} \quad (23)$$

9  
 10 where:

11  $\alpha = 2.5$  if  $RT_{MAX-xx} \leq 625$  R

12  $\alpha = 2.5 - \frac{1.5}{250} (RT_{MAX-xx} - 625)$  if  $625 \text{ R} < RT_{MAX-xx} < 875 \text{ R}$

13  $\alpha = 1$  if  $RT_{MAX-xx} \geq 875$  R

- 14  
 15  
 16  
 17 4. If  $TWCF_{95-TOTAL}$  from Step 3 is less than  $1 \times 10^{-6}$  per reactor year, the requirements of  
 18 Table 1 of 10 CFR 50.61a are met.  
 19



## 8. SUMMARY

---

In early 2010, the NRC promulgated the Alternate PTS Rule in 10 CFR 50.61a, which amended existing regulations to provide alternate embrittlement requirements for protection against PTS events for PWR RPVs. These requirements are based on more comprehensive, accurate, and realistic analysis methods than those used to establish the limits in 10 CFR 50.61. This action became desirable because the existing requirements, as contained in 10 CFR 50.61, are based on unnecessarily conservative assumptions. While still maintaining adequate safety margins, the Alternate PTS Rule reduces regulatory burden for those PWR licensees who expect to exceed the 10 CFR 50.61 embrittlement requirements before the expiration of their operating licenses. PWR licensees may choose to comply with the Alternate PTS Rule as a voluntary alternative to complying with the requirements contained in 10 CFR 50.61.

The Alternate PTS Rule provides revised PTS screening criteria in the form of embrittlement reference temperatures,  $RT_{MAX-X}$ , that characterize the RPV material's resistance to fracture initiating from flaws. The  $RT_{MAX-X}$  embrittlement limits may be used by licensees provided that the following criteria are met:

1. **Criteria relating to the date of construction and design requirements:** The Alternate PTS Rule is applicable to licensees whose construction permits were issued before February 3, 2010, and whose RPVs were designed and fabricated to the 1998 Edition or an earlier edition of the ASME Code. The reason for this applicability restriction is that the structural and thermal hydraulic analyses that established the basis for the Alternate PTS Rule's embrittlement limits only represented plants constructed before this date. It is the responsibility of a licensee to demonstrate that the risk-significant factors controlling PTS for any plant constructed after February 3, 2010, are adequately addressed by the technical basis calculations developed in support of the Alternate PTS Rule. Chapter 4 of this document describes methods by which licensees can satisfy these criteria and identifies factors to be considered in such an evaluation.
2. **Criteria relating to plant-specific surveillance data:** The Alternate PTS Rule includes statistical tests that must be performed on RPV surveillance data to determine whether the surveillance data are sufficiently "close" to the predictions of an ETC that the predictions of the ETC are valid for use. From a regulatory perspective, it is of particular interest to determine whether plant-specific surveillance data deviate significantly from the predictions of the ETC in a manner that suggests that the ETC is very likely to underpredict plant-specific data trends. Chapter 5 of this document describes guidance by which licensees can assess the closeness of plant-specific data to the ETC using statistical tests. This guidance includes the following, including:
  - A detailed description of the mathematical procedures to use to assess compliance with the three statistical tests in the Alternative PTS Rule.
  - A list of factors to consider in diagnosing the reason that particular surveillance data sets may fail these statistical tests.
  - A description of certain situations in which routine adjustments of the ETC predictions can be made.
3. **Criteria relating to ISI data and NDE requirements:** The Alternate PTS Rule describes a number of tests of and conditions on the collection and analysis of ISI data that are intended to provide reasonable assurance that the distribution of flaws that was

1 assumed to exist in the PFM calculations that provide the basis for the  $RT_{MAX-X}$  limits  
2 provide an appropriate, or bounding, model of the population of flaws in the RPV of  
3 interest. Chapter 6 of this NUREG includes guidance by which licensees can satisfy  
4 these criteria. The guidance discussed in this chapter includes the following  
5 components:

- 6     ▪ Guidance for plants for the case in which RPV flaws fall outside the  
7 applicability of the flaw tables in the Alternate PTS Rule, including:
  - 8         i. A mathematical procedure that can be used to preclude brittle  
9 fracture based on  $RT_{NDT}$  information.
  - 10        ii. A mathematical procedure that can be used to combine the NDE  
11 data with the population of flaws assumed in the PFM calculations to  
12 estimate the total flaw distribution that is predicted to exist in the  
13 RPV, as well as guidance on the use of this total flaw distribution as  
14 part of a PFM calculation using the FAVOR computer code.
- 15     ▪ Guidance for initial evaluation of NDE data obtained from qualified ISI  
16 examinations.
- 17     ▪ Guidance for further evaluation of NDE data obtained from qualified ISI  
18 examinations, as follows:
  - 19         i. The elements and NDE techniques associated with the qualified ISI  
20 examinations performed in accordance with Mandatory Appendix VIII  
21 to Section XI of the ASME Code to assess compliance with the  
22 requirements of the Alternate PTS Rule.
  - 23         ii. A mathematical procedure that can be used to adjust NDE data to  
24 account for flaw-detection and -sizing errors and comparison of the  
25 adjusted data to the population of flaws assumed in the PFM  
26 technical basis for the Alternate PTS Rule.

- 27  
28 4. **Criteria relating to alternate limits on embrittlement:** Guidance is provided by which  
29 licensees can estimate a plant-specific value of TWCF for cases in which the  $RT_{MAX-X}$   
30 limits of the Alternate PTS Rule are not satisfied. Chapter 7 of this document describes  
31 these two sets of guidance so that licensees can satisfy embrittlement acceptability  
32 criteria.

33  
34 This document provides guidance and the associated technical basis for methods by which the  
35 above criteria can be satisfied.  
36

## 9. REFERENCES

---

- [1] U.S. Code of Federal Regulations, Title 10, "Energy," Chapter I, Section 50.61a, "Alternate Fracture Toughness Requirements for Protection Against Pressurized Thermal Shock Events" (10 CFR 50.61a).
- [2] U.S. Nuclear Regulatory Commission, "Alternate Fracture Toughness Requirements for Protection Against Pressurized Thermal Shock Events," *Federal Register*, Vol. 75, No. 1, January 4, 2010, pp. 13–29 (75 FR 13).
- [3] U.S. Code of Federal Regulations, Title 10, "Energy," Chapter I, Section 50.61, "Fracture Toughness Requirements for Protection Against Pressurized Thermal Shock Events" (10 CFR 50.61).
- [4] American Society of Mechanical Engineers, *Boiler and Pressure Vessel Code*, 2013 edition, Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components," New York, NY.
- [5] U.S. Code of Federal Regulations, Title 10, "Energy," Chapter I, Section 50.66, "Requirements for Thermal Annealing of the Reactor Pressure Vessel" (10 CFR 50.66).
- [6] U.S. Nuclear Regulatory Commission, "Technical Basis for Revision of the Pressurized Thermal Shock (PTS) Screening Limit in the PTS Rule (10 CFR 50.61): Summary Report," NUREG-1806, August 2007.
- [7] U.S. Nuclear Regulatory Commission, "Recommended Screening Limits for Pressurized Thermal Shock (PTS)," NUREG-1874, March 2010.
- [8] Elliot, B.J., Senior Materials Engineer, U.S. Nuclear Regulatory Commission, memorandum to M.A. Mitchell, Branch Chief, U.S. Nuclear Regulatory Commission, "Development of Flaw Size Distribution Tables for Draft Proposed Title 10 of the Code of Federal Regulations (10 CFR) 50.61a," April 3, 2007, Agencywide Documents Access and Management System (ADAMS) Accession No. ML070950392.
- [9] Eason, E.D., et al., "A Physically Based Correlation of Irradiation-Induced Transition Temperature Shifts for RPV Steels," ORNL/TM-2006/530, November 2007, Oak Ridge National Laboratory, Oak Ridge, TN, ADAMS Accession No. ML081000630.
- [10] Electric Power Research Institute (EPRI), "Materials Reliability Program: Proposed Resolutions to the Analytical Challenges of Alternate PTS Rule (10 CFR 50.61a) Implementation (MRP-334)," Technical Update No. 1024811, January 2012, Palo Alto, CA.
- [11] U.S. Code of Federal Regulations, Title 10, "Energy," Chapter I, Section 50.55a, "Codes and Standards" (10 CFR 50.55a).
- [12] ASME, *Boiler and Pressure Vessel Code*, Mandatory Appendix VIII, "Performance Demonstration for Ultrasonic Examination Systems," to Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components," New York, NY, 2013 edition.

- 1 [13] *U.S. Code of Federal Regulations*, Title 10, "Energy," Chapter I, Part 50, "Domestic  
2 Licensing of Production and Utilization Facilities," Appendix H, "Reactor Vessel  
3 Material Surveillance Program Requirements."
- 4 [14] U.S. Nuclear Regulatory Commission, "Statistical Procedures for Assessing  
5 Surveillance Data for 10 CFR Part 50.61a," June 9, 2008, ADAMS Accession  
6 No. ML081290654.
- 7 [15] U.S. Nuclear Regulatory Commission, "Technical Basis for Revision of Regulatory  
8 Guide 1.99: NRC Guidance on Methods to Estimate the Effects of Radiation  
9 Embrittlement on the Charpy V-Notch Impact Toughness of Reactor Vessel  
10 Materials," draft NUREG report, October 1, 2007, ADAMS Accession  
11 No. ML081120289.
- 12 [16] U.S. Nuclear Regulatory Commission, "Radiation Embrittlement of Reactor Vessel  
13 Materials," Regulatory Guide 1.99, Rev. 2, May 1988, ADAMS Accession  
14 No. ML003740284.
- 15 [17] NRC Public Meeting Summary Reports:
- 16 a. U.S. Nuclear Regulatory Commission, "Category 2 Public  
17 Meeting - Discussion of Reactor Pressure Vessel Integrity Issues for  
18 Operating Nuclear Power Plants," August 5, 2011, ADAMS Accession  
19 No. ML112170262.
- 20 b. U.S. Nuclear Regulatory Commission, "Category 2 Public  
21 Meeting - Discussion of Nondestructive Examination Aspects of Reactor  
22 Pressure Vessel Integrity Issues for Operating Nuclear Power Plants,"  
23 October 6, 2011, ADAMS Accession No. ML112790501.
- 24 c. U.S. Nuclear Regulatory Commission, "Category 2 Public  
25 Meeting - Discussion of Reactor Pressure Vessel Integrity Issues for  
26 Operating Nuclear Power Plants," November 18, 2011, ADAMS Accession  
27 No. ML113220295.
- 28 [18] Palm, Nathan A., Fellow Engineer, and Michael G. Semmler, Acting Manager,  
29 Westinghouse Electric Company, letter to Dr. Aladar Csontos, Branch Chief,  
30 U.S. Nuclear Regulatory Commission, "Inspection Data for Use in Development of  
31 Alternate Pressurized Thermal Shock (PTS) Rule Implementation Regulatory  
32 Guide," LTR-AMLR-11-71, September 7, 2011, ADAMS Accession  
33 No. ML112560145.
- 34 [19] U.S. Nuclear Regulatory Commission, "A Generalized Procedure for Generating  
35 Flaw-Related Inputs for the FAVOR Code," NUREG/CR-6817 (PNNL-14268),  
36 March 2004, ADAMS Accession No. ML040830499.
- 37 [20] Oak Ridge National Laboratory, "Fracture Analysis of Vessels - Oak Ridge  
38 FAVOR, v12.1, Computer Code: Theory and Implementation of Algorithms,  
39 Methods, and Correlations," ORNL/TM-2012/567, November 2012, Oak Ridge, TN,  
40 ADAMS Accession No. ML13008A015.
- 41 [21] U.S. Nuclear Regulatory Commission, "Probabilistic Fracture Mechanics - Models,  
42 Parameters, and Uncertainty Treatment Used in FAVOR Version 04.1,"  
43 NUREG-1807, June 2007.
- 44 [22] U.S. Nuclear Regulatory Commission, "Fracture Analysis of Vessels - Oak Ridge  
45 FAVOR, v04.1, Computer Code: Theory and Implementation of Algorithms,

1 Methods, and Correlations,” NUREG/CR-6854 (ORNL/TM-2004/244),  
2 August 2007.

3 [23] Pellini, W.S., and P.P. Puzak, “Fracture Analysis Diagram Procedures for the  
4 Fracture-Safe Engineering Design of Steel Structures,” Bulletin 88, May 1963,  
5 Welding Research Council, Shaker Heights, OH.

6  
7 [24] Pacific Northwest National Laboratory, “Evaluation on the Feasibility of Using  
8 Ultrasonic Testing of Reactor Pressure Vessel Welds for Assessing Flaw  
9 Density/Distribution per 10 CFR 50.61a, Alternate Fracture Toughness  
10 Requirements for Protection Against Pressurized Thermal Shock,” PNNL-19666,  
11 June 2014, ADAMS Accession No. ML14162A001.

12 [25] U.S. Nuclear Regulatory Commission, “Evaluation of the Beltline Region for  
13 Nuclear Reactor Pressure Vessels,” NRC Technical Letter  
14 Report TLR-RES/DE/CIB-2013-01, November 14, 2014, ADAMS Accession  
15 No. ML14318A177.

16  
17 [26] EPRI, “Nondestructive Evaluation: Probabilistic Analysis of Performance  
18 Demonstration Ultrasonic Flaw Detection and Through-Wall Sizing Results for  
19 Reactor Pressure Vessel Inspections,” EPRI Report 1025787, September 2012,  
20 Palo Alto, CA.

21  
22 [27] U.S. Nuclear Regulatory Commission, “Calculational and Dosimetry Methods for  
23 Determining Pressure Vessel Neutron Fluence,” Regulatory Guide 1.190,  
24 March 2001, ADAMS Accession No. ML010890301.  
25



## APPENDIX A: DERIVATION OF THE STATISTICAL TEST FOR TYPE D DEVIATIONS

---

$C_2$  is defined so that the probability that all the normalized residuals are less than  $C_2$  is  $1 - \alpha = 0.99$ , assuming the embrittlement shift model is correct. Under this assumption, the normalized residuals all have a standard normal distribution with a mean of 0 and standard deviation of 1. The cumulative distribution function of the standard normal distribution, denoted by  $F$ , is then:

$$C_2 = F^{-1} (0.99)^{1/n} \quad \text{Eqn. A-1}$$

For any  $n$  and  $C_2$  as determined above, define:

$$p = \text{Prob} \{C_1 < X \leq C_2\} \quad \text{Eqn. A-2}$$

for any  $C_1 < C_2$  and where  $X$  has a standard normal distribution. Then:

$$1-p = \text{Prob} \{X \leq C_1\} + \text{Prob} \{X > C_2\} \quad \text{Eqn. A-3}$$

However, the second term in  $(1-p)$  is negligible compared to the first term. In fact, from Table 7 in the main body of the text,  $C_2 \geq 2.71$  for  $n \geq 3$  and therefore  $\text{Prob} \{X > C_2\} < 0.0034$  for  $n \geq 3$ . Thus:

$$1-p \approx \text{Prob} \{X \leq C_1\} \quad \text{Eqn. A-4}$$

The probability that the subject dataset does not show a Type D deviation can be expressed in terms of  $p$ . Because all of the  $n$  normalized residuals should be less than or equal to  $C_1$  to pass the Outlier Test, the following may be written:

$$\text{Prob} \{x_{[1]} \leq C_1\} = (1-p)^n \quad \text{Eqn. A-5}$$

Also, the Outlier test states that it is acceptable to have a single normalized residual between  $C_1$  and  $C_2$  while the other  $(n - 1)$  normalized residuals are all less than  $C_1$ . Therefore:

$$\text{Prob} \{x_{[2]} < C_1 \leq x_{[1]} \leq C_2\} = np (1-p)^{n-1} \quad \text{Eqn. A-6}$$

Because Eqn. A-5 and Eqn. A-6 are mutually exclusive, the sum of their probabilities is the probability of a Type D deviation, or  $1 - \alpha = 0.99$ . This sum, denoted by  $G(p)$ , is:

$$G(p) = (1-p)^n + np (1-p)^{n-1} = (1-p)^{n-1} [1 + (n-1)p] \quad \text{Eqn. A-7}$$

By iteration, the value  $p_0$  may be found that yields  $G(p_0) = 0.99$ . To calculate  $C_1$  in Table 7,  $\text{Prob} \{X \leq C_1\}$  is set to  $1-p_0$ . Then:

$$C_1 = F^{-1} (1-p_0) \quad \text{Eqn. A-8}$$





# 1 APPENDIX B: REGULATORY ASSESSMENT OF STATISTICAL SURVEILLANCE TESTS

2 Table B-1. Type A Deviations (Mean Test)

Plant Name		General Information							Type A Deviation (Mean Test)			
		Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{\text{mean}}$ [°F]	$r_{\text{max}}$ [°F]	Fails Test?		
Arkansas Nuclear	1	PWR	PAN101		P	6	21	-13	20	No		
Arkansas Nuclear	1	PWR	WAN101		W	3	26	6	36	No		
Arkansas Nuclear	2	PWR	PAN201		P	3	21	-3	29	No		
Beaver Valley	1	PWR	PBV101		P	8	21	23.0	17.5	Yes		
Beaver Valley	1	PWR	WBV101		W	4	26	-3	31	No		
Beaver Valley	2	PWR	PBV201		P	6	19	-7	18	No		
Beaver Valley	2	PWR	WBV201		W	3	26	-37	36	No		
Braidwood	1	PWR	FBD101		F	6	19	-7	18	No		
Braidwood	1	PWR	WBD101		W	3	19	3	25	No		
Braidwood	2	PWR	FBD201		F	6	19	-9	18	No		
Braidwood	2	PWR	WBD201		W	3	19	-8	25	No		
Brunswick	1	BWR	PBR_01		P	5	21	31.3	22.1	Yes		
Brunswick	1	BWR	WBR_01		W	3	26	35	36	No		
Byron	1	PWR	FBY101		F	6	19	15	18	No		
Byron	1	PWR	WBY101		W	3	19	0	25	No		
Byron	2	PWR	FBY201		F	6	19	-5	18	No		
Byron	2	PWR	WBY201		W	3	19	-1	25	No		
Callaway		PWR	PCL101		P	8	19	-2	15	No		
Callaway		PWR	WCL101		W	4	19	27.0	21.7	Yes		
Calvert Cliffs	1	PWR	PCC103		P	3	21	-6	29	No		
Calvert Cliffs	1	PWR	WCC101		W	3	26	-17	36	No		
Calvert Cliffs	2	PWR	PCC202		P	3	21	-7	29	No		
Catawba	1	PWR	FCB101		F	6	20	-16	19	No		
Catawba	1	PWR	WCB101		W	3	19	-8	25	No		
Catawba	2	PWR	PCB201		P	6	21	-1	20	No		
Catawba	2	PWR	WCB201		W	3	19	1	25	No		
Commanche Peak	1	PWR	PCP101		P	4	19	-5	22	No		
Connecticut Yankee		ex-PWR	PCTY04		P	3	21	-4	29	No		

General Information							Type A Deviation (Mean Test)			
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{\text{mean}}$ [°F]	$r_{\text{max}}$ [°F]	Fails Test?	
Connecticut Yankee		ex-PWR	PCTY02	P	3	21	-13	29	No	
Crystal River	3	PWR	PCR301	P	4	21	17	25	No	
Crystal River	3	PWR	WCR301	W	4	26	12	31	No	
Crystal River	3	PWR	WHSS66	W	4	26	-20	31	No	
Crystal River	3	PWR	WHSSCR	W	3	26	-6	36	No	
Crystal River & Surry	3 & 2	PWR	WHSS65	W	3	26	3	36	No	
D.C. Cook	1	PWR	PCK101	P	8	21	-4	17	No	
D.C. Cook	1	PWR	WCK101	W	3	26	-103	36	No	
D.C. Cook	2	PWR	PCK201	P	8	21	24.6	17.5	Yes	
D.C. Cook	2	PWR	WCK201	W	4	19	17	22	No	
Davis Besse		PWR	FDB102	F	4	19	-7	22	No	
Davis Besse		PWR	WDB101	W	5	26	1	28	No	
Davis Besse		PWR	PRS101	P	3	21	-6	29	No	
Davis Besse		PWR	WRS101	W	3	26	-14	36	No	
Diablo Canyon	1	PWR	PDC103	P	3	21	-24	29	No	
Diablo Canyon	1	PWR	WDC101	W	3	26	-2	36	No	
Diablo Canyon	2	PWR	PDC201	P	8	21	-5	17	No	
Diablo Canyon	2	PWR	WDC201	W	4	26	-3	31	No	
Dresden	3	BWR	WDR302	W	3	26	-17	36	No	
Dresden	2	BWR	PDR201	P	5	21	-32	22	No	
Dresden	3	BWR	PDR301	P	6	21	-10	20	No	
Dresden	3	BWR	WDR301	W	5	26	-5	28	No	
Duane Arnold		BWR	PDAC01	P	3	21	10	29	No	
Duane Arnold		BWR	WDAC01	W	3	19	-4	25	No	
Farley	1	PWR	PFA101	P	8	21	13	17	No	
Farley	1	PWR	WFA101	W	4	26	-7	31	No	
Farley	2	PWR	PFA201	P	8	21	15	17	No	
Farley	2	PWR	WFA201	W	4	19	-51	22	No	
FitzPatrick		BWR	PFTZ01	P	6	21	-11	20	No	
Fort Calhoun		PWR	PFC101	P	5	21	-10	22	No	
Fort Calhoun		PWR	WFC101	W	4	26	-1	31	No	
Ginna		PWR	FGIN02	F	4	19	-18	22	No	

General Information										Type A Deviation (Mean Test)		
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{\text{mean}}$ [°F]	$r_{\text{max}}$ [°F]	Fails Test?			
Ginna		PWR	FGIN01	F	4	19	17	22	No			
Ginna		PWR	WGIN01	W	4	26	13	31	No			
H.B. Robinson	2	PWR	WHB201	W	3	26	6	36	No			
Indian Point	2	PWR	PIP202	P	3	21	-1	29	No			
Indian Point	2	PWR	PIP203	P	3	21	32.6	28.5	Yes			
Indian Point	3	PWR	PIP304	P	5	21	13	22	No			
Indian Point	3	PWR	WIP301	W	3	26	33	36	No			
Kewaunee		PWR	FKWE02	F	4	19	-7	22	No			
Kewaunee		PWR	FKWE01	F	4	19	-9	22	No			
Kewaunee		PWR	WKWE01	W	4	26	16	31	No			
Maine Yankee		ex-PWR	PMY_01	P	6	21	28.5	20.2	Yes			
Maine Yankee		ex-PWR	SHSS01	SRM	17	21	1	12	No			
Maine Yankee		ex-PWR	WMY_01	W	4	26	-8	31	No			
McGuire	1	PWR	PMC101	P	8	21	13	17	No			
McGuire	1	PWR	WMC101	W	4	26	-11	31	No			
McGuire	2	PWR	FMC201	F	8	20	1	16	No			
McGuire	2	PWR	WMC201	W	4	19	3	22	No			
Millstone	1	ex-BWR	PML101	P	4	21	-6	25	No			
Millstone	2	PWR	PML201	P	5	21	13	22	No			
Millstone	2	PWR	WML201	W	3	26	-27	36	No			
Nine Mile Point	1	BWR	PNM101	P	5	21	-10	22	No			
North Anna	1	PWR	FNA101	F	6	20	-14	19	No			
North Anna	1	PWR	WNA101	W	3	26	21	36	No			
North Anna	2	PWR	FNA201	F	6	20	-18	19	No			
North Anna	2	PWR	WNA201	W	3	26	-23	36	No			
Oconee	1	PWR	POC102	P	6	21	5	20	No			
Oconee	1	PWR	SHSS02	SRM	64	21	-14	6	No			
Oconee	1	PWR	WOC101	W	3	26	5	36	No			
Oconee	2	PWR	FOC201	F	5	19	-3	19	No			
Oconee	2	PWR	WOC201	W	3	26	-23	36	No			
Oconee	3	PWR	FOC301	F	4	19	2	22	No			
Oconee	3	PWR	FOC302	F	3	19	21	25	No			

General Information							Type A Deviation (Mean Test)			
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{\text{mean}}$ [°F]	$r_{\text{max}}$ [°F]	Fails Test?	
Oconee	3	PWR	WOC301	W	4	26	-28	31	No	
Oyster Creek		BWR	PGG_01	P	4	19	2	22	No	
Oyster Creek		BWR	PCPR02	P	4	21	-3	25	No	
Oyster Creek		BWR	PEP2JP	P	5	19	-3	19	No	
Oyster Creek		BWR	WGG_01	W	4	19	-8	22	No	
Oyster Creek		BWR	WML101	W	6	26	-23	25	No	
Oyster Creek		BWR	WQC102_1	W	4	26	26	31	No	
Oyster Creek		BWR	WQC201_1	W	4	26	17	31	No	
Oyster Creek		BWR	WRB_01	W	3	19	34.6	25.0	Yes	
Palisades		PWR	PPAL01	P	7	21	-33	19	No	
Palisades		PWR	WPAL01	W	4	26	-5	31	No	
Point Beach	2	PWR	FPB202	F	4	20	19	23	No	
Point Beach	1	PWR	PPB102	P	4	21	-28	25	No	
Point Beach	1	PWR	PPB101	P	4	21	9	25	No	
Point Beach	1	PWR	WPB101	W	4	26	-42	31	No	
Point Beach	2	PWR	FPB201	F	4	19	16	22	No	
Point Beach	2	PWR	WPB201	W	4	26	6	31	No	
Prarie Island	1	PWR	FPI101	F	8	19	-2	15	No	
Prarie Island	1	PWR	WPI101	W	4	26	-19	31	No	
Prarie Island	2	PWR	FPI201	F	8	20	-4	16	No	
Prarie Island	2	PWR	WPI201	W	4	26	-11	31	No	
Quad Cities	1	BWR	PQC101	P	6	21	1	20	No	
Quad Cities	1	BWR	WQC101	W	4	26	-16	31	No	
Quad Cities	2	BWR	PQC201	P	4	21	-18	25	No	
Quad Cities	2	BWR	WQC201	W	4	26	18	31	No	
Saint Lucie	1	PWR	PSL101	P	5	21	-19	22	No	
Saint Lucie	1	PWR	WSL101	W	3	26	-18	36	No	
Saint Lucie	2	PWR	PSL201	P	3	21	14	29	No	
Salem	1	PWR	PSA103	P	3	21	-30	29	No	
Salem	1	PWR	PSA101	P	3	21	6	29	No	
Salem	2	PWR	PSA201	P	8	21	10	17	No	
Salem	2	PWR	WSA201	W	4	26	-18	31	No	

General Information							Type A Deviation (Mean Test)			
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{\text{mean}}$ [°F]	$r_{\text{max}}$ [°F]	Fails Test?	
San Onofre	2	PWR	PSO201	P	3	21	-7	29	No	
San Onofre	3	PWR	PSO301	P	3	19	40.1	25.0	Yes	
Seabrook	1	PWR	PSB101	P	4	19	19	22	No	
Sequoyah	1	PWR	FSQ101	F	8	20	18.3	16.1	Yes	
Sequoyah	1	PWR	WSQ101	W	4	26	32.4	30.8	Yes	
Sequoyah	2	PWR	FSQ201	F	8	20	7	16	No	
Sequoyah	2	PWR	WSQ201	W	4	26	23	31	No	
South Texas	1	PWR	PST101	P	4	19	3	22	No	
South Texas	2	PWR	PST201	P	4	19	4	22	No	
Surry	1	PWR	PSU101	P	3	21	5	29	No	
Surry	1	PWR	WSU101	W	3	26	43.5	35.5	Yes	
Surry	2	PWR	PSU201	P	6	21	0	20	No	
Surry	2	PWR	WSU201	W	3	26	-14	36	No	
Three Mile Island	1	PWR	PTM101	P	3	21	-17	29	No	
Trojan		ex-PWR	PTRO01	P	6	21	1	20	No	
Trojan		ex-PWR	WTRO01	W	3	19	8	25	No	
Turkey Point	3	PWR	FTP302	F	3	20	10	26	No	
Turkey Point	3	PWR	SASTM	SRM	26	21	5	10	No	
Turkey Point	3	PWR	WTP301	W	4	26	13	31	No	
Virgil Summer	1	PWR	PVS101	P	8	21	-20	17	No	
Virgil Summer	1	PWR	WVS101	W	4	19	0	22	No	
Votgle	1	PWR	PVO101	P	6	19	-1	18	No	
Votgle	1	PWR	WVO101	W	3	19	-4	25	No	
Votgle	2	PWR	PVO201	P	6	19	-14	18	No	
Votgle	2	PWR	WVO201	W	3	19	-13	25	No	
Waterford	3	PWR	PWF301	P	3	19	-13	25	No	
Watts Bar	1	PWR	FWB101	F	4	20	-6	23	No	
Wolf Creek	1	PWR	PWC101	P	8	19	8	15	No	
Wolf Creek	1	PWR	WWC101	W	4	19	17	22	No	
Zion	1	ex-PWR	PZN101	P	8	21	-2	17	No	
Zion	1	ex-PWR	WZN101	W	5	26	-6	28	No	
Zion	2	ex-PWR	PZN201	P	6	21	3	20	No	

General Information							Type A Deviation (Mean Test)		
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{\text{mean}}$ [°F]	$r_{\text{max}}$ [°F]	Fails Test?
Zion	2	ex-PWR	WZN201	W	3	26	3	36	No

1  
2  
3

1 Table B-2. Type B Deviations (Slope Test)

2

Plant Name	Unit	General Information					Type B Deviation (Slope Test)					Fails Test?
		Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	m	se(m)	$T_m$	$T_{crit(\alpha)}$		
Arkansas Nuclear	1	PWR	PAN101	P	6	21	-26.06	10.09	-2.58	3.75	No	
Arkansas Nuclear	1	PWR	WAN101	W	3	26	-37.69	19.02	-1.98	31.82	No	
Arkansas Nuclear	2	PWR	PAN201	P	3	21	-5.72	16.85	-0.34	31.82	No	
Beaver Valley	1	PWR	PBV101	P	8	21	-37.91	21.46	-1.77	3.14	No	
Beaver Valley	1	PWR	WBV101	W	4	26	-56.91	15.54	-3.66	6.96	No	
Beaver Valley	2	PWR	PBV201	P	6	19	4.78	6.63	0.72	3.75	No	
Beaver Valley	2	PWR	WBV201	W	3	26	-50.14	20.08	-2.50	31.82	No	
Braidwood	1	PWR	FBD101	F	6	19	26.30	21.44	1.23	3.75	No	
Braidwood	1	PWR	WBD101	W	3	19	8.25	8.49	0.97	31.82	No	
Braidwood	2	PWR	FBD201	F	6	19	14.24	22.91	0.62	3.75	No	
Braidwood	2	PWR	WBD201	W	3	19	6.66	19.20	0.35	31.82	No	
Brunswick	1	BWR	PBR_01	P	5	21	67.73	13.28	5.10	4.54	Yes	
Brunswick	1	BWR	WBR_01	W	3	26	41.69	45.09	0.92	31.82	No	
Byron	1	PWR	FBY101	F	6	19	7.34	15.79	0.46	3.75	No	
Byron	1	PWR	WBY101	W	3	19	26.54	8.12	3.27	31.82	No	
Byron	2	PWR	FBY201	F	6	19	0.03	19.60	0.00	3.75	No	
Byron	2	PWR	WBY201	W	3	19	27.60	8.32	3.32	31.82	No	
Callaway		PWR	PCL101	P	8	19	-8.04	14.97	-0.54	3.14	No	
Callaway		PWR	WCL101	W	4	19	-41.68	12.80	-3.26	6.96	No	
Calvert Cliffs	1	PWR	PCC103	P	3	21	13.74	2.75	4.99	31.82	No	
Calvert Cliffs	1	PWR	WCC101	W	3	26	37.90	2.00	18.95	31.82	No	
Calvert Cliffs	2	PWR	PCC202	P	3	21	11.27	12.00	0.94	31.82	No	
Catawba	1	PWR	FCB101	F	6	20	24.31	20.63	1.18	3.75	No	
Catawba	1	PWR	WCB101	W	3	19	7.91	2.47	3.20	31.82	No	
Catawba	2	PWR	PCB201	P	6	21	0.93	10.27	0.09	3.75	No	
Catawba	2	PWR	WCB201	W	3	19	91.48	9.59	9.54	31.82	No	
Commanche Peak	1	PWR	PCP101	P	4	19	-19.21	15.89	-1.21	6.96	No	
Connecticut Yankee		ex-PWR	PCTY04	P	3	21	-63.22	2.55	-24.79	31.82	No	
Connecticut Yankee		ex-PWR	PCTY02	P	3	21	-47.44	1.52	-31.24	31.82	No	

General Information										Type B Deviation (Slope Test)				
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	m	se(m)	$T_m$	$T_{crit(c)}$	Fails Test?			
Crystal River	3	PWR	PCR301	P	4	21	22.02	11.98	1.84	6.96	No			
Crystal River	3	PWR	WCR301	W	4	26	46.92	13.65	3.44	6.96	No			
Crystal River	3	PWR	WHSS66	W	4	26	-110.03	117.85	-0.93	6.96	No			
Crystal River	3	PWR	WHSSCR	W	3	26	-116.65	31.01	-3.76	31.82	No			
Crystal River & Surry	3 & 2	PWR	WHSS65	W	3	26	2.10	14.59	0.14	31.82	No			
D.C. Cook	1	PWR	PCK101	P	8	21	-8.31	11.44	-0.73	3.14	No			
D.C. Cook	1	PWR	WCK101	W	3	26	-27.17	98.72	-0.28	31.82	No			
D.C. Cook	2	PWR	PCK201	P	8	21	1.58	17.98	0.09	3.14	No			
D.C. Cook	2	PWR	WCK201	W	4	19	-14.88	17.64	-0.84	6.96	No			
Davis Besse		PWR	FDB102	F	4	19	33.72	23.70	1.42	6.96	No			
Davis Besse		PWR	WDB101	W	5	26	10.23	58.55	0.17	4.54	No			
Davis Besse		PWR	PRS101	P	3	21	19.87	18.23	1.09	31.82	No			
Davis Besse		PWR	WRS101	W	3	26	24.78	24.12	1.03	31.82	No			
Diablo Canyon	1	PWR	PDC103	P	3	21	-2.29	33.31	-0.07	31.82	No			
Diablo Canyon	1	PWR	WDC101	W	3	26	23.50	74.96	0.31	31.82	No			
Diablo Canyon	2	PWR	PDC201	P	8	21	-1.49	7.64	-0.19	3.14	No			
Diablo Canyon	2	PWR	WDC201	W	4	26	-34.17	7.34	-4.66	6.96	No			
Dresden	3	BWR	WDR302	W	3	26	-25.60	231.23	-0.11	31.82	No			
Dresden	2	BWR	PDR201	P	5	21	2.15	5.51	0.39	4.54	No			
Dresden	3	BWR	PDR301	P	6	21	-2.52	4.90	-0.51	3.75	No			
Dresden	3	BWR	WDR301	W	5	26	7.60	7.66	0.99	4.54	No			
Duane Arnold		BWR	PDAC01	P	3	21	-2.02	13.71	-0.15	31.82	No			
Duane Arnold		BWR	WDAC01	W	3	19	20.21	6.54	3.09	31.82	No			
Farley	1	PWR	PFA101	P	8	21	21.46	8.51	2.52	3.14	No			
Farley	1	PWR	WFA101	W	4	26	-27.48	10.40	-2.64	6.96	No			
Farley	2	PWR	PFA201	P	8	21	20.33	15.54	1.31	3.14	No			
Farley	2	PWR	WFA201	W	4	19	-25.24	19.69	-1.28	6.96	No			
FitzPatrick		BWR	PFTZ01	P	6	21	8.83	10.75	0.82	3.75	No			
Fort Calhoun		PWR	PFC101	P	5	21	-22.33	33.89	-0.66	4.54	No			
Fort Calhoun		PWR	WFC101	W	4	26	-73.25	49.46	-1.48	6.96	No			
Ginna		PWR	FGIN02	F	4	19	39.26	74.20	0.53	6.96	No			
Ginna		PWR	FGIN01	F	4	19	-33.49	29.11	-1.15	6.96	No			



General Information										Type B Deviation (Slope Test)				
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	m	se(m)	$T_m$	$T_{crit(c)}$	Fails Test?			
Ginna		PWR	WGIN01	W	4	26	13.77	24.57	0.56	6.96	No			
H.B. Robinson	2	PWR	WHB201	W	3	26	7.86	33.97	0.23	31.82	No			
Indian Point	2	PWR	PIP202	P	3	21	-59.41	46.88	-1.27	31.82	No			
Indian Point	2	PWR	PIP203	P	3	21	-17.19	2.14	-8.05	31.82	No			
Indian Point	3	PWR	PIP304	P	5	21	2.30	29.72	0.08	4.54	No			
Indian Point	3	PWR	WIP301	W	3	26	-0.18	79.92	0.00	31.82	No			
Kewaunee		PWR	FKWE02	F	4	19	5.09	6.32	0.81	6.96	No			
Kewaunee		PWR	FKWE01	F	4	19	-3.54	28.08	-0.13	6.96	No			
Kewaunee		PWR	WKWE01	W	4	26	-15.96	19.26	-0.83	6.96	No			
Maine Yankee		ex-PWR	PMY_01	P	6	21	-6.49	15.82	-0.41	3.75	No			
Maine Yankee		ex-PWR	SHSS01	SRM	17	21	-4.95	15.22	-0.33	2.60	No			
Maine Yankee		ex-PWR	WMY_01	W	4	26	10.14	12.08	0.84	6.96	No			
McGuire	1	PWR	PMC101	P	8	21	24.92	19.19	1.30	3.14	No			
McGuire	1	PWR	WMC101	W	4	26	-43.26	13.24	-3.27	6.96	No			
McGuire	2	PWR	FMC201	F	8	20	4.68	13.50	0.35	3.14	No			
McGuire	2	PWR	WMC201	W	4	19	-34.72	13.01	-2.67	6.96	No			
Millstone	1	ex-BWR	PML101	P	4	21	-46.63	28.45	-1.64	6.96	No			
Millstone	2	PWR	PML201	P	5	21	23.17	31.56	0.73	4.54	No			
Millstone	2	PWR	WML201	W	3	26	-56.09	3.80	-14.77	31.82	No			
Nine Mile Point	1	BWR	PNM101	P	5	21	41.45	22.11	1.87	4.54	No			
North Anna	1	PWR	FNA101	F	6	20	8.37	20.75	0.40	3.75	No			
North Anna	1	PWR	WNA101	W	3	26	-40.22	70.03	-0.57	31.82	No			
North Anna	2	PWR	FNA201	F	6	20	18.17	12.92	1.41	3.75	No			
North Anna	2	PWR	WNA201	W	3	26	-5.18	23.10	-0.22	31.82	No			
Oconee	1	PWR	POC102	P	6	21	-19.62	25.32	-0.77	3.75	No			
Oconee	1	PWR	SHSS02	SRM	64	21	1.87	4.39	0.43	2.39	No			
Oconee	1	PWR	WOC101	W	3	26	41.08	14.09	2.92	31.82	No			
Oconee	2	PWR	FOC201	F	5	19	-15.62	13.86	-1.13	4.54	No			
Oconee	2	PWR	WOC201	W	3	26	30.52	12.69	2.41	31.82	No			
Oconee	3	PWR	FOC301	F	4	19	-2.79	5.78	-0.48	6.96	No			
Oconee	3	PWR	FOC302	F	3	19	-21.76	32.80	-0.66	31.82	No			
Oconee	3	PWR	WOC301	W	4	26	41.81	33.82	1.24	6.96	No			

General Information										Type B Deviation (Slope Test)				
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	m	se(m)	$T_m$	$T_{crit(c)}$	Fails Test?			
Oyster Creek		BWR	PGG_01	P	4	19	21.14	22.39	0.94	6.96	No			
Oyster Creek		BWR	PCPR02	P	4	21	-8.62	42.21	-0.20	6.96	No			
Oyster Creek		BWR	PEP2JP	P	5	19	-32.14	8.29	-3.88	4.54	No			
Oyster Creek		BWR	WGG_01	W	4	19	39.71	61.15	0.65	6.96	No			
Oyster Creek		BWR	WML101	W	6	26	10.03	20.07	0.50	3.75	No			
Oyster Creek		BWR	WQC102_1	W	4	26	6.48	11.60	0.56	6.96	No			
Oyster Creek		BWR	WQC201_1	W	4	26	57.46	59.89	0.96	6.96	No			
Oyster Creek		BWR	WRB_01	W	3	19	20.94	63.55	0.33	31.82	No			
Palisades		PWR	PPAL01	P	7	21	-77.49	15.02	-5.16	3.36	No			
Palisades		PWR	WPAL01	W	4	26	-42.23	5.32	-7.93	6.96	No			
Point Beach	2	PWR	FPB202	F	4	20	41.30	12.36	3.34	6.96	No			
Point Beach	1	PWR	PPB102	P	4	21	-76.91	8.77	-8.77	6.96	No			
Point Beach	1	PWR	PPB101	P	4	21	-55.54	23.06	-2.41	6.96	No			
Point Beach	1	PWR	WPB101	W	4	26	-12.46	53.53	-0.23	6.96	No			
Point Beach	2	PWR	FPB201	F	4	19	-0.70	8.03	-0.09	6.96	No			
Point Beach	2	PWR	WPB201	W	4	26	38.35	27.60	1.39	6.96	No			
Prairie Island	1	PWR	FPI101	F	8	19	-0.54	17.08	-0.03	3.14	No			
Prairie Island	1	PWR	WPI101	W	4	26	57.84	38.91	1.49	6.96	No			
Prairie Island	2	PWR	FPI201	F	8	20	8.36	9.37	0.89	3.14	No			
Prairie Island	2	PWR	WPI201	W	4	26	-40.19	12.22	-3.29	6.96	No			
Quad Cities	1	BWR	PQC101	P	6	21	7.70	2.14	3.59	3.75	No			
Quad Cities	1	BWR	WQC101	W	4	26	10.12	7.81	1.30	6.96	No			
Quad Cities	2	BWR	PQC201	P	4	21	-10.04	3.17	-3.17	6.96	No			
Quad Cities	2	BWR	WQC201	W	4	26	-3.89	4.21	-0.92	6.96	No			
Saint Lucie	1	PWR	PSL101	P	5	21	-5.59	16.17	-0.35	4.54	No			
Saint Lucie	1	PWR	WSL101	W	3	26	-46.07	12.84	-3.59	31.82	No			
Saint Lucie	2	PWR	PSL201	P	3	21	49.57	1.95	25.45	31.82	No			
Salem	1	PWR	PSA103	P	3	21	-6.76	19.49	-0.35	31.82	No			
Salem	1	PWR	PSA101	P	3	21	5.06	24.98	0.20	31.82	No			
Salem	2	PWR	PSA201	P	8	21	-3.87	21.39	-0.18	3.14	No			
Salem	2	PWR	WSA201	W	4	26	-45.51	9.34	-4.87	6.96	No			
San Onofre	2	PWR	PSO201	P	3	21	11.38	26.39	0.43	31.82	No			

General Information							Type B Deviation (Slope Test)					
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	m	se(m)	$T_m$	$T_{crit(c)}$	Fails Test?	
San Onofre	3	PWR	PSO301	P	3	19	15.75	21.22	0.74	31.82	No	
Seabrook	1	PWR	PSB101	P	4	19	-6.15	14.03	-0.44	6.96	No	
Sequoyah	1	PWR	FSQ101	F	8	20	31.83	17.01	1.87	3.14	No	
Sequoyah	1	PWR	WSQ101	W	4	26	-8.36	4.54	-1.84	6.96	No	
Sequoyah	2	PWR	FSQ201	F	8	20	12.09	14.40	0.84	3.14	No	
Sequoyah	2	PWR	WSQ201	W	4	26	-71.71	89.12	-0.80	6.96	No	
South Texas	1	PWR	PST101	P	4	19	-9.15	21.18	-0.43	6.96	No	
South Texas	2	PWR	PST201	P	4	19	16.33	4.60	3.55	6.96	No	
Surry	1	PWR	PSU101	P	3	21	10.46	20.36	0.51	31.82	No	
Surry	1	PWR	WSU101	W	3	26	9.51	7.62	1.25	31.82	No	
Surry	2	PWR	PSU201	P	6	21	-2.98	13.63	-0.22	3.75	No	
Surry	2	PWR	WSU201	W	3	26	7.37	24.69	0.30	31.82	No	
Three Mile Island	1	PWR	PTM101	P	3	21	-41.07	2.89	-14.23	31.82	No	
Trojan		ex-PWR	PTRO01	P	6	21	-2.31	12.00	-0.19	3.75	No	
Trojan		ex-PWR	WTRO01	W	3	19	-14.97	10.82	-1.38	31.82	No	
Turkey Point	3	PWR	FTP302	F	3	20	52.36	70.45	0.74	31.82	No	
Turkey Point	3	PWR	SASTM	SRM	26	21	10.59	8.87	1.19	2.49	No	
Turkey Point	3	PWR	WTP301	W	4	26	15.55	35.61	0.44	6.96	No	
Virgil Summer	1	PWR	PVS101	P	8	21	-12.14	16.33	-0.74	3.14	No	
Virgil Summer	1	PWR	WVS101	W	4	19	-20.29	23.75	-0.85	6.96	No	
Votgle	1	PWR	PVO101	P	6	19	20.85	19.05	1.09	3.75	No	
Votgle	1	PWR	WVO101	W	3	19	-41.81	19.81	-2.11	31.82	No	
Votgle	2	PWR	PVO201	P	6	19	15.57	10.12	1.54	3.75	No	
Votgle	2	PWR	WVO201	W	3	19	25.29	19.30	1.31	31.82	No	
Waterford	3	PWR	PWF301	P	3	19	-87.52	64.25	-1.36	31.82	No	
Watts Bar	1	PWR	FWB101	F	4	20	41.28	90.57	0.46	6.96	No	
Wolf Creek	1	PWR	PWC101	P	8	19	-8.38	9.54	-0.88	3.14	No	
Wolf Creek	1	PWR	WWC101	W	4	19	4.70	8.95	0.53	6.96	No	
Zion	1	ex-PWR	PZN101	P	8	21	14.89	14.97	0.99	3.14	No	
Zion	1	ex-PWR	WZN101	W	5	26	43.23	8.52	5.07	4.54	Yes	
Zion	2	ex-PWR	PZN201	P	6	21	19.41	15.57	1.25	3.75	No	
Zion	2	ex-PWR	WZN201	W	3	26	17.59	31.94	0.55	31.82	No	

Table B-3. Type D Deviations (Outlier Test)

General Information										Type D Deviation (Outlier Test)				
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{i(max1)}$	$r_{i(max2)}$	C <sub>1</sub>	C <sub>2</sub>	Fails Test?			
Arkansas Nuclear	1	PWR	PAN101	P	6	21	0.98	-0.13	1.93	2.93	No			
Arkansas Nuclear	1	PWR	WAN101	W	3	26	1.47	0.03	1.55	2.71	No			
Arkansas Nuclear	2	PWR	PAN201	P	3	21	0.36	-0.32	1.55	2.71	No			
Beaver Valley	1	PWR	PBV101	P	8	21	2.52	2.26	2.05	3.02	No			
Beaver Valley	1	PWR	WBV101	W	4	26	0.83	0.14	1.73	2.81	No			
Beaver Valley	2	PWR	PBV201	P	6	19	-0.04	-0.06	1.93	2.93	No			
Beaver Valley	2	PWR	WBV201	W	3	26	-0.61	-1.39	1.55	2.71	No			
Braidwood	1	PWR	FBD101	F	6	19	0.41	0.23	1.93	2.93	No			
Braidwood	1	PWR	WBD101	W	3	19	0.42	0.03	1.55	2.71	No			
Braidwood	2	PWR	FBD201	F	6	19	0.85	0.41	1.93	2.93	No			
Braidwood	2	PWR	WBD201	W	3	19	0.04	-0.59	1.55	2.71	No			
Brunswick	1	BWR	PBR_01	P	5	21	4.09	2.99	1.84	2.88	No			
Brunswick	1	BWR	WBR_01	W	3	26	2.56	1.53	1.55	2.71	No			
Byron	1	PWR	FBY101	F	6	19	1.67	1.58	1.93	2.93	No			
Byron	1	PWR	WBY101	W	3	19	0.38	0.37	1.55	2.71	No			
Byron	2	PWR	FBY201	F	6	19	0.46	0.36	1.93	2.93	No			
Byron	2	PWR	WBY201	W	3	19	0.59	-0.10	1.55	2.71	No			
Callaway		PWR	PCL101	P	8	19	1.06	0.70	2.05	3.02	No			
Callaway		PWR	WCL101	W	4	19	3.03	0.98	1.73	2.81	No			
Calvert Cliffs	1	PWR	PCC103	P	3	21	-0.10	-0.19	1.55	2.71	No			
Calvert Cliffs	1	PWR	WCC101	W	3	26	-0.14	-0.71	1.55	2.71	No			
Calvert Cliffs	2	PWR	PCC202	P	3	21	-0.14	-0.38	1.55	2.71	No			
Catawba	1	PWR	FCB101	F	6	20	0.14	0.05	1.93	2.93	No			
Catawba	1	PWR	WCB101	W	3	19	-0.27	-0.46	1.55	2.71	No			
Catawba	2	PWR	PCB201	P	6	21	0.30	0.26	1.93	2.93	No			
Catawba	2	PWR	WCB201	W	3	19	1.75	0.74	1.55	2.71	No			
Commanche Peak	1	PWR	PCP101	P	4	19	0.38	-0.15	1.73	2.81	No			
Connecticut Yankee		ex-PWR	PCTY04	P	3	21	1.02	-0.60	1.55	2.71	No			
Connecticut Yankee		ex-PWR	PCTY02	P	3	21	0.17	-0.45	1.55	2.71	No			
Crystal River	3	PWR	PCR301	P	4	21	1.46	1.03	1.73	2.81	No			

General Information										Type D Deviation (Outlier Test)				
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{i(max1)}$	$r_{i(max2)}$	C <sub>1</sub>	C <sub>2</sub>	Fails Test?			
Crystal River	3	PWR	WCR301	W	4	26	1.12	1.00	1.73	2.81	No			
Crystal River	3	PWR	WHSS66	W	4	26	0.71	-0.78	1.73	2.81	No			
Crystal River	3	PWR	WHSSCR	W	3	26	0.77	0.06	1.55	2.71	No			
Crystal River & Surry	3 & 2	PWR	WHSS65	W	3	26	0.23	0.18	1.55	2.71	No			
D.C. Cook	1	PWR	PCK101	P	8	21	0.57	0.28	2.05	3.02	No			
D.C. Cook	1	PWR	WCK101	W	3	26	-2.30	-3.73	1.55	2.71	No			
D.C. Cook	2	PWR	PCK201	P	8	21	2.27	1.68	2.05	3.02	No			
D.C. Cook	2	PWR	WCK201	W	4	19	1.47	1.28	1.73	2.81	No			
Davis Besse		PWR	FDB102	F	4	19	0.98	-0.60	1.73	2.81	No			
Davis Besse		PWR	WDB101	W	5	26	2.01	0.32	1.84	2.88	No			
Davis Besse		PWR	PRS101	P	3	21	-0.05	-0.12	1.55	2.71	No			
Davis Besse		PWR	WRS101	W	3	26	-0.26	-0.36	1.55	2.71	No			
Diablo Canyon	1	PWR	PDC103	P	3	21	-0.53	-1.24	1.55	2.71	No			
Diablo Canyon	1	PWR	WDC101	W	3	26	1.14	-0.69	1.55	2.71	No			
Diablo Canyon	2	PWR	PDC201	P	8	21	0.21	-0.04	2.05	3.02	No			
Diablo Canyon	2	PWR	WDC201	W	4	26	0.54	-0.15	1.73	2.81	No			
Dresden	3	BWR	WDR302	W	3	26	0.74	-1.02	1.55	2.71	No			
Dresden	2	BWR	PDR201	P	5	21	-0.23	-1.56	1.84	2.88	No			
Dresden	3	BWR	PDR301	P	6	21	0.49	-0.20	1.93	2.93	No			
Dresden	3	BWR	WDR301	W	5	26	1.01	0.43	1.84	2.88	No			
Duane Arnold		BWR	PDAC01	P	3	21	0.66	0.39	1.55	2.71	No			
Duane Arnold		BWR	WDAC01	W	3	19	0.14	-0.32	1.55	2.71	No			
Farley	1	PWR	PFA101	P	8	21	1.39	1.20	2.05	3.02	No			
Farley	1	PWR	WFA101	W	4	26	0.38	-0.46	1.73	2.81	No			
Farley	2	PWR	PFA201	P	8	21	1.92	1.22	2.05	3.02	No			
Farley	2	PWR	WFA201	W	4	19	-2.12	-2.13	1.73	2.81	No			
FitzPatrick		BWR	PFTZ01	P	6	21	-0.03	-0.16	1.93	2.93	No			
Fort Calhoun		PWR	PFC101	P	5	21	0.03	-0.11	1.84	2.88	No			
Fort Calhoun		PWR	WFC101	W	4	26	0.59	0.32	1.73	2.81	No			
Ginna		PWR	FGIN02	F	4	19	1.35	-0.34	1.73	2.81	No			
Ginna		PWR	FGIN01	F	4	19	2.19	1.10	1.73	2.81	No			
Ginna		PWR	WGIN01	W	4	26	1.17	0.58	1.73	2.81	No			

General Information										Type D Deviation (Outlier Test)				
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{i(max1)}$	$r_{i(max2)}$	C <sub>1</sub>	C <sub>2</sub>	Fails Test?			
H.B. Robinson	2	PWR	WHB201	W	3	26	0.96	0.05	1.55	2.71	No			
Indian Point	2	PWR	PIP202	P	3	21	1.26	-0.57	1.55	2.71	No			
Indian Point	2	PWR	PIP203	P	3	21	1.81	1.53	1.55	2.71	No			
Indian Point	3	PWR	PIP304	P	5	21	1.41	1.11	1.84	2.88	No			
Indian Point	3	PWR	WIP301	W	3	26	1.90	1.54	1.55	2.71	No			
Kewaunee		PWR	FKWE02	F	4	19	-0.08	-0.43	1.73	2.81	No			
Kewaunee		PWR	FKWE01	F	4	19	-0.04	-0.05	1.73	2.81	No			
Kewaunee		PWR	WKWE01	W	4	26	1.10	0.74	1.73	2.81	No			
Maine Yankee		ex-PWR	PMY_01	P	6	21	2.36	1.58	1.93	2.93	No			
Maine Yankee		ex-PWR	SHSS01	SRM	17	21	1.48	0.96	2.37	3.24	No			
Maine Yankee		ex-PWR	WMY_01	W	4	26	0.05	-0.12	1.73	2.81	No			
McGuire	1	PWR	PMC101	P	8	21	1.98	1.16	2.05	3.02	No			
McGuire	1	PWR	WMC101	W	4	26	0.54	-0.68	1.73	2.81	No			
McGuire	2	PWR	FMC201	F	8	20	1.52	0.13	2.05	3.02	No			
McGuire	2	PWR	WMC201	W	4	19	1.32	0.14	1.73	2.81	No			
Millstone	1	ex-BWR	PML101	P	4	21	0.43	0.18	1.73	2.81	No			
Millstone	2	PWR	PML201	P	5	21	1.94	1.09	1.84	2.88	No			
Millstone	2	PWR	WML201	W	3	26	-0.27	-1.13	1.55	2.71	No			
Nine Mile Point	1	BWR	PNM101	P	5	21	0.05	-0.24	1.84	2.88	No			
North Anna	1	PWR	FNA101	F	6	20	0.88	-0.65	1.93	2.93	No			
North Anna	1	PWR	WNA101	W	3	26	2.07	0.94	1.55	2.71	No			
North Anna	2	PWR	FNA201	F	6	20	-0.12	-0.17	1.93	2.93	No			
North Anna	2	PWR	WNA201	W	3	26	-0.59	-0.63	1.55	2.71	No			
Oconee	1	PWR	POC102	P	6	21	1.53	1.41	1.93	2.93	No			
Oconee	1	PWR	SHSS02	SRM	64	21	1.47	1.40	2.83	3.62	No			
Oconee	1	PWR	WOC101	W	3	26	0.87	0.31	1.55	2.71	No			
Oconee	2	PWR	FOC201	F	5	19	0.94	0.00	1.84	2.88	No			
Oconee	2	PWR	WOC201	W	3	26	-0.09	-1.17	1.55	2.71	No			
Oconee	3	PWR	FOC301	F	4	19	0.37	0.16	1.73	2.81	No			
Oconee	3	PWR	FOC302	F	3	19	2.53	0.98	1.55	2.71	No			
Oconee	3	PWR	WOC301	W	4	26	0.89	-1.03	1.73	2.81	No			
Oyster Creek		BWR	PGG_01	P	4	19	0.23	-0.05	1.73	2.81	No			

General Information										Type D Deviation (Outlier Test)				
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{i(max1)}$	$r_{i(max2)}$	C <sub>1</sub>	C <sub>2</sub>	Fails Test?			
Oyster Creek		BWR	PCPR02	P	4	21	0.48	-0.17	1.73	2.81	No			
Oyster Creek		BWR	PEP2JP	P	5	19	0.86	0.12	1.84	2.88	No			
Oyster Creek		BWR	WGG_01	W	4	19	0.62	-0.32	1.73	2.81	No			
Oyster Creek		BWR	WML101	W	6	26	0.07	-0.70	1.93	2.93	No			
Oyster Creek		BWR	WQC102_1	W	4	26	1.14	1.02	1.73	2.81	No			
Oyster Creek		BWR	WQC201_1	W	4	26	1.16	1.03	1.73	2.81	No			
Oyster Creek		BWR	WRB_01	W	3	19	2.27	1.87	1.55	2.71	No			
Palisades		PWR	PPAL01	P	7	21	0.11	-0.48	2	2.98	No			
Palisades		PWR	WPAL01	W	4	26	0.21	0.07	1.73	2.81	No			
Point Beach	2	PWR	FPB202	F	4	20	1.64	1.35	1.73	2.81	No			
Point Beach	1	PWR	PPB102	P	4	21	-0.37	-0.52	1.73	2.81	No			
Point Beach	1	PWR	PPB101	P	4	21	1.08	1.03	1.73	2.81	No			
Point Beach	1	PWR	WPB101	W	4	26	-0.46	-1.58	1.73	2.81	No			
Point Beach	2	PWR	FPB201	F	4	19	1.06	0.94	1.73	2.81	No			
Point Beach	2	PWR	WPB201	W	4	26	0.00	0.00	1.73	2.81	No			
Prairie Island	1	PWR	FPI101	F	8	19	0.77	0.77	2.05	3.02	No			
Prairie Island	1	PWR	WPI101	W	4	26	0.89	-0.43	1.73	2.81	No			
Prairie Island	2	PWR	FPI201	F	8	20	0.56	0.11	2.05	3.02	No			
Prairie Island	2	PWR	WPI201	W	4	26	0.57	-0.47	1.73	2.81	No			
Quad Cities	1	BWR	PQC101	P	6	21	0.74	0.60	1.93	2.93	No			
Quad Cities	1	BWR	WQC101	W	4	26	0.63	-0.63	1.73	2.81	No			
Quad Cities	2	BWR	PQC201	P	4	21	-0.11	-0.38	1.73	2.81	No			
Quad Cities	2	BWR	WQC201	W	4	26	1.07	0.81	1.73	2.81	No			
Saint Lucie	1	PWR	PSL101	P	5	21	-0.55	-0.72	1.84	2.88	No			
Saint Lucie	1	PWR	WSL101	W	3	26	-0.28	-0.68	1.55	2.71	No			
Saint Lucie	2	PWR	PSL201	P	3	21	2.02	-0.01	1.55	2.71	No			
Salem	1	PWR	PSA103	P	3	21	-1.09	-1.33	1.55	2.71	No			
Salem	1	PWR	PSA101	P	3	21	0.91	0.01	1.55	2.71	No			
Salem	2	PWR	PSA201	P	8	21	1.58	1.20	2.05	3.02	No			
Salem	2	PWR	WSA201	W	4	26	-0.12	-0.24	1.73	2.81	No			
San Onofre	2	PWR	PSO201	P	3	21	0.02	-0.10	1.55	2.71	No			
San Onofre	3	PWR	PSO301	P	3	19	2.43	2.34	1.55	2.71	No			

General Information										Type D Deviation (Outlier Test)				
Plant Name	Unit	Reactor Type	Heat	Product Form	n	$\sigma$ [°F]	$r_{i(max1)}$	$r_{i(max2)}$	C <sub>1</sub>	C <sub>2</sub>	Fails Test?			
Seabrook	1	PWR	PSB101	P	4	19	1.39	1.19	1.73	2.81	No			
Sequoyah	1	PWR	FSQ101	F	8	20	2.37	1.73	2.05	3.02	No			
Sequoyah	1	PWR	WSQ101	W	4	26	1.39	1.31	1.73	2.81	No			
Sequoyah	2	PWR	FSQ201	F	8	20	1.57	1.36	2.05	3.02	No			
Sequoyah	2	PWR	WSQ201	W	4	26	3.62	1.44	1.73	2.81	No			
South Texas	1	PWR	PST101	P	4	19	0.71	0.59	1.73	2.81	No			
South Texas	2	PWR	PST201	P	4	19	0.67	0.39	1.73	2.81	No			
Surry	1	PWR	PSU101	P	3	21	0.80	0.02	1.55	2.71	No			
Surry	1	PWR	WSU101	W	3	26	1.88	1.58	1.55	2.71	No			
Surry	2	PWR	PSU201	P	6	21	0.55	0.47	1.93	2.93	No			
Surry	2	PWR	WSU201	W	3	26	0.00	-0.58	1.55	2.71	No			
Three Mile Island	1	PWR	PTM101	P	3	21	0.38	-1.29	1.55	2.71	No			
Trojan		ex-PWR	PTRO01	P	6	21	0.74	0.14	1.93	2.93	No			
Trojan		ex-PWR	WTR001	W	3	19	0.77	0.55	1.55	2.71	No			
Turkey Point	3	PWR	FTP302	F	3	20	1.05	0.67	1.55	2.71	No			
Turkey Point	3	PWR	SASTM	SRM	26	21	1.98	1.94	2.53	3.36	No			
Turkey Point	3	PWR	WTP301	W	4	26	1.30	0.36	1.73	2.81	No			
Virgil Summer	1	PWR	PVS101	P	8	21	0.12	-0.15	2.05	3.02	No			
Virgil Summer	1	PWR	WVS101	W	4	19	0.95	0.16	1.73	2.81	No			
Votgle	1	PWR	PVO101	P	6	19	0.70	0.56	1.93	2.93	No			
Votgle	1	PWR	WVO101	W	3	19	0.67	-0.02	1.55	2.71	No			
Votgle	2	PWR	PVO201	P	6	19	-0.17	-0.23	1.93	2.93	No			
Votgle	2	PWR	WVO201	W	3	19	-0.17	-0.49	1.55	2.71	No			
Waterford	3	PWR	PWF301	P	3	19	0.53	-0.87	1.55	2.71	No			
Watts Bar	1	PWR	FWB101	F	4	20	0.94	0.85	1.73	2.81	No			
Wolf Creek	1	PWR	PWC101	P	8	19	1.10	0.88	2.05	3.02	No			
Wolf Creek	1	PWR	WWC101	W	4	19	1.20	1.20	1.73	2.81	No			
Zion	1	ex-PWR	PZN101	P	8	21	0.43	0.33	2.05	3.02	No			
Zion	1	ex-PWR	WZN101	W	5	26	0.31	0.02	1.84	2.88	No			
Zion	2	ex-PWR	PZN201	P	6	21	1.20	0.27	1.93	2.93	No			
Zion	2	ex-PWR	WZN201	W	3	26	0.66	0.04	1.55	2.71	No			



1 **APPENDIX C: FLAW DEPTH AND DENSITY DISTRIBUTIONS**  
2 **CONSIDERING PROBABILITY OF DETECTION AND BIAS IN NDE**  
3 **DATA WITH APPLICATIONS**

---

4  
5 **Prepared for the U.S. Nuclear Regulatory Commission under**  
6 **Subcontract 4000099247with UT-Battelle, LLC (Oak Ridge National Laboratory)**  
7

8  
9  
10  
11  
12  
13 **Mohammad Modarres**

14 University of Maryland

15  
16 October 2011  
17

# Table of Contents

1			
2	TABLE OF CONTENTS .....		C-2
3	LIST OF TABLES.....		C-3
4	LIST OF FIGURES .....		C-3
5	ABBREVIATIONS.....		C-4
6	SYMBOLS .....		
7	.....		C-5
8	C.1    Introduction and Background .....		C-7
9	C.2    Probabilistic Approach to Combine Uncertain NDE Flaw Data with		
10	Prior Flaw Distributions .....	9	
11	C.2.1 <i>The Bayesian Framework</i> .....		C-9
12	C.2.2 <i>Probability of Detection and Measurement Error</i> .....		C-11
13	C.2.2.1.....	<i>Probability of Detection</i>	
14	.....		C-11
15	C.2.2.2.....	<i>Measurement (Sizing) Error</i>	
16	.....		C-12
17	C.2.3 <i>The Methodology for Updating the NDE Data</i> .....		C-13
18	C.2.3.1.....	<i>Updating Flaw Depth Distribution Models</i>	
19	.....		C-13
20	C.2.3.1.1Likelihood Function of Exact Flaw Depth Measurements.....		C-16
21	C.2.3.1.2Likelihood Function of Interval Flaw Depth Measurements.....		C-16
22	C.2.3.1.3Bayesian Updating of Parameters of the Flaw Depth Distribution ....		C-17
23	C.2.3.2.....	<i>Updating the Flaw Density Model</i>	
24	.....		C-17
25	C.3    Application Example .....		C-19
26	C.3.1 <i>Description of the NDE Data Used as Evidence to Build the Likelihood</i>		
27	Function .....		C-19
28	C.3.2 <i>Description of Flaw Depth and Density Information Used in VFLAW</i>		
29	<i>as Prior PDFs in this Example</i> .....		C-20
30	C.3.3 <i>Detection and Sizing Error Models</i> .....		C-23
31	C.3.4 <i>Bayesian Updating of the Parameters of the Flaw Depth Distributions</i> .....		C-24
32	C.3.4.1.....	<i>Bayesian Updating of the Parameters of Large Flaw Depth Distribution</i>	
33	<i>Based on the 3/8t UT Inspection Data</i> .....		C-25
34	C.3.4.2.....	<i>Bayesian Updating of the Parameters of Small Flaw Depth Distribution</i>	
35	<i>Based on the 3/8t UT Inspection Data</i> .....		C-27
36	C.3.4.3.....	<i>Results of Updating Parameters of Flaw Density Distribution Based</i>	
37	<i>on the 3/8t UT Inspection Data</i> .....		C-29
38	C.3.4.3.1Posterior Density of Large Flaws .....		C-29
39	C.3.4.3.2Posterior Density of Small Flaws .....		C-30
40	C.3.4.3.3Sensitivity of the Flaw Density Results to a Lower Bound of		
41	0.075” for the Interval Data Observed in the 3/8t Region .....		C-33
42	C.3.5 <i>Updating the 10 CFR 50.61a Tables</i> .....		C-33
43	C.4    References .....		C-37
44			
45			

1 **List of Tables**

2 Table C-1. Summary of Likelihood Functions ..... C-10  
3 Table C-2. Flaw Depth (a) and Flaw Density (b) Distributions and Hyper-PDF  
4 Parameters Used in VFLAW for PVRUF ..... C-22  
5 Table C-3. Updated VFLAW Distribution for Small Flaws ..... C-28  
6 Table C-4. Summary of the Posterior Parameter PDFs of Flaw Depth and Flaw  
7 Density to be used in VFLAW and FAVOR Runs for Beaver Valley-2 ..... C-32  
8 Table C-5. Alternate PTS Rule Flaw Table Assessment using Mean Number-of-Flaws  
9 by Size Interval for Beaver Valley-2 (Assuming a Lower Limit of 0.04” for  
10 Observed Data  
11 Interval) ..... C-35  
12 Table C-6. Alternate PTS Rule Flaw Table Assessment using Mean Number-of-Flaws  
13 by Size Interval for Beaver Valley-2 (Assuming a Lower Limit of 0.075” for  
14 Observed Data Interval) ..... C-35  
15

16  
17  
18 **List of Figures**

19 Figure C-1. A simple description of the Bayesian updating process ..... C-8  
20 Figure C-2. Measurement error distribution ..... C-13  
21 Figure C-3. Beaver Valley-2 weld map [C-14] ..... C-20  
22 Figure C-4. Flaw depth and flaw density distributions used in VFLAW and their  
23 corresponding parameter hyper-PDFs ..... C-21  
24 Figure C-5. POD vs. flaw depth ..... C-23  
25 Figure C-6. Measurement error vs. flaw depth ..... C-24  
26 Figure C-7. Bayesian updating elements of the Beaver Valley-2 example ..... C-25  
27 Figure C-8. Prior and posterior distributions of the flaw depth intensity of parameter  $\lambda_1$  ..... C-26  
28 Figure C-9. Bayesian prior and posterior PDFs of  $\lambda_s$  (per unit inch) ..... C-28  
29 Figure C-10. Marginal POD independent of small flaw depth ..... C-28  
30 Figure C-11. Prior and posterior flaw density (a) and intensity (b) for large size flaw ..... C-30  
31 Figure C-12. Prior and posterior flaw density (a) and intensity (b) for small size flaws ..... C-31  
32 Figure C-13. Posterior number of flaws in the 3/8t region in various flaw size intervals  
33 including epistemic uncertainties ..... C-33  
34 Figure C-14. Posterior number of flaws in the Supplement 4 inspection volume in  
35 various flaw size intervals including epistemic uncertainties ..... C-36  
36  
37  
38  
39  
40

1

## Abbreviations

2

Abbreviation	Definition
PDF	Probability Density Function
CDF	Cumulative Density Function
ISI	In-Service Inspection
NDE	Nondestructive Evaluation
POD	Probability of Detection
PTS	Pressurized Thermal Shock
RPV	Reactor Pressure Vessel
SAW	Submerged Arc Weld
SMAW	Shielded Metal Arc Weld
UT	Ultrasonic Test

3

4

5

1  
2

## Symbols and Expressions

Symbol	Definition
$a$	True flaw depth (inches)
$A$	Random variable representing flaw depth
$\hat{a}$	Logarithm of signal-response amplitude in flaw-detection NDE
$a^*$	NDE measured (or observed) flaw depth (inches)
$a_{th}$	Threshold flaw depth for detection below which flaw detection is beyond the capability of the NDE technology used
$D$	The event that a flaw is detected
$\bar{D}$	The event that a flaw is not detected
$E_M$	Model error of the NDE measurement error, represented by a normal distribution with mean of zero and known standard deviation
$f_a(a^*-M_\epsilon \Phi)$	PDF of the true flaw depth, given the vector of PDF parameters represented in terms of observed flaw depth $a^*$ but corrected for the measurement error $M_\epsilon$
$f_l(a \Phi, a \geq t_{tr})$	Conditional PDF of large flaw depth
$f_s(a \Phi, a < t_{tr})$	Conditional PDF of small flaw depth
$f(\cdot), g(\cdot), h(\cdot), l(\cdot), m(\cdot), x(\cdot), g'(\cdot), k(\cdot), \gamma(\cdot)$	PDF functions of model parameters, flaw depth, or flaw density
$g(M_\epsilon)$	PDF of the measurement error (in terms of $a^*$ )
$L(a \Phi)$	Likelihood of true flaw depth given the vector of parameters $\Phi$
$L(Data \theta)$	Likelihood of observed NDE data conditioned on (given) the unknown parameter $\theta$
$L(n^*   n_j)$	Likelihood of observing $n^*$ flaws given there are a total of $n_j$ true flaws
$M_\epsilon$	NDE measurement error (combined random and systematic errors)
$m_i^*$	Number of flaw depths observed (reported in NDE) in the interval $i$
$n$	Number of flaw-depth intervals (reported in NDE)
$n^*$	Number of exact flaw depths observed (reported in NDE)
$\binom{n_j}{n^*}$	Combination of $n^*$ observed flaws out of total flaws $n_j$ (observed or detected, and unobserved or not detected flaws)
$N$	Mean of the PDF of the number of flaws in volume $v$
$N(0;\sigma)$	Normal PDF with mean zero and standard deviation of $\sigma$
$POD(a)$	Probability of detection of a flaw of depth $a$
$POD(a^*-M_\epsilon)$	POD of true flaw depth represented in terms of observed flaw depth $a^*$ by correcting for the measurement error $M_\epsilon$
$Pr(\cdot)$	Probability
$Pr(D)$	POD independent of flaw depth
$Pr(\bar{D})$	Probability of no detection regardless of size
$Pr(n_j   n^*)$	Probability of total flaws $n_j$ conditioned on observing $n^*$ flaws in NDE
$Pr(\Phi, t_{tr})$	POD independent of flaw size (i.e., $Pr(D)$ )
$t_{tr}$	Transition flaw depth which separates large flaw depth from small flaw depth
$v$	Volume of inspected weld
$\beta_i$	Parameter $i$ of the POD model
$\Delta$	Weld bead thickness

Symbol	Definition
$\varepsilon$	Random error of the model
$\lambda$	Flaw-depth intensity parameter (inch <sup>-1</sup> ) of the exponential distribution $f(a) = \lambda e^{-\lambda a}$ representing flaw-depth distribution, also flaw intensity (flaws/ft <sup>3</sup> ) representing Poisson flaw density distribution: $\text{Pr}(N) = e^{-\lambda v} \frac{(\lambda v)^N}{N!}$
$\pi_0(\theta)$	Prior PDF of an unknown parameter $\theta$
$\pi_1(\theta \text{Data})$	Posterior PDF of an unknown parameter $\theta$ given observed NDE data
$\Phi$	Vector of parameters of the flaw-depth PDF
$\theta$	An unknown parameter of a model
$\Theta$	Vector of parameters of the POD model
$\rho$	Poisson distribution parameter representing the volumetric intensity of flaws (flaws per unit volume)
$\sigma_{\text{POD}}(a)$	Standard deviation of PDF of the POD model error vs. flaw depth
$\gamma(\cdot \alpha_1, \alpha_2)$	Gamma PDF with parameters $\alpha_1$ and $\alpha_2$

1  
2

## 1 **C.1 Introduction and Background**

2 In 2010, the NRC amended its regulations to provide alternative screening methods for  
3 protection against Pressurized Thermal Shock (PTS) events that could affect the Reactor  
4 Pressure Vessels (RPVs) of the operating Pressurized-Water Reactors (PWRs). The new rule,  
5 10 CFR 50.61a [C-1], provides a means for determining whether the flaws found through  
6 In-Service Inspection (ISI) of a particular RPV are consistent with the assumptions regarding the  
7 number and size of flaws used in the PTS analyses that provided the technical basis for the new  
8 rule. To address this requirement, 10 CFR 50.61a includes two tables (one table for weld  
9 material and one table for plate/forging material) that express the maximum flaw density and  
10 flaw depths that are allowed in the beltline of an RPV.


11 The new rule relies on flaw characteristics (flaw depth and density) that were simulated and  
12 used by the probabilistic fracture mechanics computer code FAVOR [C-2] to develop the  
13 10 CFR 50.61a flaw tables. These flaw characteristics were proposed by Simonen et al. in  
14 NUREG/CR-6817 [C-3] and are used by the VFLAW code to generate the input flaws for  
15 FAVOR. The data include distribution functions that represent the initial fabrication flaws in  
16 some RPVs. The FAVOR computer code fully incorporates these distributions by sampling from  
17 each using Monte Carlo techniques.

18 The flaw distributions reported in NUREG/CR-6817 are based on information obtained from  
19 destructive and very precise techniques used to experimentally detect and size the flaws.  
20 These tables have been viewed as the permissible limit for distribution of the “true” flaw depths  
21 and flaw densities. These depth and densities may be contrasted with those “observed” in an  
22 ISI using Non-Destructive Evaluation (NDE) techniques such as the Ultrasonic Test (UT). The  
23 NDE results used to assess compliance with the 10 CFR 50.61a tables would be more  
24 representative of the specific vessel inspected than the flaw distributions in NUREG/CR-6817  
25 and could be used to support development of vessel-specific flaw-size and -density  
26 distributions. However, the NDE results are influenced by detection limits, detection errors, and  
27 sizing and measurement errors. Development of the vessel-specific distribution of the true flaw  
28 density and depth should account for such uncertainties.

29 This report describes the development and application of a methodology to account for  
30 uncertainties in NDE data and to analyze such data for the purpose of developing more realistic  
31 vessel-specific flaw-depth and -density distributions for comparison to the 10 CFR 50.61a  
32 screening tables, as well as for use as an input to FAVOR analysis. The methodology  
33 considers detection probability, flaw-measurement error, and flaw-detection threshold in its  
34 application. Application of the methodology is demonstrated using the ultrasonic NDE data  
35 obtained from an ISI of the Beaver Valley 2 RPV.

36 Flaw distributions developed and reported in NUREG/CR-6817 are based on destructive  
37 evaluation of two cancelled RPVs supplemented by expert judgment data. In contrast, the  
38 vessel-specific inspection data come from NDE inspections using, for example, UT methods.  
39 The variability in both the characteristics of the data (size, range, and number of flaws  
40 measured) and the UT system performance (probability of detection and measurement/sizing  
41 errors) highlighted a need for analyzing the inspection results on a vessel-specific or  
42 data-set-specific basis. For this purpose, traditional methods were inadequate, and therefore a  
43 new methodology that could accept a very small number of flaws (typical of vessel-specific NDE  
44 results), including inspection-system flaw-detection reliability, flaw-sizing accuracy  
45 (measurement error), and flaw-detection threshold, was developed.

1 The methodology is demonstrated here through an application using the UT data reported for  
2 the Beaver Valley 2 RPV [C-13]. The objective was to provide a probabilistic description (in  
3 terms of the probability density function) of the actual flaw depth and flaw density of the welds  
4 based on the detected flaws from NDE examinations of this RPV using UT. Because the NDE  
5 data are uncertain and contain measurement errors, data developed as part of the PTS study  
6 (the so-called VFLAW data) were specialized to the Beaver Valley 2 RPV and used as the prior  
7 flaw information. Combination of the prior information and the NDE results of the Beaver  
8 Valley 2 RPV led to the development of the posterior flaw information, which represents the  
9 distribution of the true flaw depth and flaw density of the Beaver Valley 2 RPV welds. See  
10 Figure C-1 for an illustration of the Bayesian updating process. It is important to note that the  
11 VFLAW data, while representing generic values of flaw characteristics (based on expert  
12 judgment and on the PVRUF and Shoreham RPVs), may be specialized to a specific RPV, for  
13 example by using RPV-specific weld length, bead thickness, geometry and other weld  
14 characteristics of (in this case) Beaver Valley 2. Therefore, the specialized VFLAW data would  
15 be the most representative information that can be used to describe prior flaw-depth and  
16 flaw-density distributions and characteristics. If other prior information is available, such  
17 information may also be used instead of or in addition to the specialized VFLAW data.



18

19 Figure C-1. A simple description of the Bayesian updating process.

20

21 In the remainder of this report, the methodology is described first, followed by the application to  
22 the Beaver Valley 2 ISI data. The results are used to compare the Beaver Valley 2 RPV to the  
23 10 CFR 50.61a screening tables. As such, the VFLAW-based flaw models are updated to more  
24 realistically represent this RPV.

25



## 1 **C.2 Probabilistic Approach to Combine Uncertain NDE Flaw Data** 2 **with Prior Flaw Distributions**

3 In this section, a Bayesian updating methodology is proposed to combine the observed NDE  
4 data with the available flaw data and models used as part of the PTS re-evaluation effort. First,  
5 the Bayesian framework in general will be discussed, followed by the NDE data uncertainties  
6 (i.e., probability of detection and measurement/sizing error), and finally the developed Bayesian  
7 updating procedure will be discussed.

### 8 **C.2.1 The Bayesian Framework**

9 Suppose that background (prior) information is available about a model (e.g., the probability  
10 density functions representing flaw depth and flaw density). If new evidence becomes available,  
11 for example vessel-specific NDE data, it is possible to update the prior information  
12 (e.g., distribution models) in light of the new NDE-based evidence. The process of updating  
13 prior distribution models may be formally done through Bayesian inference. Bayesian inference  
14 is conceptually simple and logically consistent. It provides a powerful approach to combine  
15 observed or measured data with background (prior) information.

16 In Bayesian inference, the state of knowledge (uncertainty) of a random variable of unknown  
17 value that is of interest is quantified by assigning a probability distribution or Probability Density  
18 Function (PDF) to its possible values. Bayesian inference provides the mathematical formalism  
19 by which this uncertainty can be updated in light of any new evidence.

20 In the framework of the Bayesian approach, the parameters of the model of interest (e.g., the  
21 intensity parameter,  $\lambda$ , of an exponential distribution representing flaw depth) are treated as  
22 random variables, the true values of which are unknown. Thus, a PDF can be assigned to  
23 represent the parameter values. In practice, however, some prior information about the  
24 parameters may be known, including any prior data and subjective judgments regarding the  
25 parameter values that may be available. For example, the intensity parameter,  $\lambda$ , of an  
26 exponential distribution representing the variable flaw depth (e.g., in  $\text{inch}^{-1}$ ) may be known from  
27 related observations and data of similar vessels. If new NDE observations provide limited but  
28 more specific data about a particular RPV, it is possible to update any prior PDF of the  
29 flaw-depth intensity parameter by combining the NDE data with the prior PDF. In this case, the  
30 prior knowledge is combined with the specific NDE data to build a posterior PDF that is more  
31 representative of the true intensity parameter and thus the true flaw-depth distribution that  
32 accounts for the uncertainties in the observed NDE data.

33 Let  $\theta$  be a parameter of interest (for example the flaw intensity parameter). Assume that  $\theta$  is a  
34 continuous random variable, such that the prior and posterior PDFs of  $\theta$  are likewise  
35 continuous. Also, let  $L(\text{Data}|\theta)$  express how likely is it to observe the data (e.g., the NDE data  
36 measured) in light of given values of parameter  $\theta$ . Certain values of  $\theta$  show that the data  
37 observed are more likely to support the PDF whose parameter is  $\theta$ . Then, according to  
38 Bayesian inference [C-4], the posterior PDF that represents a properly weighted combination of  
39 the prior PDF and the likelihood of the parameter  $\theta$  will be:

$$\pi_1(\theta|\text{Data}) = \frac{\pi_0(\theta)L(\text{Data}|\theta)}{\int_0 \pi_0(\theta)L(\text{Data}|\theta)d\theta} \quad \text{Eqn. (C-1)}$$

1 The posterior PDF,  $\pi_1(\theta|\text{Data})$ , represents the updated prior PDF of  $\theta$ ,  $\pi_0(\theta)$ , in light of the  
 2 observed data (shown by its likelihood function  $L(\text{Data}|\theta)$ ). The denominator of Eqn. (C-1) is  
 3 called the marginal density of the data or the normalization constant. The most difficult part of a  
 4 Bayesian analysis, besides describing the likelihood function, is the computational challenge of  
 5 determining the normalizing constant that often requires multidimensional numerical integration.  
 6 The prior PDF  $\pi_0(\theta)$  reveals knowledge of parameter  $\theta$  before data are used. The posterior  
 7 PDF  $\pi_1(\theta|\text{Data})$  is called posterior because it reflects the PDF of  $\theta$  after the data are used.

8 Certain prior PDFs are called “conjugate” [C-4]. This is the class of prior PDFs that yields the  
 9 same functional form for the posterior distribution. For example, if flaw-depth distribution is  
 10 represented by an exponential distribution, a gamma PDF representing the intensity  
 11 parameter,  $\lambda$ , of the exponential distribution is a conjugate distribution. This means that when  
 12 updated by new NDE flaw data, the posterior PDF of  $\lambda$  will also be a gamma distribution.  
 13 Hamada et al. [C-5] present a comprehensive overview of the mathematical steps for updating  
 14 the conjugate distributions used in the Bayesian analyses. In simple problems, the conjugate  
 15 distribution makes posterior PDF calculations simple because it eliminates the complex,  
 16 computationally challenging integrations in Eqn. (C-1).

17 For example, consider NDE flaw observations (data). In this case, the likelihood of all such  
 18 data, given a parameter  $\theta$  of the flaw-depth PDF  $L(\text{Data}|\theta)$ , would be expressed as the  
 19 probability of the intersections of the individual flaw measurements; that is, the probability of an  
 20 event consisting of *flaw-measurement-1*  $\cap$  *flaw-measurement-2*  $\cap$  *flaw-measurement-3*  $\cap$  ... .  
 21 The likelihood, therefore, would be the product of the probability of observing each flaw  
 22 depth,  $a_i$ , as shown by Eqn. (C-2). The likelihood function is independent of the order of each  
 23 data point and is given by:

$$L(\text{Data} | \theta) = c \prod_i L_i(a_i | \theta) \quad \text{Eqn. (C-2)}$$

24 where  $c$  is a combinatorial constant that quantifies the number of combinations in which the  
 25 observed NDE data points,  $a_i$ , could have occurred. The constant  $c$  cancels from the numerator  
 26 and denominator of Eqn. (C-1), and therefore is usually not included in the expressions of the  
 27 likelihood function. Table C-1 summarizes the likelihood functions for different types of flaw  
 28 data observations, if the PDF of the variable of interest (flaw depth in this case) is described by

29  $f(a|\theta)$  with the corresponding Cumulative Density Function (CDF) of  $F(a|\theta) = \int_0^a f(x|\theta)dx$ .

30 Table C-1. Summary of Likelihood Functions

31

Type of Observation	Likelihood Function	Example Description
Exact Flaw Depth	$f(a_i \theta)$	Exact flaw depth $a_i$ is reported
Right Censored Flaw	$1-F(a_R \theta)$	Flaw depth exceeds $a_R$
Left Censored Flaw	$F(a_L \theta)$	Flaw depth is less than $a_L$
Interval Censored	$F(a_R \theta) - F(a_L \theta)$	Flaw depth is between $a_L$ and $a_R$
Left Truncated	$f(a_i \theta) / [1-F(a_C \theta)]$	Flaw depth is $a_i$ where flaw observations are not possible below $a_C$

32

1 **C.2.2 Probability of Detection and Measurement Error**

2 Interpretation of NDE data requires an understanding of the associated uncertainties. For  
3 example, one inspector may miss a specific flaw found by another. For this reason, the  
4 reliability of an inspection is customarily expressed in terms of the Probability of Detection  
5 (POD) of a given flaw size and expressed by curves of POD vs. flaw size. Determining detailed  
6 POD curves can also be difficult. Flaw detection depends on several factors and it can be  
7 difficult to produce statistical data to estimate the POD considering variations in material types,  
8 inspection methods, skill levels, equipment imprecision, and other factors.

9 Additionally, sizing or measurement errors occur and measurement model uncertainties exist.  
10 The measurement errors are generally composed of some combination of stochastic (random)  
11 errors and systematic errors. Random errors are intrinsic to any measurement and are caused  
12 by instrumentation imprecision and variability, among other sources. Systematic errors are  
13 biases in NDE measurement resulting in the mean of many separate measurements differing  
14 consistently and appreciably from the true value of the measured flaw. Biases or systematic  
15 errors are often significant contributors to flaw data uncertainties. For example, in UT  
16 application to RPVs, there is a general trend toward overestimating the size of small flaws while  
17 underestimating the size of larger flaws [C-6].

18 **C.2.2.1 Probability of Detection**

19 Formally, the POD can be defined as the probability that the NDE system detects a flaw of  
20 specific depth  $a$ , if it exists, and is denoted by  $POD(a)$  [C-6]. POD is generally modeled as a  
21 function of through-wall extent of the flaw. The POD also depends on other factors such as  
22 material test equipment, measurement method, and geometry. For example, POD generated  
23 for a particular material thickness might not be true for the same material with a different  
24 thickness. The POD should also consider appropriate adjustments for shallow surface flaws  
25 adjacent to the clad.

26 Consider a binary random variable  $D$  indicating a flaw detected (or  $\bar{D}$  indicating a flaw not  
27 detected). Probability of detection of a flaw of depth  $a_i$  is:

$$POD(a_i) = Pr(D | a = a_i) \quad \text{Eqn. (C-3)}$$

28 The data from which  $POD(a)$  functions are generated can be categorized into two types:  
29 hit/miss and signal-response amplitude. The hit/miss data type shows whether a flaw is  
30 detected or not. This type of data is subjective in nature depending on the operator experience.  
31 In this method, the smallest and largest flaw sizes detected should be identified. Any size below  
32 the smallest size is never detected, whereas a size above the largest size is always detected.  
33 The POD is then calculated as the ratio of the number of successful detections over the total  
34 number of inspections performed for a particular flaw size and is called the averaged POD.

35 Different forms of POD curves have been used in the literature (see References [C-7], [C-8],  
36 and [C-9]). The logistic POD model for hit/miss data is a common model and is represented as:

$$POD(a | \beta_1, \beta_2, a_{th}) = \begin{cases} \text{logistics}(a | \beta_1, \beta_2, a_{th}) & \text{for } a > a_{th} \\ 0 & \text{otherwise} \end{cases} \quad \text{Eqn. (C-4)}$$

1 where  $a$  is the flaw depth and  $N(0;\sigma(a))$  is the random error represented by a normal distribution  
 2 with a constant standard deviation  $\sigma$  or a deviation which may be a function of flaw depth (that  
 3 is,  $\sigma(a)$ ). The random error accounts for the POD model error. Model parameters  $\beta_1$  and  $\beta_2$   
 4 may be uncertain (epistemic) and would be represented by the bivariate PDF  $k(\Theta)$ , where  $\Theta$  is  
 5 the vector of the parameters,  $\Theta = \{\beta_1, \beta_2\}$ . The PDF function  $m(\sigma(a))$  may also be used to  
 6 express any epistemic uncertainties by treating  $\sigma(a)$  as a random variable. The parameter  $a_{th}$  in  
 7 Eqn. (C-4) represents the threshold (the flaw size below which detection is not possible).

8 The other type of POD data represents measurements of the amplitude of signal response  
 9 recorded by the NDE system, such as in a UT system. For signal-response data, much more  
 10 information is supplied in the signal for further analyses than is in the hit/miss data. In the  
 11 signal-response approach, the most important parameters are the inspection threshold (noise  
 12 level) and the decision threshold. All responses less than the inspection threshold are ignored.

13 In the signal-response approach, it is generally assumed that the logarithm of the  
 14 signal-response amplitude,  $\hat{a}$ , is linearly correlated to the logarithm of the flaw depth,  $a$ , as  
 15 shown in Eqn. (C-5):

$$\log(\hat{a}) = \beta_3 + \beta_4 \log(a) + \varepsilon \quad \text{Eqn. (C-5)}$$

16 where  $\varepsilon$  is the random error and  $\beta_3$  and  $\beta_4$  are the regression parameters. The random error  
 17 can be assumed to have a normal distribution with mean zero and a constant or variable  
 18 standard deviation. Based on this assumption, it can be shown that the POD curve can be  
 19 modeled using a lognormal CDF. The corresponding POD is shown as:

$$\text{POD}(a) = \Pr(\hat{a} > \hat{a}_{th}) = \Pr(\log(\hat{a}) > \log(\hat{a}_{th})) \quad \text{Eqn. (C-6)}$$

20 where  $a_{th}$  is the decision (detection) threshold signal. The decision threshold is chosen to be a  
 21 bit higher than the inspection threshold in order to minimize the probability of a false call (for  
 22 cases in which the decision threshold is not intentionally chosen to allow a certain probability of  
 23 a false call) in the POD estimates. The  $\hat{a}$  vs.  $a$  data can also be converted into hit/miss data by  
 24 using the decision threshold, and an averaged POD can be determined.

### 25 **C.2.2.2 Measurement (Sizing) Error**

26 Measurement results are always associated with errors of varying magnitudes. Measurement  
 27 error is defined as the difference between the measured and the true flaw depth. Measurement  
 28 error is defined by Eqn. (C-7), where  $M_\varepsilon$  is the measurement error,  $a^*$  is the measured value of  
 29 flaw depth, and  $a$  is the true value of flaw depth:

$$M_\varepsilon = a^* - a \quad \text{Eqn. (C-7)}$$

30 The measurement error has two components: systematic error (bias) and random error.  
 31 Random error may be represented by a normal distribution with zero mean and constant  
 32 standard deviation. Systematic error in most cases is a major contribution to flaw  
 33 measurements and cannot be ignored. In its simplest form, the measurement error can be  
 34 represented by a linear function of true size as shown in Eqn. (C-8), where  $m$  is the slope and  
 35  $c$  is the intercept of the line representing measurement error,  $M_\varepsilon$ , versus true flaw depth,  $a$ . If  
 36 available, PDFs of  $m$  and  $c$  can be expressed to represent the epistemic uncertainty in these

1 parameters. Also,  $M_\varepsilon$  may be represented as a linear function of measured flaw depth  $a^*$   
 2 because all data available are in terms of  $a^*$ .

$$M_\varepsilon = ma + c + E_M$$

where,  $a$  = true flaw depth and  $E_M = N_M(0, \sigma_M)$ ,

or based on Eqn. (7) :

$$M_\varepsilon = m(a^* - M_\varepsilon) + c + E_M; \text{ or}$$


$$M_\varepsilon = \frac{m}{m+1} a^* + \frac{c}{m+1} + \frac{E_M}{m+1} = m' a^* + c' + E'_M$$

Eqn. (C-8)

where,  $a^*$  = measured depth,  $m'$  = slope,  $c'$  = intercept,

and  $E'_M = N_M(0, \sigma'_M)$  of  $M_\varepsilon$  vs.  $a^*$

3 The aleatory random measurement error  $E'_M$  is shown by the normal distribution  $N_M(0; \sigma'_M)$  in  
 4 Eqn. (C-8). As such, the total measurement error may be represented as the normal distribution  
 5  $g(M_\varepsilon) = N(m'a^* + c'; \sigma'_M)$ . Figure C-2 shows a conceptual example of the measurement error as a  
 6 function of true flaw size (one can also show  $M_\varepsilon$  vs.  $a^*$ ). According to Eqn. (C-7), the  
 7 relationship between the true flaw depth,  $a$ , and measured depth,  $a^*$ , is  $a = a^* - M_\varepsilon$ .



8  
 9 Figure C-2. Measurement-error distribution

10 If the measurement error's given flaw depth,  $a$ , is  $M_\varepsilon$ ,  $E_M$  describes the PDF of random or  
 11 stochastic error. Clearly, Figure C-2 depicts a case in which the standard deviation of the PDF  
 12 of  $E_M$  is not constant; rather, it is a monotonically increasing line.

### 13 C.2.3 The Methodology for Updating the NDE Data

14 This section discusses the details of the Bayesian updating approach, which combines UT data  
 15 (including their uncertainties) with the prior PDF models of flaw depth and density (used in  
 16 VFLAW to generated FAVOR input) to arrive at posterior distributions of flaw characteristics.

#### 17 C.2.3.1 Updating Flaw-Depth Distribution Models

18 The ultimate objective of this analysis is to describe PDFs of the flaw depth and density  
 19 considering UT measurement of flaws (which contain modeling uncertainty and stochastic  
 20 variability in form of the POD and measurement error). We start with the Bayesian estimation of  
 21 the (large and small) flaw depths, followed by the same estimation for flaw density.

1 In the Bayesian framework described by Eqn. (C-1), prior information on the flaw depth PDF (for  
 2 example, data and expert elicitation described in NUREG/CR-6817) may be combined with the  
 3 uncertain measurement data from NDE to assess a posterior distribution of the flaw depths.  
 4 Consider the PDF of the flaw depth,  $a$ , as  $f(a | \Phi)$ , where  $\Phi$  is a vector of all the PDF  
 5 parameters.

6 The data reported in NUREG/CR-6817 show that the small and large flaw depths are  
 7 represented using different distributions. For example, the models proposed and used in  
 8 VFLAW rely on the exponential distribution for large flaw depths but use the multinomial  
 9 distribution to model small flaw depths. The flaw depth that separates the two distributions is  
 10 defined as the transition flaw depth. Therefore, a given PDF may only be true up to a limit from  
 11 which it transitions to another distribution. For the transition flaw depth  $t_{tr}$ , the PDF that  
 12 describes the flaw depth should be conditioned on exceeding or falling below the transition limit.  
 13 Therefore:

$$f_l(a | \Phi, a \geq t_{tr}) = \frac{f(a | \Phi)}{\Pr(a \geq t_{tr})}$$

$$f_s(a | \Phi, a < t_{tr}) = \frac{f(a | \Phi)}{\Pr(a < t_{tr})}$$

Eqn. (C-9)

14 In VFLAW, for example,  $t_{tr}$  for the weld regions was selected as the flaw depth of about the bead  
 15 thickness,  $\Delta$ , of the corresponding weld. Further, in VFLAW the flaw depth is normalized to the  
 16 dimensionless random variable  $a/\Delta$  instead of to  $a$ . The approach discussed herein applies to  
 17 PDFs of both  $a$  and  $a/\Delta$ , but the respective equations of the approach are only shown in terms  
 18 of the PDF similar to Eqn. (C-9).

19 Consider the PDF of NDE measurement error  $M_\epsilon$  (represented by Eqn. (C-8)) of a measured  
 20 flaw depth  $a^*$  with stochastic random variable  $E$ . The flaw-depth distribution corrected for the  
 21 measurement error,  $M_\epsilon$ , by assuming that true flaw depth,  $a$ , may be represented by correcting  
 22 the measured depth  $a^*$  using the relationship  $a = a^* - M_\epsilon$  [C-10]. As stated earlier in Eqn. (C-8),  
 23 the PDF of  $M_\epsilon$  will be  $g(M_\epsilon) = N(m'a^* + c'; \sigma'_M)$ . If there are epistemic uncertainties about  
 24 parameters  $m'$  and  $c'$ , they may be represented by the bivariate PDF  $x(\Omega)$ , where  $\Omega$  is the vector  
 25 of the parameters  $m'$  and  $c'$ . The expected distribution of measurement error would be:

$$g'(M_\epsilon) = \int_{\Omega} g(M_\epsilon) x(\Omega) d\Omega$$

Eqn. (C-10)

26 While the measurement-error-corrected PDF adjusts the flaw depths to true values, the flaws  
 27 missed, as characterized by the POD, should also be accounted for. That is, for every  
 28 measured flaw  $a^*$ , a corresponding probability (including uncertainties) that additional flaw(s)  
 29 may be missed should be accounted for.

30 If the POD is represented as a mathematical function of the flaw size,  $a$ , the vector of  
 31 parameters  $\Theta$  of the POD function may be associated with a known multivariate PDF  $k(\Theta)$  in  
 32 order to account for the uncertainties. It is also possible to add a stochastic model error term,  
 33 represented by a normal distribution with the mean zero and the standard deviation  $\sigma_{POD}(a)$ .  
 34 For simplicity, it is also possible to assume that the error term is absorbed in the PDF of the  
 35 POD model parameters (i.e.,  $k(\Theta)$ ). The marginal POD independent of the random variables  $\Theta$   
 36 and  $\sigma_{POD}(a)$  would be:

$$\text{POD}(a) = \iint_{\sigma_{\text{POD}}, \Theta} \text{POD}(a | \Theta, \sigma_{\text{POD}}(a)) k(\Theta) m(\sigma_{\text{POD}}(a)) d\Theta d\sigma_{\text{POD}} \quad \text{Eqn. (C-11)}$$

1 Marginal POD, independent of flaw depth conditional on  $\Phi$  (see Eqn. (C-9)) and  $t_{tr}$ , is then  
 2 expressed as:

$$\begin{aligned} \text{Pr}_s(D) &= \text{POD}(\Phi, a < t_{tr}) = \int_0^{t_{tr}} \text{POD}(a) f_s(a | \Phi, a < t_{tr}) da \\ \text{Pr}_l(D) &= \text{POD}(\Phi, a \geq t_{tr}) = \int_{t_{tr}}^{\infty} \text{POD}(a) f_l(a | \Phi, a \geq t_{tr}) da \end{aligned} \quad \text{Eqn. (C-12)}$$

3 where  $\text{Pr}(D)$  expresses the probability that a small or large flaw is detected regardless of size,  
 4 which in general is a function of  $\Phi$  and  $t_{tr}$ ; that is,  $\text{POD}(\Phi, t_{tr})$ . The probability of not detecting a  
 5 flaw would be  $\text{Pr}(\bar{D}) = 1 - \text{Pr}(D)$ . Let the random variable  $A$  represent the true  
 6 flaw depth. Then, according to the Bayesian formulation by Celeux et al. [C-11], the probability  
 7 that a detected flaw has a depth in the vicinity of  $a$ , inside an interval  $\Delta a$ , may be expressed as:

$$\begin{aligned} \text{Pr}(a < A < a + \Delta a | D) &= \frac{\text{Pr}[a < A < a + \Delta a \cap D]}{\text{Pr}(D)} \\ &= \frac{\text{Pr}(a < A < a + \Delta a) \cdot \text{Pr}(D | a < A < a + \Delta a)}{\text{Pr}(D)} \end{aligned} \quad \text{Eqn. (C-13)}$$

8 where  $D$  is the event that a flaw is detected. The limit of Eqn. (C-13) as the flaw depth  
 9 interval  $\Delta a$  approaches zero may be found after dividing Eqn. (C-13) by  $\Delta a$ . The left term limit  
 10 represents the likelihood that a detected flaw will have the depth  $a$ . Further, by rearranging the  
 11 right side, the PDF of flaw depth independent of detection and POD, given a flaw of depth  $a$ ,  
 12 may be found:

$$\begin{aligned} \lim_{\Delta a \rightarrow 0} \frac{\text{Pr}(a < A < a + \Delta a | D)}{\Delta a} &= L(a | D) = \lim_{\Delta a \rightarrow 0} \frac{\text{Pr}(a < A < a + \Delta a) \cdot \text{Pr}(D | a < A < a + \Delta a)}{\text{Pr}(D) \Delta a} = \\ &= \underbrace{\lim_{\Delta a \rightarrow 0} \frac{\text{Pr}(a < A < a + \Delta a)}{\Delta a}}_{f(a | \Phi, t_{tr})} \cdot \underbrace{\lim_{\Delta a \rightarrow 0} \text{Pr}(D | a < A < a + \Delta a)}_{\text{POD}(a)} \cdot \frac{1}{\text{Pr}(D)} \end{aligned} \quad \text{Eqn. (C-14)}$$

13 Using Eqn. (C-14), the corresponding likelihood that a detected flaw is of depth  $a$  may be  
 14 expressed as:

$$L(a | \Phi) = \frac{f(a | \Phi, t_{tr}) \cdot \text{POD}(a)}{\text{POD}(\Phi, t_{tr})} \quad \text{Eqn. (C-15)}$$

15 Eqn. (C-15) forms the basis for development of the likelihood function, which would be  
 16 necessary in the Bayesian framework (as discussed in Section C.2.1) to estimate the posterior  
 17 PDF of flaw depth given the observed NDE flaw data and the prior information about the  
 18 characteristics of flaw PDF.

1 **C.2.3.1.1 Likelihood Function of Exact Flaw-Depth Measurements**

2 Suppose that the NDE reports exact flaw depths. Based on Eqn. (C-2), the likelihood function  
 3 of  $n^*$  flaws of known depth (containing measurement errors)  $a_1^*, a_2^*, a_3^*, \dots$  would be

4  $L(\text{Data} | \Phi) = \prod_{i=1}^{n^*} L(a_i^* | \Phi)$ . It is important to correct for POD and the measurement error and  
 5 parameter uncertainties according to Eqn. (C-10) and to represent flaw depths in terms of the  
 6 measured value using Eqn. (C-7) so that  $a_i^* = M_{\epsilon} + a_i^1$ . Therefore, using Eqn. (C-15), the  
 7 likelihood of exact flaw measurements reported may be expressed as [C-10]:

$$L(\text{All exact measured data} | \Phi, t_{tr}) = \frac{1}{[\text{POD}(\Phi, t_{tr})]^{n^*}} \prod_{i=1}^{n^*} \int_{M_{\epsilon}} \text{POD}(a_i^* - M_{\epsilon}) f((a_i^* - M_{\epsilon}) | \Phi, t_{tr}) g'(M_{\epsilon}) dM_{\epsilon} \quad \text{Eqn. (C-16)}$$

8 Because NDE data are measured and have associated measurement error and other  
 9 uncertainties, but the POD and measurement error discussed earlier are modeled to be relevant  
 10 to the true flaw depth,  $a$ , in Eqn. (C-16) the true flaw depth is replaced with its equivalent  $(a^* - M_{\epsilon})$ .  
 11 The expectation of the numerator of Eqn. (C-15), independent of the measurement error, is  
 12 found by multiplying the term  $f(a | \Phi, t_{tr}) \text{POD}(a)$  by the expected PDF of the measurement error,  
 13  $g'(M_{\epsilon})$ , and integrating this over all values of the measurement error.

14 **C.2.3.1.2 Likelihood Function of Interval Flaw-Depth Measurements**

15 If in addition to or instead of the exact flaw-depth data, interval data are reported (such as the  
 16 number of flaws observed less than a given depth or between an upper and lower limit), the  
 17 likelihood of  $m_i^*$  flaws reported in the interval  $i$ , corrected for the measurement error but  
 18 independent of the error, would be [C-12]:

$$L(\text{Interval consisting of } m_i^* \text{ measured flaw depths} | \Phi, t_{tr}) = \left[ \frac{1}{\text{POD}(\Phi, t_{tr})} \int_{a_{i-1}^*}^{a_i^*} \int_{M_{\epsilon}} \text{POD}(a^* - M_{\epsilon}) f((a^* - M_{\epsilon}) | \Phi) g'(M_{\epsilon}) dM_{\epsilon} da^* \right]^{m_i^*}$$

Eqn. (C-17)

19 If  $n$  such flaw-depth intervals were reported, the corresponding likelihood function using  
 20 Eqn. (C-17) would be:

$$L(n \text{ interval of } m \text{ measured depths} | \Phi, t_{tr}) = \prod_{i=1}^n \left[ \frac{1}{\text{POD}(\Phi, t_{tr})} \int_{a_{i-1}^*}^{a_i^*} \int_{M_{\epsilon}} \text{POD}(a^* - M_{\epsilon}) f((a^* - M_{\epsilon}) | \Phi) g'(M_{\epsilon}) dM_{\epsilon} da^* \right]^{m_i^*}$$

Eqn. (C-18)

---

<sup>1</sup> Note that if  $X$  and  $Y$  are two continuous random variables with probability density functions  $f(x)$  and  $g(y)$ , the random variable  $Z = X + Y$  will have a probability density function  $h(Z)$  such that:

$$h(z) = \int_{-\infty}^{\infty} f(z - y)g(y)dy$$



1 If exact and interval NDE data are both reported, the likelihood function would be a multiple of  
 2 Eqn. (C-16) and Eqn. (C-18). That is:

$$3 \quad L(\text{Mix Measured Flaw Depths} \mid \Phi, t_{tr}) = \\
 4 \quad L(n \text{ Interval Measured Flaw Depths} \mid \Phi, t_{tr}) \times L(n^* \text{ Exact Measured Flaw Depths} \mid \Phi, t_{tr})$$

#### 4 **C.2.3.1.3 Bayesian Updating of Parameters of the Flaw Depth Distribution**

5 Regardless of the form of the data (exact flaw-depth and/or interval data), the Bayesian  
 6 inference of the vector of parameters  $\Phi$  of the flaw-depth PDF would be obtained (according to  
 7 Eqn. (C-1)) from  $\pi_1(\Phi \mid \text{Data}, t_{tr}) \propto L(\text{Data} \mid \Phi, t_{tr})\pi_0(\Phi)$ , where  $\pi_1(\Phi \mid \text{Data})$  is the posterior  
 8 multivariate PDF of vector  $\Phi$ , and  $\pi_0(\Phi)$  is the prior multivariate PDF of  $\Phi$ .

9 Determination of the posterior  $\pi_1(\Phi \mid \text{Data})$  requires complex integrations. Further, integration  
 10 of the denominator of the Bayesian inference in Eqn. (C-1) also requires multi-dimensional  
 11 integration that in most cases can only be performed numerically.

12 It is also critically important to note that Eqn. (C-9) through Eqn. (C-20) are all in terms of the  
 13 actual flaw depth,  $a$ , measured in English or metric units. As stated before, it is also possible to  
 14 express the equations in terms of the normalized flaw depth,  $a/\Delta$ , instead. This is simply done  
 15 by replacing flaw depth,  $a$ , with  $a/\Delta$  in all PDFs, measurement error, and POD equations.  
 16 Clearly the parameters of the equations should be adjusted accordingly.

#### 17 **C.2.3.2 Updating the Flaw Density Model**

18 If flaws are detected with a probability given by Eqn. (C-11) and Eqn. (C-12) as  
 19  $\text{Pr}(D) = \text{POD}(\Phi, t_{tr})$  (or not detected with a probability of  $\text{Pr}(\bar{D}) = 1 - \text{Pr}(D)$ ), the probability that a  
 20 specific total number of flaws  $n^*$  observed in a given volume  $v$  out of the true number of flaws  $n_j$   
 21 follows the binomial distribution (see References [C-11] and [C-12]):

$$22 \quad L(n^* \mid n_j) = \binom{n_j}{n^*} [\text{Pr}(D)]^{n^*} [1 - \text{Pr}(D)]^{n_j - n^*} \\
 23 \quad \text{or} \\
 24 \quad L(n^* \mid n_j) = \binom{n_j}{n^*} [\text{POD}(\Phi, t_{tr})]^{n^*} [1 - \text{POD}(\Phi, t_{tr})]^{n_j - n^*}$$

Eqn. (C-19)

22 where  $\binom{n_j}{n^*} = \frac{n_j!}{n^!(n_j - n^*)!}$ . The best estimate of the true number of flaws would be to assume that

23  $n^*$  represents the mean of Eqn. (C-19). Accordingly, the mean estimate of the true number of  
 24 flaws,  $N$ , would be found from:

$$N = \frac{n^*}{\text{POD}(\Phi, t_{tr})}$$

Eqn. (C-20)

25 A more formal way to estimate the number (and thus density) of flaws would be to use the  
 26 Bayesian updating of  $n_j$ , which allows the estimation of the posterior distribution of  $n_j$  to describe  
 27 the true number of flaws:

$$\Pr(n_j | n^*) = \frac{L(n^* | n_j) \Pr(n_j)}{\sum_{n_j} L(n^* | n_j) \Pr(n_j)} \quad \text{Eqn. (C-21)}$$

1 Using Eqn. (C-19) (representing the likelihood of observing  $n^*$  flaws out of the unknown  $n_j$  flaws)  
 2 and a Poisson prior flaw density model, the posterior probability distribution of the number of  
 3 flaws would be obtained from:

$$\Pr(n_j | n^*) = \frac{\binom{n_j}{n^*} [\text{POD}(\Phi, t_{tr})]^{n^*} [1 - \text{POD}(\Phi, t_{tr})]^{n_j - n^*} \left[ \frac{e^{-\rho v} (\rho v)^{n_j}}{n_j!} \right]}{\sum_{n_j=n^*}^{\infty} \binom{n_j}{n^*} [\text{POD}(\Phi, t_{tr})]^{n^*} [1 - \text{POD}(\Phi, t_{tr})]^{n_j - n^*} \left[ \frac{e^{-\rho v} (\rho v)^{n_j}}{n_j!} \right]} \quad \text{Eqn. (C-22)}$$

4 where  $\rho$  is the volumetric flaw intensity and  $\rho v$  is the expected number of true flaws in the  
 5 inspected volume  $v$ . If the mean number of flaws from Eqn. (C-20) is large, the computer  
 6 rounding issues associated with Eqn. (C-22) may be avoided by performing the analysis for a  
 7 smaller volume (for example,  $1/100^{\text{th}}$  of the inspected volume) and later prorating  $n_j$  accordingly.  
 8 An alternative approach that is approximate, but simpler than Eqn. (C-19) through Eqn. (C-22),  
 9 would be to update the parameter  $\rho$  itself based on the mean number of flaws. For example, if  
 10 the volume of the UT inspection is  $v$ , the volumetric flaw intensity  $\rho$  of the flaws associated with  
 11 the mean estimated  $N$  true flaws from Eqn. (C-20) in this volume would be  $\rho = \frac{N}{v}$ . Assuming  
 12 that the mean occurrence intensity of flaws remains constant over the volume of inspection, the  
 13 Poisson distribution may be used to represent the likelihood of  $N$  flaws in volume  $v$ , given the  
 14 volumetric flaw intensity  $\rho$  as shown by Eqn. (C-23):

$$L(N | \rho) = e^{-(\rho v)} \frac{(\rho v)^N}{N!} \quad \text{Eqn. (C-23)}$$

15 where  $v$  is the inspection volume and  $\rho$  is the flaw intensity (flaws per unit volume) associated  
 16 with the mean estimated number of flaws  $N$ .

17 If prior information about the flaw intensity,  $\rho$ , were available, it would be desirable to update the  
 18 flaw intensity by using such prior information. For example, assume that the prior volumetric  
 19 flaw intensity is described by the PDF,  $\pi_0(\rho)$ . Then, the posterior PDF,  $\pi_1(\rho | N)$ , can be  
 20 estimated using the likelihood function in Eqn. (C-23) from:

$$\pi_1(\rho | N) \propto L(N | \rho) \pi_0(\rho)$$

$$\text{where } L(N | \rho) = \prod_j L(N | \rho_j) \quad \text{Eqn. (C-24)}$$

21 If the prior PDF of the flaw intensity is expressed by the gamma distribution with parameters  
 22  $\alpha_1$  and  $\alpha_2$ , as  $\gamma_0(\rho) = \text{gamma}(\rho | \alpha_1, \alpha_2) = \frac{\alpha_1^{\alpha_2} \rho^{\alpha_2 - 1}}{\Gamma(\alpha_2)} e^{-\alpha_1 \rho}$ , the posterior PDF is a conjugate  
 23 distribution described by  $\gamma_1(\rho) = \text{gamma}(\rho | v + \alpha_1, n_j + \alpha_2)$ . The alternative form of the gamma

1 distribution used by the MATLAB tool (to be used later in the following example) uses  
2 parameter  $\beta$  instead of parameter  $\alpha_1$ , so that  $\text{gamma}(\rho | \beta = \frac{1}{\alpha_1}, \alpha_2)$ .

### 3 **C.3 Application Example**

4 As part of a cooperative effort between the Electric Power Research Institute (EPRI) and the  
5 NRC to provide guidance on evaluation of PTS, NDE analyses were performed for a PWR RPV  
6 (Beaver Valley 2). In this section, the Beaver Valley 2 NDE data will be described first. Next,  
7 the VFLAW data described in NUREG/CR-6817 will be used as prior information, followed by  
8 the application of the Bayesian updating procedure discussed in Section C.2 to determine  
9 flaw-depth and flaw-density distributions specific to Beaver Valley 2. The resulting posterior  
10 distribution of the parameters of the flaw depth and flaw density, as described in Section C.2,  
11 will be derived and discussed. The results of flaw-depth and flaw-density PDFs will be used to  
12 compare against the 10 CFR 50.61a flaw tables, and to update the distribution models in  
13 VFLAW into new flaw distributions that are representative of the Beaver Valley 2 RPV.

#### 14 **C.3.1 Description of the NDE Data Used as Evidence to Build the Likelihood Function**

15 The EPRI report by Spanner [C-13] provides UT-based measured flaw data near the inner  
16 surface (~2.5 inches) of the Beaver Valley 2 RPV, including small flaw sizes. These data, while  
17 subject to POD and measurement error, provide a more vessel-specific perspective of the  
18 distribution of flaws for Beaver Valley 2 than does the VFLAW distributions used in FAVOR.

19 The observed Beaver Valley 2 NDE data (with detection and sizing uncertainty) are mostly in  
20 the form of interval-censored data as summarized below [C-13]:

- 21 1. 19 weld flaws were detected by the UT NDE of Beaver Valley 2 in the first inch (the  
22 inspection volume specified in Supplement 4 to Mandatory Appendix VIII to Section XI of  
23 the ASME Code) of the RPV (~0.616 ft<sup>3</sup>), all having a flaw depth less than 0.125".
- 24 2. 103 weld flaws were detected and reported by the UT NDE of Beaver Valley 2 in the  
25 first 3/8t (2.953") (the inspection volume specified in Supplement 6 to Mandatory  
26 Appendix VIII to Section XI of the ASME Code) of the RPV were reported, all with flaw  
27 depths less than 0.125", except for one flaw that measured 0.260".


28 The lower limit of the detected flaw intervals described above is not stated in [C-13], but is  
29 certainly not zero. Two possible subjective lower limits were assumed, and later the sensitivities  
30 of the final (posterior) flaw-distribution results to these two choices were assessed. The two  
31 lower limits are 0.04" and 0.075".

32 The NDE data described above provide an incomplete depiction of the true flaws in the Beaver  
33 Valley 2 RPV because they contain uncertainties associated with the UT technology used to  
34 detect and size flaws. The associated weld bead thicknesses are not reported. However, the  
35 weld region of the observed flaws and flaw length is reported. Such results should be corrected  
36 for detection and sizing capability, particularly for the small flaws.

37 The Beaver Valley 2 RPV weld map is shown in Figure C-3 [C-14]. In the absence of the  
38 Beaver Valley 2 average weld bead thickness as the point of transition between large and small  
39 depths, it is assumed that all flaws reported are Submerged Arc Welds (SAWs), which form over  
40 90% of welds in the VFLAW data, with the bead thickness of  $\Delta = t_{tr} = 0.26$ ". Using the Beaver

1 Valley 2 RPV information shown in Figure C-3, the following weld characteristics were  
 2 computed and used to specialize the VFLAW data to represent the prior distributions of flaw  
 3 depth and density for Beaver Valley 2 RPV:

- 4 Total Weld Length = 816.18"
- 5 Total Weld Volume<sup>2</sup> = 4.975 ft<sup>3</sup>
- 6 Total Weld Fusion Area = 92 ft<sup>2</sup>
- 7 Weld Volume of 1" = 0.616 ft<sup>3</sup>
- 8 Weld Volume of 3/8t = 1.865 ft<sup>3</sup>



9  
 10  
 11 Figure C-3. Beaver Valley 2 weld map [C-14]

12 **C.3.2 Description of Flaw-Depth and -Density Information Used in VFLAW as Prior PDFs**  
 13 **in This Example**


14 Smaller flaws neighboring the inner surface of the RPV that would be subjected to high thermal  
 15 stresses during PTS events are dominant contributors to the risk of vessel failure posed by PTS.  
 16 During the PTS re-evaluation effort in the late 1990s and early 2000s, the Marshall distribution  
 17 was updated using the results of destructive tests of the Pressure Vessel Research User Facility  
 18 (PVRUF) and Shoreham RPVs [C-2]. These analyses assumed that the flaws were near the  
 19 inner surface of the RPV and included very small flaws of less than 0.125 inches (3 mm) in  
 20 through-wall extent. The purpose of the re-evaluation was to provide an up-to-date estimate of  
 21 the distribution of weld flaw density and sizes using modern NDE methods of analysis. These  
 22 distributions represent the flaw-depth and flaw-density models in VFLAW [C-3].

<sup>2</sup> The total volume of reactor vessel weld area according to the weld dimensions shown in Figure C-3 =  
 $[1.375 \times 99.45 \times 2 \times (86.531 - 78.656)] + [2 \times 1.375 \times 61.68 \times (86.531 - 78.656)] + [1.25 \times 3.14 \times 2 \times$   
 $86.531 \times (86.5312 - 78.6562)] = 8,595.29 \text{ in}^3 = 4.974 \text{ ft}^3$ .

1 Because we need prior distributions in the Bayesian inference described earlier, the VFLAW  
 2 distributions may be specialized to Beaver Valley 2. This is done by using the corresponding  
 3 bead thickness and other vessel characteristics for Beaver Valley 2 to determine the prior  
 4 distributions of the flaw depth and flaw density from VFLAW distributions. The prior distributions  
 5 fill the gaps in the limited inspected data and uncertainties associated with the NDE results.

6 Analysis of flaws should consider different vessel regions and welding types. Welding types  
 7 include the Submerged Arc Weld (SAW), Shielded Metal Arc Weld (SMAW), and repair weld.  
 8 Depending on the known details of fabrication, NUREG/CR-6817 estimated flaw distributions for  
 9 each weld type used in a particular region of the vessel. Measured flaw data showed  
 10 vessel-to-vessel variability in both flaw density and depth. To supplement the limited data from  
 11 the PVRUF and Shoreham flaw measurements, NUREG/CR-6817 used expert elicitation.  
 12 Distribution functions to characterize the number and sizes of flaws in the various regions of the  
 13 RPVs were then developed based on the measured data and insights from an expert elicitation  
 14 exercise and used in VFLAW.

15 The prior distributions used in this example updated the PVRUF flaw models described in  
 16 NUREG/CR-6817 and used in VFLAW, including the hyper-distributions that address the  
 17 uncertainties associated with the parameters for the distribution functions describing flaw depth  
 18 and flaw density. For example, the exponential distribution was used to represent the variability  
 19 of large flaw depths. However, the parameter  $\lambda$  of the exponential distribution (i.e., assuming  
 20  $f(a) = \lambda e^{-\lambda a}$ , where  $a$  is the flaw depth) was in turn considered to be a random variable and  
 21 described by the gamma distribution. The gamma distribution itself has two parameters,  
 22  $\alpha_1$  and  $\alpha_2$ , that are given as constants in NUREG/CR-6817. These parameters were updated in  
 23 this example based on the observed data from Beaver Valley 2. The values of the  
 24 hyper-distributions used in VFLAW are shown in Table C-2. Note that the flaw-depth data in  
 25 Table C-2 are in meters, whereas this example calculation is based on inches. The relationship  
 26 between the flaw-depth and flaw-density PDFs and the corresponding hyper-PDFs of their  
 27 parameters are illustrated in Figure C-4.



28

29 Figure C-4. Flaw-depth and flaw-density distributions used in VFLAW and their corresponding  
 30 parameter hyper-PDFs.

1 Table C-2. Flaw-Depth (a) and Flaw-Density (b) Distributions and Hyper-PDF Parameters Used  
 2 in VFLAW for PVRUF

3 (a) Flaw-depth characteristics (in meters) based on data from PVRUF RPV

Case	Flaw Size Category	Welding Process	Random Variable Representing Flaw Depth	PDF of Flaw Depth	Parameters of PDF	Distribution Describing Uncertainty of Parameters of PDF	Parameters of Uncertainty Distribution
1	Small ( $a \leq \Delta$ )	SAW	$a/\Delta$	Multinomial	$P_1, P_2, P_3$	Dirichlet	$U_1 = 34$ $U_2 = 8$ $U_3 = 1$
2	Small ( $a \leq \Delta$ )	SMAW	$a/\Delta$	Multinomial	$P_1, P_2, P_3$	Dirichlet	$U_1 = 34$ $U_2 = 8$ $U_3 = 1$
3	Small ( $a \leq \Delta$ )	Repair Weld	$a/\Delta$	Multinomial	$P_1, P_2, P_3$	Dirichlet	$U_1 = 34$ $U_2 = 8$ $U_3 = 1$
4	Large ( $a > \Delta$ )	SAW	$a/\Delta$	Exponential	$\lambda$	Gamma	$\alpha_1 = 21.68$ $\alpha_2 = 52$
5	Large ( $a > \Delta$ )	SMAW	$a/\Delta$	Exponential	$\lambda$	Gamma	$\alpha_1 = 21.68$ $\alpha_2 = 52$
6	Large ( $a > \Delta$ )	Repair Weld	$a/\Delta$	Exponential	$\lambda$	Gamma	$\alpha_1 = 17.58$ $\alpha_2 = 13$

4

5 (b) Flaw-density characteristics based on data from PVRUF RPV

Case	Flaw Size Category	Welding Process	Random Variable Representing Flaw Depth	PDF of Flaw Depth	Parameters of PDF	Distribution Describing Uncertainty of Parameters of PDF	Parameters of Uncertainty Distribution
1	Small ( $a \leq \Delta$ )	SAW	Flaws per cubic meter	Poisson	$\lambda$	Gamma	$\alpha_3 = 0.180$ $\alpha_4 = 1419$
2	Small ( $a \leq \Delta$ )	SMAW	Flaws per cubic meter	Poisson	$\lambda$	Gamma	$\alpha_3 = 0.014$ $\alpha_4 = 197$
3	Small ( $a \leq \Delta$ )	Repair Weld	Flaws per cubic meter	Poisson	$\lambda$	Gamma	$\alpha_3 = 0.00123$ $\alpha_4 = 12$
4	Large ( $a > \Delta$ )	SAW	Flaws per cubic meter	Poisson	$\lambda$	Gamma	$\alpha_3 = 0.180$ $\alpha_4 = 4$
5	Large ( $a > \Delta$ )	SMAW	Flaws per cubic meter	Poisson	$\lambda$	Gamma	$\alpha_3 = 0.014$ $\alpha_4 = 4$
6	Large ( $a > \Delta$ )	Repair Weld	Flaws per cubic meter	Poisson	$\lambda$	Gamma	$\alpha_3 = 0.00123$ $\alpha_4 = 7$

6


7

1 **C.3.3 Detection and Sizing Error Models**

2 Analysis of UT-detected performance data reported by EPRI [C-6] was used to identify a POD  
 3 function for the purpose of this example. Currently, EPRI is updating these performance data  
 4 and will supply more appropriate POD models for future consideration; the POD and flaw-sizing  
 5 error functions used here are therefore intended only to illustrate this numerical method. The  
 6 threshold limit of this POD function (Eqn. (C-4)) was taken as 0.00 and the epistemic  
 7 uncertainties associated with the parameters of the model were not considered in this example.  
 8 Accordingly, the following mean POD function based on Eqn. (C-4) was used<sup>3</sup>:

$$\text{POD}(a) = 1 - \frac{1}{1 + e^{63.2100(a-0.1124)}} \quad \text{Eqn. (C-25)}$$

9 where  $a$  is the true, unbiased flaw size. Figure C-5 shows a plot of this POD function.




16  
 17 Figure C-5. POD vs. flaw depth.

18 The measurement error was assumed, based on some examples and measurement errors  
 19 reported in EPRI report [C-6]. The measurement error is a linear function that oversizes small  
 20 flaws and undersizes large flaws. Figure C-6 depicts a plot of the measurement-error model  
 21 used in this example. The model itself can be described as a line with a slope of -0.1905 and  
 22 an intercept of 0.0476, with the variability resulting from the model error described by a normal  
 23 distribution. That is,  $M_{\epsilon} = -0.1905a + 0.0476 + N(0, 0.0298)$ , where  $N(0, 0.0298)$  is a normal  
 24 distribution with a mean of zero and a constant standard deviation of 0.0298. Note that in this  
 25 example we are not accounting for the epistemic uncertainties of the measurement-error model.  
 26 However, such uncertainties should be considered when new measurement-error models are  
 27 developed. Equally, as described by Eqn. (C-10), it is possible to represent the above line by  
 28 the normal PDF:  $g'(M_{\epsilon}) = 13.41e^{-564.55(M_{\epsilon} + 0.1905a - 0.0476)^2}$ .

29  
 30

---

<sup>3</sup> The model error associated with the logistic distribution was not considered.



1

2 Figure C-6. Measurement error vs. flaw depth.


3

4 **C.3.4 Bayesian Updating of the Parameters of the Flaw-Depth Distributions**

5 In this section, the process of updating the prior data specialized to Beaver Valley 2 with the  
 6 observed NDE data using Bayesian inference will be discussed. Figure C-7 describes the main  
 7 elements of the updating process. The observed UT-based flaw data discussed in  
 8 Section C.3.1 is corrected for POD and measurement error. The POD and measurement error  
 9 models were discussed in Section C.3.3. In the remainder of this section, development of the  
 10 likelihood functions for the two sets of observed flaw data (one for the first one inch and another  
 11 for the 3/8t of the inner RPV welds) will be discussed first. Then the Bayesian inference that  
 12 combines the observed data with the prior data will be considered. The analysis will be  
 13 performed for each of the NDE observed data sets to determine different conclusions.

- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
1. The observed data for the first 3/8t of the RPV welds were used to update the prior models shown in Table C-2 in order to specialize them for the Beaver Valley 2 RPV. The updated values can be used for PTS calculations specific to the Beaver Valley 2 RPV using VFLAW and FAVOR.
  2. The observed data for the first inch of the vessel were used to estimate the true number of flaws in the flaw-depth ranges of the 10 CFR 50.61a tables. This information is used to assess how the estimated number of flaws of a given size in Beaver Valley 2 (estimated based on inspection data, VFLAW distributions, and Bayesian inference) compares to the number and size of flaws permitted by the 10 CFR 50.61a tables.





1  
2 Figure C-7. Bayesian updating elements of the Beaver Valley 2 example.

3  
4 **C.3.4.1 Bayesian Updating of the Parameters of Large-Flaw Depth Distribution Based**  
5 **on the 3/8t UT Inspection Data**

6 According to the prior data used by VFLAW as described in Section C.3.3, small-to-large  
7 flaw-size transition occurs at flaw depths exceeding the SAW weld bead thickness. According  
8 to Table C-2, large flaws will follow an exponential distribution, conditional on exceeding the  
9 transition flaw depth. Thus, the distribution of large-flaw depths corrected for the bias would be:

$$f(a | \lambda_1, a > t_{tr}) = \frac{f(a | \lambda_1)}{\Pr(a > t_{tr})} = \lambda_1 e^{-\lambda_1(a-t_{tr})} = \lambda_1 e^{-\lambda_1(a^* - M_\epsilon - t_{tr})} \quad \text{Eqn. (C-26)}$$

10 where  $\lambda_1$  is the large-flaw depth intensity (per inch) and  $a_{tr}$  is the transition flaw depth (assumed  
11 to be 0.26"). To build the likelihood function, the flaws should be represented in terms of the  
12 measured flaw depths. Because the NDE data reported only one exact flaw depth ( $n^* = 1$ ,  
13  $a_1^* = 0.26$ ) in the large-flaw region (exceeding the transition  $t_{tr}$ ) for Beaver Valley 2, the likelihood  
14 function based on Eqn. (C-16) would be:


$$L(a_{data}^* | \lambda_1) = \frac{1}{[\text{POD}(\lambda_1)]^1} \prod_{i=1}^1 \int_{-1}^1 \left[ 1 - \frac{1}{1 + e^{63.2100(a_i^* - M_\epsilon - 0.1124)}} \right] \left[ \lambda_1 e^{-\lambda_1(a_i^* - M_\epsilon - 0.26)} \right] \left( 13.41 e^{-564.55(M_\epsilon + 0.1905 a_i^* - 0.0476)^2} \right) dM_\epsilon \quad \text{Eqn. (C-27)}$$

15 where  $\text{POD}(\lambda_1) = \int_{0.26}^{\infty} \text{POD}(a) \lambda_1 e^{-\lambda_1(a-0.26)} da$  would be near 1 in this case because the  $\text{POD}(a)$  reaches unity  
16 when the flaw depth exceeds 0.2 inch in Eqn. (C-25). Note that, for simplicity, the random  
17 variable  $M_\epsilon$  is integrated over the range of -1 to 1 because these are the extreme ranges of the  
18 measurement error. The next step is finding the posterior distribution of  $\lambda_1$  based on Eqn. (C-1).  
19 That is:

$$\pi_1(\lambda_1 | \mathbf{a}_{\text{data}}^*) = \frac{L(\mathbf{a}_{\text{data}}^* | \lambda_1) \pi_0(\lambda_1)}{\int_{\lambda_1} L(\mathbf{a}_{\text{data}}^* | \lambda_1) \pi_0(\lambda_1) d\lambda_1} \quad \text{Eqn. (C-28)}$$

1 Using Eqn. (C-27) as the likelihood, the Bayesian updating with the gamma PDF as the prior  
 2 hyper-PDF for  $\lambda_1$ ,  $\pi_0(\lambda_1) = \text{gamma}(\lambda_1 | \alpha_1 = 1.2, \alpha_2 = 4)$  (or the alternative form  
 3  $\pi_0(\lambda_1) = \text{gamma}(\lambda_1 | \beta = 0.8333, \alpha_2 = 4)$ ), from the VFLAW (SAW) information specialized to  
 4 Beaver Valley 2 by using the bead thickness of 0.26" and converted to per unit inch (using the  
 5 SAW data listed in Table 6.6 of NUREG/CR-6817<sup>4</sup>), the posterior distribution of  $\lambda_1$  is calculated  
 6 and fitted into another gamma distribution. The posterior gamma PDF representing the Beaver  
 7 Valley 2 RPV would be  $\pi_1(\lambda_1) = \text{gamma}(\lambda_1 | \alpha_1 = 1.186, \alpha_2 = 5)$  and plotted and compared to the  
 8 prior PDF in Figure C-8 (see Appendix C-1). The gamma distributions used to describe  
 9 flaw-depth intensity and flaw density in Table C-2 are normalized based on the bead thickness.  
 10 As evident from Table C-2, VFLAW uses normalized flaw-depth distributions (i.e., based on  $a/\Delta$   
 11 instead of  $a$ ). Assuming a bead thickness of 0.26", the normalized gamma prior and posterior  
 12 PDFs for large-flaw-depth intensity for Beaver Valley 2 would be  
 13  $\pi_0(\lambda_1) = \text{gamma}(\lambda_1 | \alpha_1 = 4.615, \alpha_2 = 4)$  and  $\pi_1(\lambda_1) = \text{gamma}(\lambda_1 | \alpha_1 = 4.563, \alpha_2 = 5)$ . Note that  
 14 Figure C-8 is not the normalized version. The normalized posterior would be the new  
 15 hyper-distribution that reflects the measured data and can be used in the VFLAW and FAVOR  
 16 runs for Beaver Valley 2 RPV.

17 From Figure C-8, it is evident that the prior and posterior values are very similar, because only  
 18 one flaw depth data point is reported and used, so the posterior relies primarily on the prior  
 19 information. The impact will, however, affect the density PDF more strongly.



20  
 21 Figure C-8. Prior and posterior distributions of the flaw-depth intensity of parameter  $\lambda_1$ .

22 Appendix C-1 describes the MATLAB routine used to generate the posterior distribution and  
 23 solutions to Eqn. (C-26) through Eqn. (C-28).

<sup>4</sup> Note that to specialize VFLAW flaw-depth distributions for Beaver Valley 2, only PVRUF large-flaw depths reported for SAW in Table 6.6 of the NUREG/CR-6817 were used instead of the distributions summarized in Table 2 of this report.

1 **C.3.4.2 Bayesian Updating of the Parameters of Small Flaw Depth Distribution Based**  
 2 **on the 3/8t UT Inspection Data**

3 Flaw depths smaller than the bead thickness for PVRUF (from Table 6.4 in NUREG/CR-6817)  
 4 were analyzed and appeared to best fit an exponential PDF. That is:

$$f(a | \lambda_s) = \frac{\lambda_s e^{-\lambda_s a}}{1 - e^{-0.26\lambda_s}}, \lambda_s > 0, a > 0 \quad \text{Eqn. (C-29)}$$

5 where  $\lambda_s$  is the flaw depth (per inch) for small flaws. The hyper-distribution of  $\lambda_s$  was also  
 6 estimated as the gamma distribution  $\pi_0(\lambda_s) = \text{gamma}(\lambda_s | \alpha_1 = 2.854, \alpha_2 = 39)$  that was used as the  
 7 prior PDF for Beaver Valley 2.

8 The procedure from this point on is the same as that for the large flaws with the exception that  
 9 the NDE data for small flaws were given in the form of a single flaw depth interval, as discussed  
 10 in Section C.3.1. Accordingly, with  $m = 1$  and using Eqn. (C-17), the likelihood function for the  
 11 evidence consisting of 103 detected (observed) flaws, all with a depth of less than 0.125" but  
 12 larger than 0.04" (or 0.075" as sensitivity value), will be:

$$L(\text{Data} | \lambda_s) = \left[ \frac{1}{\text{POD}(\lambda_s)} \int_{0.075 \text{ or } 0.04}^{0.125} \int_{-1}^1 \left[ 1 - \frac{1}{1 + e^{63.2100(a - M_c - 0.1124)}} \right] \left( \frac{\lambda_s e^{-\lambda_s(a - M_c)}}{1 - e^{-0.26\lambda_s}} \right) \left( 13.41 e^{-564.55(M_c + 0.1905a - 0.0476)^2} \right) dM_c da \right]^{103}$$


Eqn. (C-30)

13 The Bayesian updating for small flaws is the same as Eqn. (C-28) and the likelihood given by  
 14 Eqn. (C-30) results in the posterior distributions of  $\lambda_s$  as shown in Figure C-9 (see  
 15 Appendix C-1). Also, a plot of the  $\text{POD}(\lambda_s)$  as expressed by equation:


$$\text{POD}(\lambda_s) = \int_0^{0.26} \left( 1 - \frac{1}{1 + e^{63.2100(a - 0.1124)}} \right) \left( \frac{\lambda_s e^{-\lambda_s a}}{1 - e^{-0.26\lambda_s a}} \right) da \quad \text{Eqn. (C-31)}$$

16 is shown in Figure C-10. Clearly, because small flaws are associated with small POD and  
 17 considerable measurement error, the impact of these would be significant in the posterior  
 18 results shown in Figure C-9. The posterior can be expressed as the gamma PDF  
 19  $\pi_1(\lambda_s) = \text{gamma}(\lambda_s | \alpha_1 = 1.614, \alpha_2 = 60)$ . The normalized versions of the prior and posterior  
 20 can be expressed by dividing  $\alpha_1$  by the bead thickness of 0.26". Note that Figure C-9 does not  
 21 show the normalized versions of the prior and posterior distributions.

22 The VFLAW data for small flaw depths uses the multinomial distribution, whose parameters are  
 23 described by the Dirichlet PDF. Accordingly, it is possible to find the equivalent Dirichlet PDFs  
 24 that best describe the posterior PDF of  $\lambda_s$  expressed in form of the gamma distribution.



1  
2 Figure C-9. Bayesian prior and posterior PDFs of  $\lambda_s$  (per unit inch).



3  
4 Figure C-10. Marginal POD independent of small flaw depth.

5 To update the Dirichlet hyper-distribution that represents uncertainties in the parameters of the  
6 multinomial distribution representing small-flaw-depth PDF used in VFLAW, the posterior PDF  
7 of  $\lambda_s$  shown in Figure C-9 is used to calculate the number of flaws in each of the ranges  
8 (0" to 0.072", 0.072" to 0.126", and 0.126" to 0.170") used by the multinomial distribution in  
9 VFLAW. Because the Dirichlet distribution is a conjugate distribution, the posterior number of  
10 flaws is found (see Section C.3.4.3.2 for estimating the number of posterior flaws) by adding the  
11 posterior mean number of flaws in each flaw-depth bin (see Table C-3). When added to the  
12 prior number of flaws (see Appendix A of NUREG/CR-6817 for the procedure), the updated  
13 Dirichlet values are viewed as being more representative of the distributions of true flaws in the  
14 Beaver Valley 2 RPV and are summarized in Table C-3.

15 Table C-3. Updated VFLAW Distribution for Small Flaws

Flaw-Depth Bins (in)	Normalized Flaw-Depth Bins (per NUREG/CR-6817) per Unit of Bead Thickness	Prior U (see Table C-2)	Prior Multinomial Parameter	Posterior U	Updated Mean of Multinomial Parameter
$a_1$ (0 to 0.072)	0.25 (0.0 to 0.4)	$U_1 = 34$	$P_1 = 0.7907$	$U'_1 = 479.75$	$P'_1 = 0.9639$
$a_2$ (0.072 to 0.126)	0.55 (0.4 to 0.7)	$U_2 = 8$	$P_2 = 0.1860$	$U'_2 = 9.71$	$P'_2 = 0.0332$
$a_3$ (0.126 to 0.17)	0.85 (0.7 to 0.1)	$U_3 = 1$	$P_3 = 0.0233$	$U'_3 = 5.354$	$P'_3 = 0.0029$

16

1 A critical observation from this example is that the posterior results of the flaw-depth distribution  
2 in general and small depth distribution in particular are most sensitive to the POD model and  
3 measurement error model and their associated uncertainties. The lower tail of the POD model,  
4 in the ranges of small flaw depths (<0.1"), expects small probabilities of detection. When a flaw  
5 of small depth is reported, because of the corresponding small POD, it increases the likelihood  
6 that there are several flaws not detected for the one detected. This will substantially affect the  
7 results.

8 Appendix C-1 describes the MATLAB routine used to solve the integrals in Eqn. (C-29) through  
9 Eqn. (C-31) to estimate the posterior PDF of small flaws.

10 **C.3.4.3 Results of Updating Parameters of Flaw Density Distribution Based on the 3/8t**  
11 **UT Inspection Data**

12 In Section C.2.3.2, two methods were presented to update the flaw densities. One was based  
13 on a binomial likelihood function (Eqn. (C-19)) and one used the Poisson density and took  
14 advantage of the conjugate properties of the prior gamma PDF used as the prior distribution of  
15 the intensity,  $\rho$ , of the Poisson distribution (Eqn. (C-23)). The later method is used to update the  
16 flaw densities for this example. This method is based on the mean values only and is simpler  
17 than the former.

18 **C.3.4.3.1 *Posterior Density of Large Flaws***


19 The number of large flaws (size > 0.26 inch), given the single UT-detected flaw, yields the  
20 posterior flaw depth intensity,  $\lambda_1$ , which was shown in Figure C-8. The marginal POD  
21 independent of the flaw size was almost 1 (for any value of posterior  $\lambda_1$ ). Accordingly, using  
22 Eqn. (C-20), the number of flaws based on the posterior estimates of flaw depth would be 1.

23 Using the conjugate features of the prior gamma distribution for  $\rho_1$ , the posterior distribution (see  
24 Appendix A of NUREG/CR-6817) will be:


$$\begin{aligned} \pi_1(\rho_1 | n_1) &= \text{gamma}(\rho_1 | \alpha_1 = 6.6467 + V, \alpha_2 = 4 + n_1) = \\ &\text{gamma}(\rho_1 | \alpha_1 = 8.5119, \alpha_2 = 5) \text{ flaws/ ft}^3 \end{aligned} \qquad \text{Eqn. (C-32)}$$

25 Figure C-11 compares prior and posterior distributions of the number of flaws and flaw intensity  
26 of large flaws for Beaver Valley 2 in a volume of 1.8652 ft<sup>3</sup>. Note that VFLAW values are in  
27 cubic meter. The equivalent prior and posterior distributions in cubic meter are summarized in  
28 Table C-4.

1  
2  
3



(a)



(b)

4  
5  
6

7 Figure C-11. Prior and posterior flaw density (a) and intensity (b) for large size flaw

8 **C.3.4.3.2 Posterior Density of Small Flaws**

9 Similar to the large flaw density, the prior gamma distribution representing the flaw density per  
 10 unit volume,  $\rho_s$ , used in the VFLAW was updated based on the 103 UT-detected small flaws in  
 11 the interval of 0.04" to 0.125". This would yield the posterior flaw depth intensity,  $\lambda_s$ , as was  
 12 shown in Figure C-9. The mean value of the flaw depth intensity (i.e.,  $\lambda_s = 37.16$ ) estimated by  
 13 the posterior shown in Figure C-9 yields a marginal probability of detection independent of flaw  
 14 depth of,  $POD(\lambda_s) = 0.0274$ .

15 The likelihood of observing  $n_s$  small flaws would be expressed as:


$$\begin{aligned}
 \pi_1(\rho_s | n_s) &= \text{gamma}(\rho_s | \alpha_{1,s}^{\text{POS}} = 6.6467 + V, \alpha_{2,s}^{\text{POS}} = 1419 + n_s) \\
 &= \text{gamma}(\rho_s | \alpha_{1,s}^{\text{POS}} = 8.5119, \alpha_{2,s}^{\text{POS}} = 1909) \\
 \pi_0(\rho_s) &= \text{gamma}(\rho_s | \alpha_{1,s} = 6.6467, \alpha_{2,s} = 1419) \text{flaws} / \text{ft}^3
 \end{aligned}$$

Eqn. (C-33)


(Table 6.2 SAW – PVRUF NUREG/CR - 6817)

16 Figure C-12 compares prior and posterior distributions of the number of flaws and volumetric  
 17 flaw intensity of small flaws.

1  
2  
3



(a)



(b)

4  
5  
6  
7

Figure C-12. Prior and posterior flaw density (a) and intensity (b) for small size flaws

8 Because the posterior flaw density distributions shown in Figure C-11 and Figure C-12 are  
 9 based on the mean values of  $\lambda$  for both large and small flaws, a Monte Carlo simulation was  
 10 used to select random realizations of  $\lambda$  from the posterior PDFs of  $\lambda$  for large and small flaws to  
 11 develop the corresponding posterior flaw density PDFs. Figure C-13 shows the results of the  
 12 spread of the number of the flaws of various depths for the Beaver Valley 2 RPV, including the  
 13 epistemic uncertainties shown in the form of box plots.

14 Similar to the flaw-depth distribution, the posterior distribution of flaw density will be dominated  
 15 by the POD and measurement error models and their uncertainties. Specifically, when a large  
 16 number of small flaws are reported during the NDE inspection, the corresponding low POD  
 17 value increases the number of expected undetected flaws.

18 Based on the results of this section, Table C-4 summarizes the posterior results to be used for  
 19 Beaver Valley 2 VFLAW and FAVOR runs. The posterior results have been changed to metric  
 20 units in this table, because VFLAW uses metric values.

21

1 Table C-4. Summary of the Posterior Parameter PDFs of Flaw Depth and Flaw Density to be used in VFLAW and FAVOR Runs for  
 2 Beaver Valley 2

Case	Flaw Size Category	Welding Process	Random Variable Representing Flaw Depth	PDF of Flaw Depth	Parameters of PDF	Distribution Describing Uncertainty of Parameters of PDF	Original VFLAW Parameters of Uncertainty Distribution (Flaw Depth parameters are specialized to Beaver Valley 2)	Posterior Parameters of Uncertainty Distribution Based on Beaver Valley 2 Specialized Prior and NDE Data
1	Small ( $a \leq \Delta$ )	SAW	Flaws per cubic meter	Poisson	$\rho$	Gamma	$\alpha_3 = 0.180$ $\alpha_4 = 1419$	$\alpha'_3 = 0.230$ $\alpha'_4 = 1909$
2	Large ( $a > \Delta$ )	SAW	Flaws per cubic meter	Poisson	$\rho$	Gamma	$\alpha_3 = 0.180$ $\alpha_4 = 4$	$\alpha'_3 = 0.230$ $\alpha'_4 = 5$
3	Small ( $a \leq \Delta$ )	SAW	$a/\Delta$	Multinomial	$P_1, P_2, P_3$	Dirichlet	$U_1 = 34$ $U_2 = 8$ $U_3 = 1$	$U'_1 = 513.75$ $U'_2 = 17.71$ $U'_3 = 1.54$
4	Large ( $a > \Delta$ )	SAW	$a/\Delta$	Exponential	$\lambda$	Gamma	$\alpha_1 = 4.615^{§§}$ $\alpha_2 = 4$	$\alpha'_1 = 4.563$ $\alpha'_2 = 5$


3

4

§§ VFLAW combined all SAW and SMAW flaw data to arrive at the gamma distribution with  $\alpha_1 = 21.68$   $\alpha_2 = 52$ . As described in Section C.3.4.1, this example used only PVRUF SAW data for large flaw depths to build the specialized Beaver Valley prior PDF.



1



2

3 Figure C-13. Posterior number of flaws in the 3/8t region in various flaw size intervals including  
 4 epistemic uncertainties

5 **C.3.4.3.3 Sensitivity of the Flaw Density Results to a Lower Bound of 0.075" for the**  
 6 **Interval Data Observed in the 3/8t Region**

7 Estimations of the posterior PDFs presented in Sections C.3.4.3.1 and C.3.4.3.2 have been  
 8 made by assuming that the observed interval of small flaws was 0.075" to 0.125". To assess  
 9 the sensitivity of this assumption, it is assumed that the detection up to 0.075" is possible and all  
 10 data would be between 0.075" and 0.125". Repeating the calculations in Section C.3.4  
 11 (including subsections) yields the posterior flaw depth and density PDFs that are very similar.  
 12 Therefore, it was concluded that the results are relatively insensitive to choice for the lower  
 13 bound of the data. More discussions of this topic are presented in Section C.3.5.

14 **C.3.5 Updating the 10 CFR 50.61a Tables**

15 The NDE data from the inspection volume specified in Supplement 4 to Mandatory  
 16 Appendix VIII to Section XI of the ASME Code (the first one-inch of the weld) is used as the  
 17 evidence for the Bayesian updating procedure described in the previous sections to obtain the  
 18 flaw depth and density characteristics for Beaver Valley 2. The posterior characteristics are  
 19 used to develop the corresponding 10 CFR50.61a flaw tables (consisting of only 19  
 20 UT-detected flaws in the interval 0.04" to 0.125"). The procedure is the same as the one used  
 21 to update the UT data observed in the 3/8t region as discussed in Section C.3.4.

22 If the posterior distributions of the flaw density are used to estimate the mean number of flaws in  
 23 the ranges of flaw sizes described in the 10 CFR 50.61a flaw tables, the results should be  
 24 prorated to the number of flaws per 1,000" of weld. Because Beaver Valley 2 has a total weld  
 25 length of 816.18", the prorated mean number of flaws was calculated and compared with the  
 26 allowable number of flaws per length of weld, as shown in Table C-5. If the lower limit of the  
 27 observed data interval is changed from 0.04" to 0.075" to line up with the smallest bin size in the  
 28 10 CFR 50.61a flaw tables, the results summarized in Table C-5 are calculated. In this case,

1 the results of the mean number of flaws were also not too sensitive to the choice of the lower  
2 limit of the interval of NDE data.

3 To assess the epistemic uncertainties in the POD and measurement error uncertainties, again  
4 for the case of the Supplement 4 inspection volume (the first one inch), a Monte Carlo  
5 simulation was used to select random realizations of  $\lambda$  from the posterior PDFs of  $\lambda$  for both  
6 large and small flaws to develop the corresponding posterior flaw density PDFs. Repeating this  
7 process will result in the epistemic uncertainty for each flaw depth interval used in Table C-4.  
8 Figure C-14 shows the results of the number of the flaws of various depth intervals, by  
9 employing box and whisker plots. Epistemic uncertainties are larger (than those shown in  
10 Figure C-13), because of the smaller evidence, because there were only 19 observed flaws in  
11 the Supplement 4 inspection volume.

12

13

1 Table C-5. Alternate PTS Rule Flaw Table Assessment using Mean Number-of-Flaws by Size  
 2 Interval for Beaver Valley 2 (Assuming a Lower Limit of 0.04" for Observed Data  
 3 Interval)


Flaw Depth (inch)	Observed (Detected) Number of Flaws (Biased)	Posterior Mean Number of Flaws (Unbiased and Corrected for POD)	Rule's Limits per 1,000" of Weld
0.000 < a ≤ 0.075	19	124.98	No limit
0.075 < a ≤ 0.475		38.21	166.70
0.125 < a ≤ 0.475	0	14.13	90.80
0.175 < a ≤ 0.475	0	4.86	22.82
0.225 < a ≤ 0.475	0	1.30	8.66
0.275 < a ≤ 0.475	0	0.21	4.01
0.325 < a ≤ 0.475	0	0.13	3.01
0.375 < a ≤ 0.475	0	0.09	1.49
0.425 < a ≤ 0.475	0	0.04	1.00

4

5 Table C-6. Alternate PTS Rule Flaw Table Assessment using Mean Number-of-Flaws by Size  
 6 Interval for Beaver Valley 2 (Assuming a Lower Limit of 0.075" for Observed Data  
 7 Interval)

Flaw Depth (inch)	Observed (Detected) Number of Flaws (Biased)	Posterior Mean Number of Flaws (Unbiased and Corrected for POD)	Rule's Limits per 1,000" of Weld
0.000 < a ≤ 0.075	0	122.89	No limit
0.075 < a ≤ 0.475	19	39.05	166.70
0.125 < a ≤ 0.475	0	14.69	90.80
0.175 < a ≤ 0.475	0	5.12	22.82
0.225 < a ≤ 0.475	0	1.38	8.66
0.275 < a ≤ 0.475	0	0.21	4.01
0.325 < a ≤ 0.475	0	0.13	3.01
0.375 < a ≤ 0.475	0	0.08	1.49
0.425 < a ≤ 0.475	0	0.04	1.00

8



1

2

Figure C-14. Posterior number of flaws in the Supplement 4 inspection volume in various flaw size intervals including epistemic uncertainties

3

4

## 1 C.4 References

- 2 [C-1] *U.S. Code of Federal Regulations*, Title 10, “Energy,” Chapter I, Section 50.61a,  
3 “Alternate Fracture Toughness Requirements for Protection Against Pressurized  
4 Thermal Shock Events” (10 CFR 50.61a).
- 5 [C-2] Williams, P.T., T.L. Dickson, and S. Yin, “Fracture Analysis of Vessels - Oak Ridge  
6 FAVOR, v09.1, Computer Code: Theory and Implementation of Algorithms, Methods,  
7 and Correlations,” ORNL/TM-2010/5, January 2010, Oak Ridge National Laboratory,  
8 Oak Ridge, TN.
- 9 [C-3] U.S. Nuclear Regulatory Commission, “A Generalized Procedure for Generating  
10 Flaw-Related Inputs for the FAVOR Code,” NUREG/CR-6817, March 2004, Agencywide  
11 Documents Access and Management System (ADAMS) Accession No. ML040830499.
- 12 [C-4] Gelman, A., et al., *Bayesian Data Analysis*, 2<sup>nd</sup> Ed., Chapman & Hall/CRC, Boca  
13 Raton, FL, July 2003.
- 14 [C-5] Hamada, M.S., et al., *Bayesian Reliability*, Springer Science+Business Media, LLC, New  
15 York, NY, July 2008.
- 16 [C-6] Becker, F.L., “Reactor Pressure Vessel Inspection Reliability Based on Performance  
17 Demonstrations,” EPRI Report 1007984, June 2004, Electric Power Research Institute,  
18 Palo Alto, CA.
- 19 [C-7] Georgiou, G.A., “Probability of Detection (PoD) Curves: Derivation, Applications and  
20 Limitations,” Research Report 454, UK Health & Safety Executive, London, UK, 2006.
- 21 [C-8] Li, M., and W. Q. Meeker, “A Noise Interference Model for Estimating Probability of  
22 Detection for Nondestructive Evaluations,” *Proceedings of the Review of Progress in  
23 Quantitative Nondestructive Evaluation, July 20–25, 2008, Chicago, IL*, American  
24 Institute of Physics, College Park, MD, 2009.
- 25 [C-9] U.S. Department of Defense, “Nondestructive Evaluation System Reliability  
26 Assessment,” MIL-HDBK-1823, April 30, 1999.
- 27 [C-10] Chatterjee, K., and M. Modarres, “A Bayesian Probabilistic Approach to Improved Health  
28 Management of Steam Generator Tubes,” published online by the Prognostics and  
29 Health Management Society, 2011, available at  
30 [https://www.phmsociety.org/sites/phmsociety.org/files/phm\\_submission/2011/phmc\\_11\\_012.pdf](https://www.phmsociety.org/sites/phmsociety.org/files/phm_submission/2011/phmc_11_012.pdf)  
31 (accessed July 21, 2014).
- 32 [C-11] Celeux, G., et al., “Using Markov Chain Monte Carlo Methods to Solve Full Bayesian  
33 Modeling of PWR Vessel Flaw Distributions,” *Reliability Engineering and System Safety*,  
34 66(3):243–252, December 1999.
- 35 [C-12] Chatterjee, K., and M. Modarres, “A Probabilistic Approach for Estimating Defect Size  
36 and Density Considering Detection Uncertainties and Measurement Errors,” *Journal of  
37 Risk and Reliability*, 227(1):28–40, February 2013.
- 38 [C-13] Spanner, J., “Materials Reliability Program: Reanalysis of Reactor Vessel Examination  
39 Data from the 1996 Beaver Valley 2 Vessel Examination (MRP-207), RPV Flaw  
40 Distribution,” EPRI Report 1014548, November 2006, Electric Power Research Institute,  
41 Palo Alto, CA.

- 1 [C-14] U.S. Nuclear Regulatory Commission, "Probabilistic Fracture Mechanics - Models,
- 2 Parameters, and Uncertainty Treatment Used in FAVOR Version 04.1," NUREG-1807,
- 3 June 2007, ADAMS Accession No. ML072010411.
- 4

## Appendix C-1: Sample MATLAB Routine

```
1
2
3 clear
4 %%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%
5 %%This MATLAB routine estimates posterior values of parameters of flaw-
6 %%depth distributions for small and large flaws in RPVs using NDE data,
7 %%accounting for measurement error, POD, and epistemic uncertainties. The
8 %%routine solves Equations 16, 17 and 18. The specific data used in this
9 %%routine are related to the POD of Eqn. 25 and the measurement error
10 %%discussed in Section C.3.3 The NDE data of Beaver Valley 2 are used. It
11 %%also shows the solution to the likelihood functions of Eqn. 27 and Eqn. 30.
12 %%Finally the routine solves the Bayesian inferences in Eqn. 28 for both
13 %%small and large flaws.
14 %%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%
15 % THIS ROUTINE IS FOR DEMONSTRATION OF ONE WAY TO SOLVE THE BAYESIAN
16 % INFERENCE METHODS DISCUSSED IN THIS REPORT. THE RESULTS MAY BE USED TO
17 % CROSS-CHECK THE RESULTS IF OTHER VALUES OR OTHER SOLUTION ROUTINES ARE
18 % USED. THE ROUTINE DOES NOT COVER ALL E ANALYSES PERFORMED AND DISCUSSED
19 % IN THIS REPORT. FOR EXAMPLE, THE ROUTINE TO ESTIMATE THE FLAW-DENSITY
20 % DISTRIBUTIONS HAS NOT BEEN PRESENTED (ONLY FLAW-DEPTH MODEL
21 % DISTRIBUTIONS HAVE BEEN PRESENTED).
22 %%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%
23 %%LIMITATIONS
24 % 1. THIS ROUTINE ASSUMES THE SINGLE PARAMETER EXPONENTIAL DISTRIBUTION
25 % FOR MODELING DISTRIBUTION OF BOTH SMALL AND LARGE FLAW DEPTHS.
26 % 2. THE POSTERIOR FOR SMALL FLAWS WILL GO TO INFINITY IF THE RIGHT EXTREME
27 % OF THE LEFT-CENSORED NDE DATA OR LEFT EXTREME OF INTERVAL DATA FOR
28 % SMALL FLAWS IS EXTREMELY SMALL (THAT IS, LESS THAN 0.09 INCH).
29 % 3. THE POSTERIOR FOR SMALL FLAWS APPROACHES INFINITY FOR LARGE SIGMA;
30 % THAT IS, THE RANDOM ERROR FOR THE MEASUREMENT ERROR MODEL (WHEN SIGMA
31 % EXCEEDS 0.035").
32 %%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%
33 %%ASSUMPTIONS
34 % 1. THIS ROUTINE ASSUMES LEFT-TRUNCATED SINGLE-PARAMETER EXPONENTIAL
35 % DISTRIBUTION FOR FLAW DEPTH FOR SMALL FLAWS.
36 % 2. THIS ROUTINE ASSUMES RIGHT-TRUNCATED SINGLE-PARAMETER EXPONENTIAL
37 % DISTRIBUTION FOR LARGE FLAWS.
38 % 3. THIS ROUTINE ASSUMES TWO-PARAMETER LOGISTIC DISTRIBUTION EQN. 4 WITH
39 % A POD THRESHOLD OF ZERO.
40 % 4. SIMILARLY TO EQN. 30, INTEGRAL RANGE FOR THE MEASUREMENT IS BETWEEN
41 % -1 AND 1, WHICH COVERS THE EXTREME RANGES OF THE BIAS AND RANDOM ERRORS.
42 %%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%
43 %%NOMENCLATURE:
44 %m & c are parameters discussed in Eqn. 8; sigma is standard deviation of
45 %random error associated with the measurement error model of Eqn. 8.
46 %beta1 & beta2 are POD function parameters in Eqn. 4; ath is the detection
47 %threshold of Eqn. 4.
48 %atr is the transition flaw depth between small and large flaws discussed
49 %in Eqn. 9.
50 %lambda1 & lambda2 are flaw-depth distribution parameters (i.e., the flaw-
51 %depth intensity) for small and large defects respectively.
52 %n1 is the total number of censored NDE data for small flaws.
53 %are is the right extreme of left-censored or interval of small-flaw-
54 %depth NDE data.
55 %ale is the left extreme of interval of small-flaw-depth data; ale must
56 % be greater than the parameter c of the measurement error model.
57 %a1 is a set, representing values of exact small-flaw-depth NDE data
58 %reported.
59 %n2 is the number of exact small-flaw-depth NDE data reported
60 %n3 is the total number of exact large-flaw-depth NDE data reported
61 %n4 is the total number of interval or left-censored large-flaw-depth NDE
62 %data reported
```

```

1 %a2 is set, representing exact values of large-flaw-depth NDE data
2 %reported
3 %are_large is the right extreme of the left-censored or interval large-
4 %flaw-depth NDE data reported
5 %ale_large is the left extreme of interval data of large-flaw-depth NDE
6 %data reported
7 %*****
8 %%Measurement error parameters
9 m=0.84;c=0.04;sigma=0.0298;
10 %*****
11 %%POD parameters
12 ath=0;beta1=63.21;beta2=0.1124;
13 %*****
14 %%Transition point for large flaws
15 atr=0.26;
16 %*****
17 %*****
18 %%NDE data of small flaws
19 n1=103;are=0.125;ale=c;a1=[0.15];n2=0;
20 %*****
21 %*****
22 %%NDE data of large flaws
23 a2=[0.26];n3=length(a2);n4=0;ale_large=0.27;are_large=0.3;
24 %*****
25 %BAYESIAN INFERENCE FOR ESTIMATING POSTERIOR DISTRIBUTION OF THE PARAMETER
26 %LAMBDA (FLAW-DEPTH INTENSITY) OF THE SMALL-FLAW-DEPTH EXPONENTIAL PDF
27 lambda1=linspace(0,60,100);
28 Norm_const=0;
29 for i=2:length(lambda1)
30 Marginal_Pod=@(a)((1-(1+exp(-beta1*beta2))./(1+exp(beta1*(a-beta2-ath))))).*(la
31 mbdal(i).^exp(-lambda1(i).*a)./(1-exp(-lambda1(i).*atr)));
32 Likeli_int=@(Ea,a)((1-(1+exp(-beta1*beta2))./(1+exp(beta1*(a-Ea-beta2-ath))))).
33 *(lambda1(i).^exp(-lambda1(i).(a-Ea))./(1-exp(-lambda1(i).*atr))).*((1/sqrt
34 (2*pi*sigma^2)).*exp(-(1/(2*sigma^2)).*(m*Ea+(1-m)*a-c)/m).^2));
35 Likeli_exact=@(Ea)((1-(1+exp(-beta1*beta2))./(1+exp(beta1*(a1-Ea-beta2-ath))))
36 *(lambda1(i).^exp(-lambda1(i).(a1-Ea))./(1-exp(-lambda1(i).*atr))).*((1/sqrt
37 (2*pi*sigma^2)).*exp(-(1/(2*sigma^2)).*(m*Ea+(1-m)*a1-c)/m).^2));
38 Likelihood_exact(i)=((quad(Likeli_exact,-1,1))./(quad(Marginal_Pod,0,atr)))^n2
39 ;
40 Likelihood_int(i)=((dblquad(Likeli_int,-1,1,ale,are))./(quad(Marginal_Pod,0,at
41 r)))^n1;
42 Prior_small(i)=(gampdf(lambda1(i),39,.3504));
43 Numerator(i)=Likelihood_int(i).*Likelihood_exact(i).*Prior_small(i);
44 Norm_const=Norm_const+Numerator(i)*(lambda1(i)-lambda1(i-1));
45 end
46 Posterior_small=Numerator/Norm_const;
47 Mean_Posterior_Small_Flaw_Depth_Intensity=sum(lambda1.*Posterior_small)*0.6061
48 Mean_Posterior_Small_Flaw_Depth=1/Mean_Posterior_Small_Flaw_Depth_Intensity
49 POD_of_Posterior_Mean_Small_Flaw_Depth=1-(1+exp(-beta1*beta2))./(1+exp(beta1*(
50 Mean_Posterior_Small_Flaw_Depth-beta2-ath)))
51 subplot(211)
52 plot(lambda1,Posterior_small,lambda1,Prior_small,'-.','LineWidth',2)
53 xlabel('Flaw Depth intensity (per unit
54 inch)','fontsize',12,'fontweight','b','FontName','Times New Roman')
55 ylabel('Relative Frequency','fontsize',12,'fontweight','b','FontName','Times
56 New Roman')
57 title('Posterior and prior flaw depth intensity for small
58 flaws','fontsize',14,'fontweight','b','FontName','Times New Roman')
59 h = legend('Posterior_small','Prior_small');
60 set(h,'Interpreter','none')
61 set(gca,'FontSize',12,'FontWeight','b','FontName','Times New Roman')
62 %*****
63 %BAYESIAN INFERENCE FOR ESTIMATING POSTERIOR DISTRIBUTION OF THE PARAMETER
64 %LAMBDA (FLAW-DEPTH INTENSITY) OF THE LARGE-FLAW-DEPTH EXPONENTIAL PDF

```



```



1  lambda2=linspace(0,10,100);
2  Norm_const1=0;
3  for i=2:length(lambda2)
4  Marginal_Pod1=@(a)((1-(1+exp(-beta1*beta2))./(1+exp(beta1*(a-beta2-ath))))).*(l
5  ambda2(i).*exp(-lambda2(i).*(a-atr)));
6  Likeli_exact1=@(Ea)((1-(1+exp(-beta1*beta2))./(1+exp(beta1*(a2-Ea-beta2-ath))))
7  ).*(lambda2(i).*exp(-lambda2(i).*(a2-Ea-atr))).*((1/sqrt(2*pi*sigma^2)).*exp(-
8  (1/
9  (2*sigma^2)).*((m*Ea+(1-m)*a2-c)/m).^2));
10 Likelihood_exact1(i)=(quad(Likeli_exact1,-1,1))./(quad(Marginal_Pod1,atr,10)
11 )^n3;
12 Likeli_int1=@(Ea,a)((1-(1+exp(-beta1*beta2))./(1+exp(beta1*(a-Ea-beta2-ath))))
13 ).*(lambda2(i).*exp(-lambda2(i).*(a-Ea-atr))).*((1/sqrt(2*pi*sigma^2)).*exp(-
14 (1/
15 (2*sigma^2)).*((m*Ea+(1-m)*a-c)/m).^2));
16 Likelihood_int1(i)=(dblquad(Likeli_int1,-1,1,ale_large,are_large))./(quad(Mar
17 ginal_Pod1,atr,10))^n4;
18 Prior_large(i)=(gampdf(lambda2(i),4,0.8333));
19 Numerator1(i)=Likelihood_exact1(i).*Likelihood_int1(i).*Prior_large(i);
20 Norm_const1=Norm_const1+Numerator1(i).*(lambda2(i)-lambda2(i-1));
21 end
22 Posterior_large=Numerator1/Norm_const1;
23 Posterior_small=Numerator/Norm_const;
24 Mean_Posterior_Large_Flow_Depth_Intensity=sum(lambda2.*Posterior_large)*0.1010
25 Mean_Posterior_Large_Flow_Depth=1/Mean_Posterior_Large_Flow_Depth_Intensity
26 POD_of_Posterior_Mean_Large_Flow_Depth=1-(1+exp(-beta1*beta2))./(1+exp(beta1*(
27 Mean_Posterior_Large_Flow_Depth-beta2-ath)))
28 subplot(212)
29 f1=plot(lambda2,Posterior_large,lambda2,Prior_large,'-.','LineWidth',2)
30 xlabel('Flaw depth intensity (per unit
31 inch)','fontsize',12,'fontweight','b','FontName','Times New Roman')
32 ylabel('Relative Frequency','fontsize',12,'fontweight','b','FontName','Times
33 New Roman')
34 title('Posterior and prior flaw depth intensity for large
35 flaws','fontsize',14,'fontweight','b','FontName','Times New Roman')
36 h = legend('Posterior_large','Prior_large');
37 set(h,'Interpreter','none')
38 set(gca,'FontSize',12,'FontWeight','b','FontName','Times New Roman')
39 screen_size = get(0, 'ScreenSize');
40 f1 = figure(1);
41 set(f1, 'Position', [0 0 screen_size(3) screen_size(4) ] );
42 %%*****
43
44

```

1 **Output from the above routine is displayed in Figure C-14**  
2 **(also shown in Figure C-8 and Figure C-9)**

3  
4 Mean\_Posterior\_Small\_Flaw\_Depth\_Intensity =  
5 37.8118  
6 Mean\_Posterior\_Small\_Flaw\_Depth =  
7 0.0264  
8 POD\_of\_Posterior\_Mean\_Small\_Flaw\_Depth =  
9 0.0035  
10 Mean\_Posterior\_Large\_Flaw\_Depth\_Intensity =  
11 5.4042  
12 Mean\_Posterior\_Large\_Flaw\_Depth =  
13 0.1850  
14 POD\_of\_Posterior\_Mean\_Large\_Flaw\_Depth =  
15 0.9900  
16 f1 =  
17 230.0087  
18 231.0082  
19 Published with MATLAB® 7.12

1



C-43

2  
3  
4

Figure C-15. MATLAB Routine Output



1

2 **APPENDIX D: SENSITIVITY-STUDY RESULTS ON FLAW**  
3 **DISTRIBUTIONS CONSIDERING VFLAW DATA, POD, AND**  
4 **MEASUREMENT ERRORS IN NDE DATA**

---

5

6 Prepared for the U.S. Nuclear Regulatory Commission under the Subcontract 4000111626  
7 with UT-Battelle, LLC (Oak Ridge National Laboratory)

8

9

10

11

12

13

14 **Mohammad Modarres**

15 University of Maryland

16

17 March 2012

18

**Table of Contents**

1

2

3 *Table of Contents*.....D-2

4 *List of Tables*.....D-3

5 *List of Figures*.....D-3

6 *Abbreviations* .....D-4

7 *Symbols* .....D-4

8 D.1 INTRODUCTION.....D-5

9 D.2 OVERVIEW OF THE BAYESIAN APPROACH TO UPDATE FLAW DEPTH AND FLAW

10 DENSITY DISTRIBUTIONS .....D-5

11 D.3 APPLICATION TO A BASE CASE EXAMPLE.....D-6

12 D.4 APPLICATION TO SENSITIVITY CASES .....D-11

13 D.5 DISCUSSION AND SUMMARY .....D-18

14 D.6 REFERENCES.....D-19

15

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30

**List of Tables**

Table D-1. Alternate PTS Rule Compliance Using Mean Number-of-Flaws by Size Interval for Beaver Valley-2 (assuming a Lower Limit of 0.04” vs. 0.075” for Observed Data Interval).....D-10

Table D-2. Results of Sensitivity Case 1 .....D-12

Table D-3. Results of Sensitivity Case 2 .....D-12

Table D-4. Results of Sensitivity Case 3 .....D-13

Table D-5. Results of Sensitivity Case 4 .....D-13

Table D-6. Results of Sensitivity Case 5 .....D-14

Table D-7. Results of Sensitivity Case 6 .....D-14

Table D-8. Results of Sensitivity Case 7 .....D-15

Table D-9. Results of Sensitivity Case 8 .....D-15

Table D-10. Results of Sensitivity Case 9 .....D-16

Table D-11. Results of Sensitivity Case 10 .....D-16

Table D-12. Results of Sensitivity Case 11 .....D-17

Table D-13. Results of Sensitivity Case 12 .....D-17

**List of Figures**

Figure D-1. Beaver Valley-2 Weld Map [D-9] .....D-8

Figure D-2. Flaw Depth and Flaw Density Distributions Used in VFLAW and Their Corresponding Parameter Hyper-PDFs.....D-9

1

## Abbreviations

Abbreviation	Definition
PDF	Probability Density Function
NDE	Nondestructive Evaluation
POD	Probability of Detection
RPV	Reactor Pressure Vessel
SAW	Submerged Arc Weld
UT	Ultrasonic Test

2

3

## Symbols and Expressions

Symbol	Definition
$a$	True flaw depth (inches)
$a^*$	NDE measured (or observed) flaw depth (inches)
$a_{th}$	Threshold flaw depth for detection, below which flaw detection is beyond the capability of the NDE technology used
$D$	The event that a flaw is detected
$\bar{D}$	The event that a flaw is not detected
$E_M$	Model error of the NDE measurement error, represented by a normal distribution with a mean of zero and known standard deviation
$L(a \Phi)$	Likelihood of true flaw depth given the vector of parameters $\Phi$
$L(Data \theta)$	Likelihood of observed NDE data conditioned on (given) the unknown parameter $\theta$
$L(n^*   n_j)$	Likelihood of observing $n^*$ flaws given that there are a total of $n_j$ true flaws
$M_\epsilon$	NDE measurement error (combined random and systematic errors)
$n$	Number of flaw-depth intervals (reported in NDE)
$\bar{n}$	Mean of the PDF of the number of flaws in volume $v$
$n^*$	Number of exact flaw depths observed (reported in NDE)
$\binom{n_j}{n^*}$	Combination of $n^*$ observed flaws out of total flaws $n_j$ (observed or detected, and unobserved or not detected flaws)
$POD(a)$	Probability of detection of a flaw of depth $a$
$Pr(.)$	Probability
$Pr(D)$	POD independent of flaw depth
$Pr(\bar{D})$	Probability of no detection regardless of size
$Pr(n_j   n^*)$	Probability of total flaws $n_j$ conditioned on observing $n^*$ flaws in NDE
$\beta_i$	Parameter $i$ of the POD model
$\Delta$	Weld bead thickness
$\pi_0(\theta)$	Prior PDF of an unknown parameter $\theta$
$\pi_1(\theta Data)$	Posterior PDF of an unknown parameter given observed NDE data
$\Phi$	Vector of parameters of the flaw-depth PDF
$\theta$	An unknown parameter of a model

4

5



## 1 D.1 Introduction

2 This report discusses the results of a sensitivity analysis by applying a Bayesian updating  
3 methodology described in Appendix C to account for probability of detection (POD) and  
4 measurement (sizing) error in the data for flaws detected through ultrasonic testing (UT). The  
5 methodology estimates vessel-specific flaw depth and density distributions for comparison to  
6 the 10 CFR 50.61a screening tables and updates the VFLAW code's distributions for further  
7 analysis with the FAVOR code. The sensitivity analysis was performed using assumed  
8 nondestructive examination (NDE) flaw data. Existing VFLAW distributions for flaw depth and  
9 density, representing welds of the Pressure Vessel Research User Facility (PVRUF) vessel, were  
10 specialized to the Beaver Valley 2 reactor pressure vessel (RPV) welds and assumed to  
11 properly describe prior flaw-depth and flaw-density distributions and characteristics.

12 In the remainder of this Appendix, a very brief overview of the methodology is described first,  
13 followed by the results of the sensitivity analysis. The results are compared to the  
14 10 CFR 50.61a screening tables and conclusions are summarized.

## 15 D.2 Overview of the Bayesian Approach to Update Flaw-Depth and 16 Flaw-Density Distributions

17 Finding flaws using NDE requires characterization of associated uncertainties. The reliability of  
18 an inspection is customarily expressed in terms of the POD of a given flaw size and expressed  
19 by curves of POD vs. flaw size. Additionally, sizing or measurement errors occur and model  
20 uncertainties exist. Sizes of UT-detected small flaws in RPVs tend to be overestimated while  
21 the sizes of large flaws are underestimated [D-1].

22 POD is generally modeled as a function of true flaw depth. Different forms of POD curves have  
23 been used in the literature (see References [D-2], [D-3], and [D-4]). The logistic POD model for  
24 hit/miss data is a common model and is represented as:

$$\text{POD}(a | \beta_1, \beta_2, a_{th}) = \begin{cases} 1 - \frac{1 + e^{-\beta_1 \beta_2}}{1 + e^{\beta_1(a - \beta_2 - a_{th})}} & \text{for } a > a_{th} \\ 0 & \text{otherwise} \end{cases} \quad \text{Eqn. (D-1)}$$

25 Measurement error is defined by Eqn. (D-2), where  $M_\varepsilon$  is the measurement error,  $a^*$  is the  
26 measured value of flaw depth, and  $a$  is the true value of flaw depth:

$$M_\varepsilon = a^* - a \quad \text{Eqn. (D-2)}$$

27 In its simplest form,  $M_\varepsilon$  can be represented by a linear function of true size, as shown in  
28 Eqn. (D-1), where  $m$  is the slope and  $c$  is the intercept of the line representing measurement  
29 error versus true flaw depth:

$$M_\varepsilon = ma + c + E_M \quad \text{Eqn. (D-3)}$$

where,  $a$  = true flaw depth and  $E_M = N_M(0, \sigma_M)$

30 The likelihood of exact flaw measurements reported may be expressed as a function of POD  
31 and  $M_\varepsilon$  (see Appendix C). If, in addition to or instead of the exact flaw depth data, intervals of  
32 flaw depths are reported (such as the number of flaws observed at less than a given depth or

1 between an upper and lower limit), the likelihood may also be similarly expressed (see Appendix  
2 C).

3  
4 Regardless of the form of the data (exact flaw depth and/or interval data), the Bayesian  
5 inference of the vector of parameters  $\Phi$  of the flaw-depth probability density function (PDF)  
6 would be obtained from the Bayesian inference  $\pi_1(\Phi | \text{Data}) \propto L(\text{Data} | \Phi)\pi_0(\Phi)$ , where  
7  $\pi_1(\Phi | \text{Data})$  is the posterior multivariate PDF of vector  $\Phi$  and  $\pi_0(\Phi)$  is the prior multivariate PDF  
8 of  $\Phi$ .

9 If flaws are detected with a probability  $\text{Pr}(D)$  (or not detected with a probability of  
10  $\text{Pr}(\bar{D}) = 1 - \text{Pr}(D)$ ), the probability that a specific total number of flaws  $n^*$  observed in a given  
11 volume  $v$  out of the true number of flaws  $n_j$  follows the binomial distribution (see  
12 References [D-5] and [D-6]):

$$L(n^* | n_j) = \binom{n_j}{n^*} [\text{Pr}(D)]^{n^*} [1 - \text{Pr}(D)]^{n_j - n^*} \quad \text{Eqn. (D-4)}$$

13 Accordingly, the mean estimate of the true number of flaws  $\bar{n}$  would be found from:

$$\bar{n} = \frac{n^*}{\text{POD}(D)} \quad \text{Eqn. (D-5)}$$

14 The Bayesian updating of  $n_j$ , which allows the estimation of the posterior distribution of  $n_j$  to  
15 describe the true number of flaws, would be:

$$\text{Pr}(n_j | n^*) = \frac{L(n^* | n_j)\text{Pr}(n_j)}{\sum_{n_j} L(n^* | n_j)\text{Pr}(n_j)} \quad \text{Eqn. (D-6)}$$

16 where the prior  $\text{Pr}(n_j)$  may be expressed by a Poisson distribution with parameter  $\rho$  (defined in  
17 VFLAW).

### 18 **D.3 Application to a Base Case Example**

19 The EPRI report by Spanner [D-7] provides UT-based measured flaw data near the inner  
20 surface (~2.5 inches) of the Beaver Valley Unit 2 RPV, including small flaw sizes. These data,  
21 while subject to POD and measurement error, provide a more vessel-specific perspective of the  
22 distribution of flaws for weld metals in the Beaver Valley 2 RPV than do the VFLAW distributions  
23 used in FAVOR.

24 The observed Beaver Valley 2 NDE data (with detection and sizing uncertainty) are mostly in  
25 the form of interval data as summarized below [D-7]:

26 *19 weld flaws were detected by the UT NDE of Beaver Valley 2 in the first inch (ASME*  
27 *Code, Section XI, Mandatory Appendix VIII, Supplement 4 inspection volume) of the*

1 *RPV (these data are assumed normalized to 1,000" of weld length), all having a flaw*  
2 *depth less than 0.125".* \*\*\*

3 The lower limit of the detected flaw intervals described above was not stated in [D-7], but is not  
4 zero. Two possible subjective lower limits were assumed, and later the sensitivities of the final  
5 (posterior) flaw distributions to these two choices were assessed. The two lower limits selected  
6 were 0.04" and 0.075".

7 The associated weld bead thicknesses are not reported in [D-7]. However, the weld region of  
8 the observed flaws and flaw length is reported. Such results must be corrected for detection  
9 and sizing capability, particularly for the small flaws. The Beaver Valley 2 RPV weld map is  
10 shown in Figure D-1 [D-8]. In the absence of the Beaver Valley average weld bead thickness as  
11 the point of transition between large and small depths, it was assumed that all flaws reported  
12 are in submerged arc welds (SAWs), which form over 90% of welds in the VFLAW data, with the  
13 bead thickness of  $\Delta = 0.26$ ". Using the Beaver Valley 2 RPV information shown in Figure D-1,  
14 the VFLAW data were specialized to represent the prior distributions of flaw depth and density  
15 for Beaver Valley 2 RPV.

16  
17  
18  
19  
20  
21  
22


Total Weld Length = 816.18"  
Total Weld Volume = 4.975 ft<sup>3</sup>  
Total Weld Fusion Area = 92 ft<sup>2</sup>  
Weld Volume of 1" = 0.616 ft<sup>3</sup>  
Weld Volume of 3/8t = 1.865 ft<sup>3</sup>

---

\*\*\* In Appendix C, the same analysis is performed, except that the analysis did not assume that the data were normalized to 1,000" of linear length of weld. Instead, it assumed that the data came from 816.18" of weld, which is the actual length of weld in the Beaver Valley 2 RPV.

# Beaver Valley

$R_{\text{clad}} = 78.5"$       Clad Thick = 0.156"  
 $R_{\text{clad}} = 78.656"$       BM Thick = 7.875"  
 $R_{\text{BM}} = 86.531"$       Total Thick = 8.031"




- 1
- 2
- 3
- 4
- 5

Figure D-1. Beaver Valley 2 Weld Map [D-8]

1 The relationship between the flaw depth and flaw density PDFs and the corresponding prior  
 2 hyper-PDFs of their parameters are illustrated in Figure D-2.

3  
 4



5  
 6  
 7  
 8  
 9

Figure D-2. Flaw-Depth and Flaw-Density Distributions Used in VFLAW and Their Corresponding Parameter Hyper-PDFs

10 Analysis of UT-detected performance data reported by the Electric Power Research Institute  
 11 (EPRI) [D-7] was used to identify a POD function for the purpose of this example. The threshold  
 12 limit of this POD function was taken as 0.00, and the epistemic uncertainties associated with the  
 13 parameters of the model were not considered in this study. Accordingly, the following mean  
 14 POD function was used:

$$\text{POD}(a) = 1 - \frac{1}{1 + e^{63.2100(a-0.1124)}} \quad \text{Eqn. (D-7)}$$

15 The measurement error was assumed based on some examples and measurement errors  
 16 reported in Reference [D-7]. After combination of Eqn. (D-2) and Eqn. (D-3), the measurement  
 17 error (a linear function that oversized small flaws and undersizes large flaws) is:

$$M_e = -0.1905a + 0.0476 + N(0, 0.0298) \quad \text{Eqn. (D-8)}$$

18

1 where  $N(0, 0.0298)$  is a normal distribution with a mean of zero and a constant standard  
 2 deviation of 0.0298. The observed data for the first inch of the vessel were used to estimate the  
 3 true number of flaws in the flaw-depth ranges of the Alternate PTS Rule flaw tables. This  
 4 information was used to assess how the estimated number of flaws of a given size in Beaver  
 5 Valley 2 (estimated based on inspection data, VFLAW distributions, and Bayesian inference)  
 6 compares to the number and size of flaws permitted by the Alternate PTS Rule flaw tables. The  
 7 posterior characteristics were used to develop the corresponding Alternate PTS Rule flaw  
 8 tables.

9 If the lower limit of the observed data interval is changed from 0.04" to 0.075" to line up with the  
 10 smallest bin size in the Alternate PTS Rule flaw tables, the results summarized in Table D-1 are  
 11 calculated. In this case, the results of the mean number of flaws show no sensitivity to the  
 12 choice of the lower limit of the interval of NDE data. Given this flaw observation, true estimated  
 13 numbers of flaws in all bins were below the Alternate PTS rule flaw limits.

14  
 15 Table D-1. Alternate PTS Rule Flaw Table Assessment Using Mean Number of Flaws by Size  
 16 Interval for Beaver Valley 2 (assuming a Lower Limit of 0.04" vs. 0.075" for  
 17 Observed Data Interval)

Bin No.	Flaw Depth (in)	Base Case 1		Base Case 2		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) Number of Flaws (Biased with Lower Detection Limit of 0.04")	Posterior Mean Number of Flaws (Unbiased and Corrected for POD)	Observed (Detected) Number of Flaws (Biased with Lower Detection Limit of 0.075")	Posterior Mean Number of Flaws (Unbiased and Corrected for POD)	
1	$0.000 < a \leq 0.075$	19	111.41	0	109.09	No limit
2	$0.075 < a \leq 0.475$		25.73	19	27.02	166.70
3	$0.125 < a \leq 0.475$	0	8.46	0	8.98	90.80
4	$0.175 < a \leq 0.475$	0	2.98	0	2.88	22.82
5	$0.225 < a \leq 0.475$	0	0.79	0	0.79	8.66
6	$0.275 < a \leq 0.475$	0	0.29	0	0.29	4.01
7	$0.325 < a \leq 0.475$	0	0.14	0	0.14	3.01
8	$0.375 < a \leq 0.475$	0	0.09	0	0.09	1.49
9	$0.425 < a \leq 0.475$	0	0.05	0	0.05	1.00

18  
 19

## 1 **D.4 Application to Sensitivity Cases**

2 In order to examine the effects of changes in the number of flaws observed through NDE, as  
3 well as the significance of the POD and the VFLAW prior distributions, twelve sensitivity cases  
4 were identified and examined. Methods and tools discussed in Sections D.2 and D.3 were used  
5 to carry out these sensitivity cases. The sensitivity cases examined were as follows:

- 6 1. No flaws detected, with consideration of the VFLAW prior distributions, POD, and  
7 measurement error.
- 8 2. 70% of the Alternate PTS Rule's allowed flaws in Bins 2 and 3 are detected, with  
9 consideration of the VFLAW prior distributions, POD, and measurement error.
- 10 3. 110% of the Alternate PTS Rule's allowed flaws in Bin 3 are detected, with consideration  
11 of the VFLAW prior distributions, POD, and measurement error.
- 12 4. No flaws detected, with no consideration of VFLAW priors (i.e., non-informative priors)  
13 and POD, but with consideration of flaw measurement error only (i.e., no POD or  
14 VFLAW prior).
- 15 5. 70% of the Alternate PTS Rule's allowed flaws in Bins 2 and 3 are detected, with no  
16 consideration of VFLAW priors and POD, but with consideration of flaw measurement  
17 error only.
- 18 6. 110% of the Alternate PTS Rule's allowed flaws in Bin 3 are detected, with no  
19 consideration of VFLAW priors and no consideration of POD, but with consideration of  
20 flaw measurement error only.
- 21 7. No flaws detected, no consideration of VFLAW priors, but with consideration of POD and  
22 flaw measurement error.
- 23 8. 70% of the Alternate PTS Rule's allowed flaws in Bins 2 and 3 are detected, with no  
24 consideration of VFLAW priors, but with consideration of POD and flaw measurement  
25 error.
- 26 9. 110% of the Alternate PTS Rule's allowed flaws in Bin 3 are detected, with no  
27 consideration of VFLAW priors, but with consideration of POD and flaw measurement  
28 error.
- 29 10. No flaws detected, no consideration of POD, but with consideration of VFLAW priors and  
30 flaw measurement error.
- 31 11. 70% of the Alternate PTS Rule's allowed flaws in Bins 2 and 3 are detected, with no  
32 consideration of POD, but with consideration of VFLAW priors and flaw measurement  
33 error.
- 34 12. 110% of the Alternate PTS Rule's allowed flaws in Bin 3 are detected, with no  
35 consideration of POD, but with consideration of VFLAW priors and flaw measurement  
36 error.

37 The results of the sensitivity studies are listed in Table D-2 through Table D-13.

38  
39  
40

1 Table D-2. Results of Sensitivity Case 1

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 1		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	0.000 < a ≤ 0.075	19	111.41	0	80.13	No limit
2	0.075 < a ≤ 0.475		25.73	0	40.76	166.70
3	0.125 < a ≤ 0.475	0	8.46	0	18.79	90.80
4	0.175 < a ≤ 0.475	0	2.98	0	7.81	22.82
5	0.225 < a ≤ 0.475	0	0.79	0	2.71	8.66
6	0.275 < a ≤ 0.475	0	0.29	0	0.29	4.01
7	0.325 < a ≤ 0.475	0	0.14	0	0.14	3.01
8	0.375 < a ≤ 0.475	0	0.09	0	0.09	1.49
9	0.425 < a ≤ 0.475	0	0.05	0	0.05	1.00

2  
3

4 Table D-3. Results of Sensitivity Case 2

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 2		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	0.000 < a ≤ 0.075	19	111.41	0	306.12	No limit
2	0.075 < a ≤ 0.475		25.73	116.69	34.16	166.70
3	0.125 < a ≤ 0.475	0	8.46	63.56	7.71	90.80
4	0.175 < a ≤ 0.475	0	2.98	0	1.69	22.82
5	0.225 < a ≤ 0.475	0	0.79	0	0.44	8.66
6	0.275 < a ≤ 0.475	0	0.29	0	0.29	4.01
7	0.325 < a ≤ 0.475	0	0.14	0	0.14	3.01
8	0.375 < a ≤ 0.475	0	0.09	0	0.09	1.49
9	0.425 < a ≤ 0.475	0	0.05	0	0.04	1.00

5



1 Table D-4. Results of Sensitivity Case 3

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 3		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	$0.000 < a \leq 0.075$	19	111.41	0	155.03	No limit
2	$0.075 < a \leq 0.475$		25.73	0	41.33	166.70
3	$0.125 < a \leq 0.475$	0	8.46	99.88	15.21	90.80
4	$0.175 < a \leq 0.475$	0	2.98	0	4.51	22.82
5	$0.225 < a \leq 0.475$	0	0.79	0	1.21	8.66
6	$0.275 < a \leq 0.475$	0	0.29	0	0.29	4.01
7	$0.325 < a \leq 0.475$	0	0.14	0	0.14	3.01
8	$0.375 < a \leq 0.475$	0	0.09	0	0.09	1.49
9	$0.425 < a \leq 0.475$	0	0.05	0	0.05	1.00

2

3

4 Table D-5. Results of Sensitivity Case 4

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 4		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	$0.000 < a \leq 0.075$	19	111.41	0	0.00	No limit
2	$0.075 < a \leq 0.475$		25.73	0	0.00	166.70
3	$0.125 < a \leq 0.475$	0	8.46	0	0.00	90.80
4	$0.175 < a \leq 0.475$	0	2.98	0	0.00	22.82
5	$0.225 < a \leq 0.475$	0	0.79	0	0.00	8.66
6	$0.275 < a \leq 0.475$	0	0.29	0	0.00	4.01
7	$0.325 < a \leq 0.475$	0	0.14	0	0.00	3.01
8	$0.375 < a \leq 0.475$	0	0.09	0	0.00	1.49
9	$0.425 < a \leq 0.475$	0	0.05	0	0.00	1.00

5

1 Table D-6. Results of Sensitivity Case 5

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 5		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Lower Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	0.000 < a ≤ 0.075	19	111.41	0	56.47	No limit
2	0.075 < a ≤ 0.475		25.73	116.69	60.22	166.70
3	0.125 < a ≤ 0.475	0	8.46	63.56	36.13	90.80
4	0.175 < a ≤ 0.475	0	2.98	0	18.67	22.82
5	0.225 < a ≤ 0.475	0	0.79	0	5.98	8.66
6	0.275 < a ≤ 0.475	0	0.29	0	0.00	4.01
7	0.325 < a ≤ 0.475	0	0.14	0	0.00	3.01
8	0.375 < a ≤ 0.475	0	0.09	0	0.00	1.49
9	0.425 < a ≤ 0.475	0	0.05	0	0.00	1.00

2

3

4 Table D-7. Results of Sensitivity Case 6

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 6		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	0.000 < a ≤ 0.075	19	111.41	0	32.85	No limit
2	0.075 < a ≤ 0.475		25.73	0	67.03	166.70
3	0.125 < a ≤ 0.475	0	8.46	99.88	47.02	90.80
4	0.175 < a ≤ 0.475	0	2.98	0	27.19	22.82
5	0.225 < a ≤ 0.475	0	0.79	0	11.17	8.66
6	0.275 < a ≤ 0.475	0	0.29	0	0.00	4.01
7	0.325 < a ≤ 0.475	0	0.14	0	0.00	3.01
8	0.375 < a ≤ 0.475	0	0.09	0	0.00	1.49
9	0.425 < a ≤ 0.475	0	0.05	0	0.00	1.00

5

1 Table D-8. Results of Sensitivity Case 7

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 7		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	0.000 < a ≤ 0.075	19	111.41	0	0.00	No limit
2	0.075 < a ≤ 0.475		25.73	0	0.00	166.70
3	0.125 < a ≤ 0.475	0	8.46	0	0.00	90.80
4	0.175 < a ≤ 0.475	0	2.98	0	0.00	22.82
5	0.225 < a ≤ 0.475	0	0.79	0	0.00	8.66
6	0.275 < a ≤ 0.475	0	0.29	0	0.00	4.01
7	0.325 < a ≤ 0.475	0	0.14	0	0.00	3.01
8	0.375 < a ≤ 0.475	0	0.09	0	0.00	1.49
9	0.425 < a ≤ 0.475	0	0.05	0	0.00	1.00

2

3

4 Table D-9. Results of Sensitivity Case 8

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 8		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	0.000 < a ≤ 0.075	19	111.41	0	5131.91	No limit
2	0.075 < a ≤ 0.475		25.73	116.69	263.80	166.70
3	0.125 < a ≤ 0.475	0	8.46	63.56	35.54	90.80
4	0.175 < a ≤ 0.475	0	2.98	0	4.88	22.82
5	0.225 < a ≤ 0.475	0	0.79	0	0.39	8.66
6	0.275 < a ≤ 0.475	0	0.29	0	0.00	4.01
7	0.325 < a ≤ 0.475	0	0.14	0	0.00	3.01
8	0.375 < a ≤ 0.475	0	0.09	0	0.00	1.49
9	0.425 < a ≤ 0.475	0	0.05	0	0.00	1.00

5

1 Table D-10. Results of Sensitivity Case 9

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 9		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	0.000 < a ≤ 0.075	19	111.41	0	1233.10	No limit
2	0.075 < a ≤ 0.475		25.73	0	202.01	166.70
3	0.125 < a ≤ 0.475	0	8.46	99.88	54.12	90.80
4	0.175 < a ≤ 0.475	0	2.98	0	13.13	22.82
5	0.225 < a ≤ 0.475	0	0.79	0	1.95	8.66
6	0.275 < a ≤ 0.475	0	0.29	0	0.00	4.01
7	0.325 < a ≤ 0.475	0	0.14	0	0.00	3.01
8	0.375 < a ≤ 0.475	0	0.09	0	0.00	1.49
9	0.425 < a ≤ 0.475	0	0.05	0	0.00	1.00

2

3

4 Table D-11. Results of Sensitivity Case 10

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 10		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	0.000 < a ≤ 0.075	19	111.41	0	79.14	No limit
2	0.075 < a ≤ 0.475		25.73	0	41.18	166.70
3	0.125 < a ≤ 0.475	0	8.46	0	19.09	90.80
4	0.175 < a ≤ 0.475	0	2.98	0	7.93	22.82
5	0.225 < a ≤ 0.475	0	0.79	0	2.42	8.66
6	0.275 < a ≤ 0.475	0	0.29	0	0.29	4.01
7	0.325 < a ≤ 0.475	0	0.14	0	0.14	3.01
8	0.375 < a ≤ 0.475	0	0.09	0	0.09	1.49
9	0.425 < a ≤ 0.475	0	0.05	0	0.05	1.00

5

1 Table D-12. Results of Sensitivity Case 11

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 11		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	$0.000 < a \leq 0.075$	19	111.41	0	73.49	No limit
2	$0.075 < a \leq 0.475$		25.73	116.69	57.04	166.70
3	$0.125 < a \leq 0.475$	0	8.46	63.56	31.09	90.80
4	$0.175 < a \leq 0.475$	0	2.98	0	14.66	22.82
5	$0.225 < a \leq 0.475$	0	0.79	0	4.81	8.66
6	$0.275 < a \leq 0.475$	0	0.29	0	0.29	4.01
7	$0.325 < a \leq 0.475$	0	0.14	0	0.14	3.01
8	$0.375 < a \leq 0.475$	0	0.09	0	0.09	1.49
9	$0.425 < a \leq 0.475$	0	0.05	0	0.05	1.00

2

3

4 Table D-13. Results of Sensitivity Case 12

Bin No.	Flaw Depth (in)	Base Case 1		Sensitivity Case 12		Alternate PTS Rule Limit (per 1,000" of Weld)
		Observed (Detected) No. of Flaws (Biased with Detection Limit of 0.04")	Posterior Mean No. of Flaws (Unbiased and Corrected for POD)	Assumed No. of Detected Flaws (with Bias)	Posterior Mean No. of Flaws (Unbiased)	
1	$0.000 < a \leq 0.075$	19	111.41	0	63.04	No limit
2	$0.075 < a \leq 0.475$		25.73	0	66.84	166.70
3	$0.125 < a \leq 0.475$	0	8.46	99.88	39.42	90.80
4	$0.175 < a \leq 0.475$	0	2.98	0	20.55	22.82
5	$0.225 < a \leq 0.475$	0	0.79	0	7.21	8.66
6	$0.275 < a \leq 0.475$	0	0.29	0	0.29	4.01
7	$0.325 < a \leq 0.475$	0	0.14	0	0.14	3.01
8	$0.375 < a \leq 0.475$	0	0.09	0	0.09	1.49
9	$0.425 < a \leq 0.475$	0	0.05	0	0.05	1.00

5

1 **D.5 Discussion and Summary**

2 In this study, analysis of a base case of UT-detected weld-flaw data involving measurement  
3 (sizing) error for Beaver Valley 2 was performed. The base case was evaluated for interval flaw  
4 depths detected in the inspection volume specified in Supplement 4 to Mandatory Appendix VIII  
5 to Section XI of the ASME Code. Detected flaw-depth intervals were analyzed assuming lower  
6 UT detection limits of 0.04" and 0.075". Subsequently, twelve sensitivity cases were assessed  
7 based on variations in the assumed detected flaw-depth data (in the form of intervals), choices  
8 of considering VFLAW flaw depth and flaw densities as prior information (as opposed to no prior  
9 information), and choices of considering the POD (as opposed to perfect detection; i.e., no  
10 POD) were evaluated and compared to the base case as well as the Alternate PTS Rule flaw  
11 table limits. No sensitivities to the choice of the lower UT detection limit on the observed data  
12 were found.

13 The results obtained from the twelve sensitivity cases were consistent and showed that small  
14 overpopulations of flaws in Bins 2 and 3 of the Alternate PTS Rule flaw tables resulting from  
15 possible oversizing of small flaws would be shifted to Bins 1 and 2 after accounting for the  
16 measurement error in the Bayesian inference. When POD is considered, the effect of the  
17 missed small flaws was clearly seen in Bins 1 and 2 with an additional number of flaws in the  
18 posterior estimates as compared to the observed flaws.

19 The effects of the consideration and choice of the prior distributions of flaw density and depth  
20 were significant. When no prior information was used to describe the flaw-density and  
21 flaw-depth distributions, POD and measurement error were also sensitive and significantly  
22 amplified the number of flaws in Bins 1 and 2. However, when prior VFLAW PDFs were used,  
23 the posteriors were significantly moderated by the existence of the prior PDFs, and the POD  
24 and measurement errors played less significant roles.

25 If the approach documented in this appendix is used to reassess actual NDE flaws, it would be  
26 advisable to use informative or semi-informative prior estimates of the flaw depth and density  
27 distributions.

28

29

1 **D.6 References**

2 [D-1] Becker, F.L., "Reactor Pressure Vessel Inspection Reliability Based on Performance  
3 Demonstrations," EPRI Report 1007984, June 22, 2004, Electric Power Research  
4 Institute, Palo Alto, CA.

5 [D-2] Georgiou, G.A., "Probability of Detection (PoD) Curves: Derivation, Applications and  
6 Limitations," Research Report 454, UK Health & Safety Executive, London, UK, 2006.

7 [D-3] Li, M., and W. Q. Meeker, "A Noise Interference Model for Estimating Probability of  
8 Detection for Nondestructive Evaluations," *Proceedings of the Review of Progress in*  
9 *Quantitative Nondestructive Evaluation, July 20–25, 2008, Chicago, IL*, American  
10 Institute of Physics, College Park, MD, 2009.

11 [D-4] U.S. Department of Defense, "Nondestructive Evaluation System Reliability  
12 Assessment," MIL-HDBK-1823, April 30, 1999.

13 [D-5] Celeux, G., et al., "Using Markov Chain Monte Carlo Methods to Solve Full Bayesian  
14 Modeling of PWR Vessel Flaw Distributions," *Reliability Engineering and System Safety*,  
15 66(3):243–252, December 1999.

16 [D-6] Chatterjee, K., and M. Modarres, "A Probabilistic Approach for Estimating Defect Size  
17 and Density Considering Detection Uncertainties and Measurement Errors," *Journal of*  
18 *Risk and Reliability*, 227(1):28–40, February 2013.

19 [D-7] Spanner, J., "Materials Reliability Program: Reanalysis of Reactor Vessel Examination  
20 Data from the 1996 Beaver Valley 2 Vessel Examination (MRP-207), RPV Flaw  
21 Distribution," EPRI Report 1014548, November 2006, Electric Power Research Institute,  
22 Palo Alto, CA.

23 [D-8] U.S. Nuclear Regulatory Commission, "Probabilistic Fracture Mechanics - Models,  
24 Parameters, and Uncertainty Treatment Used in FAVOR Version 04.1," NUREG-1807,  
25 June 2007, Agencywide Documents Access and Management System (ADAMS)  
26 Accession No. ML072010411.

27





**BIBLIOGRAPHIC DATA SHEET**

(See instructions on the reverse)

1. REPORT NUMBER  
(Assigned by NRC, Add Vol., Supp., Rev.,  
and Addendum Numbers, if any.)  
NUREG-2163  
(DRAFT)

2. TITLE AND SUBTITLE  
Technical Basis for Regulatory Guidance on the Alternate Pressurized Thermal Shock Rule

3. DATE REPORT PUBLISHED

MONTH	YEAR
February	2015

4. FIN OR GRANT NUMBER

5. AUTHOR(S)  
G. L. Stevens, M. T. Kirk, and M. Modarres

6. TYPE OF REPORT  
Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Office of Nuclear Regulatory Research  
Division of Engineering  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.)

Same as above

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

During plant operation, the walls of reactor pressure vessels (RPVs) are exposed to neutron radiation, resulting in embrittlement of the vessel steel and weld materials in the area of the RPV adjacent to the core. If an embrittled RPV had a flaw of critical size and certain severe system transients were to occur, the flaw could rapidly propagate through the vessel, resulting in a through wall crack and, thereby, challenging the integrity of the RPV. The severe transients of concern, known as pressurized thermal shock (PTS), are characterized by a rapid cooling of the internal RPV surface in combination with repressurization of the RPV. Advancements in understanding and knowledge of materials behavior, the ability to realistically model plant systems and operational characteristics, and the ability to better evaluate PTS transients to estimate loads on vessel walls led the U.S. Nuclear Regulatory Commission (NRC) to develop a risk informed revision of the existing PTS Rule that was published in Section 50.61a, "Alternate Fracture Toughness Requirements for Protection against Pressurized Thermal Shock Events," of Title 10, "Energy," of the Code of Federal Regulations (10 CFR 50.61a).

This report explains the basis for the requirements that establish the entry conditions to permit use of 10 CFR 50.61a and describes methods by which the following four requirements can be met: (1) criteria relating to the date of construction and design requirements, (2) criteria relating to evaluation of plant specific surveillance data, (3) criteria relating to inservice inspection (ISI) data and non destructive examination (NDE) requirements, and (4) criteria relating to alternate limits on embrittlement.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report )  
pressurized thermal shock, probabilistic fracture mechanics, nuclear reactor pressure vessel,  
pressurized water reactor

13 AVAILABILITY STATEMENT  
unlimited

14 SECURITY CLASSIFICATION  
(This Page)  
unclassified

(This Report)  
unclassified

15. NUMBER OF PAGES

16. PRICE



Federal Recycling Program





**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
WASHINGTON, DC 20555-0001  
\_\_\_\_\_  
OFFICIAL BUSINESS



**NUREG-2163  
Draft**

**Technical Basis for Regulatory Guidance on the Alternate  
Pressurized Thermal Shock Rule**

**February 2015**