

March 30, 2020

Title: Pre-Submittal Teleconference Regarding Approximately Six Regulatory Actions for the Spring 2020 Outage at Beaver Valley Power Station, Unit 2

Date(s) and Time(s): March 31, 2020, 01:00 PM to 03:00 PM

Location: Teleconference

Category: This is a Category 2 meeting. The public is invited to participate in this meeting by discussing regulatory issues with the Nuclear Regulatory Commission (NRC) at designated points identified on the agenda.

Purpose: The purpose of this teleconference is for NRC staff and Energy Harbor Nuclear Corp. (Energy Harbor) to discuss approximately six regulatory actions for the spring 2020 outage at Beaver Valley Power Station, Unit 2.

Contact: Jennifer Tobin
301-415-2328
jennifer.tobin@nrc.gov

Participants:	<u>NRC</u>	<u>External</u>
	Jennifer Tobin, Office of Nuclear Reactor Regulation	Energy Harbor Nuclear Corp.

Teleconference:	<u>Bridge Number</u>	<u>Pass Code</u>
	(888) 659-9574	9845474

Docket No: 05000412

PUBLIC MEETING AGENDA

Pre-Submittal Teleconference Regarding Approximately Six Regulatory Actions for the Spring 2020 Outage at Beaver Valley Power Station, Unit 2

March 31, 2020, 01:00 PM to 03:00 PM

Teleconference

<i>Time</i>	<i>Topic</i>	<i>Speaker</i>
1:00 P.M.	Introductions and Opening Remarks	NRC/Energy Harbor
1:15 P.M.	Discussion of Potential Regulatory Actions for the Spring 2020 Outage	Energy Harbor
1:45 P.M.	Questions and Answers	NRC/Energy Harbor
2:30 P.M.	Public Comments and Questions	Public/NRC

Potential Regulatory Actions for Beaver Valley, Unit 2:

1. Hot Leg Nozzle Inspection, Request to extend the frequency of ASME Code Case N-770-2, Table 1, Item A-2, that the weld surface must be visually examined each refueling outage.
2. Bottom Mounted Instrumentation, Request to extend the examination frequency specified in ASME Code Case N-722-1, Table 1 for Item B15.80, to examine all penetrations every other refueling outage.
3. Relief Valve Testing, Request to extend the 10-year interval required by Mandatory Appendix I, 1?1350, and Mandatory Appendix I, 1-1390.
4. Motor Operated Valve Testing, Request to extend the testing frequency required by ASME Code Case OMN-1, including the 6-month allowance allowed by OMN-20.
5. Containment Isolation Valve Water Testing, Request to extend the 2-year testing frequency specified in ISTC-3630(a).
6. Safety Significant Dynamic Restraint (Snubber) Testing, Request to extend the testing requirement specified in ISTD-5200 to inspect snubbers each fuel cycle.

The time of the meeting is local to the jurisdiction where the meeting is being held.

The NRC provides reasonable accommodation to individuals with disabilities where appropriate. If reasonable accommodation is needed to participate in this meeting, or if a meeting notice, transcript, or other information from this meeting is needed in another format (e.g., Braille, large print), please notify the NRC meeting contact. Determinations on requests for reasonable accommodation will be made on a case-by-case basis.

ADAMS Accession Number: ML20090H762

Distribution:

RidsOpaMali
RidsACRS_MailCTR
RidsRgn1MailCenter
RidsNrrPMBeaverValley
RidsNrrDorILp11
RidsNrrDorLALRonewicz
LBetancourt, NRR
MMcCoppin, OEDO

OLopez-Santiago, OEDO

Name	JTobin	LRonewicz	JDanna
Office	NRR/DORL/LPL1/PM	NRR/DORL/LPL1/LA	NRR/DORL/LPL1/BC
Date	03/30/2020	03/30/2020	03/30/2020

OFFICIAL RECORD COPY

Link to meeting details: <https://www.nrc.gov/pmns/mtg?do=details&Code=20200333>